

CBC AMERICAS GANZ CONTROL Global Administration Guide

Thursday, October 30, 2025

© CBC AMERICA LLC

Ganz CONTROL Global Administration Guide

Table of Contents

1.	Software Purpose and Use Cases	5
1.1.	Architecture	6-7
1.2.	Edition Overview	8-10
1.3.	Hardware Requirements	11-12
1.4.	Prerequisites	13-14
1.5.	Getting Started	15
1.6.	Installation of Ganz CONTROL Global	16-22
1.7.	Initialization of Ganz CONTROL Global Server	23-24
1.8.	Management Application Installation	25-28
1.9.	Recording Server Installation	29-36
1.10.	Recording Server Initialization	37
1.11.	Software Update and Uninstall	38-46
1.12.	Start & Stop Server Service	47
2.	License Activation	48-50
2.1.	Online Activation	51
2.2.	Offline Activation	52-54
2.3.	Activation Management	55-59
3.	Ganz CONTROL Console Login	60-63
3.1.	About Product	64
3.2.	Migration From Previous Product Versions	65-68
3.3.	Database Import	69-71
3.4.	Configuration Backup	72-79
3.5.	Remote Upgrade	80-83
3.6.	Setup Wizard	84-100
3.7.	Recommended Practices	101
3.8.	Conventions and Keyboard Shortcuts	102-104
4.	Purpose and Operation Description of Folders	105-113
5.	Connect Recording Servers Using Autodiscovery	114-116
5.1.	Connect Recording Servers Manually	117-124
5.2.	Recording Server Direct Login	125

Ganz CONTROL Global Administration Guide

6.	Server Settings	126-130
6.1.	Storage	131-140
6.2.	Watchdog	141-144
6.3.	Server Policies	145-153
6.4.	Security	154-161
6.5.	Two-Factor Authentication	162-164
6.6.	Third Party Authentication Providers	165-167
6.7.	Networks	168-171
6.8.	Server Groups	172-175
6.9.	Central Server Mirroring	176-178
6.10.	Purpose and Operation Description of Failover Clusters	179-180
6.11.	Configure Failover Clusters	181-185
7.	Devices and Channels	186
7.1.	Add Devices Using Autodiscovery	187-192
7.2.	Add Devices Manually	193-202
7.3.	Manage Devices and Device Groups	203-212
7.4.	Configure Channels	213-217
7.5.	Channel Settings	218-244
7.6.	Bulk Edit for Devices and Channels	245-246
8.	Recording Profiles, Schedules, and Configurations	247-255
8.1.	Assign Recording Configurations	256-258
8.2.	Archive Replication	259-263
9.	Add Users and User Groups	264-271
9.1.	Permissions and Membership	272-276
9.2.	Active Directory and LDAP User Import	277-281
9.3.	Anonymous User	282-283
10.	Streaming Server Configuration	284-286
10.1.	Streaming Server User Interface	287-292
10.2.	Mobile Application for Streaming Server	293-311
10.3.	RTSP Streaming Server	312-315
11.	Event and Action Overview	316-317
11.1.	Add Rules	318-327

Ganz CORTROL Global Administration Guide

11.2.	Default Events	328-330
11.3.	Add Events	331-348
11.4.	Global Events	349-350
11.5.	Default Actions	351-352
11.6.	Add Actions	353-374
11.7.	ONVIF Generic Events	375-381
11.8.	Delay Timers	382-384
11.9.	Understanding Conditions	385-386
11.10.	Counters, Indicators and Variables	387-393
11.11.	Tags and Subjects	394-398
12.	Other Resources and Tools	399
12.1.	Webpages and CrossLink Channels	400-407
12.2.	Visual Groups	408-410
12.3.	Layout Templates	411-412
12.4.	Shared Layouts	413
12.5.	Video Walls	414-418
12.6.	Maps	419-427
12.7.	User Buttons	428-429
12.8.	Dewarp For Fisheye Cameras	430-431
12.9.	Audio	432-433
12.10.	Live Podcasts	434-436
12.11.	Data Sources and Data Channels	437-452
12.12.	Reports	453-462
12.13.	Manage Mail Servers	463-466
12.14.	Manage GSM Modems	467-472
12.15.	Control Panels	473-474
12.16.	Quick Access	475-476
12.17.	Create Schedules	477-482
13.	External Services	483-485
13.1.	Security systems	486-493
13.2.	Gallagher	494-503

Ganz CORTROL Global Administration Guide

13.3.	Camio	504-511
13.4.	Inner Range Integrity	512-517
13.5.	External Metadata	518-520
13.6.	OPC Client	521-524
13.7.	MQTT Client	525-529
13.8.	Modbus	530-533
14.	Health Monitoring	534-544
14.1.	Audit	545-556
15.	Tools and Wizards	557
15.1.	Archive Backup Wizard	558-563
15.2.	Renderer Test Utility	564-567
15.3.	Problem Report Wizard	568-572

Ganz CORTROL Global Administration Guide

1 Software Purpose and Use Cases

CBC AMERICA LLC software products can be used for any type of surveillance system: they offer a wide and flexible choice of components and license types to suit anyone from home users to corporate customers. Different product editions can be selected depending on the application area and available resources.

On top of traditional CCTV functions, Ganz CORTROL servers support integrations with major Security systems such as access control and security panels, external and internal analytics, and other tools that complement the surveillance system and turn it into a comprehensive data management centre.

Ganz CORTROL Server

Ganz CORTROL Server is a modern piece of the video and data management software from CBC AMERICA LLC, which offers a fast and scalable standalone solution that truly answers your company's security needs. It has been proven to be high-quality and reliable, adding an even more intuitive user interface and better functionality, as well as a long list of supported integrations.

Cross-functional and modern, Ganz CORTROL Server supports over 5000 cameras and other network devices from major producers. The software is designed for single server surveillance systems but can withhold up to several hundreds of IP cameras and also allows hybrid solutions.

Looking for a complete enterprise-level solution? We suggest that you refer to the Ganz CORTROL Global version of the software.

Ganz CORTROL Global

Ganz CORTROL Global is a complete surveillance ecosystem solution for enterprises of any size, including those distributed across multiple sites. The software was designed with the core of CBC AMERICA LLC VMS, whose quality has been proven worldwide over the last decade. The new version of the software, Ganz CORTROL Global, not only offers 64-bit speed and all the necessary tools for setting up an absolute situational alertness system aimed at responding quickly to events, as well as introducing a central server governance hierarchy of all the components.

This is one of the most comprehensive enterprise-level VMS solutions on the market, featuring interactive maps linked to alarms; an advanced event and action manager; analytics tools; video wall support and other impressive components you will definitely appreciate. To ensure the safety of your data, the software also offers archive replication, advanced system health monitoring and failover clustering mechanism, all of which reduce the disruption of your video surveillance recordings to zero. All this, as well as the various possibilities for customization and CBC AMERICA LLC flawless technical support, makes Ganz CORTROL Global a video surveillance solution you can count on.

Ganz CONTROL Global Administration Guide

1.1 Architecture

Ganz CONTROL Server

Ganz CONTROL Server is suitable for single VMS server systems. Each server can accept data streams from cameras and other sources, record, and then send these streams further to clients: Ganz CONTROL Client (thick client), Ganz CONTROL Mobile (iOS, Android, and thin client for macOS), Web browsers, and the management application - Ganz CONTROL Console. Each Ganz CONTROL Server server can serve a virtually unlimited number of remote and local clients.

Apart from device connections, Ganz CONTROL Server server can be also paired with external software: the so-called [external services](#) (API connections) and native integrations (implemented by our software development team). The latter include [generic protocols](#) like serial data or OPC, [security systems](#) software integrations, analytics suites and others.

Ganz CONTROL Global

Ganz CONTROL Global systems are more complicated: these consist of many servers having different roles.

- Ganz CONTROL Global server: **central management** server, exactly one (1) per system
- **recording** servers for data recording and stream re-distribution
- **failover** nodes: standby recording servers
- **mirror**: central server redundancy, one mirror per system

For the **Ganz CONTROL Global** server, there is a special installation package with the corresponding name. You only need to use it once per system - for the **central management** server. It is a machine dedicated to the management routines; it is the place where you apply the Ganz CONTROL Global license. The management server should not have any device configuration - although, its core does have the recording capabilities. One may say that the Ganz CONTROL Global server is similar to Ganz CONTROL Server. Thus, if you use a Ganz CONTROL Global server without any Ganz CONTROL Recorder connections, you will have a Ganz CONTROL Server system with extra features like video walls.

Apart from the system-defined server roles, you may wish to dedicate certain recording servers to specific tasks in order to optimize hardware resource usage. Examples:

- **replication** servers for automated backup: channel copies are recorded instead of live channels (or combined with other live channels)
- **analytics** servers: fewer channels with configured software VA
- FR or LPR server: a few channels dedicated to FR/LPR + **external service** software running on the same machine

Each of these function servers uses the Ganz CONTROL Recorder installation. Recording servers do not require a license to operate but they also cannot be managed directly: each recording server must be connected to the Ganz CONTROL Global server to receive its configuration. To achieve centralized management:

- use your Ganz CONTROL Console application to connect to the Ganz CONTROL Global server,
- pair Ganz CONTROL Global server with all Ganz CONTROL Recorder servers,
- choose server roles (recording, failover, mirror) and assign configuration to each one.

Some of the features are provided by Ganz CONTROL Global server only (e.g., maps, user buttons); other resources can be assigned to specific recording servers (devices, video walls, etc). After receiving the configuration, recording servers can further operate independently (without connection to Ganz CONTROL Global server) for up to two weeks. After 14 days, the connection must be restored briefly for the license check and audit information exchange. Note that centralized functionality (failover, maps, etc) will be unavailable for isolated recording servers. If the connection is not restored and the license check fails, the recording server will continue to record but it will refuse all incoming client connections.



Recording servers can operate independently (without the central server connection) for up to 2 weeks, After 14 days of no connection, the recording server will terminate all incoming connections, but will continue to record.

Ganz CORTROL Global Administration Guide

Data Flow


Streams from the cameras and other sources are requested by servers where they are configured. From each device, the following data streams may be received for further use (excluding communication):

- video: main stream/substream
- recorded video (edge)
- audio
- video analytics
- DI/DO events
- GPS data
- HTTP contents
- serial text

These streams are recorded by servers, and then further provided to connected clients, which may be thick, thin, mobile, and Web applications. Streams go directly from recording servers to the clients. If a channel is replicated, the archived stream (and not live) from the recording server is sent to the target replication server.

The recording servers report to the central management server (Ganz CORTROL Global): they exchange management information, receive configuration changes, and send back audit information, as well as communicate license data.

Clients also communicate with the central management server: in background, they receive secondary server addresses, channel status, license information. The Ganz CORTROL Global server also ensures the link between clients and external services.



Ganz CORTROL data flow diagram

Ganz CORTROL Global Administration Guide

1.2 Edition Overview

The table below contains details on all currently available CBC AMERICA LLC video management software editions.

Feel free to contact our sales department via cortrol@cbcamerica.com to get the latest information on prices and software availability in your region.

		Feature list per edition					(v1.2 January 2nd 2017)
Features		Prime	Premier			Global	
General	Number of simultaneously connected cameras	9	24	48	96	Unlimited	
	Licensing type	Per server				Central server only with camera packs	
	Technical support	Not available	2 years since last available release date				
	Version updates	Free	2 years since license activation date				
	Version update subscription plans	Not applicable	+ 2, +4, +10 years				
	License upgrade option	Available				Through camera packs	
	Archive size/duration	Unlimited (storage limitations apply)					
Server/Console	Clients application connections	1 simultaneous	Unlimited				
	Web application connections						
	Android and iOS application connections						
	Local and Remote configuration management	Per each server				Centralised	
	Local and Remote user management						
	Supported video stream resolutions	FullHD and lower	Unlimited				
	Supported cameras/devices*	> 4000 models					
	Generic Device drivers: ONVIF, RTSP, HTTP	Available					
	Analog PTZ protocols (via RS-232,422,485 ports)	Available					
	32 and 64 bit versions	Both available					
	Video capture board support	Not available	Available				
	E-mail notifications						
	Advanced Events & Actions		Available within each server	Global for all connected servers			
	Recording server autodiscovery	Not applicable				Available	
	Service mode	Available					
	Software watchdog						
	Device autodiscovery						
	Local storage support						
	Remote/network storage support						
	Storage configuration per camera						
	Camera/Device side motion detector support*						
	Camera/Device side VCA event support*						
	Software motion detector support						
	Motion information recording						
	Constant Video and Audio recording						
	Video and Audio recording by Motion						
	Recording profiles by Schedules						
	User permissions per each resource/component						
	Device and User grouping						
	User audit						
	System monitoring						
	API for third party integrations						
	Configuration backup and restore						
	Camera side multicast support						
	E-maps	Not available	Available within each server			Centralised	
	Recording Server failover support	Not available				Available	
	Archive replication/backup within multiple servers						
	Video Wall support						
	Organizations hierarchy support						
	Active directory & LDAP						
	Remote upgrade for server, Console and Monitor applications	Not available				Available	
	Edge recoding support (for ONVIF Profile G devices)						
	Support for Digital inputs*						
	Support for Digital outputs*						
	Client application multicast support						
	Software VCA support (additional license required)						
	LPR and FR support						

Ganz CONTROL Global Administration Guide

Client	32 and 64 bit versions	Both available	
	Server connections	One at a time	Unlimited
	Live video streaming	FullHD and lower	Unlimited
	Live video substream support (please refer link)		Unlimited
	Number of supported displays	Unlimited	
	Instant playback	Available	
	Archive forward and backward playback		
	Playback speed controls: regular, slow and fast		
	Archive sequence explorer		
	Archive smart search		
	Build-in and custom layouts		
	Layout management		
	Layout sequences		
	PTZ, Iris and focus control		
	PTZ presets		
	PTZ tours		
	Digital PTZ		
	Fisheye and Panomorph dewarping		
	Motion detection status and overlay		
	Multiscreen setup		
	Alerts		
	Export Snapshot from live view and archive		
	Video export from archive		
	Export Library		
	Operation modes: Always on top, Exclusivity and Locked		
	Advanced Information about live video stream		
	Video maintain aspect ratio mode		
	USB Joystick Support		
	Archive Bookmarks		
	User buttons	Not available	Available
	Shared Layouts		
	E-maps		
	LPR and FR data support		
Mobile and Web	Server connections	One at a time	Unlimited
	H.264 streaming to Web and Mobile applications	Available	
	Live video substream support (please refer link)		
	Up to 6 cameras per single live view for Mobile apps.		
	Up to 4 cameras per single live view for Web application		
	Hardware GPU utilization for Mobile application		
	Custom view layouts		
	Two-way audio support		
	PTZ control		
	PTZ presets		
	Archive playback		
	Save snapshots		
	Google Chromecast support		
	Video & audio streaming from mobile devices		

Ganz CONTROL Server

Free software version allows a limited number of channels at maximum picture resolution of 1080p. Client application - Ganz CONTROL Client - can only be connected to a single Ganz CONTROL Server server, and streaming server (Web/mobile access), which is an integral part of the server, is limited to one connection at a time.

Advanced features like centralized server management, events & actions, external components (LPR, FR, VCA), maps etc. are not supported for free software edition; technical support is not guaranteed.

Free version upgrade is offered for Ganz CONTROL Server.

Ganz CONTROL Server

Ganz CONTROL Server is, alike Ganz CONTROL Server, a single server installation with no imposed limitation on stream resolution; number of allowed cameras varies depending on the server license type: 24, 48, and 96 channel editions are available. Also, there are no restrictions for remote connection amount from Ganz CONTROL Client applications and Web/mobile clients.

CBC AMERICA LLC LPR, VCA, face recognition (FR), as well as map and event/action modules are supported locally.

Ganz CONTROL Global Administration Guide

Free software updates are offered for 2 years since last license activation date; technical support is provided for 2 years since last version installation, making it a maximum of 4 years of support for non-renewed license. In order to obtain further updates and support, a license subscription upgrade should be acquired.

Ganz CONTROL Global

Ganz CONTROL Global edition presents a full-scale CCTV solution with centralized management and advanced enterprise features. Vast number of servers can be merged into a single surveillance system, offering transparent configuration for physically separated servers.

Unlike previous two editions, Ganz CONTROL Global solution is licensed per channel, with no theoretical limitation for total amount of cameras distributed between multiple servers.

All external modules are available via centralized management, and events/actions are shared between servers.

Free software updates are offered for 2 years since last license activation date; technical support is provided for 2 years since last version installation, making it a maximum of 4 years of support for non-renewed license. In order to obtain further updates and support, a license subscription upgrade should be acquired.

Ganz CORTROL Global Administration Guide

1.3 Hardware Requirements

The table below details several typical **minimum** recommended **hardware sets** for CBC AMERICA LLC **recording servers**. Please note that these specific processor models are given only as examples and are not compulsory: you can use a different CPU model, provided that it has the same number of threads and its performance is analogous.

Calculations are given for two major configuration examples: all streams in D1 or FullHD resolution; of course, intermediate and mixed cases may also exist. Please contact CBC AMERICA LLC representatives if you require help with choosing hardware.

HARDWARE RECOMMENDATIONS TABLE					
Installation specifications			Recommended hardware per usage scenario.		
Video Stream	Number of cameras	Motion Detector	Server only	Monitor*** only	Server + Monitor***
D1 30fps	Up to 9	None or camera-side*	CPU: Intel G1840; RAM 4GB	CPU: Intel G4500; R a.m. 4GB	CPU: Intel i3-6300; RAM 8GB
		Software HP**			
		Software HA**	CPU: Intel G4500; RAM 4GB	CPU: Intel i3-6300; RAM 4GB	CPU: Intel i5-6600; RAM 8GB
	Up to 16	None or camera-side*			
		Software HP**			
		Software HA**			
FullHD 30fps	Up to 9	None or camera-side*	CPU: Intel G1840; RAM 4GB	CPU: Intel i5-6600; RAM 8GB	CPU: Intel i7-6700; RAM 8GB
		Software HP**	CPU: Intel G4500; RAM 4GB		
		Software HA**	CPU: Intel i5-6600; RAM 8GB		
	Up to 16	None or camera-side*	CPU: Intel G4500; RAM 4GB	CPU: Intel i7-6700; RAM 8GB	CPU: Intel i7-6700; RAM 16GB
		Software HP**	CPU: Intel i3-6300; RAM 8GB		
		Software HA**	CPU: Intel i7-6700; RAM 8GB		

DDR4/DD5 RAM is strongly recommended!

- *Please refer to the list of CBC AMERICA LLC supported cameras for camera-side motion detector support
- **High Performance/High Accuracy mode
- ***System must provide:
 - DirectX 10 support
 - Graphics card with at least 256MB memory
 - Latest graphics driver version

For **Ganz CORTROL Client workstations**, onboard video memory should be at least 256MB per display, and the recommended minimum is 512MB per display.

Ganz CORTROL Global Administration Guide

For **Ganz CORTROL Video Analytics (VA)**: 1x physical core 3GHz+ and 1GB RAM per video channel. To achieve better performance and accuracy, we strongly recommend using NVIDIA or AMD GPUs with DirectX 12 support. Legacy VA still requires AVX/AVX2 compatible processors.


For **Ganz CORTROL Global servers** without any camera assignment (**management only**) you can use a stable but low-spec machine with high-speed OS medium with at least 4 cores (8 threads). Example: Intel i3-10320 with 16 GB DDR4 and NVMe SSD. Virtual machines are supported but make sure to allocate enough cores. If your Ganz CORTROL Global server will assume any additional load (video channels, in the first place) and/or the number of simultaneous client connections is large (hundred or hundreds of connections), please consult with cortrol@cbcamerica.com to get tips for your server hardware.


Ganz CONTROL Global Administration Guide


1.4 Prerequisites


There are a number of requirements for the Ganz CONTROL host system:


- Microsoft Windows operating system (10, 11, 11 IoT Enterprise, Server 2016, Server 2019, Server 2022), real or virtual machine
- both .NET Framework 3.5 SP1 and 4.x installed (the latest version should come with OS updates)
- for Windows Server operating systems, make sure the Desktop Experience feature is installed
- Windows Media Features must be installed (via Windows Features), it is missing by default in Windows N editions
- all Windows updates must be installed (especially, this is critical for Windows 10 and newer editions and for pending updates)
- ports for remote connections should be enabled through the firewalls (default ports are 60554 for Ganz CONTROL Client and Ganz CONTROL Console and 8080 for the Ganz CONTROL Streaming Server and external services)
- disable HTTP traffic analysis in the antivirus settings (especially ESET) to ensure the correct work of external services (LPR, FR, and other external video analytics modules)
- installation and recording directories should be added to antivirus exception list so that they are not scanned or interfered with in any other manner
- indexing and defragmentation services must be disabled for the storage locations
- for the software analytics requirements, see the corresponding section of the VCA/VA manual (provided as a separate document)
- for Ganz CONTROL Client application, DirectX 10+ is required along with the latest stable graphics card drivers
- for Ganz CONTROL Client, display resolution of 1280x720 pixels or higher is recommended

 Please pay attention to the difference between "Windows 11 IoT" and "Windows 11 IoT **Enterprise**"—they are two different systems, and we do not support "Windows 11 IoT"!

 For Windows Server 2016 and 2019, specify the *Server with Desktop Experience* option as part of the OS installation. Prior versions of Windows Server allow you to install this feature post installation.

 If you use a server with a clean Windows installation, make sure to install **all available Windows updates before** starting the software installation. Component deficiency (framework components, redistributables etc.) may lead to unexpected issues in software operation.

 If you are using Windows 10 N or KN (special edition without media technologies), make sure to install **Windows 10 Media Feature Pack** in order to ensure Ganz CONTROL operation. Without media features, Ganz CONTROL will not work. You will find the media feature pack online, provided by Microsoft.

 In order to enable GPU usage for video analytics, please install **NVIDIA CUDA toolkit redistributable** package, which is NOT a part of the Ganz CONTROL installation. You can download the toolkit from the CBC AMERICA LLC website (usually available with the latest Ganz CONTROL version), or request it from CBC AMERICA LLC representative or via control@cbcamerica.com.

For **recording**, the following recommendations apply:

- for 48+ channels and/or >20MB/s total recorded stream, RAID 5/6/10 with high speed hardware controller is strongly advisable
- defragmentation and indexing must be disabled for all storages
- every recording location, regardless of its type, must have 10-15% of free space, not used by Ganz CONTROL or any other software
- recording to the system disk is strongly not recommended
- antivirus software or any other scanners should be disabled for the storage locations
- no third-party VMS should be recording to the same location as Ganz CONTROL
- for NAS, make sure to disable the *Recycle Bin* feature, so that the erased files are actually deleted and not

Ganz CORTROL Global Administration Guide

just moved to trash folder

- after adding the channels for recording, check the disk load (**disk queue**)
- disable read cache for RAID controllers



High disk queue may result in gaps in the recordings, freezing client during archive playback, etc. Minimize the disk queue to avoid system performance issues.



Antivirus **scanning, defragmentation, indexing** and other similar processes being enabled for Ganz CORTROL storages may result in dramatically decreased write speed, recording disturbances and, occasionally, database corruption. We strongly recommend that you make sure that storage locations are not affected by these processes.



CBC AMERICA LLC is **not responsible** for software failures and/or any footage loss caused by underlying OS and/or hardware issues. It is the responsibility of the systems administrator to configure the server and provide maintenance, unless otherwise agreed (e.g., if server hardware has been shipped by CBC AMERICA LLC for bespoke configuration).

Ganz CORTROL Global Administration Guide

1.5 Getting Started

Before starting the installation, make sure that:

- you have downloaded the correct software package
- you have acquired the corresponding valid **license** key
- the host operating system is stable (functioning correctly) and has all the **updates and drivers** installed
- server **hardware matches** the project **requirements**, taking into account all used features and planned post-deployment modifications
- host system retains all the [features and configuration](#) required for software operation



We strongly advise that you keep the software versions (e.g., 1.x.x) and subversions (e.g., 1.2.x) across your system match exactly. Software build numbers (e.g., 1.2.0.xxxxx) may differ slightly in case you are using 64-bit and 32-bit editions.



If you are not sure about what server hardware to choose, do not hesitate to use CBC AMERICA LLC provided hardware calculators and/or contact CBC AMERICA LLC representative for an accurate estimation.

We advise installing and activating the software on the ultimate server assembly, as extensive subsequent hardware changes are likely to cause software license activation failure. If this happens, undo these changes, if possible, or contact product support to find a solution.

Ganz CORTROL is installed as a Windows service so please make sure that the Windows user you are logged in as has sufficient privileges; otherwise, software may not be installed correctly. Note that there is no option to install and run the software in application mode.

The following topics will guide you through the installation process, as well as provide details on product configuration. If you are using a CBC AMERICA LLC product for the first time, we strongly advise you to carefully read and follow the instructions in this manual and related documentation.



CBC AMERICA LLC is **not responsible** for software failures and/or any footage loss caused by underlying OS and/or hardware issues. It is the responsibility of the systems administrator to configure the server and provide maintenance, unless otherwise agreed (e.g., if server hardware has been shipped by CBC AMERICA LLC for bespoke configuration).


Ganz CORTROL Global Administration Guide

1.6 Installation of Ganz CORTROL Global

Start the installation by double-clicking the Ganz CORTROL Global executable package file. The setup wizard will guide you through the installation process, providing available installation-time options depending on the software package you have chosen. Note that, depending on your Windows UAC configuration, you may have to confirm and/or provide administrative credentials.

We strongly advise that you stop all running third-party applications, as well as stopping antivirus scanning and Windows (and any other) updates during this phase, as these may interfere with the process and result in corrupt installation, which may cause unexpected behavior and hard-to-track issues during further software operation.

The installation wizard displays an overview of the process; also, you are able to select the installation language here. You will be prompted to select the Ganz CORTROL Global interface language later.



Ganz CORTROL Global Setup Wizard

Step 1

Carefully read the CBC AMERICA LLC license agreement: you must agree to all parts of the given document in order to proceed. If you agree, select *I agree...* in order to continue; otherwise, terminate software installation. If you have any questions regarding the contents of the present license agreement, please contact ctrlol@cbcamerica.com.

Ganz CONTROL Global Administration Guide

Step 1 of 3 - Licence agreement

Central Server Licence Agreement

Please read the following Licence agreement. You must accept the terms of this agreement before you can continue with the installation.

misconfiguration, hardware failure, hardware conflict, software conflict, user data misconfiguration, and/or data loss.

You expressly assume the entire risk and cost associated with the Software, including risk resulting from Maintenance services (whether performed in whole, in part, or not at all), or from any virus, downloaded material, harmful component, or through any Internet use of the Software or any site or server through which the Software is available. You are solely responsible for any damage that results from or is associated with use of the Software. The Disclaiming Parties shall not be liable in any manner whatsoever for the results obtained through use of the Software. Persons using the Software are responsible for the supervision, management and control of the Software including determination of the

☒ I accept the terms of the agreement

Previous

Next

Cancel

License Agreement

Step 2

Select the destination folder you want the software to be installed in. By default, Ganz CONTROL Global is installed in:

32-bit: *C:\Program Files (x86)\CBC AMERICA LLC\Ganz CONTROL Global*

64-bit: *C:\Program Files\CBC AMERICA LLC\Ganz CONTROL Global*

If you are re-installing Ganz CONTROL Global and have previously selected a non-default location, make sure to select the same destination directory, or, alternatively, completely uninstall previous Ganz CONTROL Global version. If unsure about this, ask for CBC AMERICA LLC technical support team assistance. A full description of the software upgrade procedure is available in the corresponding section of the Ganz CONTROL administration manual.

Ganz CORTROL Global Administration Guide

Step 2 of 3 - Destination location

Select and confirm the folder where you want the Central Server software to be installed

Where do you want Central Server to be installed?

Setup will install Central Server in the following folder. Click browse to select a different folder.

C:\Program Files (x86)\Central

Browse...

Installation requires at least 423.33 MB of disk space.

Previous

Next

Cancel

Installation Directory

The setup wizards estimates required disk space for you. Make sure you have enough free space on the target disk. Note that low system disk space will dramatically decrease system performance and affect overall system stability.


Step 3

Some components are optional and you can choose not to install them. The main Ganz CORTROL Global parts are obligatory and cannot be deselected (by default, these options are selected and grayed out).

If not chosen at this stage, Ganz CORTROL Client can be installed later separately.

Ganz CORTROL Global Administration Guide

Step 3 of 3 - Select components



Specify which components to install

Configure the components of the installation package:

☒ Central Server Server Service (390.90 MB)

☒ Central Server Management Application (3.82 MB)

☒ Central Server Client Application (1.39 MB)

Select the language to use in the user interface

English

At least 424.72 MB of free space is required.

Previous


Next

Cancel

Select Software Components

If you are ready to proceed, hit *Next* to begin the installation. Depending on selected components and host system condition, the process may take some time to complete, so please be patient.


Important notice for US users!



According to the National Defense Authorization Act, section 889, federal agencies and their contractors are prohibited from using video surveillance equipment from certain Chinese companies. If your installation falls into this category, please follow the sub-step below.

Here, you have an option to exclude the drivers for the abovementioned surveillance cameras, thus making the installation NDAA compliant.

In order to exclude the drivers for the non-compliant devices from the installation, expand the Ganz CORTROL Server Service node in the list, and enable the *NDAA approved cameras only* option.



Specify which components to install

Configure the components of the installation package:

☒ Server Service


☐ NDAA approved cameras only

☒ Management Console Application

An additional installation option for NDAA compliance (disabled by default).

Ganz CONTROL Global Administration Guide


After selecting this option, you will get a more detailed description to read and agree.



Details about the limited installation package

If you are doing an software **upgrade**, the corresponding drivers will be removed. In case your database **uses some of these devices** and therefore contains them already, you will be asked to **cancel the installation** and remove these from the configuration manually first.


Ganz CORTROL Global Administration Guide



Installation Progress

Upon completion, the setup wizard will show you an installation summary. If all the steps have been fulfilled successfully, simply hit *Finish* to close the wizard.

Ganz CORTROL Global Administration Guide



Installation Complete

After the installation has been completed, there are a few more steps necessary for you to begin using the software:


- apply server initialization settings via Server Setup Wizard - it will pop up automatically after the installation in case you are doing a clean or a new installation
- activate the software - if it is not activated, the wizard will also pop up automatically
- after you run the console for the first time, you will be offered to complete the Setup Wizard to start the deployment, following the recommended configuration steps

All of these steps are described in details in the full version of the Ganz CORTROL management manual, which is available right after the installation via your Start menu.


Ganz CONTROL Global Administration Guide

1.7 Initialization of Ganz CONTROL Global Server

After completing the installation wizard, you will be given the option to enter server setup. These settings can be changed later at any time via [Server Setup Wizard](#).

 You will be unable to connect to the server that has not been initialized, it will return an error (*The server is not configured*).

This step is mandatory; you will be unable to connect to your server and configure it if it has not been initialized. It is necessary to initialize the server even if you are planning to restore its configuration using the [Server Backup and Restore Wizard](#).




Initial Server Setup

Setting	Description	Default Value
Server name	User defined server title	[depending on the server type]
Connection type	LAN only, LAN/Internet, Internet only	Determined automatically
Server port	TCP port for incoming remote Client connections	60554
Local network	IP subnet for software operation, choose one from the drop-down list. Server will use the local computer IP address.	Configurations are determined and loaded automatically depending on the available network adapters
External IP address	Server public IP address or hostname, if applicable	[empty]

Ganz CORTROL Global Administration Guide

Note that the port defined here will be used to connect to the central server via local Ganz CORTROL Client and Ganz CORTROL Console connections. You will need to define the external (Internet) port for your Ganz CORTROL Global via Ganz CORTROL Console in order to be able to connect from remote Ganz CORTROL Client connections.



Setup Completed

Ganz CORTROL Global Administration Guide

1.8 Management Application Installation

All server configuration is conducted through a dedicated interface - the Ganz CORTROL Console management application. The management interface has been intentionally separated from the Ganz CORTROL Client application in order to concentrate all administrative utilities in one place and also to conceal the unnecessary menus from the Ganz CORTROL Client operator.

The Ganz CORTROL Console central server management application can be installed either locally on one of the servers, or remotely, on a dedicated server management machine.


If you want to install Ganz CORTROL Console **together with Ganz CORTROL server**, run the **same** installation **package** and select Ganz CORTROL Console among **components**.

For **dedicated** Ganz CORTROL Console installation on a separate management machine (admin laptop, etc.), use the Ganz CORTROL Console installation package and follow the steps below.

Dedicated Installation

Start the installation by double-clicking on the Ganz CORTROL Console executable package file. The setup wizard will guide you through the installation process, providing available installation-time options depending on the chosen software package.

Installation wizard shows you the process overview; also, you also have the opportunity to select the installation language here. You will be prompted to select Ganz CORTROL interface language later.



Ganz CORTROL Console Setup Wizard

Carefully read the CBC AMERICA LLC license agreement: you must agree to all parts of the given document in order to proceed. Select *I agree...* in order to continue, if you do; otherwise, terminate software installation. If you have questions regarding the contents of this license agreement, you can contact cortrol@cbcamerica.com.

Ganz CORTROL Global Administration Guide

Step 1 of 3 - Licence agreement

VMS Management Application Licence Agreement

Please read the following Licence agreement. You must accept the terms of this agreement before you can continue with the installation.

1.1. Additional License Restrictions. Except as specifically permitted by this Agreement, Licensee shall not:

- 1.1.1. Copy (except as permitted by applicable law or as provided in this Agreement), sell, modify, translate, transfer, reverse engineer, decompile or disassemble the Software;
- 1.1.2. Remove any Software proprietary notice, label or mark, whether in machine language or human-readable form;
- 1.1.3. Transmit or distribute the Software to any person outside Licensee's internal business organization(s) (for the sake of clarity, in no event may this Agreement, including the License

☒ I accept the terms of the agreement

Previous

Next

Cancel

License agreement

Select destination folder for Ganz CORTROL Console to be installed in.

Step 2 of 3 - Destination location

Select and confirm the folder where you want the VMS Management Application software to be installed

Where do you want VMS Management Application to be installed?

Setup will install VMS Management Application in the following folder. Click browse to select a different folder.

C:\Program Files (x86)\VMS\VMS Management Application

Browse...

Installation requires at least 332.43 MB of disk space.

Previous

Next

Cancel


Installation directory

The setup wizards will estimate the amount of disk space required for the installation. Make sure you have enough free space on the target disk. Note that low system disk space will dramatically decrease system performance and affect overall system stability.

Along with Ganz CORTROL Console, this installation package also allows you to have Ganz CORTROL Client application installed at the same time. If you do not wish to install Ganz CORTROL Client at the moment, simply uncheck it in the components list.

Ganz CONTROL Global Administration Guide

Step 3 of 3 - Select components



Specify which components to install

Configure the components of the installation package:

- ☒ VMS Management Application Management Application (303.82 MB)
- ☒ VMS Management Application Client Application (1.39 MB)

Select the language to use in the user interface

English ▼

At least 333.82 MB of free space is required.

Previous **Next** Cancel



Select software components

If you are ready to proceed, hit *Next* to begin the installation. Depending on selected components and host system condition, the process may take some time to complete, so please be patient.

Installing...

Installation in progress

Please wait while Setup installs VMS Management Application on your computer



Installing...


49 %

Cancel

Installation progress

Upon completion, the setup wizard will show you an installation summary. If all the steps have been fulfilled successfully, simply hit Finish to close the wizard.


Ganz CORTROL Global Administration Guide



Installation complete

After completing the Ganz CORTROL Console installation, you will be given the option to enter the settings of server you wish to connect to. You can skip this step if you wish to configure your Ganz CORTROL Global server later; you will be asked for the same information next time you run Ganz CORTROL Console.

To log in, simply enter your server's local or remote address (IP or host name) and user information. Note that users must have corresponding permissions in order to connect. Default username and password are **admin/[empty]**.



Ganz CORTROL Console login window and a password change reminder

After logging in for the first time with the default username and password, you will be reminded to change your password. For security reasons, we strongly recommend that you do so.

Ganz CONTROL Global Administration Guide

1.9 Recording Server Installation


Recording server is a part of distributed Ganz CONTROL Global installation; its main purpose is video recording. Recording server installations can also be assigned other roles - failover node (standby recording server), mirror (central server redundancy), or replication server (a particular case of the recording server). In other words, for every server in the Ganz CONTROL Global system, except for the central management server itself, you need to use the Ganz CONTROL Recorder installation file. Ganz CONTROL Recorder server management is carried out via central server Ganz CONTROL Console.

Installation

Start installation by double-clicking the Ganz CONTROL Recorder executable package file. Setup wizard will guide you through the installation process, providing available installation-time options depending on the chosen software package. Note that you may have to confirm and/or provide administrative credentials, depending on your Windows UAC configuration.

It is strongly recommended that you stop all running third-party applications, antivirus scanning and Windows (and other) updates during this phase, as these may interfere with the process and result in corrupt installation, which causes unexpected behavior and hard-to-track issues during further software operation.

Installation wizard presents the process overview; also, you are welcome to select the installation language here. You will be prompted for Ganz CONTROL Recorder interface language later.



Ganz CONTROL Recorder Setup Wizard

Step 1

Carefully read the CBC AMERICA LLC license agreement: you must agree to all parts of the given document in order to proceed. If you agree, select *I agree...* in order to continue; otherwise, terminate software installation. If you have any questions regarding the contents of the present license agreement, please contact control@cbcamerica.com.

Ganz CORTROL Global Administration Guide

Step 1 of 3 - Licence agreement

Recording Server Licence Agreement

Please read the following Licence agreement. You must accept the terms of this agreement before you can continue with the installation.

Upon expiration or termination of this Agreement for any reason, this License shall terminate and any user accessing the Software shall immediately cease to use or have access and support for it. **If you breach any provision of this Agreement, including by making any unauthorized copy of the Software or by failing to comply with any prohibition set forth in this Agreement, the License shall immediately terminate automatically.**

1.2. Update Policy. Any Software license purchased, whether for a Previous Version or a New Version, will not include, and you shall not be entitled to, any free Software updates.

☒ I accept the terms of the agreement

Previous

Next

Cancel

License Agreement

Step 2

Select the destination folder you want the software to be installed in. By default, Ganz CORTROL Recorder is installed in:

32-bit: *C:\Program Files (x86)\CBC AMERICA LLC\Ganz CORTROL Recorder*

64-bit: *C:\Program Files\CBC AMERICA LLC\Ganz CORTROL Recorder*

If you are re-installing Ganz CORTROL Recorder and have previously selected a non-default location, make sure to select the same destination directory, or, alternatively, completely uninstall previous Ganz CORTROL Recorder version. If unsure about this, ask for CBC AMERICA LLC technical support team assistance.

Setup wizards estimates required disk space for you. Make sure you have enough free space on the target disk. Note that low system disk space will dramatically decrease system performance and affect overall system stability.

Ganz CORTROL Global Administration Guide

Step 2 of 3 - Destination location

Select and confirm the folder where you want the Recording Server software to be installed

Where do you want Recording Server to be installed?

Setup will install Recording Server in the following folder. Click browse to select a different folder.

Installation requires at least 419.51 MB of disk space.

Installation Directory

Step 3

Some components are optional and can be chosen not to be installed. you can choose not to install them. The main Ganz CORTROL Recorder part - recording server service - is obligatory and cannot be deselected (by default, these options are selected and grayed out).

If not checked at this stage, Ganz CORTROL Client and Ganz CORTROL Console can be installed later separately.

Ganz CONTROL Global Administration Guide

Step 3 of 3 - Select components

Specify which components to install

Configure the components of the installation package:

☒ Recording Server Server Service (390.90 MB)

☒ Recording Server Management Application (3.82 MB)

☒ Recording Server Client Application (1.39 MB)

Select the language to use in the user interface

English

At least 424.72 MB of free space is required.

Previous


Next

Cancel

Select Software Components

If you are ready to proceed, hit *Next* to begin the installation. Depending on selected components and host system condition, the process may take some time to complete, so please be patient.

Important notice for US users!



According to the National Defense Authorization Act, section 889, federal agencies and their contractors are prohibited from using video surveillance equipment from certain Chinese companies. If your installation falls into this category, please follow the sub-step below.

Here, you have an option to exclude the drivers for the abovementioned surveillance cameras, thus making the installation NDAA compliant.

In order to exclude the drivers for the non-compliant devices from the installation, expand the Ganz CONTROL Server Service node in the list, and enable the *NDAA approved cameras only* option.

Specify which components to install

Configure the components of the installation package:

☒ Server Service


☐ NDAA approved cameras only

☒ Management Console Application

An additional installation option for NDAA compliance (disabled by default).

Ganz CONTROL Global Administration Guide


After selecting this option, you will get a more detailed description to read and agree.



Details about the limited installation package

If you are doing an software **upgrade**, the corresponding drivers will be removed. In case your database **uses some of these devices** and therefore contains them already, you will be asked to **cancel the installation** and remove these from the configuration manually first.


Ganz CORTROL Global Administration Guide



Installation Progress

Upon completion, the setup wizard will show you installation summary. If all the steps have been fulfilled successfully, simply hit *Finish* to close the wizard.

Ganz CONTROL Global Administration Guide



Installation Complete

After the installation, Ganz CONTROL Recorder initialization setup wizard will automatically pop up: please wait for it to appear and then apply the offered settings in order to complete the Ganz CONTROL Recorder deployment.

If you have removed a Ganz CONTROL Recorder from the Ganz CONTROL Global configuration and have issues finding it again either from the same Ganz CONTROL Global server or from another one, the following procedure is foreseen: run the Ganz CONTROL Recorder upgrade (to the same or a newer version) and reset its configuration at the initialization step. Then, proceed with Ganz CONTROL Recorder autodiscovery from your central management server.

Step 1. Server setup

Server setup

Server port60555

TCP listener port

☐ Reset configuration

Existing configuration will be backed up and deleted. The server will be initialized with empty configuration.

OK


Cancel

Reset Ganz CORTROL Recorder configuration after upgrade


Ganz CORTROL Global Administration Guide

1.10 Recording Server Initialization

After completing the installation wizard, you will be given the option to enter initial server setup: server initialization is required for the central server to be able to connect and apply settings to the target recording server. The settings selected during server setup can be changed later at any time using the [Server Setup Wizard](#) tool, which is installed together with the Ganz CORTROL Recorder and can be found via *Start -> All Apps -> CBC AMERICA LLC -> Server Setup Wizard*.




Ganz CORTROL Recorder local port can be only changed by running the *Server Setup Wizard* tool locally on the Ganz CORTROL Recorder machine. By changing the Ganz CORTROL Recorder port via Ganz CORTROL Console you simply tell the central server what port should be used to connect to the Ganz CORTROL Recorder.



Set Server TCP/IP Properties

Setting	Description	Default Value
Server port	TCP port for incoming central server connections	60554

Note that the port defined here will be used for Ganz CORTROL Recorder automatic discovery from the central server, and also to retrieve Ganz CORTROL Recorder data for local Ganz CORTROL Client connections. You will need to define the external (Internet) port for each Ganz CORTROL Recorder via Ganz CORTROL Console in order to be able to receive video streams from remote Ganz CORTROL Client connections. Further information can be found in the [Connections](#) section of the manual.




Setup Completed


Ganz CORTROL Global Administration Guide

1.11 Software Update and Uninstall

This topic provides guidelines on the installation management use cases.

We recommend that you keep the software version up to date, as new versions include new features, various improvements and optimizations, as well as the latest bug fixes.

 We strongly advise that you keep the software versions (e.g., 1.x.x) and subversions (e.g., 1.2.x) across your system match exactly. Software build numbers (e.g., 1.2.0.xxxxx) may differ slightly in case you are using 64-bit and 32-bit editions.

 Before starting the upgrade/uninstall procedure, ensure that all Ganz CORTROL processes have been terminated and that Ganz CORTROL files are not in use: this is necessary in order to upgrade all files to the newer versions. This includes any Ganz CORTROL processes or related applications that are running, and also any third-party applications that have access to Ganz CORTROL files, e.g., antivirus scanners, third-party integrations, etc. Ganz CORTROL processes can be found via Task Manager->Details tab: these start with *VMS*, e.g., *VMSServer.exe*.

If the processes are not stopped, or if other applications are still interfering with the process, you may be asked for a **reboot**: in that case, please restart your server machine afterwards to complete the action. This will not affect the overall process quality.


Upgrade Software

This section describes manual software update (newer version installation on top of the older one) by running the installation **locally**. For [remote upgrades](#), see the [corresponding section](#) of this document.

Before starting the software upgrade:

1. Make sure there are no other running installations and that the operating system is not in the middle of installing updates. If Windows updates are pending, apply them, then restart the computer (if required), and start the Ganz CORTROL upgrade.
2. Verify that the operating system is stable and is running normally (check system logs, overall health) - these must be no "blue screens", unexpected shutdowns, slowdowns etc. (Normally, we recommend that you regularly run such system checkups, not only before upgrade).
3. Ensure stable power and connectivity (the latter is essential if you are connected via RDP).
4. See if there are any special requirements or recommendations from CBC AMERICA LLC regarding the target version. Usually, these are either mentioned on the download page, or provided alongside the download links in case the new version was recommended and sent by our engineers.
5. Check your software license subscription, and renew it, if necessary: the subscription must not run out before the target version release date. You can check the software release date by right-clicking the installation file > *Properties* > *Digital signatures* > see timestamp. The license information is available via license manager, *Ganz CORTROL Activation Wizard*.

Ganz CORTROL Global Administration Guide




Choose license preference for the upgrade

If you launch a newer version installation package of the same kind as the already installed Ganz CORTROL edition, you will be given the option to **upgrade** the product. It is not possible to install another type of package on top of the existing one, e.g., Ganz CORTROL Recorder on top of Ganz CORTROL Server: if you wish to change the server type, uninstall the old software package first.

Press *Next* to go through the steps and complete the wizard, which is very much alike the installation wizard. At each step, read all the information displayed and press *Next* until finished.

Ganz CONTROL Global Administration Guide




Use existing database configuration

If you want a clean installation, choose to ignore the existing **configuration**: the current database will not be used and will be replaced with an empty one, as if you were installing the software from scratch. Otherwise, leave the wizard to use the existing configuration. In either case, the old database is not actually removed but is saved as a backup, so you will be able to load it anytime later via [Backup and Restore Wizard](#).


In case the installation wizard detects your **license subscription** has run out, you will get a **warning** about license compatibility. By default, the initial subscription will allow for version upgrades during 2 years, starting from the license activation date. Hence, if the target upgrade version is newer, this warning will pop up.

- If you have already acquired a subscription upgrade, proceed with the installation, then run the [license manager](#) and upgrade your license in either online or offline mode
- Otherwise, cease the installation and choose another software version that was released before the license subscription ran out (or continue using the existing version)

You can contact our sales department via cortrol@cbcamerica.com or via direct manager contact to learn about the license subscription options and price offers.




If you proceed with the upgrade but do not provide a valid license after the installation is complete, the software will not operate. Therefore, do not proceed with the upgrade until you have renewed the subscription.

 To verify the software release date against your license subscription expiration date, right-click the installation file > choose *Properties* > go to the *Digital Signatures* tab and check the timestamp.

If some of the files cannot be upgraded because they are in use, you will get a corresponding warning.


- Choose *Ignore* to proceed with the installation: reboot may be required afterwards but it is safe to select this option, esp. if the processes are from Ganz CORTROL; or
- Stop the listed applications/services and click *Retry* to continue installing the software, or
- Click *Abort* to roll back the installation (the process will be cancelled and you will get a corresponding error in the wizard's dialog box).

Ganz CORTROL Global Administration Guide



Click *Ignore* to proceed with installation (reboot may be required afterwards)

Important notice for US users!

 According to the National Defense Authorization Act, section 889, federal agencies and their contractors are prohibited from using video surveillance equipment from certain Chinese companies. If your installation falls into this category, please follow the sub-step below.

Here, you have an option to exclude the drivers for the abovementioned surveillance cameras, thus making the installation NDAA compliant.

In order to exclude the drivers for the non-compliant devices from the installation, expand the Ganz CORTROL Server Service node in the list, and enable the *NDAA approved cameras only* option.

Ganz CONTROL Global Administration Guide


Specify which components to install

Configure the components of the installation package:

- ☒ Server Service
- ☐ NDAA approved cameras only
- ☒ Management Console Application

An additional installation option for NDAA compliance (disabled by default).

After selecting this option, you will get a more detailed description to read and agree.



Details about the limited installation package

If you are doing an software **upgrade**, the corresponding drivers will be removed. In case your database **uses some of these devices** and therefore contains them already, you will be asked to **cancel the installation** and remove these from the configuration manually first.

The upgrade process will then continue and replace your Ganz CONTROL software version to the newer one.

Ganz CONTROL Global Administration Guide

Uninstall/Change Software

Software can be uninstalled in two ways:


1. From the Windows Control Panel
2. By launching the same package that was used for installation

In either case, you have a choice between changing and uninstalling the product.



Before making any changes to the installation, make sure to close and stop all software services and applications. If processes are not stopped, some of the software components may not be removed or replaced during the installation process.

In order to check this, open Windows Task Manager, select '*Show processes from all users*' and make sure there are no processes starting with 'VMS..'. If there are any, stop them manually and then proceed with the installation changes.



Change or uninstall the product


Select *Change* if you wish to re-install or add software components. The process will be similar to the initial installation.

Select *Uninstall* to remove all software components. You will be asked if you wish to keep the configuration and the current license; the following common use cases apply:

- keep the license and remove the configuration if you wish to re-configure everything from scratch after re-installation (e.g., in event of a corrupt database or having to move the server to a different system);
- keep both if you are going to clean install the software;
- remove both if you do not intend to use the software on this machine anymore.


Press *Next* to proceed with the de-installation process. Note that you may have to confirm these changes if UAC has been turned ON.

Ganz CONTROL Global Administration Guide



Uninstall

If you did not stop the Ganz CONTROL server before starting the uninstall process or if some third-party software (e.g., antivirus) has locked Ganz CONTROL files, you will get a warning.



A warning about some files being locked by a process

In this case:

- choose **Abort** to cancel the uninstall process
- stop the processes manually yourself and then click **Retry**

Ganz CORTROL Global Administration Guide

- click **Ignore** to let the wizard handle the files automatically (recommended, an reboot may be required)

Generally, if you see that the process mentioned in the warning is Ganz CORTROL **own process**, simply choose the **Ignore** option and let the wizard do the job.

When the wizard finishes removing software components, hit *Finish* to exit.

Clean Install

Sometimes it is necessary to install software anew, i.e., to change software bit version, roll back version, and also in event of major [software-related troubles](#).



You can perform clean install yourself if you are already familiar with the software. If you are doing it for the first time, we recommend that the procedure is supervised by a CBC AMERICA LLC support engineer so that you learn how to do this quickly and effectively, avoiding possible mistakes.



Although software upgrade is not possible with different bit versions, you can migrate your installation to a different bit version by performing a clean install.

To perform a clean installation, it is crucial to make sure that no CBC AMERICA LLC software processes are running, whether explicitly or in the background. Follow these steps:


1. Stop all CBC AMERICA LLC software services and/or applications;
2. Open Windows Task Manager, click '*Show processes from all users*' and check that there are no processes starting with 'VMS.'; if there are any, stop them;
3. Uninstall software as described above, keeping your license and configuration;
4. Install [new] software version, carefully following all [steps](#) and [recommendations](#);
5. Start the software and check if the desired change has been carried out.

1.12 Start & Stop Server Service

After software installation (except for the Ganz CORTROL Console or Ganz CORTROL Client only installations), two components are registered as **Windows services**: CBC AMERICA LLC Server service and the accompanying Watchdog service. Both these services are set to automatic start meaning that they will be launched straight after Windows start-up regardless of whether any user is logged in or not.


By default, the server will run in silent service mode, i.e., without any status indication other than that in the Windows Services management console; from there, both services can be stopped, started and restarted.

Double-click the server shortcut on your desktop to launch the system tray shell for the server: the server icon will appear in the system tray, allowing you to start and stop the service by right-clicking it and selecting your desired option. Ganz CORTROL Watchdog service runs silently in background as an auxiliary service and has no user interface except for the settings' dialog box in Ganz CORTROL Console.



Start and stop the server service from the system tray

If the server service is stopped while Ganz CORTROL Console connections are active, the wait-for-server-connection window will appear on top of Ganz CORTROL Console, disabling any input. The same thing will happen if there are any problems with server connectivity. It will automatically disappear when the server is online again; alternatively, you can click *Close* to exit Ganz CORTROL Console at this point and open it manually later.



Connection lost


Ganz CONTROL Global Administration Guide

2 License Activation

In order to use the product, a **valid license** is required - whether this is a trial or a purchased one. Any of these licenses can be activated using this wizard; note that license activation choice will differ depending on the installation package you have selected.

For the standalone server edition, Ganz CONTROL Server, the license is applied to that specific server. Client applications do not require a license to operate.

For the Ganz CONTROL Global system, the license is applied to the Ganz CONTROL Global server (central management server) only; Ganz CONTROL Recorder machines do not require a license to operate because they cannot operate independently. Client applications do not require a license to operate.



Ecosystem with two Ganz CONTROL Server servers and one Ganz CONTROL Global: components requiring license are marked with the key icon

Each server only accepts one Ganz CONTROL license key, no matter how many and which features it includes. Each Ganz CONTROL license key can only be applied on one machine.

License Types

Each license includes a certain number of channels. Traditionally, these are **video channels** (normally, one video source equals to one license), and then there are special channels with **advanced functionality**. Ganz CONTROL features (video walls, maps, redundancy, etc.) do not require any additional feature licenses.

License types:

- **video** channels: regular video channels.
- **VA** - embedded video analytics (embedded, generic VA engine)
- specialized VA (embedded, different engine types)
- CrossLink - interactive channels
 - **CrossLink Basic**: interactive web applications (webpages)
 - **CrossLink Advanced**: interactive remote applications (workstations)

Ganz CONTROL Global Administration Guide

- advanced device integrations (Leica, etc.)
- **data channels.**

Also, each Ganz CONTROL license contains 1 (one) generic video analytics channel free of charge.

Other CBC AMERICA LLC product licenses (for other modules) are not included into Ganz CONTROL license and should be purchased separately. For detailed information on Ganz CONTROL license options, as well as other software modules and their licensing, please contact our sales via control@cbcamerica.com.

The Ganz CONTROL server controls the total number of the channels of each type in the system. For Ganz CONTROL Global systems, you must apply the license onto the Ganz CONTROL Global server (the central management server), and then you are free to allocate and move the channels across the Ganz CONTROL Recorder servers. The Ganz CONTROL Global server will keep track of all license channels used throughout the system.

The server tracks the license channels using the following logic:

- [video channels](#): one license channel is used for each channel that is created when you create a device of any model (except for CrossLinks).
- VA: VA licenses are separated from video channel licenses and do not include them. You should purchase VA channels on top of the regular video channels. You are free to enable [VA for any video channel](#), as long as the total number of enabled video analytics does not exceed the VA number in the license.
- [CrossLinks](#):
 - CrossLink Basic: one Basic license channel allows you to create one Webpage or one device of the CrossLink Basic model
 - CrossLink Advanced: one Advanced license channel allows you to create one Webpage or one device of any CrossLink model
- advanced integrations: each special integration (e.g., Leica) channel allows you to create a device of the corresponding type.
- [data channels](#): one data channel license is required to create one [data channel](#). Databases are unlocked automatically (DBs do not operate without a data channel).



The free Ganz CONTROL Server license is not available anymore starting from the software release 1.22.0 for **all software versions**. Enjoy the fully featured [trial version](#) of Ganz CONTROL Server!



Starting with version 1.30, you can extend your License on a subscription basis. To learn more about available options, please contact sales representatives.

License Activation

Once you have installed the software and entered the server initialization settings, the activation wizard will appear. If it does not, or if you have rebooted the server computer after completing the installation, simply run the **activation manager** in one of the following ways:

- from the Windows Start Menu, under CBC AMERICA LLC folder, or
- by typing *Activation Wizard* in the search field, or
- by right-clicking the server tray icon and selecting *About > Manage license* (server tray icon appears only after you run the Ganz CONTROL Server shortcut from your Desktop or Start menu), or
- when connected to localhost via Ganz CONTROL Console, go to the main menu > *About > Manage license*.

The license manager will only pop up automatically after the initial installation. If you wish to apply license upgrades at any time, including the after-software-upgrade, run the license manager manually as described above.

It is advisable to run hardware stability tests and finalise the server hardware configuration before applying the license, as subsequent hardware changes may cause activation related issues. Approximately up to 30% of the initial hardware components can be replaced without losing the activation.

Subtopics here describe every type of license activation in details.



Licensing is mandatory for Ganz CONTROL Server and Ganz CONTROL Global software packages. Ganz CONTROL Recorder does not require a license as it is not an independent component but rather operates under a Ganz CONTROL Global server only.

Ganz CORTROL Global Administration Guide




Virtualized environment is supported starting from software version 1.13.0. If you experience any issues with the license activation, kindly contact our support engineers by emailing cortrol@cbcamerica.com.

Ganz CONTROL Global Administration Guide

2.1 Online Activation

If your server has Internet connection available, you can choose online activation mode. The software will automatically connect to the activation server and register your pre-purchased license.




The screenshot shows a dialog box titled "Step 1. Activation type selection". It contains three radio button options under the heading "Activation types":

- ☒ **Activate existing license key**
You should have valid licence key from your service provider
- ☐ **Offline activation via license file**
You should have valid license file provided by Support
- ☐ **Request Evaluation license key**
Generate Evaluation licence key via web interface

At the bottom right, there are two buttons: "OK" and "Exit".

Activation Type Selection

Enter your product license key and hit *Activate*. If your key is incorrect, the wizard will notify you with a red *X* sign next to the key field: if this happens, double-check the key you have typed, looking out for mistyped characters and superfluous spaces at the start or end.




The screenshot shows a dialog box titled "Step 2. Activate existing license key". It contains a text input field labeled "Enter licence key" with the text "InCoRrEcTkEy123" entered. A red "X" icon is visible to the right of the input field, indicating an error. Below the input field, there is a note: "You can find licence key in the mail from VMS sales or ask your surveillance service provider." At the bottom right, there are two buttons: "Activate" and "Cancel".

Enter License Key

When you have entered a valid license key, the wizard will activate your software. If you have decided to go with a different activation option, click *Cancel* to return to the activation type selection step.

2.2 Offline Activation

If there is no Internet connection for security reasons and/or server disposition particularities, choose the *Offline Activation* type.



The screenshot shows a dialog box titled "Step 1. Activation type selection". It contains three radio button options under the heading "Activation types":


- ☐ Activate existing license key
You should have valid licence key from your service provider
- ☒ Offline activation via license file
You should have valid license file provided by Support
- ☐ Request Evaluation license key
Generate Evaluation licence key via web interface

At the bottom right, there are two buttons: "OK" and "Exit".

Activation Type Selection

This mode consists of three steps:

- generate the activation file on the target server
- go to the online activation system at <http://ganzsecurity.com/CORTROL-Activation> and fill in the form
- apply provided license file to your system



The screenshot shows a dialog box titled "Step 2. Activate existing license". It contains two main sections:

License file

System activation file

Fill activation form online
upload generated file and get signed license file.

Specify license file


Locate signed license file to finish activation

At the bottom right, there are two buttons: "Activate" and "Cancel".

Offline Activation Steps

Ganz CONTROL Global Administration Guide


Click *Generate* to create the activation file; choose a location and save it. The default file name is *system.bin* and we do not recommend changing it.



Save Activation File

Next, copy this binary file to any other computer that has Internet access, then go to the online form available at <http://ganzsecurity.com/CORTROL-Activation>, fill in the required fields and upload the file. The activation system will process your file and allow you to download a license file. This license file will be unique and will only be valid on the same machine from which the original *system.bin* file comes.

You can close the activation wizard after creating the activation file and reopen it later to apply the license file. Click *Browse* to locate it and open the *license.dat* file provided by the activation system.



Browse for License File

The validated *license.dat* file will be loaded, allowing you to finish the registration process.

Ganz CONTROL Global Administration Guide

Step 2. Activate existing license

System activation file

Specify license file

License file

Generate...

Fill activation form online
upload generated file and get signed license file.

Browse...

license.dat

Locate signed license file to finish activation

Activate

Cancel

Load the License File

Click *Activate* to apply the license file. If the license is valid, you will see an activation success confirmation with the following details:

- product type
- license key
- license key expiration date, if applicable
- support subscription expiration date
- allowed channel amount

The license information will be stored on your server. However, you may wish to save a snapshot of this screen for your future reference, so that this information will be accessible in case of server OS or hardware failure.

Finally, click *Done* to exit the activation wizard or click *Start Quick Setup Wizard* to proceed with server configuration.

2.3 Activation Management

When a server already has a license key installed, you can retrieve that information in two ways:

- right-click server icon in the system tray and select *About*. The dialog box will contain basic information about the product version and license type
- run the *Product Activation Wizard* from the Start menu

To start the wizard, go to *Start -> All Apps -> CBC AMERICA LLC -> Activation Wizard* (in Windows 7 and older versions, use *Start -> All Programs -> software installation folder -> Tools -> Activation Wizard*); alternatively, use Search to locate the Activation Wizard in the programs menu.

Step 1. Manage license

Your license: Global

License details:

Key:

Expiry date: never

Subscription valid until: 1/25/2018

Channels supported: up to 100

☐ Upgrade current license

Upgrade product using same license key

☐ Upgrade current license via license file

Upgrade product using activation file

☒ Remove license

OK

Cancel

Choose an option in order to proceed


The wizard will display a summary about the currently installed license key and show the available management options.

Online license upgrade

License upgrade is available for the license keys purchased earlier. Note that all the software processes (both applications and services) must be stopped in order for the license to be applied correctly.


For upgrade acquisition details and assistance, please contact us via cortrol@cbcamerica.com.

Ganz CONTROL Global Administration Guide



All software processes must be stopped in order to apply license related changes

Ganz CORTROL Global Administration Guide



License upgrade option

After acquiring the upgrade from CBC AMERICA LLC, click *Upgrade Existing License Key* to enter it. Your license information will be synchronized with the activation server and you will be presented a license summary. Click *Cancel* to return to the beginning of the wizard.

Offline license upgrade

Offline license upgrade essentially the same as the offline license activation process: the same steps should be taken to retrieve the new license file.


- generate activation file on the target server
- go to the online activation system at <http://ganzsecurity.com/CORTROL-Activation> and fill in the form
- apply provided license file to your system

Click *Cancel* to return to the beginning of the wizard.

Remove license


Select *Remove License* if you wish to completely delete all the license information from the server.

Ganz CORTROL Global Administration Guide



Deactivate license


Click *Deactivate Existing License* to confirm deletion of the currently installed license. Note that you will be unable to log into Ganz CORTROL Console to access your current server configuration without a valid license of the same type; Ganz CORTROL Client applications will also not connect to such a server. In order to use the server again, you will have to enter the license again - either the same or a new one.



An attempt to log into Ganz CORTROL Console failed because the license is missing

Alternatively, press *Cancel* to return to the wizard start page. If you are not sure about the deactivation, consult CBC AMERICA LLC technical support.

Ganz CORTROL Global Administration Guide



License successfully deactivated

After license deactivation, you will be offered the chance to go back to license management in order to enter a new software license.


Ganz CONTROL Global Administration Guide

3 Ganz CONTROL Console Login

All server configuration is conducted through a dedicated interface - the Ganz CONTROL Console management application. The management interface has been intentionally separated from the Ganz CONTROL Client application in order to concentrate all administrative utilities in one place and also to conceal the unnecessary menus from the Ganz CONTROL Client operator. Applications are totally independent from each other and can be or not be installed on the same machine. Ganz CONTROL Console for a single installation management can be installed on one or more computers, depending on the system administrator's needs.

💡 It is implied that Ganz CONTROL Global installations are handled through the **central server** by logging into the target central server locally or remotely via Ganz CONTROL Console. **Recording servers** can be also reached via Ganz CONTROL Console but it is not possible to change their settings directly.

Run Ganz CONTROL Console application by double-clicking the Ganz CONTROL Console shortcut from the desktop or Start menu.



To log in, simply enter your Ganz CONTROL Global server's local or remote address (IP or host name), TCP port and user information. If you have logged into different servers from this Ganz CONTROL Console instance in the past, the Ganz CONTROL Console login dialog box will have a drop-down list in the *Server* field.

💡 If your server has default TCP port configured (which is 60554), you do not need to specify it when connecting: simply type the IP or hostname of the server to connect to. However, if the server TCP port has been altered, you need to specify the port explicitly, making the connection address look as follows:

<address>:<port>, e.g., 192.168.1.77:60555 or localhost:60887

Server TCP port can be changed via Ganz CONTROL [Server Setup Wizard](#).

Note that, if you already have pre-configured user accounts, the user must have corresponding [permissions](#) in order to connect.

Ganz CONTROL Console can be launched **multiple times** if you need to control multiple different servers simultaneously, e.g., if you need to configure Ganz CONTROL Global and check Ganz CONTROL Recorder configuration directly at the same time. In general, you only need to connect to your Ganz CONTROL Global server machine directly once for all configuration routines. Direct Ganz CONTROL Recorder login is usually required for monitoring and audit purposes.



First-Time Login

When logging in for the first time, use the default combination of user name and password: admin/[empty]. You will be asked to change the password to a more secure one immediately afterwards.

💡 The **default username and password** for the new installation is **admin/[empty]**.


If you are refused a connection, make sure that the server is running and accessible over the network. (For more detailed information about what to do, please refer to the [Troubleshooting](#) section of this document: it is constantly updated with most common cases).

Ganz CORTROL Global Administration Guide

A login dialog box titled "Login" with a standard Windows window border. It contains three input fields: "Server" (with a placeholder "IP address or host name of the server"), "Username", and "Password". Each field has a small red 'x' icon to its right. At the bottom are "OK" and "Cancel" buttons.

Ganz CORTROL Console login

After logging in for the first time with default username and password, you will be reminded to change your password. For security reasons, we strongly recommend that you do so at once.




Change Password reminder

You will be given the option to change the password using an additional dialog box. To change the password, enter your old password (initial, default password is empty so just leave the field empty), then enter your new administrative password for the current server, enter it for the second time to confirm, then click *OK to save*.



The new password must **comply with server policies**, by default these are: minimum 8 characters total length, including at least 2 lowercase and 2 uppercase letters.

Ganz CORTROL Global Administration Guide



Password must meet the server policy requirements

After you are done with the password update, you will be given the opportunity to fill in the initial server settings using the quick [Setup Wizard](#). We recommend that for optimum first-time configuration you follow the steps in the wizard.

Two-Factor Authentication Login

Starting from the version 1.21, Ganz CORTROL supports 2FA for Ganz CORTROL Console. You can use it to log into the Ganz CORTROL Global system and or individual Ganz CORTROL Recorder servers.

This application supports two-factor authentication as an additional security measure for the user login. It does not eliminate the necessity to enter the user password; instead, it serves as an additional security layer.

If the target server has two-factor authentication (2FA) policy enabled, you will be asked to confirm your identity by requesting and entering a code. Depending on the server configuration, the code may be requested by email or by SMS.

💡 2FA is configured by the Ganz CORTROL server administrator, so if you have any issues with requesting, receiving, or entering the code, contact the person who maintains the target Ganz CORTROL server. Provide the server administrator with your valid email and full phone number.

💡 The 2FA settings affect all users and all clients by default; the system administrator can set up exceptions for localhost connections and also for individual users.

The login procedure with 2FA is as follows:

- an additional dialog box pops up upon the server connection attempt
- choose one of the provided verification methods and click *Request code*
- in the next dialog, you will see a session ID and an empty box
- check your email or phone (or other provided verification source) for a message with the same session ID (for example, marked as #6708 here) and copy the code from the message body (1234 here)
- click *Submit code*: if everything is OK, you will be logged in

Ganz CORTROL Global Administration Guide

192.168.66.44

Two factor authentication

Verification method

email

Request code

Verification code will be sent using specified notification method. If you can't receive the code, please contact your system administrator.

Target server has two-factor authentication enabled. Please verify your identity by receiving and entering a code using one of the options.

Cancel

192.168.66.44

Two factor authentication

Session identifier

6404

Session identifier must match the identifier in the message containing the verification code

Enter code

1234

Submit code (8:29)

Please enter code you just received.

Cancel


Two-factor authentication example for Ganz CORTROL Console: request a 2FA code and enter it in order to log in

Ganz CORTROL Global Administration Guide

3.1 About Product

Information about the currently running product can be viewed from the local computer in three ways:

- right-click the system tray icon and select *About* (if there is no tray icon, launch server shortcut to run the tray shell);
- from Ganz CORTROL Console, click the Application menu icon on the navigation panel and choose *About*;
- from Ganz CORTROL Client, go to the main menu, click Help and select *About*.



About Server

If you are connected to your Ganz CORTROL server locally (via *localhost*), the *About* window will allow you to open the activation manager from here (except for Ganz CORTROL Client). For remote connections, this option will be grayed out.


Ganz CONTROL Global Administration Guide

3.2 Migration From Previous Product Versions

It is possible to migrate the basic configuration from the older CBC AMERICA LLC software version, ZNSNVR. All you have to do is export an XML file from ZNSNVR and then import it via Ganz CONTROL Console.

⚠ In Ganz CONTROL version 1.6.0, major changes were made to permission management. As a result, configuration imported from an XML file (from ZNSNVR) will **not contain any user permissions: you will need to **review and set all user permissions after importing the configuration**.**


In your ZNSNVR Client, right-click your desired server and choose *Tasks -> Configuration Export*.



Run *Configuration Export* from the server right-click menu


Export wizard will display a summary of all the exported resources and give you an option to save the configuration in XML format. In order to do this, click the *Export to...* button and choose a location and enter the filename, then click *Save*.

Ganz CORTROL Global Administration Guide



Export tool

Next, switch to your Ganz CORTROL installation where you want to load the configuration: open Ganz CORTROL Console and log into the target server. In Ganz CORTROL Console, click the application menu button located in the upper-right-hand corner of the Ganz CORTROL Console window and choose *Configuration import*. Locate your pre-saved XML file in the *Open file* dialog box and click *Open*: *Configuration import* dialog box will open, giving you the option to review the resources to be imported.



Choose devices to be imported

Review the list of devices to be imported from your pre-saved configuration; note that you can only view the settings but there is no option to change them. You will be able to alter device settings later, after you import the configuration. At this stage, you can choose whether or not the device will be imported: to do this, simply put a checkmark next to each device name. By default, all devices are selected for import.

Ganz CORTROL Global Administration Guide

Configuration import

Resources

Devices

Channels

Users

User groups

Channels

Channels

☒

TITLE

☒

Park Gate

Park Gate

Add

☒

Main Entrance

Main Entrance

Add

☒

Beach

Beach

Add

☒

Gate

Gate

Add

☒

1st Floor

1st Floor

Add

☒

Conference Hall

Conference Hall

Add

☒

Park PTZ

Park PTZ

Add

Import via

☒ Add

☐ Merge

Details

Title

Park Gate

Enabled

yes

Device

Park Gate

OK

Cancel

Choose channels to be imported

Next, switch to the *Channels* tab and review the channel list.

Configuration import

Resources

Devices

Channels

Users

User groups

Users

Users

☒

Built-in adminis...

admin

Merge

☐

Built-in demo u...

demo

Add

☒

Joe Doe

Joe Doe

Add

☒

Johnny English

Johnny English

Add

☒

Judy Monroe

Judy Monroe

Add

Import via

☐ Add

☒ Merge

Details

Full name

Built-in Administrator account

Login name

admin

Permissions

TITLE


VERB

OK

Cancel


Choose users to be imported

When you have finished with devices and channels, review users and user groups to be imported.




If some resource is already present in Ganz CORTROL configuration, the wizard will mark the imported copy to be **merged** to the existing one; you can change this by selecting the desired resource and choosing the import type below: *Import via -> Add/Merge*. Merging means that user permissions are extended and in case of any differences Ganz CORTROL settings have priority. Otherwise, the import wizard will simply **add** the target resource to your configuration and action type choice will be grayed out.

Ganz CORTROL Global Administration Guide



Choose user groups to be imported

When you are done, click OK to import the configuration. Ganz CORTROL will show you a short summary and ask you to confirm the action.



Confirm import

After the import, you will be able to edit the newly added resources as usual via corresponding menu sections.


Ganz CONTROL Global Administration Guide

3.3 Database Import

You can use an existing Ganz CONTROL database to import resources into any other Ganz CONTROL installation. This feature allows you to **migrate** the server configuration 1-to-1 or **reuse** the configuration of devices and channels, user profiles, maps, recording calendars, etc., to speed up the site configuration.

Prerequisites


The database may come from any server and/or software edition, but it must contain not more than one server in its configuration. If you wish to import from a Ganz CONTROL Global database, create a copy of it for backup, then remove all recording servers from its configuration first (move the devices to the Ganz CONTROL Global server first if you need to preserve them), and use the single-server version for resource import.

 It is only possible to import the data from **single-server** databases.


Possible scenarios for this feature may be as follows:

- combine many Ganz CONTROL Server servers into a single Ganz CONTROL Global installation
- transfer configuration from one Ganz CONTROL Server server to another

The database you need to take for future import is named *VMSSConfig-xxxxxxxxxxxx.db* and it is located in the ProgramData directory.

 By default, all Ganz CONTROL databases are located in the following directories:

- C:\ProgramData\CBC AMERICA LLC\Ganz CONTROL Server - for the Ganz CONTROL Server product edition
- C:\ProgramData\CBC AMERICA LLC\Ganz CONTROL Global - for the Ganz CONTROL Global product edition
- C:\ProgramData\CBC AMERICA LLC\Ganz CONTROL Recorder - for the Ganz CONTROL Recorder component of a Ganz CONTROL Global installation




Choose the database import option from the application menu

Import from Database

To start data import, press the application menu button in the upper-right-hand corner of the Ganz CONTROL Console window and choose the *Configuration import from a database* option.


From the standard Windows Explorer *Open File* dialog box, locate the target *VMSSConfig-xxxxxxxxxxxx.db* file and open it.

Ganz CONTROL Global Administration Guide



Locate the database file

The resource selection dialog box will appear. Choose the items to be imported using checkmarks in the left column; use the search field in the upper right corner to filter the items by type or by any other text field. In case the imported entities already exist on the host server (e.g., built-in recording profiles), their import action will be *Merge*; otherwise, the action will be marked as *Add*. When resources are merged, their permissions are merged as well. All types of resources can be imported.




Choose resources to be imported

When you have finished with resource selection, click *OK* to proceed.

Important: this action cannot be undone. Before confirming, make sure to review all the changes you wish to apply.

Before applying all the changes, review your import summary and click *OK* to confirm and finish the import.

Ganz CONTROL Global Administration Guide



Review the summary and confirm configuration import


All selected items will be added to the server configuration immediately and you will be able to work with them normally.

3.4 Configuration Backup

Server configuration is a time-consuming process and it is wise to save a copy of your Ganz CONTROL database after certain changes so that you have something to start the server with in case the main database becomes corrupt because of a hard disk failure or some other reason. Ganz CONTROL provides several options for database backup and we strongly recommend that you create configuration restore points to save the trouble of re-configuring the server from scratch.

Automatic Backup

Automated configuration backup allows you to save your Ganz CONTROL database based on a schedule. To access the settings via Ganz CONTROL Console, click the application menu button in the upper-right-hand corner and choose *Automated backup configuration*.



The screenshot shows a window titled "Automated backup configuration" with a dark blue header bar. Below the header, there is a sidebar on the left with a "Settings" tab selected. The main area is titled "Settings" and contains the following fields:


- Mode:** A dropdown menu set to "Enabled".
- Preferred time:** A time picker set to "2:00:00 AM". Below it, a note says "Preferred time when the automated backup is scheduled to run."
- Interval:** A text box with "2" and a dropdown menu set to "Days". Below it, a note says "Interval between automated backups".
- Maximum files to keep:** A text box with "15". Below it, a note says "Maximum number of files to keep in the backup folder."
- Directory:** A text box with "C:\ProgramData\CustomBackupFolder" and a "Change..." button. Below it, a note says "Directory where backup files are stored."

At the bottom right, there are three buttons: "Apply", "OK", and "Cancel".

Set automatic database backup preferences

Automated backup is enabled by default with the following settings: a restore point is created every two days at 2AM, with a maximum of 15 files to be kept. You can either leave the default settings, including the default location, or define your own backup time and frequency in the *Settings* tab.

Ganz CORTROL Global Administration Guide



The screenshot shows a window titled 'Automated backup configuration' with a sidebar containing 'Settings' and 'Status' (selected). The main area is titled 'Status' and displays the following information:

- Next run:** 1/12/2017 2:00:00 AM
Date and time of next run.
- Last run:** 1/10/2017 2:00:00 AM
Date and time of last run.
- Message:** Automated backup has been completed successfully.

At the bottom right, there are three buttons: 'Apply', 'OK', and 'Cancel'.


Backup status

In the *Status* tab, you can see the date of the last backup attempt and the next scheduled backup time.

Backup and Restore Wizard

Additionally to the automated backup, it is possible to create a configuration restore point manually at any time. The same wizards provides an opportunity to start the Ganz CORTROL with an earlier database version.

Run the *Backup and restore wizard* from your Windows Start menu: *Start -> All Apps -> CBC AMERICA LLC -> CBC AMERICA LLC Server Backup and Restore Wizard*. In Windows 7 and older versions, use *Start -> All Programs -> software installation folder -> Tools -> CBC AMERICA LLC Server Backup and Restore Wizard*; alternatively, use Cortana/Search to locate the wizard in the programs menu.



The screenshot shows a window titled 'Backup and restore wizard' with a dark blue header bar that says 'Welcome to backup & restore wizard'. The main area has a light gray background with a large gear icon. The text 'Choose what you want to do:' is displayed above two radio button options:

- ☒ **Backup**
Create restore point.
- ☐ **Restore**
Restore to an earlier restore point.

At the bottom right, there are two buttons: 'Next' (highlighted with a dashed border) and 'Cancel'.

Choose whether you want to back up or restore the database

Create Backup

Choose the first option to back up the database contents to serve as a restore point and click *Next*.

Ganz CONTROL Global Administration Guide

Backup and restore wizard

Step 1 of 1. Backup options

Choose items to back up:

☒ Configuration

Include configuration.

☒ Audit

Include audit.

☒ Events

Include events.

Description

Backup description.

Filename

C:\ProgramData\CustomBackupFolder\Backup20170110163240242.lxb

Browse...

Backup will be saved to the file specified.

Previous


Next

Cancel

Choose items to back up

Here, you can choose the information to be saved and also add a custom description for your future reference. You can either use the default destination folder or choose a custom one, even located on a different disk or a network drive.

Ganz CORTROL Global Administration Guide



Restore point successfully created

The wizard will create the backup and display a success message. Click *Finish* to exit.

Restore to an Earlier Database Version

Choose this option if you wish to start the Ganz CORTROL server with a database from an earlier time instead of the current configuration.



If you have a clean Ganz CORTROL installation and wish to restore its configuration from an earlier point, make sure to initialize the server using the Server Setup Wizard, which usually pops up automatically after the installation is completed and is available via Start menu. (There is no need to do this if you upgraded the software to a newer version so that it already has been initialized earlier).

Ganz CONTROL Global Administration Guide

Backup and restore wizard

Step 1 of 2. Select a backup

Pickup a backup

☒ Select one from list

Scan selected folder for previously created backups and pickup one from the list.

☐ Manually select a file

Select file manually using file browser.

Folder

C:\ProgramData\CustomBackupFolder

Browse...

Select a folder to scan for the restore points.

DATE/TIME	NAME	VERSION	CONFIGURATION	EVENTS	AUDIT
1/10/2017 4:43:40 PM	Backup20170110163240242.lxb	1.3.0.15947	yes	yes	yes

<

>

Previous


Next

Cancel

Choose a restore point

Here, you have two options: select a backup file from the list or manually locate the necessary *.lxb file. In either case, make sure you have chosen the right backup to be used and then click *Next*.

Ganz CORTROL Global Administration Guide



Choose items to restore

Make sure you have chosen a suitable database to be restored by reviewing the items and using your earlier comments as a reference. Click *Next* when ready.

On this additional step for Ganz CORTROL Global, you will be able to choose to **reset** the Ganz CORTROL Recorder configuration.

How to choose the right option?

- If you are just restoring the Ganz CORTROL Global server database (e.g., after the central server version rollback), you do not need to reset the recording servers because their configuration is actually the same (just the DB version is incompatible).
- If you are using a much earlier database backup that certainly has a different Ganz CORTROL Recorder configuration, then you need to include the reset.




Recording server reset is usually necessary if the remote server configuration is invalid (corrupt or different from the target DB contents).

If you choose to reset all recording servers at this point, it will take some time for them to re-synchronize (remove and then accept the restored configuration), which may result in some downtime. On slow connections with a lot of remote servers the downtime may be significant.

If you have many recording servers on a slow connection, we recommend that you do NOT reset them at this point. These servers will continue to operate with their current configuration but their status in the *Monitoring* section may turn to *Not synchronized*. In that case, initiate the re-synchronization manually later via Ganz CORTROL Console main menu > System upgrade > select server > Re-synchronize configuration.

This option is disabled by default to decrease the potential downtime.

Ganz CONTROL Global Administration Guide




Recording servers are not reset by default

When you click *Next*, you will see additional details about the recording server reset, which will help you choose the correct option for your system before proceeding - and give you a chance to re-consider. Carefully estimate the need for the reset before initiating the restore procedure!



A database from a newer software version cannot be used for this. Older database versions can be used without issues; however, we recommend that you use the latest available backup from a stable software version (not beta).

Ganz CORTROL Global Administration Guide



Restore in progress

Then, the wizard will ask you to stop the Ganz CORTROL services and start restoring the database after your confirmation.



Caution! This is an irreversible operation. Do not abort the process or shut down the server machine during the process.

If nothing interferes with the restore process and the backup file is intact, you will receive a success message after the wizard finishes restoring your Ganz CORTROL server configuration. Server service will be automatically started with the restored database. If you chose to reset the recording server configuration, all Ganz CORTROL Recorder instances will receive the restored configuration as well.


Ganz CONTROL Global Administration Guide


3.5 Remote Upgrade

In addition to traditional installation, you can also apply upgrades to the software components remotely from the central management server. Eligible components are: Ganz CONTROL Recorder, Ganz CONTROL Console and Ganz CONTROL Client application. This feature will allow you to deploy the remote Ganz CONTROL Recorder and client machines once and then easily handle the upgrades from any place, keeping the whole system up to date with little effort.

Briefly, the idea of the remote upgrade procedure is that you first upgrade your Ganz CONTROL Global server, then carry out the upgrade for Ganz CONTROL Recorder machines and remote workstations. For Ganz CONTROL Recorder installations, the upgrade procedure is conducted from the central management server side; for Ganz CONTROL Console and Ganz CONTROL Client applications, you simply enter file locations on the central server, allowing the remote machines to perform their upgrades by downloading the installation files.

Below, you will find a detailed description of the recommended upgrade procedure, and details on each step.

 For the remote upgrade feature to work properly, the Ganz CONTROL Global server must be reachable over HTTP from the Ganz CONTROL Recorder machines. Starting with software version 1.25, you can upgrade the system via HTTP or HTTPS protocols. Depending on your settings, the system will use different protocols:
HTTP on + HTTPS on - the system will use HTTPS
HTTP on + HTTPS off - the system will use HTTP
HTTP off + HTTPS on - the system will use HTTPS
HTTP off + HTTPS off - the system will return a connection error

 We strongly advise that you keep both major (e.g., 1.2.x) and minor software versions (e.g., 1.2.3) across your system match exactly. Software build numbers (e.g., 1.2.0.xxxxx) may differ slightly in case you are using 64-bit and 32-bit editions.
Different major versions (e.g., 1.5.0 and 1.6.0) **will not work together** by design.

Prerequisites

Before starting the upgrade process:

- make sure you have downloaded the target version files for all components
- use a good uplink with enough bandwidth as you will have to transfer the installation packages to the remote machines
- ensure all Ganz CONTROL Recorder servers are stable and have the latest OS updates installed (and no OS updates are being installed at the moment)
- make sure that remote servers are reachable via HTTP or HTTPS from the central management machine

The simplest way to verify the HTTP connection status is to try opening the Ganz CONTROL Global server in your browser, as if you were trying to reach its Ganz CONTROL Streaming Server interface, e.g., <http://192.168.4.56:8081> (default port is 8080). Another simple alternative is to use telnet to the same IP and port.

If required, it is also possible to perform the recording server upgrade manually locally, similarly to the initial installation.

Ganz CONTROL Recorder Upgrade Procedure Description

The general idea is to: transfer the upgrade packages and verify remote server availability, upgrade the central server, then carry out the remote server upgrade. The order of steps is important for smooth experience, especially in case you have a lot of recording servers.

Steps:

0. Download the new version installation packages onto the Ganz CONTROL Global server PC.

1. Do NOT upgrade the central server yet. Open Ganz CONTROL Console locally on the Ganz CONTROL Global server. In Ganz CONTROL Console, go to the main menu > *System upgrade* > *File locations* > specify the local paths to the new Ganz CONTROL Recorder installation packages (both bit versions, if necessary).

Ganz CONTROL Global Administration Guide

2. Go to the *Upgrade tasks* tab > select all required recording servers > click *Upload upgrade*. By doing so, you verify the HTTP port availability and transfer the files.

3. After the upload is complete and Ganz CONTROL Recorder status is *Ready to install*, you can proceed with the central server upgrade. If some server does not have the *Ready...* status (Waiting for connection/connection timeout), double-check if HTTP connection is available. Close Ganz CONTROL Console and upgrade the Ganz CONTROL Global server locally.

Recording servers will now have incompatible server versions. They are still operating but it is impossible to re-configure them, so therefore you need to upgrade them ASAP.

4. Open Ganz CONTROL Console and go to main menu > *System upgrade* > *File locations* > check if packages are defined, and, if not, then point to them again.

5. From now on you can use either local or remote Ganz CONTROL Console connection to the Ganz CONTROL Global server. In the *System upgrade* dialog, to *Upgrade tasks* > click *Upload upgrade* until all servers have the *Ready for upgrade* status.


6. Now upgrade recording servers one by one. Click the *Install upgrade* button to launch the installation on the remote server. Repeat for each recording server.

You can do this for all servers at once, but it is better to upgrade step-by-step: if something goes wrong, you will have the system partially running.

Upgrade Procedure Step-by-Step

To access the remote upgrade feature, open your Ganz CONTROL Console application, click the main application menu button in the upper-right-hand corner and choose the *System upgrade* option. The *System upgrade* dialog box will appear.


The *Upgrade tasks* tab will contain all the currently configured recording servers with their type, status, current version and upgrade status. As the upgrade proceeds, the server status reflects the changes.



One connected Ganz CONTROL Recorder with an out-of-date software version


Before starting the upgrade procedure, specify paths to the new installation packages. To do so, switch to the *File Locations* tab. The locations must be on the central management machine, even if you are accessing the Ganz CONTROL Global server from a remote Ganz CONTROL Console.

Ganz CORTROL Global Administration Guide




Review locations of the executable files


Here, you can review the existing locations of the packages. In order to pick different installation packages for your next upgrade, click the *Edit* button on the upper panel.



Change file locations

For every software component, click the *Select* button on the right side and choose the appropriate installation package; use the *Clear* button to remove the currently defined field value. Make sure to define correct packages for 32-bit and 64-bit.

 The specified paths must point to the files, which are located on the **central management** server.

 Please make sure to use original, valid installation packages for Ganz CORTROL, which have been either downloaded from CBC AMERICA LLC website or FTP, or provided by its representatives or certified partners. Files that are not proper Ganz CORTROL packages will not be accepted, resulting in an error.


Do not use beta versions (pre-release) of the installation files on production servers.

Ganz CORTROL Recorder Upgrade

When you have entered locations of all the required components, switch back to the *Upgrade tasks* tab. From the list of all the configured recording servers, choose one to be upgraded by clicking it once in the list. Note that only online servers (i.e., those having their status as *Connected*) can be upgraded.


Here, you have two options: transfer the upgrade package to the target server and run the **upgrade at once**, or just **upload** the file. The latter option is convenient when, for example, you have a good upload speed at the moment but it is not possible to perform the upgrade for some reason: you can transfer the file at once and then log in remotely later over a slower connection and simply hit the *Update and install* button - the installation package will not be uploaded repeatedly and, instead, the installation of the upgrade will be conducted immediately.

Ganz CORTROL Global Administration Guide



Upgrade in progress

After the upgrade, the remote Ganz CORTROL Recorder service will be restarted automatically so you will get a *Disconnected* status for a moment, and then the Ganz CORTROL Recorder will appear back online with a new version installed.




Successful upgrade of a remote Ganz CORTROL Recorder

Ganz CORTROL Console and Ganz CORTROL Client Upgrade

Remote UI applications are upgraded in a slightly different way. First, you need to set the paths to the new packages on the central management server side; then, every connecting Ganz CORTROL Console or Ganz CORTROL Client will get an upgrade notification if their version is older than the one specified in the upgrade package path. No upgrades will be offered in case no upgrade package has been specified.

If Ganz CORTROL Console or Ganz CORTROL Client detects that an upgrade is available, it will offer you to download it straight away. If your network connection allows it, click *OK* to agree and download the upgrade package.




Ganz CORTROL Console application offering an upgrade on startup

The upgrade package will be downloaded using your default Web browser and saved on your local computer. You can start its installation at any time, provided that your Windows user has enough privileges to run the installation. After the installation, just start the application as usual.

3.6 Setup Wizard

The Ganz CORTROL Console Setup Wizard is automatically started after product installation and activation is complete. You can skip the wizard at this point and launch it later anytime from the Ganz CORTROL Console upper-right corner menu; we recommend, however, that you use the wizard for the initial server setup.




Run the Setup Wizard from the menu in the upper-right-hand corner

The Setup Wizard will show you the process summary and guide you through the necessary steps in order to configure the installation. To proceed with each next step, simply click the button below the list of steps; to exit the wizard without completing the setup, press either *Exit* or *Launch Ganz CORTROL Client* button in the bottom left corner.

Ganz CORTROL Global Administration Guide

Step 1: Server Autodiscovery

Bring online all Ganz CORTROL servers to be automatically discovered and make sure they are reachable from the central server machine. When you are ready, press the *Launch Step 2* button. The wizard will mark the already finished steps for you, providing a short description of what has been achieved at each step as you go.



Ganz CORTROL Console Setup Wizard: Step 1 complete, proceed with Step 2

The wizard will automatically scan the network for available recording servers and list them for you. If no recording servers are found, check network connection and configuration, and make sure that the installations you are searching for are up and running.

Ganz CORTROL Global Administration Guide

Server autodiscovery

Found servers

Found servers

Start server search

Scanning finished, 1 new servers(s) discovered.

Server properties

Found servers

Title

{Multiple values}

Server name

Connections

Available connections, IP:PORT

☒ Failover node

The server takes failover node role

Failover cluster

{Multiple values}

Change...

The server is a member of the specified failover cluster.

Apply

Reset

SERVER TITLE

192.168.1.138:60554

FAILOVER NODE

no

FAILOVER CLUSTER

none

Add selected servers

Cancel

Ganz CORTROL Recorder autodiscovery

Select discovered servers in the list on the right side of the screen one by one and enter settings for each; use the *Search* field in the upper-right-hand corner to find a specific recording server. Alternatively, just click *Add selected servers* to attach all checked servers to the system configuration and adjust all settings later.


There are two types of selection in the item list: checkboxes and color highlight. **Checkboxes** are used to choose the items to be added to server configuration after you close the dialog box; **highlighted** items are subject to immediate properties changes. Use *CTRL+click* or *Shift+click* to select all or several items at once to change their settings.

The following settings are available:

Setting	Description	Default Value
Title	User-defined recording server name	IP:port
Connections	Network settings to reach target recording server; multiple values can be listed in the form of [IP:port] if a server is reachable via multiple interfaces	Autodiscovered IP:port
Failover node	Determines if target server takes role of failover node	Disabled
Failover cluster	Failover cluster for the target server to be a part of	[none]

If you are running the setup wizard immediately after software installation, there will be no default [failover clusters](#). You can add a new failover cluster on the fly by clicking the *Change* button near the *Failover cluster* field and then by clicking the *+ New failover cluster* button.

Ganz CONTROL Global Administration Guide



Add a new failover cluster by clicking the + *New...* button below

You will be given the opportunity to enter a title for the newly created failover cluster; after clicking *OK*, you will be brought back to the *Server Autodiscovery* dialog box, with target cluster selected for the server currently being modified. You can repeat the procedure if you wish to add more failover clusters at this stage. Click the *Apply* button below to save your modifications before selecting another server.


Click the *Reset* button below to restore the autodetect settings; the failover clusters created will not be deleted if you reset server settings here.

After you have adjusted settings for all automatically discovered servers, review the server list and put a checkmark next to those you wish to add at this point (by default, all servers with valid settings are checked), then click *Add selected servers* to return to the main wizard window.

Step 2: Devices and Channels

Next step will allow you to automatically search and add cameras and other video source devices from the servers found on the previous step; note that this step will fail if no servers are available. Press the *Launch Step 3* button to open the dialog box.

Ganz CORTROL Global Administration Guide



Ganz CORTROL Console Setup Wizard: Step 2 complete, proceed with Step 3

Select the server to perform device discovery for by clicking the *Change* button and choosing one of the recording servers found on the previous step.

Scan Parameters

First, select scan mode; the following options are available:


- scan IP address range: specify a continuous LAN segment to be scanned
- scan network adapter address range: select one or more network interfaces to be fully scanned
- scan attached devices: the local hardware system will be scanned for capture boards and Direct Show video sources

If you have chosen to search for IP video sources, you should review additional connection settings and change or update them, if required:

Ganz CORTROL Global Administration Guide


- ports: HTTP ports, comma separated
- user credentials: pairs of comma-separated user names and passwords, one pair per line

Use the *Reset* button below to discard all changes and start entering scan parameters again. When you are ready, press *OK* button below to begin scanning.



The 'Scan parameters' dialog box shows three radio button options. The third option, 'Scan attached devices', is selected. Below the options are 'Reset', 'OK', and 'Cancel' buttons.

Scan attached devices



The image shows two side-by-side screenshots of the 'Scan parameters' dialog box. The left screenshot shows 'Scan network adapter address range' selected, with a table of network adapters. The right screenshot shows 'Scan IP address range' selected, with fields for IP range, ports, and passwords.

ADAPTER	IP ADDRESS	MASK
<input checked="" type="checkbox"/> Realtek PCIe GBE Family Contro...	192.168.1.83	255.255.252.0
<input checked="" type="checkbox"/> VirtualBox Host-Only Ethernet ...	192.168.56.1	255.255.255.0


The right screenshot shows the 'Scan IP address range' option selected. The 'From' field is 192.168.10.2 and the 'to' field is 192.168.10.187. The 'Ports' field contains 80,8080. The 'Passwords' field contains admin.admin, admin.1234, and root.pass.

Scan address range

Ganz CONTROL Global Administration Guide

Device Autodiscovery

After scanning has been completed, you will be taken to the Device Autodiscovery dialog box, which will allow you to review the found [devices and their channels](#), and enter/modify related settings. Use the *Search* field in the upper-right-hand corner to find a specific device by name, model, IP, port or hardware ID (for IP devices, ID includes MAC address).



There are two types of selection in the item list: checkboxes and color highlight. **Checkboxes** are used to choose the items to be added to server configuration after you close the dialog box; **highlighted** items are subject to immediate properties changes. Use *CTRL+click* or *Shift+click* to select all or several items at once to change their settings.

Click a device in the item list to load its settings into the *Device Properties* window. Note that some settings may be missing for some of the automatically found devices; this depends mostly on device and whether user data was correctly provided. In such cases, simply fill in the missing data manually and click the *Apply* button below to save the configuration changes.

Device autodiscovery

Device autodiscovery

Found devices

Found channels

Found devices

Scanning for new devices... 96% Stop

Device properties

Found devices

Device name

Grundig GCI-H0522V on 192.168.3.14

Device name

Model

Grundig GCI-H0522V

Change...

Device model

Host

192.168.3.14

Host name or IP address

Port

80

Port number

Username

admin

Username to access the device

Password

1234

Password to access the device

Apply

Reset

Found devices

DEVICE NAME

MODEL

HOST

PORT

☒

Axis (Legacy Autodetect) on 192.168.3.4

Axis (Legacy Autodetect)

192.168.3.4

80

☒

Grundig GCI-H0522V on 192.168.3.14

Grundig GCI-H0522V

192.168.3.14

80

☒

KT&C KNC-SPDNI120HD on 192.168.3.2

KT&C KNC-SPDNI120HD

192.168.3.2

80

☐

Select model

192.168.3.36

80

☒

Vivotek IP7131 on 192.168.3.12

Vivotek IP7131

192.168.3.12

80

☒

Vivotek IP7131 on 192.168.3.3

Vivotek IP7131

192.168.3.3

80

☒

Vivotek IP7131 on 192.168.3.19

Vivotek IP7131

192.168.3.19

80

Add selected devices and channels

Cancel

Set up discovered devices

Ganz CONTROL Global Administration Guide

If device is not integrated with the software (native support), it may be detected as generic type (e.g., ONVIF). If you think some devices have not been discovered, check if they have different HTTP ports; also, try adding them [manually](#).


Device properties	Found devices																
<p>Device name</p> <p>Unknown on 192.168.3.220</p> <p>Device name</p> <p>Model</p> <p>none</p> <p>Change...</p> <p>Device model</p>	<p>Search</p> <table border="1"> <thead> <tr> <th>DELETED</th> <th>DEVICE NAME</th> <th>MODEL</th> <th>HOST</th> </tr> </thead> <tbody> <tr> <td><input checked="" type="checkbox"/></td> <td>Unknown on 192.168.3.220</td> <td>Unknown</td> <td>192.168.3.220</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td>UScreenCapture on 192.168.1.83</td> <td>(Generic) DirectShow Device</td> <td></td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td>Microphone (High Definition Audio Device) on...</td> <td>(Generic) Audio Input Device ...</td> <td></td> </tr> </tbody> </table>	DELETED	DEVICE NAME	MODEL	HOST	<input checked="" type="checkbox"/>	Unknown on 192.168.3.220	Unknown	192.168.3.220	<input checked="" type="checkbox"/>	UScreenCapture on 192.168.1.83	(Generic) DirectShow Device		<input checked="" type="checkbox"/>	Microphone (High Definition Audio Device) on...	(Generic) Audio Input Device ...	
DELETED	DEVICE NAME	MODEL	HOST														
<input checked="" type="checkbox"/>	Unknown on 192.168.3.220	Unknown	192.168.3.220														
<input checked="" type="checkbox"/>	UScreenCapture on 192.168.1.83	(Generic) DirectShow Device															
<input checked="" type="checkbox"/>	Microphone (High Definition Audio Device) on...	(Generic) Audio Input Device ...															

If an unknown device is discovered, change its model manually




If the device cannot be matched with a model in the list and it also does not respond as generic ONVIF, it may be discovered as *Unknown*; in that case, try settings its model manually to the closest one (from the *Suggested models*), or try Generic RTSP and specify an [RTSP URL](#) in the [channel settings](#). This may happen to devices that are not listed as an exact model and are also old enough not to support ONVIF Profile S.

Setting	Description	Default value
Device name	User-defined video source name	Autodetected model + IP, empty if not detected
Model	Device manufacturer and model, or generic type	Autodetected vendor and model, empty if not detected
Host	Device IP address	Autodetected
Port	Device HTTP port	Autodetected
Username	Device user credentials; note that you have to provide administrative profile credentials in order to be able to change device settings via software interface	Appropriate username from provided list or autodetected
Password	Device user password	Appropriate password from provided list or autodetected

Make sure you select all the devices you wish to add by putting a checkmark next to them. Devices with missing configuration (model and/or IP) are unchecked by default and will not be added to active server configuration.

 If the autodiscovery **does not find any cameras** or all of them are Generic ONVIF instead of proper models:

- check models
- check IPs and passwords and ports
- make sure that the UPnP Device Host service is functioning properly on your system.

Services (Local)					
UPnP Device Host					
Name		Description	Status	Startup Type	Log On As
 Udk User Service_77174		Shell compo...	Running	Manual	Local System
 Update Orchestrator Service		Manages Wi...	Running	Automatic (De...	Local System
 UPnP Device Host		Allows UPnP ...		Manual	Local Service

Switch to *Channels* tab to review the detected video channels of the discovered devices: this is particularly important if you are using multichannel devices, e.g., capture boards and encoders. Use the *Search* field in the upper-right-hand corner to find specific channels by name or device name.

Ganz CORTROL Global Administration Guide

Device autodiscovery

Device autodiscovery

Found devices

Found channels

Found channels

Start device search

Scanning has be

Channel properties

Channel name

Vivotek IP7131 on 192.168.3.12

Channel name

Recording settings

none

Change...

Recording settings

Apply

Reset

Found channels



CHANNEL NAME	RECORDING SETTINGS	DEVICE
Axis (Legacy Autodetect) on 1...	none	Axis (Legacy Autodetect) on 1...
Vivotek IP7131 on 192.168.3....	none	Vivotek IP7131 on 192.168.3....
Vivotek IP7131 on 192.168.3....	none	Vivotek IP7131 on 192.168.3....
eVidence Apix - 18ZBox / M2 ...	none	eVidence Apix - 18ZBox / M2 ...
Samsung SNP-3120V on 192....	none	Samsung SNP-3120V on 192....

Add selected devices and channels

Cancel

Set up discovered channels

Here you can edit the channel name and assign recording configuration. By default, recording is enabled for all channels: click the *Change* button near *Recording settings* to [manage recording profiles](#) and [assign them](#) to your channels. To add a new recording profile, click the + *New recording configuration* button below; you can find more details about recording profiles in the [corresponding section](#). Click *OK* to save and return back to devices and channels; click *Apply* to save configuration changes.

-  After changing the channel recording configuration, do not forget to click *Apply*, otherwise the changes will not take effect.
-  Recording configuration here is assigned to the **main streams** of the target channels. In order to set up substream recording, please go to [channel configuration](#).

Select recording configuration

Available recording configurations

TITLE	ID	TYPE
No recording	(31)	Recording configuration
Continuous recording	(32)	Recording configuration


+ New recording configuration

OK

Cancel


Select the recording configuration or create a new recording profile

Click the *Start device search* button above at any time to restart device discovery.

-  All previously discovered devices and all configuration changes will be discarded if you restart camera autodiscovery.

Ganz CONTROL Global Administration Guide

Click *Add selected devices and channels* to save and go back to the main wizard window. You will be asked if you wish to scan more servers at this point: choose *Yes* if you wish to add more automatically discovered devices to the same or some other recording server.




Setup Wizard: scan more servers

Select *No* to finish with device autodiscovery and proceed with user management.

Step 3: Users

This step will allow you to add users and user groups and give them permissions for the servers, devices and channels added earlier. Press the *Launch Step 4* button to open the dialog.


 The built-in Administrator user account and built-in Administrators group are root users with access to absolutely all the available resources. As a result, resources choice is unavailable for the Administrators group, and it is also impossible to add Administrator user to any other group.

Ganz CORTROL Global Administration Guide

Any users added as members to the built-in Administrators group will have the same full authority as root users.

User Groups


First, decide whether you want to create user groups or work with a non-systemized array of user accounts. For large systems with complex user structure, groups are strongly recommended for reasons of improved manageability.



Setup Wizard: users and user groups


Choose *No* to proceed with plain user management at once; otherwise, you will be offered the chance to create user groups and distribute existing resources between them. Note that the Setup Wizard interface offers simplified settings for user groups at this point; later, you will be able to create nested groups via the [corresponding](#) Ganz CORTROL Console section.

Ganz CONTROL Global Administration Guide



Add one or multiple user groups

Enter a name for the first user group and then click the *Create* button below: newly created group will appear in the item list on the right. By default, the last modified group stays opened for changes. Correct group name, if necessary and then click *Apply changes*, or click *Reset* to discard the latest changes and revert to the most recently saved state (the same thing will happen if you select a different item for editing).


To create more groups, click the + *New* button on the upper panel and proceed in the same way as on the first iteration. Use the  recycle bin icon to delete selected group(s) (hold CTRL or Shift to select multiple items). Switch to the *Resources* tab to assign servers and server contents for this user group. Available resources at this point include servers, connections, folders, devices and channels.

Choose the group name in the first column to manage its resources. To add a resource, pick at least one permission for it and it will be automatically moved to the *Selected resources* list. To remove a resource, uncheck all its permissions - either manually or using the *Clear* button below. Note that double-clicking resources does not work here as one or multiple different permissions must be specified.

When you have finished, click *OK* to proceed with user accounts.

Users

To create the first user, simply fill in their details and then click *Create* below. By default, the most recently modified user will stay open for changes; correct user details, if necessary and then click *Apply changes*, or click *Reset* to discard the most recent changes and revert to the latest saved state (the same thing will happen if you select a different item for editing). Note that you do not have to re-enter the password when editing - only activate *Set password* if you wish to re-define it.

To add more users, press the + *New* button on the upper panel and proceed in the same way as described previously. Use the  recycle bin icon to delete selected user(s) (hold CTRL or Shift to select multiple items).

Ganz CONTROL Global Administration Guide

Users

Users

Details

Membership

Resources

Details

Create user

User login name

cartman

Account name for logging into the system

User full name

Eric Cartman

Insert user's first name and last name

E-mail

cartman@mydomain.com

E-mail address for notifications

☒ Set password

.....

Password to log into the server

.....

Reenter password

☒ Enable

User login status

Create

Cancel

+ New

Users

TITLE

LOGIN NAME

ENAB...

EMAIL

OK

Cancel

Enter user details

One the *Details* tab, the following user properties are available (all fields are required): login, full user name, email address, password and status. Passwords must be entered twice - this is a security precaution to avoid typos. Every user is enabled by default meaning that the target account is active and can be used for server logon; disable user accounts you wish to suspend while keeping all user-related information and resource permissions.

Users

Users

Details

Membership

Resources

Membership

Users

Selected groups

Available groups

TITLE

Eric Cartman

Joe Dassin

Clara Oswald

TITLE

ID

TYPE

Torchwood Ins...

(-45)

User group

Torchwood HQ

(-50)

User group

Remove

TITLE

ID

TYPE

Built-in Admini...

(3)

User group

Add

OK

Cancel

Choose groups for the newly created users

On the *Membership* tab, select groups for the specified users to become members of: move groups by double-clicking them or by using the *Add/Remove* buttons below.

Ganz CORTROL Global Administration Guide

Users

Users

Details

Membership

Resources

Resources

Users

Selected resources

PERMISSIONS

Available resources

Users	Selected resources	PERMISSIONS	Available resources
TITLE	TITLE ID TYPE		TITLE ID TYPE
<div>Eric Cartman</div>	<div>(Generic) O... (1... Channel</div>	<div><div><input checked="" type="checkbox"/> Administer</div><div><input checked="" type="checkbox"/> ReceiveData</div><div><input checked="" type="checkbox"/> AccessArchive</div><div><input checked="" type="checkbox"/> Navigate</div><div><input type="checkbox"/> ControlDigitalOutput</div></div>	<div><div>Torchwood (... Organisation</div><div>Nightwatch (... Organisation</div><div>Section 31-1 (... Server</div><div>Vivotek IP8... (... Device</div><div>Axis 215 PT... (... Device</div><div>Vivotek PZ... (... Device</div><div>(Generic) O... (... Device</div><div>Samsung S... (... Device</div><div>Vivotek IP8... (... Channel</div><div>Axis 215 PT... (... Channel</div><div>Vivotek PZ... (... Channel</div><div>Samsung S... (... Channel</div><div>UDP IPX33... (... Device</div><div>UDP IPX33... (... Channel</div></div>

Clear

OK

Cancel

Enter individual user permissions

Switch to the *Resources* tab to add individual resource permissions. This can be used both for group members and for users not belonging to any of the groups; individual permissions will not be removed if the user is excluded from the group.


To add a resource, pick at least one permission for it and it will then automatically be moved to the *Selected resources* list. To remove a resource, uncheck all its permissions - either manually or using the *Clear* button below. Note that double-clicking resources does not work here as one or multiple different permissions must be specified.

When you have finished, click *OK* to save and go back to the main wizard window.

Step 5: Events and Actions

On the last step, alarm and action management for the target servers is introduced. Press the *Launch Step 5* button to open the dialog box.

Ganz CONTROL Global Administration Guide



Setup Wizard: Step 4 completed, proceed with Step 5

The wizard offers quick setup of email notifications for several common event types (camera video loss, recording error and motion).

Ganz CONTROL Global Administration Guide

Events and actions

Video lost event
Event fires when camera stopped sending video

☒ E-mail notification

Gmail Send mail (-4) Change...

Configured action to send e-mail notifications

☒ Pop-up corresponding camera on the Client application screen (-s).

Archive recording error
Event shouts if recording cannot be longer saved to archive

☒ E-mail notification

Send mail to admin (-6) Change...

Configured action to send e-mail notifications

Motion detection
Event fires when capable camera detects motion

☒ Pop-up corresponding camera on the Client application screen (-s).

Please note! All above common settings will be applied to channels added through Setup Wizard.
Open Events & Actions configurator for advanced editing.

Open Events & Actions configurator

Apply Cancel

Setup Wizard: quick events & actions


Note that all the settings here apply solely to the channels discovered on the previous step; if you have configured other devices prior to launching this wizard, they will **not** receive the current event & action settings - launch the *Event & Action Configurator* to set up rules for other devices. You can also use *E&A Configurator* if you wish to add other types of alarms and/or actions.

When you are finished with all steps, you have the following options:

- **Restart wizard:** start the wizard again to set up more resources

Ganz CONTROL Global Administration Guide

- **Launch Ganz CONTROL Client:** open Ganz CONTROL Client application (will close the wizard)
- **Done:** close the wizard and proceed to Ganz CONTROL Console



Setup Wizard completed

3.7 Recommended Practices

General



We strongly advise that you keep the software versions (e.g., 1.x.x) and subversions (e.g., 1.2.x) across your system match exactly. Software build numbers (e.g., 1.2.0.xxxxx) may differ slightly in case you are using 64-bit and 32-bit editions.

Setup

When carrying out new installations, especially if you are new to this product, we advise that the following configuration priority is maintained:

2. Servers and failover clusters
3. Networks (connections)
4. Devices and channels
5. Users
6. Events and actions
7. Other features, in any order

In such a way, the optimum course of actions is maintained; in the sense that, if everything is set up properly, you will not have to go through the same configuration section multiple times. This makes the setup process logical and transparent. For instance, if you go to user setup first and then switch to adding servers and devices, you will still have to go back to the users' section in order to add corresponding privileges; so, the suggested priority is not obligatory, but it is advisable for efficient implementation.

You may have noticed that quick setup wizards have the same configuration order as described above. This is due to an analysis of our own and our customers' wide experience in system deployment and configurations, and thus this scheme has been brought to you as a recommended practice.

For existing (running) installations, when only a partial settings update is intended, the scheme above may not make sense; any specific settings can be changed later on independently via corresponding sections of the Ganz CORTROL Console management application. However, if you are adding a new server, it would be sensible to follow the procedure partially (steps 2 to 5).

Groups

Another important pragmatic recommendation for enterprise installations is the usage of groups. In case of large amount of users, servers, devices and other resources splitting them into groups makes the overall deployment process easier and enables more comprehensible and easy utilization of the system for the end-users.

Grouping is heavily dependent on the actual target system and should take into account the peculiarities of the system. Segregation may be logical, virtual, actual, based on location or access type; the main idea is to facilitate the usage, so, the needs of the end-user should be properly understood first.

A striking example of the advantage of groups is in situations when you need to add permissions for multiple users: instead of browsing the whole user list and searching for those required, you only have to click one group to assign permissions to all users inside it. Different types of groups can be used, with not just dividing resources, but also having overlapping categories for better manageability.

3.8 Conventions and Keyboard Shortcuts

Mouse Gestures

Double-click an item containing more entities (e.g., any group): opens item contents in the same window

Double-click a **non-expandable** item (e.g., server, user): opens entity configuration dialog box

CTRL+click or **Shift+click**: select multiple items in a list

Right-click on a text field: standard text edit menu

Right-click on a text field when creating an action: standard text edit plus text macros

Keyboard Shortcuts

Backspace: browse one step back in Ganz CORTROL Console



Alt+F4: close Ganz CORTROL Console

CTRL+A: select all items

CTRL+i: Invert selection

Visual Elements

General

 New item (click  drop-down arrow to see available options)



Remove item(s)



Deselect item(s)



Unacceptable filed value, hover mouse cursor for more information



More information about the item, click to view the details



Refresh item list



Search

Ganz CORTROL Console sections



Configuration



Events & Actions



Health monitoring



Audit log

Management



Network (server connection), connection settings



Server



Server group
































External service



External service group

Ganz CONTROL Global Administration Guide

-  Failover cluster
-  Software Watchdog
-  Storage
-  Resources (all or any type)
-  User account/session
-  User group
-  General details
-  Members of the current item
-  Current item membership in other groups
-  User and user group permissions for target item
-  Device
-  Device group
-  Channel
-  Channel group
-  Recording profile (core recording settings)
-  Recording schedule (recording itinerary based on core recording settings)
-  Recording configuration (recording interface assignable to channels)
-  Motion detector
-  Layout Template
-  Layout
-  Layout group
-  Map
-  Video wall
-  User button
-  Visual group
-  Shared channel
-  Audit Journal (software log)
-  Set (period etc.)
-  Event & Action schedules

Events & Actions

-  Rules
-  Events

Ganz CORTROL Global Administration Guide

➡ Actions

📢 Global events

🔌 Conditions

📧 Mail servers


⌚ Action delay timers

Ganz CORTROL Global Administration Guide

4 Purpose and Operation Description of Folders

1. Overview

Ganz CORTROL *Folders* feature allows users to manage *User access* on a very granular level. It is a very powerful tool, but like every powerful tool, it requires some planning ahead. This chapter will guide you through the feature on the example of the Happy Tree Corp. Global structure.




Though *Folders* are not strictly connected with the physical network implementation, we recommend considering it when planning your *Folder* structure. The abstract idea is to create a hierarchical tree-like structure and grant access to different-level administrators.

Take a pencil, a bit of time and plan your structure ahead.




N.B. *Folders* replace *Organizations*. If you have previously configured *Organizations*, they will be automatically converted to the top-level *Folders* with related resources:




2. Interface overview

You will find *Folders* inside the *Console* -> *Configuration* pane, after enabling it in the *Console* settings. It consists of two panels, the *Folder tree* panel and the *Resources* panel.


Ganz CONTROL Global Administration Guide



- The *Folder tree* panel provides overview and access to the folder structure. You will be able to review and edit all the structures accessible to your *User*. Buttons at the top of the panel provide controls to create + *New Folder*, *Edit*, *Move to folder*, and *Delete* folders. You also can edit folders by double-clicking the corresponding item.
- The *Resources* panel displays content of the selected *Folder*. By Clicking the *Title*, *ID* or the *free space* over the resource icons you can sort *Resources* correspondingly.




- The *Folder* structure affects all the *Resources*, so for easier navigation you can turn *ON* or *OFF* tree-view *Folders* panel by clicking the *Folder* button.



You will *enable/disable* tree-view for all the resources by *enabling/disabling* it in any particular resource panel.

- You can see to which *Folder* the particular resource belongs inside the main panel of the selected resource. You also can add *Linked folders* column to the table view by clicking the *Table view* button.


Ganz CONTROL Global Administration Guide



3. Creating Folders

The first step to implement *Folders* is to enable it inside the *Console*. Go to:


- *Hamburger menu -> Settings -> General -> Enable folders checkbox.*




The next step is to create previously thought-through folder structure:

- Configuration -> Folders -> +New folder

Ganz CONTROL Global Administration Guide



- Provide a meaningful *Title*, then select the parent folder by clicking the “Change...” button, pick the parent folder and confirm your choice with the “OK” button.



Continue until the complete structure is created.


N.B. *Folders can't have same names*, so think of naming conventions you want to adhere to, when creating a similar subfolder for the different branches.

4. Moving resources


When the basic folder structure is created, you can spread your resources across your hierarchy tree. Almost any resource can be moved to a particular *Folder* or *Linked* with multiple *Folders*. Let's do it on the *Channels* example, go to:

- *Configuration* -> resource (example: *Channels*) - select one or multiple entries and click the “Move to folder” button

Ganz CONTROL Global Administration Guide



- Select *Folder* from the new popup window and confirm your choice.



Continue with all the resources you want to moderate access to.

5. Granting access rights

To limit *Access rights* accordingly to the *Folders* structure, go to:

- *Configuration -> Users -> Folder access* and provide access to the *Folder*

Ganz CONTROL Global Administration Guide

Configuration > Users

admin

Search

Configuration

- Servers
- Networks
- External services
- Failover clusters
- Users**
- Devices
- Channels
- Recording
- Maps
- Layout templates
- Configuration
- Events & Actions
- Monitoring
- Audit

Folders

- All folders
- System (2)
- APAC Region (870)**
- APAC Retail 1 (874)
- APAC Retail 2 (875)
- EU Region (868)
- Berlin HeadQ (871)
- Berlin Retail 1 (876)
- Berlin Retail 2 (877)
- Lisbon HeadQ (872)
- Lisbon Retail 1 (878)
- USA Region (869)
- New York HeadQ (873)
- New York Retail 1 (88...
- USA Retail 1 (879)
- USA Retail 2 (880)
- USA Retail 3 (881)

1 selected

TITLE	ID	FOLDER	FULL NAME
APACAdmin	(884)	APAC Region (870)	Koi Zen

Recently added, 0 Recently updated, 1 Warning, 0 Groups, 0 External groups, 0

Users, 1 External users, 0 Structured view

- Inside the new popup window select *Folder access* and mark the checkbox starting with the top-level *Folder* you want the *User* to have access to.

User APACAdmin

User

- Details
- Folder
- Membership
- Resources
- Administration profile
- Time-based access
- Folder access**

Folder access

Folders

FOLDER	INHERITED FROM
<input type="checkbox"/> Lisbon Retail 1 (878)	
<input type="checkbox"/> USA Region (869)	
<input type="checkbox"/> New York HeadQ (873)	
<input type="checkbox"/> New York Retail 1 (882)	
<input type="checkbox"/> USA Retail 1 (879)	
<input type="checkbox"/> USA Retail 2 (880)	
<input type="checkbox"/> USA Retail 3 (881)	
<input checked="" type="checkbox"/> APAC Region (870)	
<input checked="" type="checkbox"/> APAC Retail 1 (874)	
<input checked="" type="checkbox"/> APAC Retail 2 (875)	

Apply OK Cancel

6. Sharing Resources from different folders (Link folder)

Resources such as *Recording profiles* or *Schedules* may need to be accessed by more than one *User*, so you also can share a single *Resource* with multiple *Folders* by linking it. To do so, go to:

- Configuration -> resource -> Move to folder arrow down button -> Link folder

Ganz CONTROL Global Administration Guide


The screenshot displays the 'Configuration > Channels' page in the Ganz CONTROL interface. The left sidebar shows the 'Channels' menu item selected. The 'Folders' pane on the left lists a hierarchy of folders, with 'APAC Retail 1 (874)' highlighted. A context menu is open over the 'Emu_guns' folder, showing options like 'Move to folder', 'Link folder', and 'Unlink folder'. The 'Link folder' option is circled in red. The main table displays the following data:

TITLE	ID	FOLDER
Emu_guns	(829)	APAC Retail 1 (874)
Emu_UIC	(833)	APAC Retail 1 (874)
	(831)	APAC Retail 1 (874)

At the bottom, a summary bar shows: 'Recently added, 0', 'Recently updated, 0', 'Groups, 0', 'Channels, 3', 'Replication channels, 0', 'Detached, 0', 'Enabled, 3', 'Disabled, 0', and 'Structured view'.

- From the new popup window select the *Folder* you want to share resources with and confirm by clicking the “OK” button.

Ganz CONTROL Global Administration Guide



- Grant access permissions for the *Folder* and its subfolders by checking corresponding checkboxes.

Ganz CONTROL Global Administration Guide

Link folder

Link

Folder

APAC Retail 2 (875) Change...

Linked folder

☐ Edit
Check to allow to edit the resource in the folder

Subfolders

☐ View
Check to make the resource visible in the subfolders

☐ Edit
Check to allow to edit the resource in the subfolders

OK Cancel

That's it! Now the user with access to the "APAC Retail 2" *Folder* will be able to see the Linked resource from the "APAC Retail 1".

To delete *Folder* and its *Subfolders* you need to remove all the associated resources from it.

All the *User privileges* stay actual. If the *User* does not have permissions to the particular resource, it will stay inaccessible even in the shared *Folder*!

Some specific server *Events and Actions* require access to the server itself or they will stay invisible for the local administrators.

Shared resources such as *Recording profiles*, *Schedules*, or *Events and Actions* must be linked with all the sub-admins in order to allow them make corresponding changes inside allowed resources. For example: APAC admin from demo structure will not be able to use *Recording profiles* even with accessible channels, unless the global admin links the *Recording profile* with APAC admin. As a global admin you can link common resources with the particular *Folder* to allow changes only to APAC admin, or link to the root folder - *System* to make it accessible to all the local admins.


Ganz CONTROL Global Administration Guide


5 Connect Recording Servers Using Autodiscovery

When you have installed and initialized your recording servers, the next step is to connect them to your central server and conduct the configuration of the recording servers through the central server.

In addition to the manual recording server setup and recording server discovery via [Setup Wizard](#), it is possible to launch the recording server autodiscovery from the central server at any time. It is convenient to use the autodiscovery feature if the number of recording servers within the system is large, and it also helps track connectivity issues at early configuration stages.

Before launching the automatic discovery process, please bring online all Ganz CONTROL servers to be discovered at this stage and make sure they are reachable from the central server machine. Note that autodiscovery can be only conducted from the central server; you can be logged into the central server via Ganz CONTROL Console from any machine, provided that system configuration allows it.

In order to launch the recording server autodiscovery via Ganz CONTROL Console, open the *Configuration* section, click *Servers* in the menu on the left, then click the little arrow  next to the + *New server* button and choose *Find servers*.




Launch server autodiscovery via *Servers* menu

Server autodiscovery dialog box will then pop up, with the recording server scanning process launched automatically. As the process goes on, discovered servers will appear in the *Found servers* list and become available for setup at once. Note that only recording servers that have not been configured will be discovered; if a recording server has already been configured from the current or from any other central server, the scanner will not detect such a server.

You can click the *Stop* button in the upper-right-hand corner in order to terminate the scanning process if you think that enough servers have been found so far. You can press the *Start server search* button at any time to restart the autodiscovery process; note that all changes made to the servers' settings will be then discarded.

Ganz CORTROL Global Administration Guide



Ganz CORTROL central server is scanning your network for available recording servers

When the autodiscovery process is finished, click your desired server in the list on the right, then adjust server settings and click *Apply* for the changes to take effect. Use the *Reset* button to load the default settings. The table below details the available settings.

Setting	Description	Default Value
Title	A user-defined name for the target recording server	<IP>: <port>
Connections	Networks via which the target server has been reached (discovered), unchangeable	<IP>: <port>
Failover Node	Select this option if you want to make the target server a failover node; deselect if the target server is planned to act as a primary recording server	undefined
Failover Cluster	Choose a pre-configured failover cluster you want the target server to be a member of	none

When you have finished setting up the discovered servers, review the list of detected servers: use the checkboxes next to each server in the list to select/deselect it; deselected items will not be added to the central server configuration.

Ganz CONTROL Global Administration Guide

Server autodiscovery

Found servers

Start server search Scanning finished, 1 new servers(s) discovered.

Server properties	Found servers
Title Section 31-9 Server name	<input checked="" type="checkbox"/> 192.168.1.126:60554
Connections 192.168.1.126:60554 Available connections, IP:PORT	no none
<input type="checkbox"/> Failover node The server takes failover node role	
Failover cluster none Change... The server is a member of the specified failover	

Apply Reset

Add selected servers Cancel

Enter settings for the newly discovered server and click *Apply*

Then, click the *Add selected servers* button in the bottom right corner to close the dialog box; all the servers you have selected in the previous dialog box will appear in your server list.

Configuration > Servers

Built-in Administrator account Search

Configuration

+ New server Edit Assign group 1 selected

TITLE	ID	FAILOVER CLUSTER
Global Server	(101)	
Section 31-9	(112)	

Recently added, 1 Recently updated, 0 Groups, 0 Servers, 2

Newly added server(s) appear in the list in the *Servers* section

The buttons on the upper panel offer the following possibilities:

- *Edit*: open the dialog box to change server settings (the dialog box will differ from the autodiscovery settings dialog box, offering advanced settings such as user permissions and membership)
- *Assign group*: select server group from the list and make the target server a member of it
- *Delete*: remove selected server(s)
- *X*: deselect all

Double-clicking the selected server in the list will bring up the server settings' dialog box for editing.

The filter panel at the bottom enables you to view recently added/updated items, as well as other relevant filters. The filter that is currently active is highlighted blue: click the *N filtered* button to reset all filters and display all the available items again.

9 filtered X


Ganz CORTROL Global Administration Guide

5.1 Connect Recording Servers Manually


When you have installed and initialized your recording servers, it is possible to connect them to your central server and conduct all the configuration of the recording servers through the central server.

It is possible to add recording servers manually, by entering all the necessary data manually instead of searching for existing servers. This approach may be helpful when you know the network configuration but actual servers are unavailable - whether they are unreachable for some specific reason or even if they have not been installed yet. The central server will connect these recording servers and apply all settings as soon as these servers become available.

If the number of servers is large it may be wise, though, to use [automatic discovery](#) in situ to save time and eliminate possible misconfiguration.

 Recording servers must be installed and initialized before the central server can apply settings to them.

First, locate the corresponding menu item in Ganz CORTROL Console by selecting *Configuration* in the sections' panel and then clicking *Servers* in the menu on the left.



Servers configuration component

Click the + *New server* button on the upper panel to bring up the *New Server* dialog box.

Ganz CONTROL Global Administration Guide

Details

Server Replication Server*

Server

Details

Connections

Failover

Membership

Permissions

Watchdog

Storage

Details

Title

Replication Server

Server name

Roles

☐ Failover node

The server takes failover node role

OK

Cancel

Add new server dialog box, Details tab

Details tab comprises general server settings.

Setting	Description	Default value
Title	User-defined server name	[empty]
Failover node	Makes target server serve as a failover node; option is available for servers without any device configuration	Disabled
Show Open VCA video analytics license	Access Open VCA license management for the target server	[button]

Ganz CORTROL Global Administration Guide

Connections

Server *

Server

Details

Connections

Failover

Membership

Permissions

Watchdog

Storage

Connections

Network

Camera LAN (106)

Change...

Local network where the server is physically located, or internet.

Local IP address

10.10.10.145

The local IP address of the server within the network.

VMS port

60554

VMS port.

HTTP port

8080

HTTP port, 0 to disable.

Internet IP address

168.212.226.204

The IP address by which this server can be accessed from outside the local network.

VMS port

60554

VMS port.

HTTP port

8080

OK

Cancel

Add new server dialog box, Connections tab

Select one of the existing connections or create a new one to be used as server location. Click the *Change..* button to bring up the network selection dialog box.

Select a network

Available networks

TITLE	ID	TYPE
Internet only		
Central Server network	(102)	Network
Camera LAN	(106)	Network
offices	(115)	Network

+ New network

OK

Cancel

Ganz CORTROL Global Administration Guide

Select an existing network from the connection list

If you wish to add a new network at this step, click the + *New network* button to bring up the network setup dialog box. After creating the connection, you will be brought right back to the server configuration dialog box, with the new network having been added to the server settings.

Setting	Description	Default value
Network	Defines server location in the network; you can select one of the pre-created connections or create a new one on the spot	Internet only
Local IP address	Only available if a local network is chosen above; server's local IP address in the selected network	[empty]
Server port (local)	TCP/IP port for incoming local connections from Ganz CORTROL Console and Ganz CORTROL Client	60554
HTTP port (local)	HTTP port for local video streaming; enter 0 to disable HTTP connection	8080
Enable multicast mode (local only)	Allow data transmission in multicast mode from this server to the connected Ganz CORTROL Client applications	Disabled
Internet address	External (Internet) IP address of the target server; if a pre-created network is chosen, Internet IP is loaded from network configuration and the field is non-editable	[empty] or [automatic]
Server port (external)	External TCP/IP port for incoming connections from Ganz CORTROL Console and Ganz CORTROL Client; may differ from the local port of the same purpose	60554
HTTP port (external)	HTTP port for local video streaming; enter 0 to disable HTTP connection	8080
SNMP port	The port to be used for outgoing SNMP traps (from the Event&Action scenarios) and for incoming requests (NOT traps!) from third-party SNMP managers	0 (disabled)
SNMP community	SNMP community for outgoing SNMP traps (from the Event&Action scenarios)	0 (disabled)

Ganz CORTROL Global Administration Guide

Failover

Server Recording Server I*

Server

Details

Membership

Permissions

Connections

Failover

Watchdog

Storage

Failover

Failover cluster

FC1

Change...

The server is a member of the specified failover cluster.

Current failover server

none

When specified, the server's tasks are running on the specified failover server.

Failover timeout

600

Time interval in seconds before the server will be considered as non operational and its tasks will be picked up by a failover server.

Central server connection timeout

300

Time interval in seconds to wait for central server connection on the server startup. When the interval expires the server will be started up even when the central server is unavailable.

☐ Auto recovery

Auto recovery

Recovery timeout

600

Time interval in seconds to wait before taking tasks back from failover server on the server startup. 0 - no timeout.

OK

Cancel

Add new server dialog box, Failover tab

If you wish to make this server a member of a failover cluster, click the *Change* button to open the existing cluster list. To remove this server from the failover cluster, simply select *none* in the cluster list.

Select failover cluster

Available failover clusters

TITLE	ID	TYPE
none		
HQ Servers (Failover)	(135)	Failover cluster
Cluster 1	(141)	Failover cluster

+ New failover cluster

OK

Cancel

Select an existing failover cluster or create a new one

If you need to create a new cluster at this point, use the + *New failover cluster* button: you will be redirected to the corresponding dialog box and then, upon completion, brought back to the server configuration, with the newly created cluster already selected for the target server.

Setting	Description	Default value
---------	-------------	---------------


Ganz CONTROL Global Administration Guide

Failover cluster	Makes server a member of a specific failover cluster	[none]
Current failover server	Failover server currently running instead of target server, if any; this field is informative (non-editable) and is only available if the target server has not been selected to be a failover node itself	[automatic]
Failover timeout	Time in seconds to wait before the target server is considered to be unreachable and replaced with a failover node	600
Central server connection timeout	Time in seconds to wait for the central server connection on server startup; after the timeout, the target server will start without central server connection	300
Auto recovery	Enable automatic replacement of a failover node with the original recording server after its recovery	Disabled
Recovery timeout	Time in seconds to wait before replacing the failover node with the original recording server, thus freeing the failover node; type zero here to enable immediate recovery	600

Membership

Server membership in existing server groups is displayed. If no groups exist, the lists will be empty.

Manipulate groups with the *Add* and *Remove* buttons below or by simply double-clicking the desired group. One server may belong to a single or multiple groups at once.




Add new server dialog box, Membership tab

Permissions

Add users and/or user groups simply by checking at least one permission for the target server; remove by clearing permissions - either by unchecking them or by clicking the *Clear* button below. You can also double-click users to remove them from the list of privileged users.

Ganz CONTROL Global Administration Guide




Add new server dialog box, Permissions tab

Watchdog

Here you can see and edit the watchdog service settings for the target server. Please refer to the [Server Watchdog](#) section for a detailed explanation of this; we strongly advise against changing the default settings unless you absolutely know what you are doing.

Storage

Manage storage configuration for the target server from here: click *Open storage properties* to bring up the dialog box. Detailed information and guidance on storage management can be found in the [Storage topic](#).



Add new server dialog box, Permissions tab

Management

Click *OK* to save your changes and close the dialog box; the newly created server will appear in the item list. The buttons on the upper panel will offer the following possibilities:


- *Edit*: go back to the dialog box to change server settings
- *Assign group*: select server group from the list and make the target server a member of it
- *Delete*: remove selected server(s)

Ganz CONTROL Global Administration Guide

- *X*: deselect all


Double-clicking the selected server will bring up the server settings' dialog box for editing.


The filter panel at the bottom enables you to view recently added/updated items, as well as other relevant filters. The filter that is currently active is highlighted blue: click the *Nfiltered* button to reset all filters and display all the available items again.



5.2 Recording Server Direct Login

You can log directly into your recording servers via Ganz CORTROL Console just in the same way as you do with the central server in order to view their **monitoring** data and **audit** data. In order to do this, run Ganz CORTROL Console and enter your Ganz CORTROL Recorder details; note that you need to enter the administrative user credentials in order to log in successfully.

 You will not be able to change the recording server settings via direct login. In order to do this, log into your central server via Ganz CORTROL Console.



	TITLE	ID	STATUS	CONNECTION	CONFIGURATION	STATUS UPDATE TIME	VERSION	FAILOVER CLUSTER	FAILOVER STATUS
		192.168.1.84:60554	(118)	Normal	Connected	Synchronized	4/18/2016 3:25:57 PM	1.1.0.2514	Not in cluster

Recently added, 0 Recently updated, 0 Groups, 0 Servers, 1 Not connected, 0 Not synchronized, 0

Note how Ganz CORTROL Recorder look differs when you are logged in directly


For the direct login, the following Ganz CORTROL Console sections and their relevant components are available:

- **Monitoring**
 - *Servers*: only the target Ganz CORTROL Recorder status will be displayed
 - *Devices*: devices from the target Ganz CORTROL Recorder and their replicas will be displayed
 - *Channels*: channels from the target Ganz CORTROL Recorder and their replicas will be displayed
 - *User sessions*: open user sessions with the target Ganz CORTROL Recorder will be displayed
- **Audit**
 - *Servers*: audit messages related to the target Ganz CORTROL Recorder
 - *Users*: audit messages for user actions related to the target Ganz CORTROL Recorder

6 Server Settings

Any **changes to the system configuration** are done via Ganz CORTROL Console application by connecting to the Ganz CORTROL Global server. All the Ganz CORTROL Recorder servers are connected and configured via Ganz CORTROL Global as well. The settings are immediately saved and stored in an **encrypted internal database**, which guarantees that your system configuration cannot be accessed without entering a valid username and password. Each Ganz CORTROL Recorder has its own local database but Ganz CORTROL Global stores the settings of all the connected Ganz CORTROL Recorder entities.

This topic describes the available server settings. Some of them are unique for the central management server - Ganz CORTROL Global - only; other settings are common for all server types.

 Server database encryption is automatic, meaning that you do not need to enabled it explicitly, and is available starting from the software version 1.8.0.

In order to access the server settings via Ganz CORTROL Console, select *Configuration* section and then choose *Servers* components from the menu on the left. By default, the central management server entry already exists; all the discovered and manually added [recording servers](#) will appear in the same list as you add them.

Configuration > Servers

admin

Search

Configuration

Organisations

Networks

Servers

Configuration

Events & Actions

Monitoring

Audit

New server

Edit

Assign group

1 selected

TITLE	FAILOVER CLUSTER	NETWORK	LOCAL IP	LOCAL VMS PORT	INTERNET IP	INTERNET VMS PORT
Global Server		Global Server network	192.168.1.83	60554		60554

Recently added, 0

Recently updated, 1

Groups, 0

Servers, 1


Configuration -> Servers

Double-click a server or click the *Edit* button on the upper panel to access server configuration dialog box.

Details

On the *Details* tab, you can change the server **name**: it will appear everywhere in Ganz CORTROL Console and in the connected Ganz CORTROL Client applications, including HTTP clients.

Ganz CORTROL Global Administration Guide



The screenshot shows a window titled 'Server Global Server'. On the left is a sidebar with icons for 'Details', 'Connections', 'Membership', 'Permissions', 'Watchdog', and 'Storage'. The 'Details' tab is selected. The main area has a 'Title' field containing 'Global Server'. Below it is a 'Server name' label. The 'Roles' section contains a disabled checkbox for 'Failover node' and the text 'The server takes failover node role'. At the bottom right are 'OK' and 'Cancel' buttons.

Global server details

Next, here you can choose the **server role**: regular recording (unmarked) or failover (marked). The central management server cannot act as a failover node so this option will be grayed out. However, it will be available for all recording servers: please see the related sections of this manual to learn about [failover](#) and [Ganz CORTROL Recorder](#) setup in details.

Also, here you can apply the video analytics license to the target server. Although a 32-bit Ganz CORTROL Console application is required to set up VCA, you can use any bit version to enter the VCA license. For details on the VCA setup and licensing, please see the CBC AMERICA LLC VCA documentation.

Connections

The *Connections* tab allows you to define the [network](#), which will be used for accessing the Ganz CORTROL Global server, and corresponding **ports** for Ganz CORTROL Client and Ganz CORTROL Streaming Server connections; the default ports are **60554** for Ganz CORTROL Client and **8080** for Ganz CORTROL Streaming Server (HTTP).


The HTTP port is also used for Ganz CORTROL Mobile applications (both iOS and Android), thin OS X client, Web browser connections and [external services](#). Note that, in case you plan to access your Ganz CORTROL Global server from the Internet, the ports must be properly forwarded on your router according to your desired topology and allowed through the firewall. Details on the port forwarding setup can be found in your router operation guide. Set 0 in the HTTP port field to disable incoming HTTP connections.



The Ganz CORTROL Global server HTTP port must be reachable from Ganz CORTROL Recorder machines if you plan to use [remote upgrade](#).

If you wish to run Ganz CORTROL Client connections in **multicast** mode, you can enable it here by putting a check mark in the corresponding option. Understandably, this option is only available for the local network.

Ganz CONTROL Global Administration Guide




Global server connection properties

Next, you can **enable encryption** for client-server connections and also for HTTP connections (by default, it is disabled). This setting only appears for the central management server and is applied to the whole Ganz CONTROL Global system.

Server-client encryption setting affects all TCP traffic, i.e.:

- Ganz CONTROL Console connections to the Ganz CONTROL Global server and Ganz CONTROL Recorder machines
- Ganz CONTROL Client connections to the servers
- server-to-server connections (configuration, audit and auxiliary information exchange)


When you change the server-client encryption setting, all currently connected clients - both Ganz CONTROL Console and Ganz CONTROL Client applications - will be disconnected so that the encryption settings can be applied correctly. They will re-connect back shortly provided that they support encryption, too - make sure to upgrade them so that their version matches server version.

 Connection encryption is supported starting from software version **1.8.0**. If your system has remote Ganz CONTROL Console and/or Ganz CONTROL Client applications of **older versions**, these will be **unable to connect** to a server that has encryption enabled; therefore, first make sure to **upgrade all the clients** and only then enable encryption on the server side.

To enable **HTTPS** (HTTP over TLS), mark the corresponding setting and then:

- specify HTTPS ports (different from HTTP) (set 0 to disable HTTPS)
- add a digital certificate

You can either use your own valid **digital certificate** or generate one right in the software. In the latter case, the certificate will be self-signed and you will need to add it as trusted when connecting from the mobile app and from your Web browser(s).

 If you are using your own **CA certificates**, create a **.pem** file with your certificate chain as described here: <https://www.digicert.com/ssl-support/pem-ssl-creation.htm>

This is necessary for the certificate to be recognized correctly by all HTTP clients - Web browsers and Ganz CONTROL mobile applications. If you simply apply your CA certificate in Ganz CONTROL Console, there is a chance it is not recognized because some applications require the entire certificate chain.

Then, apply the **.pem** file as the certificate together with your key when the importing certificate into Ganz CONTROL Console.

Ganz CORTROL Global Administration Guide



In addition to the setup in the Ganz CORTROL Global server settings, HTTPS should be enabled for each Ganz CORTROL Recorder **separately**, in the settings of the target server. The certificate has to be added only once, and then you just need to choose it from the list, when setting up HTTPS on the Ganz CORTROL Recorder machines.

In other words, you need to apply the same certificate to every Ganz CORTROL Recorder in your Ganz CORTROL Global system.

Here you can define server's **SNMP community** name and also **SNMP port** for incoming and outgoing messages. Community will be used by the external SNMP manager to send requests; SNMP port will serve for both incoming and outgoing messages (supported incoming messages are third-party SNMP manager requests, **not** external SNMP traps!). Leave both values zeroed to disable this functionality.

The *Test* button allows you to [test connection quality](#) for the target Ganz CORTROL Recorder.

Ganz CORTROL Global Administration Guide

Failover

As the failover feature is only meant for recording servers, the Ganz CORTROL Global server will not have this tab. For the central server redundancy setup, see [Mirroring](#).

To make the target server a member of a **failover cluster**, click the *Change* button to open the existing cluster list and then choose your desired cluster. To remove this server from the failover cluster, simply select *none* in the cluster list.

If you need to create a new cluster at this point, use the + *New failover cluster* button: you will be redirected to the corresponding dialog box and then, upon completion, brought back to the server configuration, with the newly created cluster already selected for the target server.

Setting	Description	Default value
Failover cluster	Add server to the specified failover cluster	[none]
Current failover server	Failover server currently running instead of target server, if any; this field is informative (non-editable) and is only available if the target server has not been selected to be a failover node itself	[automatic]
Failover timeout	Time in seconds (from 0 to 3600) to wait before the target server is considered to be unreachable and replaced with a failover node; 0=immediate reaction	600
Central server connection timeout	Time in seconds (from 60 to 3600) to wait for the central server connection on server startup; after the timeout, the target server will start without central server connection with the last known configuration	300
Auto recovery	If this option is enabled (marked), the target recording server will be automatically activated upon recovery (the central server will activate it and free the failover server)	[disabled]
Recovery timeout	Amount of time in seconds for the central server to wait before activating the recovered recording server; 0=immediately	600

Membership

The *Membership* tab allows you to manage server [group attachment](#). Use double-click or *Add* and *Remove* buttons below to move server groups between the columns.

Permissions

Here, [user permissions](#) for the target server can be defined.

The next topics describe the remaining aspects of server settings in details.


Ganz CONTROL Global Administration Guide

6.1 Storage

Server storage configuration includes storage directories, size and duration quotas, optional encryption, cleanup time settings and storage differentiation by name for further flexible allocation of the recorded streams. These settings are managed **separately** for each Ganz CONTROL Recorder server by logging into the central server via Ganz CONTROL Console.

To access the storage settings for the server via Ganz CONTROL Console, choose the *Configuration* section, select *Servers* from the menu on the left, double-click your target server and then click the *Storage* tab. Click the *Open storage properties* button to open the configuration dialog box.

There are also several settings in server settings dialog box itself. These are explained in the end of this chapter.



Access storage settings for the selected server


To **save the changes** after you have finished with storage configuration, hit the *Apply* button beneath the storage settings, then hit *OK* to close the storage configuration dialog box, and then click *OK* to finally save the storage settings together with the server configuration. Pressing *Cancel* on the last step will revoke the changes in the storage configuration.

Directories

All available **local disks** will be automatically listed after the first installation (with empty configuration) and enabled for recording with default archive directories using the *Default* storage label. By default, system disk (C:) is not listed if other disks are available, as we strongly do not recommend recording to the system disk.

If you are upgrading, re-installing the software, [restoring](#) an earlier database configuration, or inserting new local disks into the server after the software has been installed, the local disks will not be listed automatically so you need to **add** them as **new storages**. You can also add network paths to remote storage locations.

Use UP and DOWN arrows on the right to change the disk order (**priority**); use the recycle bin button in the top panel to **remove** any local or network directory from the storage configuration.

 Mapped network shares that appear as drives in Windows Explorer will **not** be listed automatically because Ganz CONTROL operates as Windows Service and therefore is unable to access these (due to Windows API peculiarities). You are welcome to add these as network directories in storage settings.

For each storage location, the following information will be displayed:

- storage priority: determined by the item position in the list
- storage label (see description below)
- current quota size
- free space on disk (except network storages)

Ganz CONTROL Global Administration Guide

- total disk size (except network storages)

Storage properties

Storage properties

Directories

Duration quota

Retention

Directories

Path

Quota (GB)

Storage

Apply changes

Cancel

	PATH	STORAGE	QUOTA	FREE SPACE	TOTAL SIZE
1	D:\L...	Default	500.00 GB	764.71 GB	803.51 GB
2	C:\L...	Disabled	25.56 GB	28.40 GB	127.90 GB
3	E:\L...	Disabled	70.16 GB	77.96 GB	78.12 GB
4	F:\L...	Important...	614.49 GB	682.77 GB	725.38 GB
5	G:\L...	Disabled	115.03 GB	127.81 GB	127.90 GB
6	H:\L...	Disabled	63.00 MB	70.00 MB	99.00 MB
7	I:\Lu...	Disabled	62.00 MB	69.00 MB	99.00 MB
8	Q:\L...	Disabled	0.00 KB	0.00 KB	0.00 KB

OK

Cancel

Configure storage directories

Each directly attached storage location will be automatically assigned a quota of 90%; each storage will have 20GB (minimum possible) quota by default. We strongly advise that you review all the settings and make sure that all the storage locations have sufficient free space, and, if necessary, free up some space. It is recommended that every recording location has 10-15% of free space: this helps avoid fragmentation effect and also allows highly loaded software to effectively enforce recording quotas.

Minimum quota per each storage location for any storage type is 20GB.

We advise against recording to the system drive because this drive is often used by other processes like defragmentation and system restore/backup, not to mention OS itself, and so this may affect recording efficiency and stability. As a result, disk C: is excluded from recording configuration by default.

Total size and free space on the **network storages** is not displayed here. You can check these in the *Monitoring* section of Ganz CONTROL Console, under *Storages*.

To change the disk quota, simply highlight the desired location for storage from the item list, then enter the quota size in GB and click *Apply changes*.

If you plan to **protect** some footage from being erased (this functionality is available via Ganz CONTROL Client application), keep in mind that **protected archive** areas will be **ignored when forcing quotas**. Make sure there is enough free space on the disk(s) and set lower quotas, if necessary.

To review and/or **un-protect** such areas, go to the *Monitoring* section of Ganz CONTROL Console, choose *Archive statistics* on the left, highlight one or more target channels, and press the [Protected intervals](#) button on the top panel.

Storages

You can either use the *Default* storage category for all locations, or create multiple different **storages** (names, types, tags, labels). These can be used for manually distributed streaming between storage directories:

- storage directories are marked with corresponding storage tags

Ganz CONTROL Global Administration Guide


- each channel is [assigned](#) to a recording location

To choose a storage profile different from *Default*, select storage location from the *Directories* list and click the *Change* button.



Change storage

Select one of the built-in storage profiles or create and edit a new one.



Choose storage profile

The built-in storage types are:

- **Disabled:** storage location will not be used
- **Default:** default storage tag
- **Fallback:** storage destination to be used if all the storage units with specified tags have failed
- **Readonly:** existing data will be available for reading and will not be erased; no new recordings will be appended to this location


These profiles cannot be edited or removed. Fallback storage settings are available in the corresponding tab of the *Storage properties*.

Readonly storage type can be used, for example, in the following cases:

- it is necessary to view the old data from a different Ganz CONTROL server when you need to insert the disks originating from another computer and you do not wish that these data are erased
- some storage unit contains important footage that has been requested to be kept for a longer time so that the recordings are not erased over time while still allowing access to the footage

Click + *New storage* button to create a new storage profile, or select an existing one and click the *Edit* button in the upper-right-hand corner to change its name.

Ganz CONTROL Global Administration Guide



New storage profile

Enter the storage profile title and click *OK* to save and exit.

The storage tag you have selected or just created will appear as selected. Click the *Apply* button below to **confirm** storage configuration settings before proceeding.


Add Storage

In order to add a new **local disk** or a **network storage** (NAS, SAN, network share), click + *New* button on the upper panel, select *New local directory* or *New shared directory*, and then enter the setup details.



If you are using a NAS, make sure to **disable** the *Recycle Bin* feature (for some NAS models, it is called *trashbox* or similar). This will ensure that the erased files (e.g., when reaching quota) are actually **deleted** permanently.

Ganz CONTROL Global Administration Guide



Add a new storage directory

The table below details the available settings for a **shared directory**. Enter the settings for the target storage and click *Create* below: the storage will be validated immediately.

Setting	Description	Default Value
Path	Full network path to the storage directory	\\Server\Share\CBC AMERICA LLC\Archive Files
Username	User name to connect to the storage	[empty]
Password	Define storage access password, if applicable	[empty]
Quota	Maximum amount of storage in gigabytes to be used for recording; 85-90% is recommended	20GB
Storage	Storage label to be assigned to the target storage directory	Disabled


When adding a **local directory**, you are first offered to choose the disk from the list of detected ones. If there is just one disk left available, it will be chosen automatically.

Setting	Description	Default Value
Path	Full path to the archive directory	X:\CBC AMERICA LLC\Archive Files
Quota	Maximum amount of storage in gigabytes to be used for recording; 85-90% is recommended	20GB
Storage	Storage label to be assigned to the target storage directory	Disabled

Storage Encryption

Once you have added all the necessary storages, you can enable encryption and set a password for each storage separately.

Ganz CORTROL Global Administration Guide



Storage encryption settings

Choose the **desired encryption type** and specify the **password** you want. You can change the password at any point, and there is also an additional field that lets you add a hint that may help remembering the password in future: it will appear either as regular text or a tooltip when hovering your mouse cursor over the password prompt field.

The currently available encryption options:

- **None**: no encryption
- **AES-128** or **AES-256**: choose the one you need



When assigning a new password for the storage, make sure to remember it or store in a secure place: you will require it, should you need to access the storage contents in the following scenarios:

- when accessing the archive with the Portable Player tool
- when adding the same disk as a storage unit for another server
- when adding a disk containing archive backup as a storage unit
- if you delete the encrypted disk from the storage configuration and then add it anew

There is a field that allows you to enter a password hint, which will be displayed in these situations.

You will not be prompted for the password when accessing the archive from the Ganz CORTROL Client application connected to a server with encrypted archive: Ganz CORTROL server will decrypt it automatically.



There is no option to recover the password if you have forgotten it.


Starting from the moment you set the password, all footage recorded to the target storage becomes encrypted; retroactive encryption for the previously recorded archive is not supported.

When the storage password is changed, the new password is used for encryption from then on. If storage encryption is disabled for some time and then enabled back, that part of the archive will remain unencrypted.

Duration Quota

Ganz CORTROL Global Administration Guide

Set a limit on global recording duration for your server here: enable quota management and then enter your desired number of days. All recordings older than specified number of days will be erased.




The screenshot shows the 'Storage properties' dialog box with the 'Duration quota' tab selected. The left sidebar contains 'Directories', 'Duration quota', and 'Retention'. The main area has a title bar 'Duration quota' and a description: 'Use the controls below to setup the global recording duration. Selected quota will be applied to all media devices and storage drives.' There is a checkbox 'Enable global duration quota management' which is checked. Below it, 'Storage duration' is set to '90' and 'Days'. A warning icon and text state: 'Note that Server will maintain configured maximal storage duration so that it will force erasure of footage older than the specified point in time.' At the bottom right are 'OK' and 'Cancel' buttons.

Global duration quota

Note that the global duration quota has priority over the individual (per-channel) duration quota that is set in the [Recording Configurations](#).

Retention


You can restrict the software erasing mechanism so that it cleans up old recordings only during specific hours, e.g., when the recorder is less overloaded or when the quality of recordings are less important.



The screenshot shows the 'Storage properties' dialog box with the 'Retention' tab selected. The left sidebar contains 'Directories', 'Duration quota', and 'Retention'. The main area has a title bar 'Retention' and a description: 'To recover disk space, storage subsystem deletes the oldest footage and implements ring buffer recording. Use the controls below to finetune the process.' There is a checkbox 'Enable cleanup hours' which is checked. Below it, the cleanup hours are set to '18:00' and '03:00'. A warning icon and text state: 'Note that reducing cleanup hours might result in there being a lack of storage space for new recordings. When the feature is enabled, reviewing and reducing disk quotas to avoid storage overflow is recommended.' At the bottom right are 'OK' and 'Cancel' buttons.

Enable cleanup hours

To do this, enable the cleanup hours setting and then specify the time period during which erasing is allowed.


 This control has priority over the storage quota. Setting insufficient cleanup time may lead to storage overflow and result in partially missing recordings. We strongly recommend that you do not enable any cleanup hours' restrictions unless you absolutely know what you are doing.

Fallback

You can dedicate a specific recording location to serve as a failover storage, called **fallback storage**. Such storage location will be used for recording only if all specified target storages of the certain type have failed.


Ganz CORTROL server automatically detects when a channel or channels cannot be written onto their normal destination storage and switches to the fallback storage if conditions are met. A default [system event](#) is raised when fallback is activated.

Ganz CORTROL Global Administration Guide



Fallback storage settings


After setting the desired timeout, switch to the *Directories* tab and specify, which storage will serve as fallback.



Set fallback storage units

Usage example:

Consider a system where all main streams are recorded to the storage with the tag *Main* and all secondary streams are, in their turn, recorded to the *Substreams* storage. If either or both of these storages fail, recording will automatically proceed to the *Fallback* storage.

 The fallback storage must be able to handle the load and have enough free space to keep the recordings until the main storage gets back online.

Server checks if the main storage is available if one of the conditions has been fulfilled:

- server has finished and closed a data file (4GB)
- the data file has not reached 4GB in size but six hours have passed
- server was restarted

In other words, the recording mechanism checks if the main storage is available every 6h OR every 4GB of recorded data OR after a restart (upon startup). If the main storage is OK, Ganz CORTROL server continues to record onto it; the recordings made onto the fallback storage stay there and are not transferred anywhere.

Ganz CORTROL Global Administration Guide


To **save the changes**, hit the *Apply* button beneath the storage settings, then hit *OK* to close the storage configuration dialog box, and then click *OK* to finally save the storage settings together with the server configuration. Pressing *Cancel* on the last step will revoke the changes in the storage configuration.

Archive Protection and Deletion


Outdated archive is erased automatically once any of the quotas is reached (storage or duration, server wide or individual). Oldest recordings are removed to free up some space for the newer recordings. However, there are some exceptional cases when the footage is not or may not be erased:

- storage marked as *Readonly* will not be used for writing and no data will be erased from such storages based on quotas (however, footage from such storages can be removed using selective erasing from the Ganz CORTROL Client application)
- no erasing will be conducted outside cleanup hours (by default, erasing is allowed 24/7 and this setting is recommended)
- protected archive intervals will be also ignored by the erasing mechanism until you un-protect them

Archive protection is an additional feature available in the Ganz CORTROL Client application, in playback mode. You can mark certain footage to protect it from being erased if it is important to keep it for longer, overriding the quotas (e.g., important evidence). To unlock the protected intervals, go to *Archive statistics* in the [Monitoring](#) section of Ganz CORTROL Console.

 If there are too many protected recordings on a disk, the storage may be filled up to 100%: this may negatively affect the overall recording operation. Pay attention to the amount of free space on every storage unit in case you are using archive protection:


- set lower recording quotas so that there are always 10-15% of free space on each storage,
- [un-protect the archive](#) that no longer needs to be protected from erasing.

 When you **protect a short period** of the archive (e.g., several minutes), in fact, the **whole file** containing this period is protected from erasing. Therefore, intervals adjacent to protected period will also be locked. You can verify the exact protected interval by opening Ganz CORTROL Console >> *Monitoring* section >> *Archive statistics* >> *Protected intervals*.

Keep this in mind when protecting too many short intervals: as all files containing them are locked, they will not be erased when forcing quotas, so you may come to a point when there is **not enough free space** on the disk. If you know you will use the archive protection feature a lot, it may be wise to set a **lower disk quota** - for example, 80% instead of 90%.

Ganz CORTROL Client application allows users with corresponding privileges to delete certain parts of the archive. This mechanism can delete recordings from storages marked as *Readonly* but cannot erase protected archive from any storage unit.

If the footage is not protected, it will be removed as outdated when the server eraser reaches one of the quotas. Also, the **unprotected** footage can be removed manually by someone who has a permission to **delete archive**. However, as such a feature may be regarded as a potential threat for the archive integrity, it is **disabled by default**. You can enable it in the server storage settings by marking the *Allow manual deletion* option.


 Enabling manual archive deletion will automatically enable the **admin** user to do so, as admin is a root user who has all possible privileges. The same is true for all users belonging to the *Administrators group*. If you are enabling this feature, make sure that no unauthorized personnel have access to the administrative accounts.

Time Restricted Access to Archive

There is a possibility to grant **archive access** permissions for a **limited time**: for example, for the last N days or M hours. The access permissions are a part of the [channel permission](#) set.

Here, in the server settings dialog box > *Storage* tab, you can define the allowed archive access period, starting from the present moment.

Ganz CORTROL Global Administration Guide



The screenshot shows a sidebar on the left with three menu items: 'Storage' (highlighted with a teal background), 'Security policy', and 'Audit policy'. The main content area is titled 'Recent archive interval'. It contains a text input field with the value '30' and a dropdown menu currently set to 'Hours'. Below these elements is a small text note: 'Recent archive interval available for viewing when restricted view archive permission is set. Interval must be in range [10 minutes - 366 days].'

Depending on your needs, the duration can be expressed in **minutes**, **hours**, or **days**. The minimum period is 10 minutes and the maximum value is 366 days (1 year).

Example: if the recent archive interval is set to 30 minutes, all users having a *Restricted video playback* permission will be able to browse the last half an hour of the target channel archive in all archive playback modes of the Ganz CORTROL Client application.

6.2 Watchdog

General

Server *Watchdog* is an important part of the Ganz CORTROL software. It runs as a separate Windows service and protects the software from certain types of failures by automatically attempting to restart the server.

Watchdog operates based on the software and system overall health monitoring; default trigger values have been selected on the grounds of our analysis of extensive tests, which we conducted on many systems with different configuration and stability level.


Although it is possible to disable the *Server Watchdog* service, we strongly advise against doing so, as the principal role of the watchdog is to keep the software operation as stable as possible in the given circumstances.

Watchdog operation can be tracked by messages in the Windows Application log and in the software [Audit log](#). If you do experience frequent disturbances such as software restarts or server rebooting, this might be an indication of some serious issue related to the software, operating system and/or underlying hardware. In such a situation, the best course of action is to:

- carefully read the messages in the Windows Application Log, as these may already contain some indication of why Watchdog was triggered;
- refer to the [relevant topic in the Troubleshooting section](#) of this manual to read about typical causes of such cases;
- send a [Problem Report](#) from the faulty server, providing as much information as possible about the issue;
- consult the CBC AMERICA LLC technical support team directly via control@cbcamerica.com.

Configuration

Watchdog operation can be configured for each server independently. To access the watchdog settings in Ganz CORTROL Console, select *Configuration* in the bottom left menu and select *Servers* from the list on the left, then double-click the desired server or simply click *Edit* button on the top panel for the pre-selected server.



Locate server for Watchdog configuration

In the *Server* dialog box, select Watchdog from the left menu.

Ganz CONTROL Global Administration Guide

Server Central Server*

Server

Details

Connections

Membership

Permissions

Watchdog

Storage

Watchdog

Watchdog options

☒ Enable watchdog

Operation

After the start of the application, the watchdog will not perform restart or reboot actions within this grace interval.

Grace interval, seconds:

The watchdog may be set to reboot in cases of frequent failure. If at least the specified number of failures are detected within the specified amount of time, a restart of Windows will be initiated. Entering zero in any field below will disable the restart.

Reboot interval, minutes:

Number of failures to reboot:

Performance

Configure watchdog to monitor system performance, detect contingent situations and attempt to fix problems.

☒ Monitor system committed memory usage ratio ⓘ

Maximum allowed:

☐ Monitor system pool non-paged memory usage (MB) ⓘ

Maximum allowed:

☒ Monitor server private memory usage ratio ⓘ

Maximum allowed:

☒ Monitor server virtual memory usage ratio ⓘ

OK

Cancel

Watchdog configuration

© 2025. CBC AMERICAS, Corp. All Rights Reserved.

142

Ganz CORTROL Global Administration Guide

The table below contains a detailed explanation of the watchdog settings. Please note that, for most cases, **default and near-default settings are recommended**; it is advisable that you consult with CBC AMERICA LLC support if, for some reason, you plan to make extensive changes to these settings. Click the information icon next to each setting to read more about them.

Setting	Description	Default Value
Enable Watchdog	Enables Watchdog operation for the target server	Enabled
Grace Interval, seconds	Time interval in seconds, counting from server start, during which Watchdog will not attempt to restart the software	30
Reboot Interval, minutes	Watchdog will reboot Windows if there have been a certain number (N) of software restarts (N is specified below) in the given time interval; the default for rebooting is 3 restarts in 5 minutes; setting the specified number to 0 will disable rebooting	5
Number of Failures to Reboot	Watchdog will reboot Windows in case there have been N software restarts in the time interval specified above; the default for rebooting is 3 restarts in 5 minutes; setting the specified number to 0 will disable rebooting	3
System Committed Memory Usage Ratio, %	Watchdog will restart the software if the ratio of total system committed memory exceeds the specified percentage; this value is shown under <i>Memory</i> section of <i>Performance</i> tab in the Windows Task Manager	Enabled, 95%
System Pool Nonpaged Memory Usage, MB	Watchdog will restart software if the amount of system nonpaged pool memory exceeds the specified amount	Disabled
Private Memory Usage Ratio, %	Watchdog will restart software if the amount of private memory used by server process exceeds the specified value	Enabled, 45%
Virtual Memory Usage Ratio	Watchdog will restart software if the amount of virtual memory used by server process exceeds the specified ratio; ratio shows the amount of virtual memory used by server process versus maximum per-process virtual memory allowed by OS	Enabled, 90%
Enable periodic restart	Enables automatic software restart for performance optimization	Enabled
Restart interval	Choose between every N weeks, days, or hours; use hours for troubleshooting purposes	1 week
Weekday	Restrict periodic restart to specific day of the week	Sunday
Enable periodic restart times	Limit periodic restart to specific hours, e.g. only restart at night; we recommend to leave at least a 1h interval for the restarts	Disabled

Up to software version 1.22, the *System Committed Memory Usage Ratio* was equal to 70% by default. Afterwards, it has been changed to 95% for a more optimal usage of system resources.

If you choose to limit the periodic restart time to specific hours or weekdays, the watchdog service will attempt to restart the main service straight away (at the very beginning of the allowed interval). If the watchdog does not succeed for some reason, it will continue to try until the end of the period, and then the next attempt will only take place when the next safe period begins. For example: if the restart is limited to 00:00-08:00 on Sundays, you should typically expect the restart at 00:01 on Sunday; if the watchdog was manually stopped before that time and started at 08:30, the following periodic restart would not happen until next Sunday at 00:01.



Ganz CORTROL 1.27 Update: The *Server Watchdog* now automatically monitors the *Streaming Server*, enhancing system stability and reliability. This integration ensures uninterrupted streaming and improved performance, with no additional settings required.

Ganz CORTROL Global Administration Guide


6.3 Server Policies

Ganz CORTROL policies are configurable sets of rules that are followed by Ganz CORTROL servers when handling access requests. At this point, these include security settings and external database configuration. Default values and state of the policies depend on the chosen security level.

Security Policy

Security settings related to password management, connections etc. can be defined for each system. To access the server security policy settings via Ganz CORTROL Console, choose the *Configuration* section, select *Servers* from the menu on the left, double-click your target server and then click the *Security policy* tab.

It is recommended that, in order to enhance your system security, you do not leave the default policy settings but rather define your own, system-specific preferences.



Server security settings

The table below details the available settings.

Setting	Description	Default Value
Minimum password length	Minimal mandatory length of a user password	8
Minimum number of special symbols	Define how many (at least) special characters (#\$%&...) must be present in a user password	2
Minimum number of digits	Define how many (at least) digits must be present in a user password	2
Minimum number of uppercase letters	Define how many (at least) UPPERCASE letters must be present in a user password	2
Minimum number of lowercase letters	Define how many (at least) lowercase letters must be present in a user password	2
Number of previous passwords to remember	Password history to be kept by the server to prevent the user from using the same password again when changing it	1
Maximum number of days between password change	Define how frequently Ganz CORTROL will ask users to change their password; this setting can be overridden in the user settings to make the password never expire for a specific user	0 (unlimited)
Maximum number	Allowed number of simultaneous incoming connections from the same user	0

Ganz CORTROL Global Administration Guide

of simultaneous connections with the same login name	account via any port (TCP/HTTP) or client app, this setting can be overridden for the specific user in the user settings; 0=unlimited	(unlimited)
Maximum unsuccessful login attempts*	After this number of unsuccessful login attempts the user account will be blocked (can be unlocked via user properties). Set 0 to allow unlimited attempts.	0
Disconnect disabled users**	Disconnects User from Server as soon as system marks account as disabled	Disabled (not selected)
Disconnect upon user password change**	Disconnects User from Server as soon as password change event happens	Disabled (not selected)
Disconnect if password expires**	Disconnects User from Server if user password is expired	Disabled (not selected)
Disconnect if auth token is reset**	Disconnects User from Server if authentication token was reset	Disabled (not selected)
Put user ID as an OSD watermark	<p>Ads watermark with the logged-in monitor User's ID over the all <i>Live View</i> and <i>Playback</i> viewports displaying video streams. Such a watermark allows compliance with GDPR and specific countries' local data and privacy protection regulations, making it possible to identify any data leak source recorded even by a third-party recorder (such as a phone) directly from the display. You can't change the text displayed in the watermark - the only option is to turn on or off the feature.</p> <p>By default, the <i>OSD watermark</i> will be applied to all users. You can also disable <i>OSD Watermarks</i> for particular users. To do so, go to <i>Configuration -> Users</i>, double-click on the particular <i>User</i>, and inside the popup window, find the <i>Administration profile</i> tab. Scroll to the bottom and find the subsection <i>Client Permissions -> Do not display OSD watermark</i>. Mark the corresponding checkbox and confirm with the apply button.</p>	Disabled (not selected)

Password related policies are solely meant for Ganz CORTROL internal users and they do not affect any other user account settings (e.g., Windows users etc.). All policies are in effect for **all user accounts**, including the built-in root *admin* user account.

*To **unlock the user** account, go to the *Users* section > open the user details for editing > enable the *Active* option > save. To override the policy for a specific user, enable the *Never lock account on bad password* option in the user account details.

** if the option is disabled - the user will continue with the current session, even if this particular user is already disabled.



The **maximum number of simultaneous connections** from the same user account can be re-defined for any specific user via user settings dialog box. User-specific setting has priority over global connection quota and it may be either larger or smaller than the global quota.


Example 1: global policy is set to 0, which means no imposed limitations. However, user account *admin* has his max number of connections set to 3, which means that three incoming connections with this user account are allowed at a time so that the administrator can connect via Ganz CORTROL Console, Ganz CORTROL Client and Ganz CORTROL Mobile at once for troubleshooting purposes.

Example 2: global policy is set to 1, which means only one connection from each user is allowed at a time. However, user *demo* has an allowance of 30 simultaneous connections so that this account can be used for demonstration purposes.

Two-Factor Authentication

Ganz CORTROL Global Administration Guide

For additional security, you can turn ON **two-factor authentication** (2FA) for all client logins. When 2FA is enabled, all users who want to connect to your Ganz CORTROL server, will have to enter both their password and a code they receive. Thus, the users prove their identity not just by entering what they know (the password) but also what they have (the email or phone). By default, this policy affects all users; you can disable 2FA for individual users in their permissions.


 At this point, Ganz CORTROL 2FA supports code sending via **email** and **SMS**, and works for Ganz CORTROL Console and Ganz CORTROL Client login.


Terminology:

- session: an established connection between client and server once the user logs in
- code: a numeric code sent to the user's email

The following settings are available here:

Setting	Description	Default Value
Enable two-factor authentication	If selected, additional authentication will be required for server login	Disabled
Set up notification providers	Set up desired providers (using email servers or other means) that will be used for sending out authentication codes	[button]
Session expiration time	During this time period, 2FA will not be requested again if client disconnect was caused by server; after this time or after user-initiated disconnect, the user will have to use additional authentication again	1 day
Code expiration time	The time period during which the sent code will be valid, starting from the code sendout moment; after this time, the user will have to request another code	00:05:00 (5 minutes)
Code generation interval	The minimum time between two consequent code requests; the user will be unable to request a code more frequently	00:00:10 (10 seconds)
Skip for localhost connection	If enabled, 2FA will not be applied to localhost connection	Enabled
Subject	Message subject line, can consist of text and macros (via right-click)	{SESSION_ID}
Body	Main message part, can consist of text and macros (via right-click)	{CODE}

 Name your **notification providers** according to the used verification source (e.g., **Email**) so that the users understand where to look for the code.

 Write some text in addition to the session ID and the code so that:

1. The user understands which one is which
2. The email does not go to Spam

When you try enabling 2FA, you will get a **warning** that you will need to test 2FA before saving the configuration. This is necessary to ensure that all the settings are correct and 2FA actually works; otherwise, you may be unable to log into the system at some point. The 2FA verification will start when you click OK to save and close the settings window.

Settings to be verified before enabling 2FA:

- make sure you have added a valid 2FA notification provider (SMTP server)
- add a contact email for each user
- it is recommended that at least one administrative user account is allowed to log in without 2FA, or 2FA is disabled for localhost connections: this is to ensure that you can log into the system if your 2FA notification provider fails or becomes unavailable

Ganz CORTROL Global Administration Guide

Server My Server*

Server

Two-factor authentication

Code generation interval

00:00:10

The minimal amount of time between two consequent code requests, 10 seconds by default

☒ Skip for localhost connection

If enabled, 2FA will never be used for connections to local server that are using loopback address

Subject

2FA code for session #{SESSION_ID}

Subject text template for the notification messages

Body

{USER_FULLNAME}, your 2FA code for server {SERVER_NAME} login is {CODE}.

Insert field

OK Cancel

Two-factor authentication settings

The best approach for 2FA configuration:

- in 2FA settings, add a notification provider and adjust everything but do not enable 2FA yet, click OK to save
- make sure your email server user for notification provider is valid, and that all users have correct emails
- go to 2FA settings again and enable it, and go through the test verification


When you turn off 2FA, you will have to go through the setting verification again next time you enable it. If you make changes to the 2FA settings and enable it at once, this test verification will use the previous settings for formatting and intervals (because it basically happens before saving the settings, and these will not be saved until you pass 2FA successfully).

Two-factor authentication is also a recommended setting when you choose the highest [cybersecurity](#) level - the system will check if 2FA is enabled and remind you with a warning mark if it is not.

Audit Policy

Whenever a [permission](#) is used, a corresponding entry appears in the internal Ganz CORTROL [audit log](#); internal server events are logged as well. The audit policy lets you define, which user actions and server events are recorded, as well as set the maximum size and duration of the audit log.

Ganz CORTROL Global Administration Guide



Ganz CORTROL audit policy


The default limit for the number of audit entries is one million and they are kept for one month; set zero days to disable the duration limitation (the quota for the number of records will still have effect). By default, all the events are audited.

External Audit

For Ganz CORTROL Global software edition, it is possible to set up set up log event storing in an **external audit database**.

The main (internal) audit log is kept always, and the external audit is a copy (addition). You cannot turn OFF the internal audit if you do not need it, but you can limit it to one or two days, and keep the external log for a longer period. The built-in database (SQLite) is OK for low and medium load; for high and extra high load, especially for lots of entries per second, an external database with extra hardware is strongly recommended.

Ganz CORTROL Global Administration Guide





Connecting an external database for the audit log

At this point, three database formats are supported:

- SQL database
- PostgreSQL
- MySQL

First, set up your external database, and then fill in the corresponding settings in Ganz CORTROL Console: server **host**, **port**, **user account**, and target **database name**.


 Please consult with your database server architect to build the database server. Ganz CORTROL hardware recommendations do not include hardware for the external database server.



Ganz CORTROL Global Administration Guide


Once you have entered the database connection details, you can test it and enable it

After adding the database connection, you can **test** it to verify that the entered configuration is correct. The database **must exist** for the Ganz CORTROL server to connect successfully, and you cannot create a new external database from Ganz CORTROL Console. The connection test runs **automatically** once you have entered a new DB connection or modified the connection settings.

 The connection **test may take some time**. You can tell by the disabled (grayed out) buttons below. If you close the server settings dialog box, the test will still run in background so you will have the result pop up after some time.

If your target database contains something else and you want to clean it, press *Reset*: all contents of the target database will be then **removed** and replaced with the tables necessary for the audit log.

Similarly to internal audit, here you can **limit** for how long and how many records should be kept in the external audit database. Set zeroes for **unlimited** options (the number of records will be then only limited by database type).

 External databases are recommended when you need to keep larger amounts of information for much longer periods of time. The built-in database (SQLite) is OK for low and medium load; for high and extra high load, especially for lots of entries per second, an external database with extra hardware is strongly recommended.

You can prepare the database connection and leave it disabled (default mode) until you decide to **enable** the external logging. To do this, put the check mark in the corresponding checkbox.


When done, click *OK* to save the settings and close the dialog box.


Troubleshooting: if, during operation, the Ganz CORTROL server is **unable to write** events to the external database, you will have a **warning** (highlighted orange) in the *Monitoring* section of Ganz CORTROL Console, under the [Servers category](#). Click the target Ganz CORTROL Global server, then click *Details* on the upper panel to see the **database connection errors**.


External Databases

For certain data types, you can set up separate databases in a similar manner. In the *External Databases* tab, available databases will appear.

Currently available: a separate database named *Recognition history database* can be used for storing [external recognition](#) events. Without it, only metadata (bounding boxes) are stored for external recognitions (in the video archive), so you will be unable to search these events in a separate tab in Ganz CORTROL Client. If you do not use external services/cameras for LPR/FR recognition, you will not be needing this database.

 If you have made a clean installation, this DB is enabled by default. If you made an upgrade from a software version prior to 1.21, this DB is disabled.

Click the  *Edit* button to change the built-in database settings: limit the number of recordings and the number of days, and enable/disable the database. Click *OK* to save and then *OK* again to save and close the dialog box.



Ganz CORTROL Global Administration Guide

Change built-in database settings


The built-in database cannot be removed and it is enabled by default for all new installations.

Bookmark Policy

Here, you can set limits for the bookmark database by defining its desired duration and size, and also change bookmark colors for different severity levels. The settings here affect the whole system - all servers, all channels.

The default (and also the maximum) **number of records** (items in the database) is 500000, and they are kept for 5 (five) years. Set 0 days to set unlimited **duration quota** (the items' quota will still have effect).

These limitations were introduced in the software version 1.14.1. Therefore, when you upgrade from an older version, database will be reduced in size by removing the oldest bookmarks so that their number matches the default quota (500000). If the old database contains more than 1 million items, it is truncated and compacted during the upgrade.



Limitations for the bookmark database and default colors

Bookmark **severity levels** were introduced in the software version 1.16.0. Prior to this version, all bookmarks were red and had no ranking; to preserve compatibility with older archive, all bookmarks from the older archive will stay red and have the highest severity, *Critical*. Here, in the policy tab, you can change the colors used for different bookmark labels. To do this, select an item in the ranking list, then choose a color using the built-in picker.


After you change the color related to a certain severity level, all bookmarks with that severity level will start using the new color. If the bookmarks are already opened somewhere (e.g., on the timeline of a Ganz CORTROL Client), simply refresh the timeline to see the new color: remove the channel from the view and add it anew. In instant playback mode, switching to live and back will do the trick.

NTP Server

Ganz CORTROL servers use the local machine time. Ganz CORTROL Console provides you with an opportunity to force **sync time** with the specified NTP server.

Essentially, this is the same as configuring the target server OS use the specified NTP server: the time server you set via Ganz CORTROL Console is applied to the underlying OS settings. The only difference is that you can do this remotely via Ganz CORTROL Console interface, without connecting via RDP or other remote control software.

Ganz CONTROL Global Administration Guide



NTP server connection settings

The available settings here are:

- **NTP server:** the target IP or hostname of the time server, local or public
- **Time synchronization interval:** how often to sync the time, choose any desired interval from 30 seconds up to 1 year.

6.4 Security


All Ganz CORTROL editions have enhanced security aimed at data protection, which includes not only advanced permission management but also encryption wherever possible. Data protection for Ganz CORTROL encompasses database encryption, server-to-server and server-to-clients connection encryption, password protection for the proprietary archive, as well as certain system settings and policies that increase the level of cybersecurity.

The system offers pre-configured security levels, each of which includes a certain preset of security-related features. Some of the security settings are system-wide, and some other can be adjusted for individual servers (e.g., archive encryption).


Cybersecurity Dashboard

You can access the cybersecurity dashboard via Ganz CORTROL Console main menu in the top right corner > *Cyber security*.

Four pre-defined **security levels** range from the lowest to the highest. You can choose any level as a basis and, either leave it as it is, or turn off individual security checks.

 The security checks for the selected settings mean that these settings are monitored and you are warned trying to assign an inappropriate value. Enabling a certain security level does NOT change any of the related configuration parameters!

Each security check means that the related setting is tracked and you are notified if it does not meet the security requirements. For example, if the automated backup location is on the same disk as the main configuration file, the backup directory setting in the *Automated backup configuration* dialog box will have a warning shield. Thus, the **selected security level is a set of recommended security settings**, and you are free to ignore the warnings or exclude individual checks from the security profile.




Cybersecurity warning example: the setting does not fit the currently selected security profile

Security Levels

The cybersecurity dashboard will display recommended setting values accompanied by warnings if the current preference is lower than recommended. For some of the checks, the warnings cannot be displayed: this happens if the security check is applied at a certain moment. For example, this is true for the storage and device passwords: the server cannot validate the existing password so the password complexity will be estimated on the password creation step.

Ganz CONTROL Global Administration Guide




Cybersecurity dashboard

Cybersecurity levels:

- **None:** no security checks at all
- **Low:** only some password policies and server backup settings are tracked
- **Medium:** more of these settings plus user- and device-related settings
- **High:** all possible settings related to security are monitored for maximum system protection

If the security check concludes there are **issues** with the current configuration, you will be notified with an orange shield and offered to **review** the list of issues.



The shield in the upper right corner displays the number of active issues

Click the *Show active issues* button to see the list of detected security issues and recommendations on how to get rid of them.

Ganz CONTROL Global Administration Guide

Cybersecurity report	
Active issues	
<div>Export to CSV</div> <div>Search</div>	
SOURCE	PROBLEM
Automated backup configuration	Automated backup folder is on the same drive as configuration folder. It is recommended to use a different drive for automated backup.
Automated backup configuration	One or more databases is not selected for backup. It is recommended to backup all databases.
Glo	'Maximum number of days between password change' condition is not met. It is recommended to set less than 91 value.
Glo	'Maximum number of simultaneous connections' condition is not met. It is recommended to set less or equal to 1 value.
Glo	'Maximum unsuccessful login attempts' condition is not met. It is recommended to set less or equal to 5 value.
admin	'Never lock account on bad password' is enabled. It is recommended to disable 'Never lock account on bad password' setting.
Close	

The list of active issues with recommendations on how to rectify them

From here, you can save the list of active cybersecurity issues into a CSV file.

Security Checks

The following security checks are available with their corresponding recommended values for different security levels:

Category	Security check	Low	Medium	High
Automated configuration backup	Automated configuration backup mode	Enabled	Enabled	Enabled
	Automated configuration backup interval	Every 5 days	Every 2 days	Every day
	Number of config backup files to keep (max)	1 or more	15 or more	30 or more
	Backup directory is located on a different drive	-	+	+
	Databases to be backed up	-	All	All
Server security policy	Minimal user password length	6+ characters	8+ characters	12+ characters
	Minimum number of uppercase letters in the user password	1+	2+	2+
	Minimum number of lowercase letters in the user password	1+	2+	2+
	Number of previous passwords to remember	-	1+	3+
	Number of days between password changes	-	90-	30-
	Max number of simultaneous connections using the same user account	-	1	1
	Max unsuccessful login attempts before blocking the user account	-	5-	3-
	Minimum number of special symbols in the user password	-	-	1+
	Minimum number of digits in the user password	-	-	2+
Server storage	Check storage password complexity (upon setting the password)	-	+	+
	Storage encryption is enabled	-	-	+
Audit policy	All audit options related to security policy are enabled	-	+	-


Ganz CORTROL Global Administration Guide

Server connections	Client-server connection encryption is enabled	-	-	+
	HTTPS is enabled	-	-	+
Two-factor authentication (2FA)	2FA is enabled	-	-	+
User account	Check password complexity against server policy	-	+	+
	Lock account after N unsuccessful login attempts ("never lock on bad password" option is disabled)	-	+	+
	User password is valid for a limited time ("password never expires" option is disabled)	-	-	+
Device settings	Verify password complexity (upon entering the password)	-	+	+

Some of the security options are hard-coded so it is impossible to disable them (e.g., database encryption) and these are therefore not listed here.


Database Encryption

Ganz CORTROL server uses several databases for storing the server configuration, audit logs and other software data, and all of them are encrypted by default. Once you install the software version that supports database encryption, all the databases are automatically converted to the encrypted format. There is no need to adjust any settings to enable this feature.

 Database encryption was introduced starting from the Ganz CORTROL version 1.8.0 and is supported in all succeeding versions.

Connection Encryption

Traffic encryption is not enabled by default, it can be turned ON in the [server settings](#), in the *Connections* tab. There are separate settings for TCP connection encryption and HTTPS.



Ganz CORTROL Global server connection settings with encryption options


Client-Server Connections

This setting affects all TCP traffic between servers and clients, including server-to-server communications in Ganz CORTROL Global.

Ganz CONTROL Global Administration Guide

The currently available encryption options:


- **None:** no encryption
- **AES-128** or **AES-256:** choose the one you need

 When [configuring a Ganz CONTROL Global system](#) that has remote servers and clients of version 1.7 or earlier, make sure to upgrade all remote components to the same version as Ganz CONTROL Global so that they support encrypted connections. As soon as it is done, you can safely enable encryption for TCP connections.

HTTPS

Connections from remote Web browser clients and mobile applications, as well as API connections, can also use a secure channel instead of plain HTTP.

To enable secure communications, enable HTTPS in the server settings, then specify desired HTTPS ports (different from HTTP ports) for local and internet connections, and then add the digital certificate you wish to use; you can either use your own certificate or generate a self-signed one right on this step.

 If you are setting up a Ganz CONTROL Global system:
In addition to the setup in the central management server settings, HTTPS should be enabled for each Ganz CONTROL Recorder **separately**, in the settings of the target server. The certificate, though, should be only added **once**, and then you just need to choose it from the list, when setting up HTTPS on the Ganz CONTROL Recorder machines.

 It is recommended that you use a valid digital certificate signed by a trusted authority instead of self-signed ones. If you use a certificate generated by Ganz CONTROL, your browser will show you a warning.


Archive Encryption

Each archive storage (local or network), as well as archive backups made through the [Archive Backup Wizard](#), can be encrypted. You can provide a different password for every storage unit, and there is also an option to change the password at any time.

Regular Server Archive

To access the archive encryption settings in Ganz CONTROL Console, open the *Configuration* section, choose *Servers* on the left, then double-click the desired server to edit its settings. In the *Storage* tab, click the *Open storage properties* button.

Ganz CONTROL Global Administration Guide



Password-protected storage setup

Click the target storage in the list on the right or add a new local or network storage unit by using the **+New** button above the storage list: its properties will appear on the left. Mark the *Enable encryption* option and specify the password you want.

The currently available encryption options:

- **None**: no encryption
- **AES-128** or **AES-256**: choose the one you need

To **save the changes**, hit the *Apply* button beneath the storage settings, then hit *OK* to close the storage configuration dialog box, and then click *OK* to finally save the storage settings together with the server configuration. Pressing *Cancel* on the last step will revoke the changes in the storage configuration.



When assigning a new password for the storage, make sure to remember it or store in a secure place: you will require it, should you need to access the storage contents in the following scenarios:

- when accessing the archive with the Portable Player tool
- when adding the same disk as a storage unit for another server
- when adding a disk with archive backup as a storage unit
- if you delete the encrypted disk from the storage configuration and then add it anew

There is a field that allows you to enter a password hint, which will be displayed in these situations.

You will not be prompted for the password when accessing the archive from the Ganz CONTROL Client application connected to a server with encrypted archive: Ganz CONTROL server will decrypt it automatically.



There is no option to recover the password if you have forgotten it.


Starting from the moment you set the password, all footage recorded to the target storage becomes encrypted; retroactive encryption for the previously recorded archive is not supported. If you wish to have the already recorded data to be encrypted, you can use the [replication feature](#) in Ganz CONTROL Global, targeting the replicas to an encrypted storage.

Ganz CORTROL Global Administration Guide

When the storage password is changed, the new password is used for encryption from then on. If storage encryption is disabled for some time and then enabled back, that part of the archive will remain unencrypted.

Adding an Encrypted Disk

If you wish to use a storage, which contains encrypted archive, as a new storage unit and add it to the server configuration, you will be prompted for the password. You need to provide the **password** that was used to encrypt that disk. If you have provided a password hint earlier, it will appear as a **tooltip** when hovering your mouse over the password field.

 Do not modify the contents of encrypted disks manually, this may result in the corruption of the whole archive.

Archive Backups

The [archive backup tool](#) also provides an option to specify a password to encrypt the backup.

Archive backup wizard

Step 3 of 4. Select tracks and backup destination

Select tracks selection and specify target location

Tracks

☒

TITLE

SERVER

SIZE

INFORMATION

☒

Store

26.91 GB

Estimated size: 26.91 GB

☒ Encrypt backup archive

☐ Include portable player (209.02 MB)

Location

Browse...

Previous

Next

Cancel


Password protection for the archive backup

There is no difference if the backup is made from an encrypted or an unencrypted storage; the password provided at this step will be used in future for archive access, whether you read the disk contents using the Portable Player tool or add the disk as a new storage to some Ganz CORTROL server.

Encrypted Archive Access

When accessing an encrypted storage via Ganz CORTROL Client and Ganz CORTROL Mobile, the archive is decrypted automatically and provided for browsing according to the user permissions.

Should you want to access a directory that contains proprietary Ganz CORTROL archive or its part (backup) using Ganz CORTROL Portable Player tool, you will be prompted for the password.




Encrypted archive access in the Portable Player tool.

If you have specified a hint at the point of setting the password, it will be displayed as text or as a hint when hovering your mouse over the password field.

6.5 Two-Factor Authentication

Ganz CONTROL servers support two-factor authentication (2FA) for the Ganz CONTROL Console and Ganz CONTROL Client logins. It is disabled by default, and you can turn it ON via [server policies](#). When 2FA is enabled, all users who want to connect to your Ganz CONTROL server and who are not an exception, will have to enter both their password and a code they receive. Thus, the users prove their identity not just by entering what they know (the password) but also what they have (the email or phone). By default, this policy affects all users; you can disable 2FA for individual users in their permissions.

 At this point, Ganz CONTROL 2FA supports code sending via **email** and **SMS**, and works for Ganz CONTROL Console and Ganz CONTROL Client login.

Terminology:

- **session**: an established connection between client and server once the user logs in
- **code**: a numeric code sent to the user's email
- **notification provider**: an SMTP server or a GSM modem that will relay the notification


The **recommended** course of action is: first, create a notification provider, then fill in all the settings, save, and then enable and test 2FA.


2FA Settings

2FA is configured via server settings: in the *Configuration* section, choose *Servers* on the left, then double-click your server to open its properties. In case of a Ganz CONTROL Global system, make sure to open the central management server properties.

The following settings are available here:

Setting	Description	Default Value
Enable two-factor authentication	If selected, additional authentication will be required for server login	Disabled
Set up notification providers	Set up desired providers (using email servers or other means) that will be used for sending out authentication codes	[button]
Session expiration time	During this time period, 2FA will not be requested again if a client was disconnected by server; after this time or after user-initiated disconnect, the user will have to use additional authentication again	1 day
Code expiration time	The time period during which the sent code will be valid, starting from the code sendout moment; after this time, the user will have to request another code	00:05:00 (5 minutes)
Code generation interval	The minimum time interval between two consequent code requests; the user will be unable to request a code more frequently	00:00:10 (10 seconds)
Skip for localhost connection	If enabled, 2FA will not be applied to localhost connection	Enabled
Subject	Message subject line, can consist of text and macros (via right-click)	{SESSION_ID}
Body	Main message part, can consist of text and macros (via right-click)	{CODE}

 Name your **notification providers** according to the used verification source (e.g., **Email**) so that the users understand where to look for the code.

 In the verification message, write some text in addition to the session ID and the code so that:

- The user understands which one is which

Ganz CONTROL Global Administration Guide

- The email does not go to Spam

When you try enabling 2FA, you will get a **warning** that you need to test 2FA before saving the configuration. This is necessary to ensure that all the settings are correct and 2FA actually works; otherwise, you or other user(s) may be unable to log into the system at some point. The 2FA verification will start once you click *OK* to save the settings and close the window.

Settings to be verified before enabling 2FA:

- make sure you have added a valid 2FA notification provider ([SMTP server](#) or [modem](#))
- add a contact email/phone number for each user
- we recommend that you allow at least one administrative user account to log in without 2FA, or that you disable 2FA for localhost connections: this is to ensure that you do not lose access to the system if your 2FA notification provider fails or becomes unavailable

You can configure 2FA without enabling it, verify these settings, and then finally enable 2FA.

Two-factor authentication settings

The best approach for 2FA configuration:

1. In 2FA settings, add a notification provider and adjust everything but do not enable 2FA yet, click *OK* to save.
2. Make sure your email server or GSM modem used as a notification provider is valid, and that all users have correct emails/phone numbers in their account properties.
3. Go to 2FA settings again and enable it, then go through the verification.

When you **turn off** 2FA, you will have to go through the setting verification again next time you enable it. If you make changes to the 2FA settings and enable it at once, this test verification will use the previous settings for formatting and intervals (because it happens before saving the settings, and these will not be saved until you pass 2FA successfully).

Two-factor authentication is a recommended setting when you choose the highest [cybersecurity](#) level - the system will check if 2FA is enabled and remind you with a warning mark if it is not.

Set Up Notification Providers

You can set up one of multiple notification providers of each kind to give your users an alternative in case one of the providers does not work or is unacceptable for some reason.

To add a new notification provider, click the corresponding button in the 2FA settings. In the dialog box, you will see the list of existing providers (none exist by default). Click the + *New..* button in the bottom or use the drop-down arrow to see all options.


For each provider, specify:

- **Title:** name that will be shown to the user (so make sure to include the communication means, e.g., Email

Ganz CONTROL Global Administration Guide

via Office 365)


- **Mail server:** for e-mail notification providers, choose one of the pre-configured SMTP servers
- **GSM modem:** for messages, choose one of the pre-configured modems



Add new or edit existing notification provider

If you have no pre-configured means of notification delivery, add them, and then return to this screen.

Click **OK** to save the provider, then click **OK** to go back to 2FA settings. All created providers will be shown to the user when they try logging in.

 **Tip:** if some of your notification providers do not work temporarily, add a corresponding note to the provider name. Thus, you will not have to remove it from the configuration but the users will know that they cannot use it for 2FA.

To edit an existing provider, use the pencil button on the top panel; to remove any of the items, select it and then click the *Recycle bin* button. Removed providers will be erased from the list, but the related email servers & modems will be preserved.

Ganz CORTROL Global Administration Guide


6.6 Third Party Authentication Providers

Ganz CORTROL servers can use external authorization frameworks, such as OAuth, to facilitate user login, allowing your engineers and operators to use their existing accounts to log into Ganz CORTROL servers.

Currently supported authentication means:

- Google account
- Apple ID
- Microsoft account
- Okta
- custom (generic)

You can use public OAuth providers or, if your organization requires so, set up a local custom OAuth service.

 For public OAuth services to work: please reconfigure your system firewall(s) to allow browsers to connect to connect.vmsregistrationportal.com:5001 (allow HTTPS traffic to that port).

To set up user login with external authorization, follow these steps:


1. Add authentication provider(s) of your choice
2. Add user account
3. Activate the user account
4. Log in routinely
5. Repeat steps 2-4 for other users

Below, you will find a detailed description of each step.

Add a New Authentication Provider

In Ganz CORTROL Console, go to *Configuration > Servers* > double-click your server (Ganz CORTROL Global server if you are using Ganz CORTROL Global system) > choose the *Authentication providers* tab. Click the *Set up authentication providers* button to open the existing provider list.

Choose your desired authentication service from the drop-down list in the bottom part of the window: for example, *New OAuth provider (Google)* if you wish to use Google accounts.



External authentication provider setup in the server settings

For each authentication provider, different settings are available. For Google, Microsoft, and Apple accounts, the settings are as follows:

Setting	Description	Default Value
Title	User-defined provider name that will be shown	Google

Ganz CORTROL Global Administration Guide

Enable	Enable or disable current authentication provider (use this option to temporarily disable the provider if you do not to remove it)	Enabled
Provider type	[Automatic field]	[Automatic field]
Token expiration time	Time interval, during which the user will not have to enter their password again (session length)	7 days (7d 00:00:00)

The token expiration time defines how frequently the users will have to log in again. You may want to set the session expiration time equal to the operators' shift.



For Okta and other (generic) authentication types you must provide additional settings and fill in all the suggested fields. You can retrieve these from the administrator who configured the authentication server.

Click **OK** to *Save* the newly created provider, then **OK** again to close the server settings dialog box.

OAuth 2.0 authentication provider GOOGLE ACCOUNT*

OAuth 2.0 authentication provider

Details

Details*

Title

GOOGLE ACCOUNT

Authentication provider title

☒ Enable

Enable or disable the authentication provider

Provider type

Google

Provider type

Token expiration time

05d 00:00:00

The amount of time during which the authentication token will be valid

Apply OK Cancel

Enter settings for the Google authentication provider

Add Users

In Ganz CORTROL Console, go to the *Configuration* section and choose *Users* on the left. Click the drop-down arrow next to the *New user* button and choose *New OAuth 2.0 user*. It is a special user type for external authorization, which is first created in Ganz CORTROL Console and then activated after the user logs in for the first time, thus binding the internal user to the external authentication means.

Ganz CORTROL Global Administration Guide

The screenshot displays the 'Users' configuration page in the Ganz CORTROL Global Administration interface. The header shows 'Configuration > Users' and a search bar. The left sidebar lists various configuration categories, with 'Users' selected. The main content area shows the 'Details' for a user named 'User we*****@gmail.com'. The 'User login name' field is filled with 'we*****@gmail.com'. The 'Active' checkbox is checked. The 'User type' is set to 'OAuth 2.0'. At the bottom right, there are buttons for 'Apply', 'OK', and 'Cancel'.

Create a new user of the special type

Checklist:

1. In the login field, enter the target user's **full login**, which they would normally enter into Google to log in. If the domain name is different from gmail, make sure to specify the full email address.
2. Grant the user the necessary **permissions**.
3. Save the settings, then copy the security **token** and send it to the user - they will need it when they log in for the first time.

After the user logs in, the account entry in Ganz CORTROL will become bound to the external authentication provider, and the security token here will be replaced with security ID. The user's name and full email address will be filled in automatically.

The rest of the settings are similar to the regular user settings.

Login


Users can now log into Ganz CORTROL servers using OAuth via both Ganz CORTROL Console and Ganz CORTROL Client. In either case, it is necessary to choose OAuth as login method.

When logging in for the very **first time**, they will have to enter the user token from Ganz CORTROL Console to bind the accounts. Provide them with the token to ensure they can use the OAuth login method.

Ganz CONTROL Global Administration Guide

6.7 Networks

Networks (connections) is an auxiliary feature for surveillance systems with multiple different networks in use. It gives you the opportunity to define a sort of a proper connection table for the central server, allowing the system to combine remote and adjacent LANs and making the *client* ↔ *server* and *recording* ↔ *central server* connectivity transparent for the users. In simple words, it is a way to teach the Ganz CONTROL Global server about the used networks, so that it knows from where to expect the incoming connections. Network connections allow you to combine servers from different network environments into a single Ganz CONTROL Global system.




Example of a system with multiple networks


Ganz CORTROL Global Administration Guide

For instance: a system contains several LANs, physically detached from each other and connected to the central server via the Internet; remote and mobile clients are connected both directly via the Internet and also from different LANs with Internet access. Thanks to the connections' table, Ganz CORTROL Client administrators do not have to worry about remembering and entering the correct network configuration every time, as the interconnection routines will be carried out by the central server. From the Ganz CORTROL Client point of view, the administrator simply enters the Ganz CORTROL Global server address, and the rest servers are automatically connected in background (including failover servers).


It is important to understand that Ganz CORTROL network connections require a proper underlying infrastructure. All LANs, firewalls, port forwarding rules, VPNs and/or any other involved configurations must be set up beforehand.

 Proper TCP/IP configuration, firewall and port forwarding must be set up in each LAN segment to ensure unobstructed access from the central management server and remote clients' locations.

 When you change the central server's IP address (move to different hardware or environment), do not forget to change it in the server configuration via Ganz CORTROL Console.

 Networks for the recording servers are assigned from Ganz CORTROL Console management interface as well. In order to discover recording servers from networks, which are different from the central server's network, corresponding connections must be pre-defined in order to 'teach' the central server about possible locations.

To access the network configuration dialog box, select *Configuration* in the sections' panel and choose *Networks* from the menu on the left.



VMS Management Console 2015 - localhost

Configuration > Networks

Configuration

- Organizations
- Networks**
- Servers
- Failover clusters
- Users
- Devices
- Channels
- Configuration
- Events & Actions
- Monitoring

+ Create network Edit 1 selected

TITLE	ID	LOCAL MASK	PUBLIC IP
Camera LAN	(106)	10.10.10.1/24	168.212.226.204
Central Server network	(102)	145.94.218.158/22	
first floor	(140)	192.168.4.1/26	
offices	(115)	192.168.9.2/24	98.54.34.2

Recently added, 1 Recently updated, 1

ASUS WebStorage
1 file(s) have been synchronized

Networks configuration component

Click the + *New network* button on the upper panel to bring up the dialog box.

Ganz CORTROL Global Administration Guide

Network

Details

Details

Title

Network name

Local mask

Local mask in format [IP/MASK], exampe 192.168.1.1/24

Public IP address

Public IP address

OK

Cancel

Create a new connection

The table below describes the configuration parameters.

Setting	Description	Default value
Title	User-defined connection name, e.g. <i>Remote Client HQ Office</i>	[empty]
Local mask	LAN subnet defined in the IP/MASK format, e.g. 192.168.1.1/24	[empty]
Public IP address	Internet IP address as a gateway to/from the subnet; this field is optional, and if the network is only locally accessible, it should be left empty. If the target network is routed in relation to the central server, enter the gateway address here.	[empty]

Local mask: lets you define the subnet size. This field accepts the network mask in the CIDR notation, i.e., in the [IP/MASK BITS] format. The IP address can be any IP from that subnet. It may be the first one in the subnet, or correspond to the Ganz CORTROL Global server address. The mask (subnet size) is defined as /x (slash X) format (see the cheat sheet below). Thus, entries 192.168.1.1/24 and 192.168.1.83/24 designate the same LAN. Entries 192.168.1.1/26 and 192.168.1.83/26 designate different, non-overlapping subnets. If not sure about the subnet sizes, use any IP subnet calculator widely available online.

If you have multiple LANs in the same physical environment, it may be a good idea to make them adjacent. In that case, you can simply create a single network of a larger size in Ganz CORTROL Console.

Example:

- real server LANs: 192.168.0.1/24, 192.168.1.1/24, 192.168.2.1/24
- Ganz CORTROL Console network configuration: 192.168.0.1/22

Ganz CORTROL Global Administration Guide

CIDR	MASK	IP RANGE EXAMPLE
\30	255.255.255.252	192.168.0.1 - 192.168.0.2
\29	255.255.255.248	192.168.0.1 - 192.168.0.6
\28	255.255.255.240	192.168.0.1 - 192.168.0.14
\27	255.255.255.224	192.168.0.1 - 192.168.0.30
\26	255.255.255.192	192.168.0.1 - 192.168.0.62
\25	255.255.255.128	192.168.0.1 - 192.168.0.126
\24	255.255.255.0	192.168.0.1 - 192.168.0.254
\23	255.255.254.0	191.168.0.1 - 191.168.1.254
\22	255.255.252.0	191.168.0.1 - 191.168.3.254

Public IP address: this is not necessarily an Internet address. Enter your LAN **gateway** here if your central server is in a different network. If the target network is remote, enter the remote gateway here.

Example: a network configuration includes subnets 192.168.1.1/24 and 192.168.45.1/24, with corresponding gateways set up as 192.168.1.254 and 192.168.45.254, routed via a router. Ganz CORTROL Global server is in the first subnet and Ganz CORTROL Recorder machines are in the second subnet. In order for this to work:

1) Make sure your router configuration is correct, and then


2) Set Ganz CORTROL network settings as follows:

a. Central server address - 192.168.1.x

b. Central server network mask 192.168.1.1/24, public IP address 192.168.1.254

c. Add another network with network mask 192.168.45.1/24 and public address 192.168.45.254


Having done that, you should be able to run Ganz CORTROL Recorder autodiscovery.

 Ganz CORTROL settings do not alter your network configuration. We understand that every network in every system has a different configuration, therefore, the software provides you with a possibility to "teach" the Ganz CORTROL about the network configuration. If your network does not provide correct routing, please contact your network administrator.

After you have entered all settings, click *OK* to close the dialog box. The newly created connection will appear in the item list.

Use the buttons on the upper panel to edit and remove existing connections; double-clicking an item will also bring up the dialog box for editing. If you make changes to your server network environment, make sure to go back here and update the network settings.

The filter panel at the bottom enables you to view recently added/updated items, as well as other relevant filters. The filter that is currently active is highlighted blue: click the *N filtered* button to reset all filters and display all the available items again.


9 filtered 

Ganz CORTROL Global Administration Guide

6.8 Server Groups


For even more convenient management, servers can be separated in a logical way based on their type, location, importance or a number of other characteristics; also, grouping is helpful when it comes to dividing administrators' responsibilities. Groups can be hierarchically nested, i.e. contain other groups, and one server can belong to multiple groups at once.

Select *Configuration* in the sections' panel and then click *Servers* in the menu on the left. To add a new group, click the little arrow next to the + *New server* button and select *New server group*. The corresponding dialog box will appear, allowing you to enter group configuration.



Select *Create server group* from the drop-down menu

On the *Details* tab, enter a name for the target group of servers.



Enter a name for the server group

On the *Members* tab, select which servers and/or server groups you want to be a part of the target server group. You can also leave the group empty at this stage and create them later.

Ganz CORTROL Global Administration Guide

Server group HQ Servers*

Server group

Details

Members

Membership

Permissions

Members

Selected members

TITLE	ID	TYPE
Recording Server I	(136)	Server

Remove

Available members

TITLE	ID	TYPE
Central Server	(101)	Server
Recording Server II	(137)	Server

Add

OK

Cancel

Select the existing servers and/or server groups you want to become a part of the target group

Use double-click or *Add* and *Remove* buttons below to move servers or server groups between the columns.

Switch to *Membership* in order to assign this server group to a different, higher level group. Items are handled in exactly the same way: by using buttons below or simply double-clicking.

Server group HQ Servers

Server group

Details

Members

Membership

Permissions

Membership

Selected groups

TITLE	ID	TYPE
-------	----	------

Remove

Available groups

TITLE	ID	TYPE
NY Servers	(138)	Server group

Add

OK

Cancel

Select which existing group you want the server to become a member of

In the *Permissions* section, you can grant user privileges for the target server group. Permissions will be applied to all servers in the target group. If no user is selected, only the global administrator will be able to administer the servers in this group.

Select a user and grant at least one permission by checking the corresponding row in the *Permissions* column; the user will then automatically appear in the *Selected users* column on the left. To remove a user, clear all his permissions either by manually unchecking them or by using the *Clear* button below; alternatively, just double-click the user name in the list to remove him/her from the list of privileged users.

Ganz CORTROL Global Administration Guide

The screenshot shows a dialog box titled 'Server group HQ Servers'. On the left is a sidebar with icons for 'Details', 'Members', 'Membership', and 'Permissions' (which is selected). The main area is titled 'Permissions' and contains a search bar. Below the search bar are two tables: 'Selected users' and 'Available users'. The 'Selected users' table has columns 'TITLE', 'ID', and 'TYPE'. It contains one entry: John Doe (107) User. The 'Available users' table has columns 'TITLE', 'ID', and 'TYPE'. It contains one entry: Jane Doe (139) User. Between the tables is a 'PERMISSIONS' section with checkboxes for 'Administer' (checked) and 'AccessArchive' (unchecked). A 'Clear' button is at the bottom of the permissions section. At the bottom of the dialog are 'OK' and 'Cancel' buttons.

Selected users			Available users		
TITLE	ID	TYPE	TITLE	ID	TYPE
John Doe	(107)	User	Jane Doe	(139)	User

PERMISSIONS

- ☒ Administer
- ☐ AccessArchive

Clear

OK Cancel

Grant user privileges in the *Permissions* tab

Once you have finished, click *OK* to close the dialog box. The newly created server group will appear in the item list. Notice how the group icon in the item list differs from the single server icon.

The screenshot shows the 'VMS Management Console 2015 - localhost' interface. The top navigation bar shows 'Configuration > Servers'. On the left is a sidebar with icons for 'Organizations', 'Networks', 'Servers' (selected), 'Failover clusters', 'Users', 'Devices', 'Channels', 'Configuration', 'Events & Actions', and 'Monitoring'. The main area has a top bar with 'Create server', 'Edit', 'Assign group', and '1 selected' buttons. Below this is a table with columns 'TITLE', 'ID', and 'FAILOVER CLUSTER'. It contains two entries: 'Central Server' (101) and 'HQ Servers' (134). The 'HQ Servers' entry is highlighted. At the bottom are buttons for 'Recently added, 1', 'Recently updated, 0', 'Groups, 1', and 'Servers, 1'.

TITLE	ID	FAILOVER CLUSTER
Central Server	(101)	
HQ Servers	(134)	

Recently added, 1 Recently updated, 0 Groups, 1 Servers, 1


Newly added group will appear in the item list

The buttons on the upper panel will offer the following possibilities:

- *Edit*: go back to the dialog box to change selected group settings
- *Assign group*: select server group from the list and make target group a member of it
- *Delete*: remove selected group(s)
- *X*: deselect all

Double-clicking any group in the item list will open the group in the same window (notice the path on the navigation panel), allowing you to create servers directly from inside the group.

Ganz CORTROL Global Administration Guide



Create or find new servers directly inside the group

6.9 Central Server Mirroring

Central Server Mirroring (**CSM**) feature is designed to allow to carry on major system operations while the central server (**CS**) is out of order. CSM is based on the Ganz CORTROL Recorder installation, has limited functionality and does not require additional licensing. Therefore, CSM does not require same level hardware as Ganz CORTROL Recorder and even can run in a virtual environment.

In each system, there can be one CSM server, just as there is only one Ganz CORTROL Global server for the central management. CSM duplicates the contents of the central management server onto another server hardware, allowing clients' access to the contents of recording servers and Ganz CORTROL Global features. CSM operates constantly and is standing by, ready to provide immediate communication with client applications as an emergency host while CS is undergoing maintenance. Client applications keep record of CS and its CSM automatically to provide continuous and fully transparent system operation for CS out of order situations. This means continuous system operation is maintained for system operators while CS is inaccessible and client applications are forwarded back to CS automatically after it is brought back online.

The system administrator must restore CS server operation as soon as possible since CSM is designed as a temporary solution for CS out of order situation and limits some of the features as listed below.



Mirroring server provides the following **functionality**:

- all connected Ganz CORTROL Client applications are automatically forwarded to and back from the mirror server, provided that they are not deliberately disconnected
- all channels from all recording servers can be viewed
- it is possible to log into the CSM via Ganz CORTROL Console to view monitoring and audit information
- video wall state is constantly pushed to CMS

CSM has major operation **limitations by design**:

- CSM does not cover neither device configuration assigned to the Ganz CORTROL Global, nor central server's E&A configuration
- it is impossible to make any changes to the CS configuration via CSM (apart from video wall, see details below)
- failover clusters do not operate under CSM
- bookmarks are not available under CSM (as they are only stored on the CS)

This topic describes CSM setup and configuration.

Mirror Installation

First, install a Ganz CORTROL Recorder (as you would [normally do](#) for a recording server) on the machine you plan to use as a backup server for the central management server. After installation, [initialize](#) it but do **not** run server autodiscovery from the central server.



If you want to use an existing recording server as a mirroring server, do the following:

- make sure you have transferred all device configuration from this recording server to a different one
- remove event and action configuration from this server
- remove the target recording server from the server list (if it still has any items attached to it, you will get a warning and an option to remove all related items)
- go to the Ganz CORTROL Recorder machine, run the *Server Setup Wizard* tool, select *Reset configuration* and finish the wizard
- proceed with the steps described further in this topic

To turn a mirroring server back to a normal recording server, simply do the steps 3-4 described above and add the recording server as usual using either manual or autodiscovery procedure.

Add a Mirror

Ganz CONTROL Global Administration Guide

Next, it is necessary to add the newly installed Ganz CONTROL Recorder **manually** into the central server configuration. Log into your Ganz CONTROL Global server via Ganz CONTROL Console, choose the *Configuration* section and go to the *Servers* category in the menu on the left. On the top panel, click the little arrow next to the + *New server* button and select *New mirroring server*. The corresponding dialog box will appear, allowing you to enter server configuration manually.

Server MirrorMirrorOnTheWall*

Server

Details

Title

MirrorMirrorOnTheWall

Server name

Roles

☒ Mirroring

The server takes mirroring role. Only one server can have mirroring role assigned.

OK Cancel

Create a mirroring server

All settings for this type of server are the same as for a regular [recording server](#), except for:

- server role is defined as *Mirroring server* and it cannot be changed
- server cannot accept any active configuration (like a failover node)

Enter and save your settings, then go to the *Monitoring* section and make sure your mirroring server has been successfully discovered and synchronized.

Monitoring > Servers

admin

Search

Monitoring

Servers

Devices

Channels

Configuration

Events & Actions

	TITLE	STATUS	CONNECTION	SYNCHRONIZATION	CONFIGURATION	STATUS UPDATE TIME	VERSION	FAILOVER CLUSTER	FAILOVER STATUS
	Global Server	Normal	Connected	Synchronized	Applied	1/10/2017 12:58:47 PM	1.3.0.15947		Not in cluster
	MirrorMirrorOnTheWall	Normal	Connected	Synchronized	Applied	1/10/2017 12:58:35 PM	1.3.0.15947		Not in cluster

Recently added, 0

Recently updated, 0

Critical, 0

Not connected, 0

Not synchronized, 0

Monitor the status of the newly added server

Now, if your Ganz CONTROL Global central server fails, the mirroring server will be available for you to log into and view live statistics and aggregated audit information from all recording servers.

Mirror Functionality

CSM operation mode is best described by the word "mirror" itself. It does not offer configuration modifications; rather, it reflects the last good known CS state and provides enterprise features for all connected Ganz CONTROL Recorder computers and clients:

- all connected Ganz CONTROL Client applications re-connect to/from CSM automatically (but not Ganz CONTROL Mobile)
- you see all live channels from Ganz CONTROL Recorder machines and will be able to play them back, as usually
- you have your maps and geo maps, shared layouts, mail servers (with E&A and reports), data sources on Ganz CONTROL Recorder
- live podcasts from Ganz CONTROL Recorder machines will not be interrupted

Ganz CONTROL Global Administration Guide

- Folders and user permissions work as usual
- replication from/to Ganz CONTROL Recorder computers works, too
- user buttons, global events and other events (E&A) still work on all Ganz CONTROL Recorder machines (and not on CS)
- it is possible to log into the CSM via Ganz CONTROL Console to view monitoring and audit information - directly and anytime
- CSM always has the latest video wall configuration received from CS
- you will be able to change CSM's video wall configuration via Ganz CONTROL Client application (video wall management tab)

It is possible to change the video wall state via CSM. If, during these changes, CS is down, it will retrieve the CSM's video wall configuration after CS comes back online (sync back). However, if any changes are made to the CSM's video wall configuration while CS is up, these changes will not be pushed back. Instead, any new changes to the video wall on CS will be immediately pushed to CSM. In other words, CS video wall configuration is primary, and it only accepts video wall updates from CSM upon startup.

Exceptions - what will **not** operate under CSM:


- no alterations can be made to the configuration via Ganz CONTROL Console
- any channels assigned to CS
- any events and action (E&A) rules assigned to CS
- all external services, Web clients, and Ganz CONTROL Mobile clients (you can connect directly to CSM from Web clients and Ganz CONTROL Mobile)
- failover clustering

Remember that CSM is designed to serve as a temporary solution for periods when CS is not available due to hardware or network failures. CSM does not take over CS recording configuration and E&A, so we recommend that you keep your channels and their associated rules on the dedicated Ganz CONTROL Recorder machines: these are not limited in number by your Ganz CONTROL Global license.

6.10 Purpose and Operation Description of Failover Clusters


The failover feature enables automated recovery of your system in the event of a sudden recording server failure. Ganz CORTROL carefully tracks all server operations, and, if it detects that any of the recording servers have failed, it quickly activates a spare server to perform the actions that the malfunctioning server had been performing prior to failing. CBC AMERICA LLC offers native failover clustering mechanism for Ganz CORTROL Global recording servers: you do not need to maintain the backup server manually or use Microsoft failover clustering. Easy setup and centralized tracking is available via Ganz CORTROL Console for administrator's convenience.

Failover clusters are groups of servers (failover nodes) working together to provide a higher service availability rate, thus increasing system fault tolerance and overall stability. When one recording server (node) fails, another one takes its place, guaranteeing service availability to the end user and minimizing service downtime.

 Note that failover clusters have been designed specifically for recording servers; the central server is not subject to failover using this mechanism.

Each failover cluster consists of at least one failover node and at least one actual recording server - there is no limit on the number of either. Depending on the scenario, server importance and estimated system stability, cluster contents may be different: 1 failover node for N servers, M failover nodes for N servers, M failover nodes for 1 server. Each server (whether recording or failover) can only belong to a single failover cluster at a time; there is no limit imposed on the number of failover clusters.

- If a recording server is down for more than the specified amount of time, the failover node **automatically** assumes its responsibilities
- When the recording server is back online, system administrator should **manually** turn off acting failover node to enable the main recording server
- There is an option to enable **automatic recovery** of the recording servers
- Failover node **status** is available in the monitoring section of Ganz CORTROL Console and in the *View servers* mode via the *Failover* section


 Starting from Ganz CORTROL version 1.7.0, there exists an option of **automatic recording server recovery**. Up to 1.7.0, the returning a recording server back to operation should be done manually. Default failover mode is manual recovery.

The central server controls the failover start conditions. Recording servers communicate with the central server by sending 'heartbeat' signals: if no heartbeat is received for longer than the period of time specified, then a timeout is reached and the central server triggers failover operation. Each recording server can have individual settings for timeouts. Once a Ganz CORTROL Recorder reaches the failover timeout, the central management server assigns its configuration to the first available failover node.

The following **functionality is supported** and guaranteed **during failover operation**:

- live channels
- video (main and secondary stream), audio and motion recording, archive access
- server-side VCA (additional VCA license must be applied to the failover server)
- Event & Action rules
- Ganz CORTROL License Plate Recognition, when it is set up to use one of the channels from the failed Ganz CORTROL Recorder (LPR must be connected to Ganz CORTROL Global and NOT to Ganz CORTROL Recorder for this to work!)

Recorded archive and counters will stay on the failover server after the main recording server comes back online: they will not be transferred or copied anywhere. While the Ganz CORTROL Recorder is offline, it will not be possible to retrieve its video archive and counters' database. However, once both servers are reachable, all data will become available for investigation in the Ganz CORTROL Client application, and the hardware layer will be transparent for the user.

 Failover server must be located in the same environment as main recording server(s) in order to be able to access all cameras from the failing server configuration.

It is best that the failover server hardware is as powerful as the most powerful Ganz CORTROL Recorder in the cluster: otherwise, if the most powerful Ganz CORTROL Recorder goes down, the failover node might not have enough resources and will have issues carrying out operation with the assigned configuration.

Ganz CONTROL Global Administration Guide

Failover servers themselves cannot accept any device configuration: as a single failover server may take over operation of one of N different servers, its device configuration remains empty until the precise moment of a recording server failure. Storage configuration is not transmitted to the failover node, the failover server records the data to whichever storage is configured on it so there is no need to match the failover node storage configuration to any of the recording servers.



Streams recorded on a failover server during its operation are kept on the failover server storage and are not transferred to the recording server storage.

If recording servers in a failover cluster have different [storages](#), it is not necessary to set up the same storage labels on the failover nodes: instead, it is sufficient to have a *Default* storage and all recordings will be saved there.

When a server belonging to a cluster fails, its operation is carried on automatically by the first idle failover node. The central server transmits the failing server configuration to the failover node and the failover server then begins operation in place of the failing server. Recording server recovery can be performed by the administrator or automatically, if the corresponding setting is enabled; until then, failover node will continue performing its primary function. The administrator can also manually assign a specific failover node to operate instead of any recording server.


6.11 Configure Failover Clusters

In order to create a functioning failover cluster, you need to:

- have a set of [pre-created servers](#) to act as main recording servers and failover nodes for those
- create a cluster itself as described below
- add recording and failover servers to the cluster (at least one of each type)


Create a Cluster

You can access the configuration dialog box by first selecting the *Configuration* section and then choosing *Failover clusters* in the menu on the left.



Locate *Failover clusters* in Ganz CONTROL Console

Click the + *Create failover cluster* button on the upper panel to open the cluster editing dialog box. Enter a name for the target cluster and click *OK* to save and close the dialog box. The failover cluster thus created will appear in the item list.



Create new failover cluster

Click the *Edit* button on the upper panel or double-click an item in the list to change the cluster title; use the *Delete* button with the recycle bin icon to remove items from the list. To select multiple items, use CTRL or Shift buttons on the keyboard.

Ganz CONTROL Global Administration Guide

Manage the Cluster

Click the *View servers* button on the upper panel to switch to the *Servers* view. The path in the navigation bar will indicate that you are now inside a cluster; as a result, all the changes made to the servers here will concern the target cluster only.

For a newly created cluster, the server list will be empty. Use the *Add server* button on the upper panel to add existing servers to this failover group.

Select server

Available resources

TITLE	ID	TYPE
Recording Server IV	(128)	Server
Recording Server V	(129)	Server
Failover Server III	(130)	Server
HQ Server I	(132)	Server
HQ Server II	(133)	Server


OK

Cancel

Choose from the existing servers and add them to the failover cluster


In the item list, servers currently running on their own will have empty field in the *Failover Server* column; servers currently being down and replaced by acting failover nodes will have failover server name in the same column.

Ganz CONTROL Global Administration Guide



Recording Server I is currently backed up by Failover Server II

The failover node is picked automatically; click the *Change failover server* button on the upper panel to engage another failover node in place of the one currently operating. To **attempt to resume the operation of the main recording server**, select *none*.



Select a different failover server manually or select *none* to disable failover operation for current server

Upper panel controls offers the following management options:


- *Add Server*: open the list of all available servers and select some to become part of the target cluster
- *Remove Server*: remove server from the cluster; this button will NOT delete the server itself from system configuration
- *X*: deselect items


Ganz CORTROL Global Administration Guide


Server Settings for Failover Clusters

Each server belonging to a cluster has a number of settings related to failover. These are: server role (recording/failover), assigned failover cluster, connection timeouts.

Double-click any server to bring up the server configuration dialog box. First, **enable or disable failover node mode** for any server via the *Details* tab and then the *Roles* section: servers marked as failover nodes will not accept any device configuration.

 You cannot make a server act as a failover node if it has an active device configuration currently assigned to it. Remove all device configurations from the server to make the server available for failover role.

 In the same section, you have an option to apply a VCA license to the target server, either recording or failover. You need to apply a separate VCA license to each failover node in a cluster in case you want these servers to take over VCA configuration of a failed recording server as well. (Detailed information about VCA licensing and settings can be found in the VCA documentation).




Choose the server to act as main recording station or a failover node

Switch to the *Failover* tab to change **failover cluster attachment** and **timeout values** for the target server:

- **Failover cluster**: a failover cluster for the target server to belong to
- **Current failover server***: (automatic value) shows, which failover node is currently acting instead of the target recording server
- **Failover timeout***: the time for the target recording server to be unavailable (offline or down) for it to be automatically replaced by a failover node
- **Central server connection timeout**: the time for the target server to wait for the central server connection upon startup; after the timeout, the server will start with the last received configuration and will continue attempting to reach the central server
- **Auto recovery***: if enabled, the failed recording server will automatically resume operation after coming back online, thus replacing the failover node
- **Recovery timeout***: if auto recovery is enabled, this value defines the time in seconds to wait before the recording server automatically resumes its normal operation

*Settings marked with an * (asterisk) above only refer to regular recording servers without the failover node role.

 Starting from Ganz CORTROL version 1.7.0, there exists an option of **automatic recording server recovery but it is disabled by default**. Up to version 1.7.0, the returning a recording server back to operation can be only done **manually**, via failover cluster management as described above.

Ganz CORTROL Global Administration Guide

Server Recording Server I*

Server

Details

Membership

Permissions

Connections

Failover

Watchdog

Storage

Failover

Failover cluster

FC1

Change...

The server is a member of the specified failover cluster.

Current failover server

none

When specified, the server's tasks are running on the specified failover server.

Failover timeout

600

Time interval in seconds before the server will be considered as non operational and its tasks will be picked up by a failover server.

Central server connection timeout

300

Time interval in seconds to wait for central server connection on the server startup. When the interval expires the server will be started up even when the central server is unavailable.

☒ Auto recovery

Auto recovery

Recovery timeout

600

Time interval in seconds to wait before taking tasks back from failover server on the server startup. 0 - no timeout.

OK

Cancel

Failover settings of a specific server

Once you have put at least one recording server and one failover node into the same failover cluster, the Ganz CORTROL failover mechanism will ensure that, if the recording server fails to respond for the specified time, its configuration will be assigned to the failover server. If there is more than one failover node in a cluster, a faulty failover server will be consequently replaced by the next idle failover node.

7 Devices and Channels

The traditional idea of cameras as surveillance software entities has been developed, resulting in the concept of **devices and channels**. Essentially, it represents the separation of physical and data layers for reasons of security and easier management.

"Device" refers to any piece of physical equipment that serves as a data provider; a hardware piece delivering video, audio and event streams to the server. IP cameras, video encoders, capture boards, USB web cameras - these are all examples of devices that can be added to CBC AMERICA LLC software. Devices do not include any data streams.

"Channel" refers to any actual video stream (with corresponding audio/event stream, if applicable) delivered to the server from any of the configured devices. Software [licensing mechanism](#) counts channels and not devices.

In Ganz CORTROL Console, devices hold camera TCP/IP and user settings, as well as actual hardware model. By contrast, channels do not possess these properties: this allows them to be handled as virtual entities, detaching and re-attaching them from/to devices. Channels feature video stream configuration settings - resolution, frame rate, bit rate and others - as well as all supplementary data streams, such as audio, motion and digital input/output events, PTZ control and camera-side analytics information. Thus, the underlying device may be removed or replaced without losing its channel's configuration, which also includes user permissions.

As there are also some multichannel devices, e.g., capture boards and video encoders, each device can have one or more channels attached to it - these can either be assigned or detected automatically; maximum number of channels for each specific device is stipulated by the device model.


Devices only appear within Ganz CORTROL Console, allowing the administrator to apply all necessary configurations. Ganz CORTROL Client only displays the channels and does not provide any access to the devices' properties to the end users.

Both devices and channels can be grouped independently. For internal Ganz CORTROL Console management, device groups and channel groups are available; for Ganz CORTROL Client channel grouping, [visual groups](#) are to be used.

7.1 Add Devices Using Autodiscovery

Use automatic device discovery feature to find all available devices. This method is of great help when dealing with large amounts of cameras, and also when exact addresses of devices are not available.

To access the configuration dialog box from Ganz CORTROL Console, open *Configuration* section and select *Devices* in the menu on the left; in the upper panel, click down arrow near *New device* button and then select *Find devices*.



Add new device

Scan Parameters


First, select scan mode; the following options are available:

- scan IP address range: specify a continuous LAN segment to be scanned
- scan network adapter address range: select one or more network interfaces to be fully scanned
- scan attached devices: the local hardware system will be scanned for capture boards and Direct Show video sources

If you have chosen to search for IP video sources, you should review additional connection settings and change or update them, if required:


- ports: HTTP ports, comma separated
- user credentials: pairs of comma-separated user names and passwords, one pair per line

Use the *Reset* button below to discard all changes and start entering scan parameters again. When you are ready, press *OK* button below to begin scanning.



Scan attached devices

Ganz CORTROL Global Administration Guide




Scan address range

Ganz CONTROL Global Administration Guide

Device Autodiscovery

After scanning has been completed, you will be taken to the Device Autodiscovery dialog box, which will allow you to review the found [devices and their channels](#), and enter/modify related settings. Use the *Search* field in the upper-right-hand corner to find a specific device by name, model, IP, port or hardware ID (for IP devices, ID includes MAC address).



There are two types of selection in the item list: checkboxes and color highlight. **Checkboxes** are used to choose the items to be added to server configuration after you close the dialog box; **highlighted** items are subject to immediate properties changes. Use *CTRL+click* or *Shift+click* to select all or several items at once to change their settings.

Click a device in the item list to load its settings into the *Device Properties* window. Note that some settings may be missing for some of the automatically found devices; this depends mostly on device and whether user data was correctly provided. In such cases, simply fill in the missing data manually and click the *Apply* button below to save the configuration changes.

Device autodiscovery

Device autodiscovery

Found devices

Found channels

Found devices

Scanning for new devices... 96% Stop

Device properties

Found devices

Device name

Grundig GCI-H0522V on 192.168.3.14

Device name

Model

Grundig GCI-H0522V Change...

Device model

Host

192.168.3.14

Host name or IP address

Port

80

Port number

Username

admin

Username to access the device

Password

1234

Password to access the device

Apply Reset

Found devices

DEVICE NAME

MODEL

HOST

PORT

Axis (Legacy Autodetect) on 192.168.3.4

Axis (Legacy Autodetect)

192.168.3.4

80

Grundig GCI-H0522V on 192.168.3.14

Grundig GCI-H0522V

192.168.3.14

80

KT&C KNC-SPDNI120HD on 192.168.3.2

KT&C KNC-SPDNI120HD

192.168.3.2

80

Select model

192.168.3.36

80

Vivotek IP7131 on 192.168.3.12

Vivotek IP7131

192.168.3.12

80

Vivotek IP7131 on 192.168.3.3

Vivotek IP7131

192.168.3.3

80

Vivotek IP7131 on 192.168.3.19

Vivotek IP7131

192.168.3.19

80

Add selected devices and channels Cancel

Set up discovered devices

© 2025. CBC AMERICAS, Corp. All Rights Reserved.

189

Ganz CONTROL Global Administration Guide

If device is not integrated with the software (native support), it may be detected as generic type (e.g., ONVIF). If you think some devices have not been discovered, check if they have different HTTP ports; also, try adding them [manually](#).


Device properties	Found devices																
<div>Device name</div> <div>Unknown on 192.168.3.220</div> <div>Device name</div> <div>Model</div> <div>none</div> <div>Change...</div> <div>Device model</div>	<div>Search</div> <table><thead><tr><th></th><th>DEVICE NAME</th><th>MODEL</th><th>HOST</th></tr></thead><tbody><tr><td><input checked="" type="checkbox"/></td><td>Unknown on 192.168.3.220</td><td>Unknown</td><td>192.168.3.220</td></tr><tr><td><input checked="" type="checkbox"/></td><td>UScreenCapture on 192.168.1.83</td><td>(Generic) DirectShow Device</td><td></td></tr><tr><td><input checked="" type="checkbox"/></td><td>Microphone (High Definition Audio Device) on...</td><td>(Generic) Audio Input Device ...</td><td></td></tr></tbody></table>		DEVICE NAME	MODEL	HOST	<input checked="" type="checkbox"/>	Unknown on 192.168.3.220	Unknown	192.168.3.220	<input checked="" type="checkbox"/>	UScreenCapture on 192.168.1.83	(Generic) DirectShow Device		<input checked="" type="checkbox"/>	Microphone (High Definition Audio Device) on...	(Generic) Audio Input Device ...	
	DEVICE NAME	MODEL	HOST														
<input checked="" type="checkbox"/>	Unknown on 192.168.3.220	Unknown	192.168.3.220														
<input checked="" type="checkbox"/>	UScreenCapture on 192.168.1.83	(Generic) DirectShow Device															
<input checked="" type="checkbox"/>	Microphone (High Definition Audio Device) on...	(Generic) Audio Input Device ...															

If an unknown device is discovered, change its model manually

If the device cannot be matched with a model in the list and it also does not respond as generic ONVIF, it may be discovered as *Unknown*; in that case, try settings its model manually to the closest one (from the *Suggested models*), or try Generic RTSP and specify an [RTSP URL](#) in the [channel settings](#). This may happen to devices that are not listed as an exact model and are also old enough not to support ONVIF Profile S.

Setting	Description	Default value
Device name	User-defined video source name	Autodetected model + IP, empty if not detected
Model	Device manufacturer and model, or generic type	Autodetected vendor and model, empty if not detected
Host	Device IP address	Autodetected
Port	Device HTTP port	Autodetected
Username	Device user credentials; note that you have to provide administrative profile credentials in order to be able to change device settings via software interface	Appropriate username from provided list or autodetected
Password	Device user password	Appropriate password from provided list or autodetected

Make sure you select all the devices you wish to add by putting a checkmark next to them. Devices with missing configuration (model and/or IP) are unchecked by default and will not be added to active server configuration.

 If the autodiscovery **does not find any cameras** or all of them are Generic ONVIF instead of proper models:

- check models
- check IPs and passwords and ports
- make sure that the UPnP Device Host service is functioning properly on your system.

Services (Local)					
UPnP Device Host		Name	Description	Status	Startup Type
Start the service		Udk User Service_77174	Shell compo...	Running	Manual
		Update Orchestrator Service	Manages Wi...	Running	Automatic (De...
		UPnP Device Host	Allows UPnP ...		Manual

Switch to *Channels* tab to review the detected video channels of the discovered devices: this is particularly important if you are using multichannel devices, e.g., capture boards and encoders. Use the *Search* field in the upper-right-hand corner to find specific channels by name or device name.

Ganz CORTROL Global Administration Guide

Device autodiscovery

Device autodiscovery

Found devices

Found channels

Found channels

Start device search

Scanning has be

Channel properties

Channel name

Vivotek IP7131 on 192.168.3.12

Channel name

Recording settings

none

Change...

Recording settings

Apply

Reset

Found channels

CHANNEL NAME

RECORDING SETTINGS

DEVICE

Axis (Legacy Autodetect) on 1...

none

Axis (Legacy Autodetect) on 1...

Vivotek IP7131 on 192.168.3....

none

Vivotek IP7131 on 192.168.3....

Vivotek IP7131 on 192.168.3....

none

Vivotek IP7131 on 192.168.3....

eVidence Apix - 18ZBox / M2 ...

none

eVidence Apix - 18ZBox / M2 ...

Samsung SNP-3120V on 192....

none

Samsung SNP-3120V on 192....

Add selected devices and channels

Cancel

Set up discovered channels

Here you can edit the channel name and assign recording configuration. By default, recording is enabled for all channels: click the *Change* button near *Recording settings* to [manage recording profiles](#) and [assign them](#) to your channels. To add a new recording profile, click the + *New recording configuration* button below; you can find more details about recording profiles in the [corresponding section](#). Click *OK* to save and return back to devices and channels; click *Apply* to save configuration changes.

⚠ After changing the channel recording configuration, do not forget to click *Apply*, otherwise the changes will not take effect.

💡 Recording configuration here is assigned to the **main streams** of the target channels. In order to set up substream recording, please go to [channel configuration](#).

Select recording configuration

Available recording configurations

TITLE

ID

TYPE

● No recording

(31)

Recording configuration

● Continuous recording

(32)

Recording configuration

+ New recording configuration

OK

Cancel

Select the recording configuration or create a new recording profile

Click the *Start device search* button above at any time to restart device discovery.

⚠ All previously discovered devices and all configuration changes will be discarded if you restart camera autodiscovery.

Ganz CONTROL Global Administration Guide

When you are ready, click the *Add selected devices and channels* button below; all checked devices will be added with selected corresponding channels. Newly added devices and channels will be added to the item list.

Configuration > Devices

Configuration

Servers

Users

Devices

Channels

Recording

Layout templates

Configuration

Monitoring

New device

Edit

Assign group

View channels

1 selected

TITLE	ID	DEVICES/MODEL	HOST/IP	PORT	HARDWARE ID
(Generic) ONVIF Compatible on 192.168.3.33	(104)	(Generic) ONVIF Compatible	192.168.3.33	80	MAC:00:00:00:9A:16:EC:92:0B
Asoni CAM613 on 192.168.3.47	(102)	Asoni CAM613	192.168.3.47	80	MAC:00:00:00:0F:0D:20:D5:AA
Basler BIP2-1600c-dn on 192.168.3.148	(107)	Basler BIP2-1600c-dn	192.168.3.148	80	MAC:00:00:00:30:53:10:CD:CA
eVidence Apix - 18ZBox / M2 on 192.168.3.5	(103)	eVidence Apix - 18ZBox / M2	192.168.3.5	80	MAC:00:00:00:D0:89:08:D6:26
Mobotix M25M-Secure on 192.168.3.137	(106)	Mobotix M25M-Secure	192.168.3.137	80	MAC:00:00:00:03:C5:10:2B:70
Mobotix Q25M-Secure on 192.168.3.138	(105)	Mobotix Q25M-Secure	192.168.3.138	80	MAC:00:00:00:03:C5:10:21:F0

Recently added, 0

Recently updated, 0

Groups, 0

Devices, 6

Added devices will appear in the item list


Use the buttons on the upper panel to manage your devices. You can now add new devices and/or device groups, launch autodiscovery again, assign devices to groups, as well as removing both devices and groups.

When deleting devices, remember that corresponding channels will **not** be **removed** at the same time and therefore your newly discovered devices may not be added due to license limitation. Go to the *Channels* tab to manage them separately.

7.2 Add Devices Manually


You can add devices manually instead of using autodiscovery in the following cases:

- actual devices have not been connected yet
- devices are not connected at the current deployment stage but it is planned that they will be connected later
- the server needs to be configured while being away from its future position
- some devices in use cannot be automatically discovered (not listed as models and do not support ONVIF Profile S at the same time)

 Only IP devices can be added manually. Attached devices (e.g., capture boards) require [autodiscovery](#).

Add single device


To access the configuration dialog box from Ganz CORTROL Console, open the *Configuration* section and select *Devices* in the menu on the left; in the upper panel, then click the + *New device* button.



Add new device


Enter a user-defined name for your new device and pick a model. If your camera model is not listed, select the closest similar model or choose a generic type.

Ganz CORTROL Global Administration Guide



Select device model

After you have chosen manufacturer and model, additional tabs will become available in the main configuration dialog box: *Network* and *Channels*. These tabs are described in details later in this section.



Network and *Channels* become available after device model has been chosen

Ganz CONTROL Global Administration Guide

Details

Setting	Description	Default value
Title	User-defined device name	[empty]
Model	IP device manufacturer and model, or generic type	[empty]
Hardware ID	Unique hardware identifier containing a device hardware identifier; this field should be left empty, as it will be filled automatically later, when the device has been connected and identified	[empty]

Membership

Choose groups for the current device to become a member of. Use *Add* and *Remove* buttons below or double-click to manipulate groups. One device may belong to several groups at once.

Device Park South*

Device

Details

Membership

Permissions

Network

Channels

Membership

TITLE

ID

TYPE

Outdoors

(117)

Device group

Remove

TITLE

ID

TYPE

Add

OK

Cancel

Define groups for the device being added

Permissions

Add users and/or user groups simply by checking at least one permission for the target server; remove by clearing permissions - either by deselecting them or by clicking the *Clear* button below. You can also double-click users to remove them from the list of privileged users. Devices with an empty permission list will not be available to anyone except for the root (global) administrator.

Ganz CONTROL Global Administration Guide

Device Park South*

Device

Details

Membership

Permissions

Network

Channels

Permissions

Selected users

TITLE	ID	TYPE	PERMISSIONS
John Doe	(120)	User	<input checked="" type="checkbox"/> Administer

Clear

Available users

TITLE	ID	TYPE
-------	----	------

OK

Cancel

Add user permissions for this device

Network

Enter TCP/IP settings for device access here.

Device Park South*

Device

Details

Membership

Permissions

Network

Channels

Network

Host

192.168.10.155

Host name or IP address

Port

80

Port number

Username

admin

Username to access the device

☒ New password

.....

Password to access the device

Open device in browser

Ping device

OK

Cancel

Enter TCP/IP settings for device access

Before filling in the details, make sure the settings match those on the camera. If device has not been connected yet, ensure that the same settings are applied during the camera installation. You can use the *Ping Device* button to check camera availability and/or verify your settings; the *Open Device in Browser* button will try to reach your camera Web interface using you default browser.

Ganz CONTROL Global Administration Guide

Setting	Description	Default value
Host	Device IP address	[empty]
Port	Device HTTP/HTTPS port. Use port 80 for HTTP and 443 for HTTPS connection (or change to corresponding forwarded ports).	80
Secure connection	Use HTTPS instead of HTTP (change port above to 443). Warning: if you have HTTPS enabled on the camera side , make sure to enable HTTPS here, too. Otherwise, some camera features may be unavailable.	Not enabled
Username	Device user credentials; note that you need to provide a valid administrative user profile to be able to change device settings via software	[empty]
Password	Password for camera access	Enabled

In order to enable HTTPS connection:


- change port to 443 (or whatever port is used/forwarded for secure HTTP)
- enable *Secure connection* option

Note that HTTPS must be enabled on the device side for this feature to work properly. On the other hand, if you are not planning to enable HTTPS in the software, disable HTTPS on the device side. Different settings on the device and software side may cause malfunctions (e.g., device metadata will not be available).

Channels

Here you can detach automatically detected channels from the device and replace them with one of the existing 'free' channels (not attached to any device). Use the *Reset* button to undo any changes made to the channels (this only works for current editing session, reset will not be available after you save the changes and reopen this dialog box).

If you wish the original camera channel(s) to stay attached to the device, just leave the channel list as it is.



Channels

Add multiple devices*

*Feature is subject to license limitations and may be **unavailable in some software editions**.

If you have a number of devices of the same type in your system, you can add them all at once to save time. This method is also suitable if you have multiple groups of devices of the same type.

Open the *Configuration* section and select *Devices* in the menu on the left; in the upper panel, click the little arrow next to the + *New device* button and select *Create multiple devices*.

Ganz CORTROL Global Administration Guide

Add devices

Multiple devices creation

Create multiple devices

Add Devices

New devices

Available models

VENDOR	MODEL	CHANNELS
(Generic)	Custom Config	1
(Generic)	JPEG/M-JPEG Compatible	1
(Generic)	ONVIF Compatible	1
(Generic)	RTSP Compatible	1
3sVision	N1073	1

Device name

Amount

Custom Config

1

+ Add

New devices

DEVICE NAME	MODEL
-------------	-------

OK

Cancel

Create multiple devices dialog box

You can add any number of different devices here (assuming this is permitted by license limitations). First, select the device model from the list, and then enter your desired number of existing devices of the same model.

Multiple devices creation

Create multiple devices

Add Devices

New devices

Available models

VENDOR	MODEL	CHANNELS
CBC (Ganz)	ZN-S1000AE	1
CBC (Ganz)	ZN-S1000VE	1
CBC (Ganz)	ZN-S100V	1
CBC (Ganz)	ZN-S4000AE	4
CBC (Ganz)	ZN-Y11	1
CBC (Ganz)	ZN-YH305	1
CBC (Ganz)	ZN1-D4FN5	1
CBC (Ganz)	ZN1-M4FN3	1
CBC (Ganz)	ZN1-N4NFN6	1
CBC (Ganz)	ZV-S306	1

Device name

Amount

ZN-S4000AE

10

+ Add

New devices

DEVICE NAME	MODEL
-------------	-------

OK

Cancel

Select the desired model and number of devices

When you are ready, click the + *Add* button below to attach the camera set to the new devices list. As soon as there is at least one device, additional tabs will become available: *Device Parameters* and *Channel settings*. Device list on the right will be available in all tabs.

Ganz CORTROL Global Administration Guide

To **remove** any of the listed items, select them with your left mouse button (use *CTRL+click* or *Shift+click* to select multiple devices at once) and hit the *Delete* button on the upper panel or on your keyboard. Select any device and use the **+** *Add* button on the upper panel to add a copy of that device.

Multiple devices creation

Create multiple devices

- Add Devices
- ✎ Device parameters
- ⚙ Channel settings

New devices

Available models

VENDOR	MODEL	CHANNELS
(Generic)	RTSP Compatible	1
(Generic)	JPEG/M-JPEG Compatible	1
(Generic)	ONVIF Compatible	1
(Generic)	Custom Config	1


Device name: Amount: **+** Add

New devices **+**

DEVICE NAME	MODEL
ONVIF Compatible 1	(Generic) ONVIF Compa
ONVIF Compatible 2	(Generic) ONVIF Compa
ONVIF Compatible 3	(Generic) ONVIF Compa
ONVIF Compatible 4	(Generic) ONVIF Compa

Ok Cancel

Add several new devices



Starting with version 1.26, the system no longer uses *Legacy authentication* by default when **adding multiple devices manually**. If your cameras use legacy auth (old/legacy cameras and firmware versions), please do the following after adding devices:

1. Go to *Configuration > Devices* and select your device.
2. In the pop-up window, navigate to *Advanced Configuration*.
3. Check the *Use Legacy Authentication* checkbox.

Device parameters

For each added device, enter corresponding settings. Note that you can skip IP and port on this step if you wish to use automatic incremental IP assigning (see *IPs and Ports* tab description below).

Multiple devices creation

Create multiple devices

- Add Devices
- ✎ Device parameters
- ⚙ Channel settings

Device parameters

Device name:

Model:

New devices **+**

DEVICE NAME	MODEL
1st Floor Lounge	(Generic) ONVIF Compa
ONVIF Compatible 2	(Generic) ONVIF Compa
ONVIF Compatible 3	(Generic) ONVIF Compa
ONVIF Compatible 4	(Generic) ONVIF Compa

Ok Cancel

Modify device parameters


Ganz CORTROL Global Administration Guide

Select a device by clicking on it in the item list: it will become highlighted green and related available settings will be displayed in the *Device parameters* window. You can select multiple devices by holding *CTRL* or *Shift* when clicking.


Ganz CONTROL Global Administration Guide

Setting	Description	Default value
Device name	User-defined device name	Device model
Model	Device manufacturer and model, or generic type; click Change to alter	Loaded automatically
Host	Device hostname or IP address	[empty]
Port	Device HTTP port	80
Username	Device user credentials; note that you need to provide a valid administrative user profile to be able to change device settings via software	[empty]
Password	Password for camera access	[empty]
Server	Target server, to which the device will be attached	Central Server

When you have finished, click the *Apply* button below for the changes to take effect.

 If you do not apply the modifications, they will be discarded when you select a different device from the item list. Remember to always click the *Apply* button.

You will be asked to review the list of modified fields and confirm the changes.



Confirm changes

Click *OK* to accept the changes and go back to the configuration dialog box.

You can select multiple devices and assign IP addresses incrementally with the defined increment. Similarly, it is possible to change the HTTP port for all devices at once, if required (port value stays the same for all selected devices, with no increment). In order to do this, select desired devices by using *CTRL+click* or *Shift+click*, then start entering the IP address: the field will expand, giving you the option to enter the increment.

Ganz CONTROL Global Administration Guide

Multiple devices creation

Create multiple devices

■ Add Devices

✎ Device parameters

⚙ Channel settings

New devices

Device parameters

Host

192.168.7.11

Host name or IP address

☒ Auto increment

1

Last selected IP will be 192.168.7.12

Apply

Reset

New devices +

DEVICE NAME

MODEL

1st Floor Lounge

(Generic) ONVIF Compa

2nd Floor Lobby

(Generic) ONVIF Compa

ONVIF Compatible 3

(Generic) ONVIF Compa

ONVIF Compatible 4

(Generic) ONVIF Compa

Ok

Cancel

Assign IP addresses with increment

Click the *Apply* button below to save the changes, similarly to the previous step.

Channel Settings

Here you can modify channel names and recording configuration. Note that channel name is not copied from the device name.

Unlike with automatic device discovery, default recording configuration here is [none], meaning that recording is not conducted. Select one or multiple devices and then click the *Change* button in order to choose an existing recording configuration for the target devices or create a new one.

Depending on the selected device model, the number of channels may coincide with or exceed the number of devices, e.g., when device is a 4-channel encoder.

Multiple devices creation

Create multiple devices

■ Add Devices

✎ Device parameters

⚙ Channel settings

New channels

Channel settings

Channel name

ONVIF Compatible 1

Channel name

Recording settings

none

Change...

Recording settings

Apply

Reset

New channels

CHANNEL NAME

RECORDING SET

ONVIF Compatible 1

none

ONVIF Compatible 2

none

ONVIF Compatible 3

none

ONVIF Compatible 4

none

Ok

Cancel

Channel properties

Select one or multiple devices and click *Change*, then select appropriate recording profile or [create a new one](#).

When you have finished, click *OK* to add all the new devices and their channels to your server configuration.

© 2025. CBC AMERICAS, Corp. All Rights Reserved.

202

7.3 Manage Devices and Device Groups


This topic describes general device handling as well as common use cases in device management.

Device Drivers (Models)

There are several device types available in the Ganz CORTROL model list:

- emulation
- generic
- models by vendor

Each group of models is further explained in more details. The selected model affects device-specific functionality; server-side functions (e.g., motion detection, Open VCA) will be available regardless of the device model.



Generic device drivers

Emulation From File

Emulation devices allow using a video/image file as the video source. This is an auxiliary driver often used for demo purposes, or when configuring/troubleshooting [license plate](#) or [facial recognition](#). Still images must be in JPG/JPEG format. Video files must be in AVI format, encoded as MPEG4 AVC h.264; video files exported from Ganz CORTROL Client or Portable Player will work, too, provided that they were exported as AVI with JPEG compression.

After creating an emulation device, go to its channel's properties and specify the full local path to the target video/image file (*Channels* > open channel for editing > *Channel configuration* tab > *Channel properties* > *Settings* > *Location*). If you move such a device to another server, make sure to copy the file to the new server, or adjust the path in the channel settings.


Generic Streaming Drivers

Ganz CONTROL Global Administration Guide

Generic drivers are based on common video transfer protocols, so these can be used for legacy hardware, non-integrated cameras/video servers, or non-traditional video sources (e.g., screen capturing software).

Generic RTSP (deprecated)

RTSP uses **generic RTSP** streaming over TCP/UDP, and includes two video streams and also audio (G.711). After adding this kind of device, go to its channel properties and specify the RTSP tag for both main and secondary video streams (*Channels* > open channel for editing > *Channel configuration* tab > *Channel properties* > *RTSP* > *Path to Session Description Protocol File*). The RTSP tag is the URL part after the IP address, so it should look something like `/mpeg4/media.amp` or `/videostream.cgi`. You can find this information in the device HTTP/CGI documentation provided by the manufacturer. You can also specify a **custom RTSP port** here, in case the device configuration uses a non-standard port, or if port forwarding is set up.




Example of channel properties for the generic RTSP driver

Generic RTSP (new)


The new RTSP Compatible driver replaces the old implementation.
Key differences compared to the deprecated driver:

- **Device selection**
 - **deprecated:** model named *RTSP Compatible (deprecated)*
 - **New:** model named *RTSP Compatible*

Ganz CORTROL Global Administration Guide



- **Channel configuration**
 - A new **RTSP Streams** item is available in the channel popup (left panel).
 - Here you specify only the stream paths (e.g., /video, /video?inst=2) for the main and secondary streams. Host, username, and password are already configured at the device level.




- **Simplified UI**
 - The **Open Channel Properties** button in the channel configuration popup has been removed.
 - Advanced options (ports, unicast/multicast, RTSP flags) are still available under **RTSP Configuration** in the channel popup.

Custom configuration driver is similar to the generic RTSP driver, but it allows adding RTSP flags and PTZ commands via .INI file (text file with configuration, formatted in a special way). The file should contain the desired HTTP/CGI commands and URLs, according to the device documentation. The path to the configuration file is also

Ganz CONTROL Global Administration Guide

specified in the channel properties, in the *Configuration* tab. Browse for the file, then hit *Apply*: you should see the configuration details appear above. If there are no details and the date is incorrect, the file has incorrect extension, or is not formatted properly.




Custom config channel with a sample configuration file

JPEG/MJPEG driver is also similar to the generic RTSP driver, the only difference being that the transport here will use HTTP instead of RTSP. This model is rarely used, mostly for legacy devices not supporting RTSP/ONVIF.

ONVIF Driver

This driver can be used for all devices that are ONVIF Profile S conformant. By default, the *ONVIF Compatible* model is recommended (and it is also used when auto-detecting devices). It it does not work with older cameras, try the *ONVIF Compatible (legacy)* driver.

 Due to extensive changes in ONVIF standards, older ONVIF driver marked as **Deprecated** - named (Generic) ONVIF Compatible (Deprecated) - has reached its end of life. It will still be available if you have cameras configured to use this driver, but no new devices can be created with this driver starting from the software version 1.23.1.

Starting from the software version 1.24, channel settings are disabled for devices that use the legacy ONVIF driver. This means, you can change the settings on the camera side, but the software will only be able to read them.

Please switch to the newest, *ONVIF Compatible* device driver wherever possible. If your ONVIF cameras do not operate correctly with this latest driver (e.g., some features are unavailable), kindly contact cortrol@cbcamerica.com with details.

In [device autodiscovery](#), this model will be used alongside with the native integrations: for not-yet-integrated brands/models, ONVIF model will be assigned wherever possible (i.e., if device responds properly to the ONVIF communication).

External Source

This device type is reserved for receiving streams from the Ganz CONTROL Mobile applications. Channels belonging to such devices are only counted by the license when the app streaming is active.


After adding this device, copy the *Code* from its properties to your Ganz CONTROL Mobile app to enable streaming from the app to the Ganz CONTROL server. You will find more details in the [mobile app section](#) of this document.

Ganz CORTROL Global Administration Guide

HTML Source

Choose this model to add streaming emulation from a **website** UI. The contents rendered from the specified URL will be displayed as a single, **static** (non-interactive) live **video stream**, with an option to record it. You can use this device driver for streaming from public services, monitoring web services, sites with dynamic contents etc.

Unlike for the generic RTSP driver (where you set the device IP and then add the RTSP URL in the channel properties), here you need to specify the full URL in the device settings at once. [Channel properties](#) for webpages will have a [separate tab](#), *Web page configuration (Channels > open channel for editing > Web page configuration)*.



HTML Source device example

The device settings include full resource URL (mandatory) and username/password (optional, you only need to specify the user account is the target web service requires it).

As the webpage contents will be static in the Ganz CORTROL Client application, you need to take care of the contents transition. To force refresh contents from the Ganz CORTROL side, use the auto refresh parameter in the channel properties. In the example here with YouTube streaming, the video is looped by adding URL parameters; the final link will look as follows:

<https://www.youtube.com/embed/VIDEOID?autoplay=1&mute=1&loop=1&playlist=VIDEOID> - video added in such a way will be played on repeat indefinitely.

Please note that this type of device uses Ganz CORTROL **channel license** as any other regular IP camera.

CrossLink Devices

Two types of devices are available here: **interactive Web pages** and **interactive remote desktop** applications. Both are fully functional server-side devices that provide live and recorded contents. All interactive items require a special [license type](#) called CrossLink.

Models by Brand

Native device integrations are available for over 140 manufacturers and their 5000+ device models. This list includes cameras, NVRs, video encoders, and I/O modules. Models from this list are used when running device autodiscovery, and you can also use them when manually adding devices.

If you cannot find your exact device model in the list, try the closest available model: quite often, cameras within a series are intercompatible. Also, if you know the device's OEM brand, you can try models from that manufacturer.

Manage Devices

Device management is accessible via Ganz CORTROL Console *Configuration* section, by choosing the *Devices* category in the menu on the left.

Ganz CORTROL Global Administration Guide

Configuration > Devices

Built-in Administrator account

Search

Configuration

Users

Devices

Channels

Recording

Maps

Configuration

Events & Actions

Monitoring

New device

Edit

Assign group

Assign server

View channels

1 selected

TITLE	ID	SERVER	DEVICES/MODEL	HOST/IP	PORT	HARDWARE ID
(Generic) ONVIF Com...	(... Primary (101)	(Generic) ONVIF Com...	192.168.3.33	80	MAC:00:00:00:9A:16:EC:92:0B	
Axis 215 PTZ on 192....	(... Primary (101)	Axis 215 PTZ	192.168.3.4	80	MAC:00:00:00:40:8C:8B:09:99	
Grundig GCI-H0522V...	(... Primary (101)	Grundig GCI-H0522V	192.168.3.14	80	MAC:00:00:B8:41:5F:01:B0:5F	
Samsung SNP-3120V...	(... Primary (101)	Samsung SNP-3120V	192.168.3.11	80	MAC:00:00:00:09:18:70:D1:F6	
Vivotek IP816A on 19...	(... Primary (101)	Vivotek IP816A	192.168.3.12	80	MAC:00:00:00:02:D1:31:B4:8F	
Vivotek PZ7131 on 1...	(... Primary (101)	Vivotek PZ7131	192.168.3.19	80	MAC:00:00:00:02:D1:0A:35:F8	

Recently added, 0

Recently updated, 1


Groups, 0


Devices, 6

Replication devices, 0

Unassigned, 0

Configuration -> Devices

Upper panel items allow you to add devices [automatically](#) or [manually](#), edit, view and  remove them, as well as quickly assign groups and servers. Double-click any device to open it for editing; click *View channels* on the upper panel to open channel-specific controls in the same window. If device has multiple channels, all of them will be listed.

 If you have opened a device for editing but there is a need to **open** the associated **channel's properties at the same time**, use the *Related items* buttons in the bottom left corner of the *Edit device* dialog box.

Please refer to the *Add Devices Manually* section of this document for detailed description of all available tabs and settings.

Use bottom panel buttons to quickly filter recently added/updated devices, choose groups only or solely devices not assigned to any of the servers.

Remove Devices

To remove a device, select it in the item list and use the  *Recycle bin* button on the upper panel to delete the target device. Use *Shift+click* or *CTRL+click* to select multiple devices, or *CTRL+A* to select all.

Delete request

?

Delete all channels that belong to the selected devices?

☐ Please don't show this again


Yes

No

You can choose to remove all associated channels together with the device(s)
You will be offered to remove all the attached channels together with the device(s). Press *Yes* to delete the channels or choose *No* to leave the channels: they will appear as detached in the channel list then and you will be able to re-

Ganz CONTROL Global Administration Guide

attach them to other devices, keeping the channel recording configuration. If you choose *Yes*, all existing shared channels based on the channels of the target device will be removed automatically as well.

 If you try deleting a device that has **associated rules** in the [Event & Action Configurator](#), you will get a warning dialog box with those rules listed. You can either proceed with removing the target device, its channel(s) and its rule(s), or cancel the deletion.

Add Device Groups

As with other resources, devices can be grouped together for easier management. Click the little arrow near + *New device* button and select *New device group*.

Device group

Device group

Details

Members

Membership

Permissions

Details

Title

Group name

OK

Cancel

Device group details

Enter a name for the device group in the *Details* tab, then switch to the *Members* tab and choose devices to join this group. Double-click items or use the *Add/Remove* buttons below to select and deselect devices.

Device group PTZ*

Device group

Details

Members

Membership

Permissions

Members

Selected members

Available memebers

TITLE	ID	TYPE	TITLE	ID	TYPE
Axis 215 PTZ on 192.1...	(103)	Device	Vivotek IP816A on 19...	(105)	Device
Vivotek PZ7131 on 19...	(104)	Device	(Generic) ONVIF Com...	(106)	Device
			Grundig GCI-H0522V...	(107)	Device
			Samsung SNP-3120V ...	(108)	Device

Remove

Add

OK

Cancel

Device group members

In the *Membership* tab, you can select 'higher' level groups to contain this device group (nested architecture).

Ganz CORTROL Global Administration Guide

Device group PTZ*

Device group

Permissions

Details

Members

Membership

Permissions

Selected users			Available users	
TITLE	ID TYPE	PERMISSIONS	TITLE	ID TYPE
Johnny English	(119) User	<input checked="" type="checkbox"/> Administer	James Bond	(120) User
Supervisors	(122) User group		Jimmy Neutron	(121) User

Clear

OK

Cancel

Device group permissions

Finally, open the *Permissions* tab to assign user privileges for this device groups: check at least one permission to select the user or user group, uncheck all or use the *Clear* button below to deselect. When you have finished, click *OK*; the newly created group will then appear in the item list.

Double-click any group to open its contents in the same window; use the buttons on the upper panel to edit/remove it. Click *Edit* to adjust group settings: procedure is similar to that of creating a new device group.

Copy Device*

*Feature is subject to license limitations and may be **unavailable in some software editions**.

Starting from the Ganz CORTROL version 1.11.0, it is possible to **copy an existing device** and its channel(s). To copy a device, click the little arrow next to the *+ New device* button on the upper panel and choose *Create copy* from the drop-down list. The related channel(s) will be copied automatically.

Multiple devices creation

Create multiple devices

Add Devices

Device parameters

Channel settings

New devices

Existing devices

New devices

TITLE	DEVICE NAME	MODEL
Arecont AV5125DN on 192.168.3.75	(Generic) ONVIF Compatible ...	(Generic) ONVIF Compatible
Arecont AV1325IR on 192.168.3.84	(Generic) ONVIF Compatible ...	(Generic) ONVIF Compatible
Arecont AV5115 on 192.168.3.89	(Generic) ONVIF Compatible ...	(Generic) ONVIF Compatible
Arecont AV2825IR on 192.168.3.85	UDP IPN1202HD on 192.168...	UDP IPN1202HD
(Generic) ONVIF Compatible on 192.168.3.204	Canon VB-H41 on 192.168.3....	Canon VB-H41
UDP IPN1202HD on 192.168.3.36	Canon VB-H41 on 192.168.3....	Canon VB-H41
Arecont AV40185DNHB on 192.168.3.141		
Canon VB-H41 on 192.168.3.142		
Grandeye EVO-05NID on 192.168.3.7		
eVidence Discontinued – Apix - Bullet / E3 36 on 192.168.3.231		

Device name Amount

Canon VB-H41 on 192.168.3.142 2

+ Add

Ok

Cancel

Copy one or multiple devices

In the dialog box that appears, you can create one or multiple copies of any device(s) currently present in the Ganz CORTROL server configuration. In the list on the left, all existing devices will be listed; in the list on the right, your copies will appear.

First, choose the source for the copy in the *Add devices* tab:

Ganz CORTROL Global Administration Guide

- select one of the existing devices in the list on the left (a single device can be selected at a time),
- set the number of target copies below,
- when ready, click the + **Add** button to **create** the selected copies,
- repeat previous steps with other devices, if required.

To add a single device copy, you can simply double-click it in the list.

Use the search fields on top of the lists to find the necessary item in a long list. If you no longer wish to add any of the created copies, you can select multiple items using **CTRL+left click** or **Shift+click** and **remove** them using the **Recycle bin** icon above.

The screenshot shows a window titled 'Multiple devices creation' with a sidebar on the left containing 'Add Devices', 'Device parameters' (selected), and 'Channel settings'. The main area is divided into two panes. The left pane, titled 'New devices', contains the 'Device parameters' section with the following fields: 'Device name' (with a placeholder '{Multiple values}'), 'Model' (set to 'Canon VB-H41'), 'Host' (set to '192.168.3.142'), and 'Host name or IP address' (with a checked 'Auto increment' checkbox and a value of '1'). Below these fields are 'Apply' and 'Reset' buttons. The right pane, titled 'New devices', contains a search bar and a table with two columns: 'DEVICE NAME' and 'MODEL'. The table lists several entries, including '(Generic) ONVIF Compatible ...' and 'UDP IPN1202HD on 192.168.3.142'. The last two entries, 'Canon VB-H41 on 192.168.3.142', are highlighted in green. At the bottom right of the window are 'Ok' and 'Cancel' buttons.

Change parameters of the target copies

In the *Device parameters* tab, you can adjust:

- the **name(s)** of the target copy (copies),
- their **IP addresses**, with an option to select multiple with CTRL+left click and then assign a range of IP addresses using auto increment with the specified step,
- **HTTP port** and **user credentials**.


After you have altered any settings here, do not forget to hit the *Apply* button to **save** them, otherwise the changes will be discarded when you deselect the device(s) or switch to a different tab. Use the *Reset* button to **roll back** to the original settings (this works if you have not applied the settings yet).

Note that, at this step, the new device **model** remains the same as the source device model and it cannot be changed at this point. This is necessary for the Ganz CORTROL engine to successfully create a duplicate. You will be able to change the model later via editing the desired device.

The same applies to the **server** where the device is attached: at the moment of cloning, the new devices are created on the same server. If you are using Ganz CORTROL Global, you will be able to move the devices to a different server after you have added the copies by editing the target device(s).

In the *Channel settings* tab, the only available parameter at this point is the **channel name**. You will be able to edit other settings after creating the copy (copies) by editing the target channel(s).

When finished with the settings, click the **OK** button to **save** your newly created device+channel copies. They will be automatically added into the server configuration database.

 After you have added new devices using this method, please allow **some minutes** for the configuration to be saved. After that, you will be able to change the newly created device and channel settings.

Ganz CORTROL Global Administration Guide

The associated **channel(s)** will be added **automatically** with all the existing settings, including the assigned recording configuration.

Replace Camera

In the Ganz CORTROL versions up to 1.11.0, it was impossible to alter the device model, so a special procedure was foreseen if the camera needed a replacement.

Now, if you replace the hardware, you can simply **change the device model** by opening the target device for editing - either by double-clicking it in the device list, or by using the *Edit* button on the upper panel. Note that, when you change the model of an existing device, you will only see model suggestions with the **same number of channels**, and not the whole list of available devices.

Device Canon VB-H41 on 192.168.3.142

Device

Details

Membership

Network

Channels

Details

Membership

Network

Channels

Title

Canon VB-H41 on 192.168.3.142

Device name

Model

Canon VB-H41

Select Model

Server

My Favorite Server

Select device model

Available models

VENDOR	MODEL	CHANNELS
(Generic)	Custom Config	1
(Generic)	JPEG/M-JPEG Compatible	1
(Generic)	ONVIF Compatible	1
(Generic)	RTSP Compatible	1
(Generics)	External Source	1

OK Cancel

Related items


Apply

OK

Cancel

Change the device model

To quickly open the associated channel settings without closing this dialog box, use the *Related items* button in the bottom left corner.




When you change the device model, all the **channel settings** that are configured via *Channel properties* dialog box are **discarded**. These settings include video stream properties, audio, DI/DO etc.

Channel settings that are **preserved** are: motion detection, dewarp, data source, user permissions and recording configuration.

Ganz CORTROL Global Administration Guide

For easier management, channel groups can be added in Ganz CORTROL Console; by default, there are no built-in channel groups. Click the + *Create channel group* button to bring up the corresponding dialog box.

Enter the group title here, choose which channels will be group members and, if desired, select which higher-level group(s) will contain the target group as a member. Set user permissions for channels in this group.



Edit Channel group properties


Click *OK* when you are ready: the newly created group will appear in the item list.

Edit Channel Group


Double-click any existing channel group in the list or use the *Edit* button on the upper panel to bring up the configuration dialog box. The available options are analogous to the ones displayed while the group was being created.

Edit Channel

Channels are automatically created with each newly created device; it is not possible to create a channel separately. Click any channel in the list twice or use the *Edit* button in the upper panel to manage the channel properties.

 Channels with the same device driver (e.g., ONVIF), can be edited **together**. You can select multiple channels by holding CTRL and then open the settings dialog box.

Some of the settings (e.g., recording properties) can be edited for multiple channels simultaneously. Use the CTRL or Shift buttons to select multiple channels.



Edit channel properties

The configuration dialog box has the following options:

- **Details tab:** change channel title and assign recording configuration
- **Members tab:** bind [user buttons](#) to channels so that they appear together in the Ganz CORTROL Client

Ganz CORTROL Global Administration Guide

- **Membership:** make the channel a part of a channel group or a [visual group](#)
- **Permissions tab:** grant channel access permissions to users and user groups
- **Video file configuration:** settings for the generic video emulation driver: main and substream file path and delay between frames
- **Motion detector* tab:** choose between a camera-side or software-side motion detector, default state is disabled
- **Video analytics:** server-side video analysis configuration
- **Audio tab:** combine current channel with audio from another source
- **Inputs/Outputs:** DI/DO settings
- **Channel configuration:** open an additional channel configuration dialog box to manage video stream settings, frame adjustments and DI/DO
- **Video overlay:** configure different overlay elements, e.g., textual contents received from [data sources](#) or use channel shortcuts aka "Portal" with different resources
- **Dewarp tab:** select dewarp profile for fisheye and Panomorph lenses
- **Video configuration:** main and secondary stream adjustment (for newer device drivers)
- **RTSP configuration:** RTSP port and transport selection (for newer device drivers)
- **Edge configuration:** configuration of edge (device-side) synchronization (for newer device drivers)

Please refer to the [Channel Settings](#) topic for detailed description for each of the tabs.

*The motion detector on the software side has two options: **high performance** and **high accuracy**:

High Performance mode: this type of analysis is performed for only key frames whose frequency can vary from several frames per second to one frame every few seconds - this is less sensitive for picture quality, but greatly affects detector operation. CPU consumption is significantly lower due to this, and it can be additionally reduced by increasing time interval between two analyzed frames.

High Accuracy mode: this mode performs motion analysis for the whole video stream, so we recommend selecting this option when you want to achieve best detection results. The lower time interval means higher precision. Keep in mind that CPU and virtual memory usage is much greater if this mode is selected.

If you have opened a channel for editing but there is a need to **open** the associated **device's properties at the same time**, use the *Related items* buttons in the bottom left corner.

Live Channel Preview


After a device and its associated channel has been added to the configuration, it is vital to check if the actual video is received. There are several methods to do this in Ganz CORTROL Console:

- click the *Show video* button on the upper panel in the *Configuration > Channels*: you can switch from main to the secondary stream and back
- go to the *Monitoring* section > *Channels* and check the channel status
- open the target channel for editing and go to *Dewarp* or *Data source* settings

Quick Assign Group

Channel membership can be managed via the channel properties dialog box. To quickly assign a group to any of existing channels, select the desired channel(s) (using *CTRL+click* or *Shift+click* to select multiple items at once) and then click the *Assign group* button on the upper panel.


Ganz CORTROL Global Administration Guide



Assign channel group

Pick a group from the existing channel groups list and then click *OK* to save. It is not a problem if any of the channels already belong to another group: membership in multiple channel groups is allowed.

Quick Assign Recording Configuration


Select one or multiple channels and click the *Assign Recording Configuration* button on the upper panel, then either select an existing recording configuration from the list or create a new one from the dialog box currently in use (the newly created configuration will be automatically chosen after creation). The recording scheme will be applied to the **main streams** of the selected channels; in order to assign configuration to the **secondary streams**, click the  arrow near the *Assign recording configuration* button and choose *Assign substream recording configuration*.

Other

Select one or multiple channels/channel groups and click the *Disable* button on the upper panel to deactivate target items. **Disabled** channels will not be requested from actual physical devices, and, as a consequence, will not be recorded; neither will they be displayed in Ganz CORTROL Client application(s).

For each channel, you can create one **replication** channel: see [archive replication section](#) for details and setup instructions.

The filter panel at the bottom enables you to view recently added/updated items, as well as other relevant filters. The filter that is currently active is highlighted blue: click the *N filtered* button to reset all filters and display all the available items again.




Replace Camera

In the Ganz CORTROL versions up to 1.11.0, it was impossible to alter the device model, so a special procedure was foreseen if the camera needed a replacement.


Now, if you replace the hardware, you can simply **change the device model** by opening the target device for editing - either by double-clicking it in the device list, or by using the *Edit* button on the upper panel. Note that, when you change the model of an existing device, you will only see model suggestions with the **same number of channels**, and not the whole list of available devices.

Ganz CONTROL Global Administration Guide



Change the device model

To quickly open the associated channel settings without closing this dialog box, use the *Related items* button in the bottom left corner.



When you change the device model, all the **channel settings** that are configured via *Channel properties* dialog box are **discarded**. These settings include video stream properties, audio, DI/DO etc.

Channel settings that are **preserved** are: motion detection, dewarp, data source, user permissions and recording configuration.

7.5 Channel Settings

The channel configuration dialog box offers several setting categories. As you move across the tabs and alter the configuration, the tabs containing **unsaved changes** will be marked with an asterisk (*).

Some of the tabs are present for all channels. Other tabs only appear for special driver types (e.g., Web page, Video emulation etc.).

Details


Here you can change the channel title and assign a recording configuration to both main and secondary streams, as well as change organization membership for the target channel.


- **Title:** user-defined channel name, as it will appear in Ganz CORTROL Console and Ganz CORTROL Client applications
- **Organization:** assign this channel to an organization, if applicable
- **Main stream recording configuration:** choose how the first video stream (usually, higher resolution) will be recorded
- **Main stream storage:** destination storage for this stream (may differ from other streams)
- **Substream recording configuration:** choose how the second video stream (usually, lower resolution) will be recorded
- **Substream storage:** destination storage for this stream (may differ from other streams)
- **Edge stream recording configuration:** choose how the edge stream will be recorded, if used (available for ONVIF Profile G conformant devices and also for offline recordings made by Ganz CORTROL Mobile)
- **Edge stream storage:** destination storage for this stream (may differ from other streams)
- **Record supplementary streams with substream*:** if enabled, the selected auxiliary data streams will be stored with the substream
 - *Audio:* incoming sound track
 - *VCA:* video analytics metadata
 - *Motion:* motion detector data
 - *Data:* data from [data sources](#) (serial text like POS etc.)
- **Video lost time:** the amount of time in seconds for Ganz CORTROL to wait after all channel's video streams disappear and before triggering a *Video loss* event
- **Passive mode:** Disable recording unless the camera is opened in monitor (Thin client and mobile clients does not "awake camera")
- **Keep Service connection:** Write metadata accordingly to the recording profile even while device is in passive mode
- Passive Mode Differences for ONVIF and Media Devices Drivers:
 - **Simple Passive Mode (No Viewers)**
 - ONVIF Driver: Maintains service connection(s) only (HTTP/HTTPS).
 - Media Devices (RTSP): No connections to the device.
 - **Improved Passive Mode (No Viewers)**
 - ONVIF Driver: Maintains service connection(s) (HTTP/HTTPS) and "limited" RTSP connection(s).
 - Media Devices (RTSP): Maintains both service connection(s) (HTTP/HTTPS) and "limited" RTSP connection(s).
 - **Any Passive Mode (At Least One Viewer)**
 - ONVIF Driver: Maintains full service and RTSP connection(s) (HTTP/HTTPS).
 - Media Devices (RTSP): Maintains full service and RTSP connection(s) (HTTP/HTTPS).
- **Recording identifier** (only displayed if *Show object IDs* option is enabled in the application settings): unique channel identifier that is used as its folder name in the archive

If you enter a custom **title** for a channel, a special button on the right side will allow you to revert to the device title with a single click.

Ganz CONTROL Global Administration Guide

*By default, all **supplementary data streams** are stored with the main stream, and the secondary stream is recorded is video only. However, if you wish to keep the secondary stream for a longer period (e.g., 7 days for the main stream and 30 days for the substream), you may wish to keep the data streams with the substream so that these tracks are available when you play back the archive. Otherwise, the supplementary data will be erased with the main stream based on the quotas. This setting is also useful when you use different storages for both streams and wish to use replication. For replication channels, you can choose these settings differently from the source channel settings and get combined replicas.

 Each of the supplementary data streams - audio, MD, metadata, and serial data - can only be recorded **once**: either with the main or with the secondary video stream. None of these streams are copied. Thus, for example, if you keep the substream longer than the main video stream, you may want to record the audio together with the secondary stream.



The screenshot shows the 'Channel Axis_RTSP*' configuration window with the 'Details' tab selected. The left sidebar contains a list of configuration categories: Details*, Members, Membership, Permissions, Motion detector*, Video analytics, Audio, Inputs (1), Outputs (1), Channel configuration, Video overlays, and Dewarp. The main content area is divided into several sections:

- Main stream recording configuration:** A radio button for 'Continuous recording' is selected, with a 'Change...' button next to it. Below it, a note states: 'Recording configuration assigned to the main video stream (includes supplementary streams by default)'.
- Main stream storage:** A dropdown menu shows 'Default' as the selected storage, with a 'Change...' button. Below it, a note states: 'Target storage for the main stream recording'.
- Substream recording configuration:** A radio button for 'Recording by motion' is selected, with a 'Change...' button next to it. Below it, a note states: 'Recording configuration assigned to the secondary video stream'.
- Substream storage:** A dropdown menu shows 'Default' as the selected storage, with a 'Change...' button. Below it, a note states: 'Target storage for the substream recording'.
- Record supplementary streams with substream:** Four checkboxes are present: 'Audio stream' (checked), 'VCA stream' (unchecked), 'Motion stream' (unchecked), and 'Data stream' (checked). Below them, a note states: 'If enabled, the selected data stream will be recorded with the substream instead of the main stream'.
- Video lost time:** A text input field contains the value '20'. Below it, a note states: 'Video timeout interval in seconds, after which the video loss event is triggered'.
- Recording identifier:** A text input field is empty.

At the bottom of the window, there is a 'Related items' dropdown menu and three buttons: 'Apply', 'OK', and 'Cancel'.


Channel details

You can either use the *Default* storage category for all target streams, or use different storages for different streams. The latter can be used for manually distributing streams between different directories:

- [storage directories](#) are marked with the relevant storage profiles (e.g., *Main*, *Substreams*, *Edge*),
- each channel and even channel's streams are then assigned different storages.

To choose a storage profile that is not *Default*, select a storage from the *Directories* list and click the *Change* button. Select one of the built-in storage profiles or create and edit a new one.

Ganz CONTROL Global Administration Guide



Choose storage profile

The built-in storage types are:

- **Disabled:** storage location will not be used
- **Default:** default storage tag
- **Fallback:** storage destination to be used if all the storage units with specified tags have failed
- **Readonly:** existing data will be available for reading and will not be erased; no new recordings will be appended to this location

These profiles cannot be edited or removed. Fallback storage settings are available in the corresponding tab of the *Storage properties*.



Readonly storage type can be used, for example, in the following cases:

- it is necessary to view the old data from a different Ganz CONTROL server when you need to insert the disks originating from another computer and you do not wish that these data are erased
- some storage unit contains important footage that has been requested to be kept for a longer time so that the recordings are not erased over time while still allowing access to the footage

Click + *New storage* button to create a new storage profile, or select an existing one and click the *Edit* button in the upper-right-hand corner to change its name.

Ganz CORTROL Global Administration Guide

Storage SecondaryStreams*

Storage

Details

Details

Title

SecondaryStreams

Storage name

OK


Cancel


New storage profile

Enter the storage profile title and click *OK* to save and exit.


Ganz CORTROL Global Administration Guide

Click the *Change* button to choose the recording configuration: you can pick an existing configuration or create a new one, or a schedule on the spot from the same dialog box.

 Please choose *Continuous Recording* configuration for **edge** streams to ensure proper recording.

 When you assign a **motion-based recording configuration** to a channel with a disabled motion detector, the software will automatically suggest enabling motion detection for the target channel. The camera-side detector is given priority; if it is not available, the software-side detector will be enabled and set to the high-performance mode. We recommend that you **review** the motion detector settings to make sure it operates as desired, especially if the camera-side detector is in use.

Note that if you leave motion detection OFF and assign motion-based recording configuration to the target channel, no data will be recorded.




Automatically enable motion detection

Members

This section allows you to attach [user buttons](#) to channels, so that they appear together in the Ganz CORTROL Client application. User buttons bound to channels in this way will appear as video overlay controls when the target channel is placed into a viewport.

If you are editing a channel group, this tab will allow you to put other channels and channel groups into the target group.


Ganz CORTROL Global Administration Guide



User buttons can be bound to channels via *Members* tab

Membership

Choose the group(s) you want to contain the target channel as a member: double-click the relevant items or use the *Add/Remove* buttons below to select/deselect. You will have both channel groups (internal in Ganz CORTROL Console) and [visual groups](#) here.




Choose channel membership

Permissions

Allow users and user groups to access and administer the target channel. To **add** a user or user group, simply select at least one permission, and the user (user group) will be automatically moved to the *Selected users* list. To **clear** all permissions, double-click the user in the left-hand column. You can also use the **checkbox** next to *Permissions* in the central column to toggle between **all/none** (if not all permissions are selected, the checkbox will be filled with a black rectangle).


Ganz CORTROL Global Administration Guide



Change user privileges

Crosslink (Webpage) Configuration

This kind of tab will only appear for [Crosslink](#) channels and channels bound to [devices](#) with the *HTML Source* model (generic model specifically dedicated to static streaming from web), and will affect both live and recording.



Web page properties

The following settings may be available here are:

- **Ignore certificate errors:** if the target webpage has a self-signed certificate, the built-in browser may be unable to open it; choose this option to prevent certificate-related issues (unsafe but more likely to operate)
- **Auto refresh interval:** if the page contents is not dynamic (i.e., does not refresh itself), define a refresh period in seconds here (0=disabled, for dynamic contents)

Resolution and frame rate settings have been moved to the *Video configuration* tab.

Video File Configuration

This tab only appears if the underlying device is of the (*Emulation*) *Video File* type. Here, you can specify the paths to the video streams that will act as main and secondary stream.

Click the *Browse* button to choose the file using Windows Explorer.

Ganz CONTROL Global Administration Guide

Channel Imported Video

Channel

Video file configuration

Mainstream file path

C:\Users\weraf\Downloads\test1.avi

Browse...

Mainstream file path.

Mainstream delay

40

Mainstream delay (ms).

Related items

Apply OK Cancel

Video file properties

For both streams, you can adjust the frame delay: this will affect the speed of the video.

Motion Detector (MD)

Choose between **camera-side** or **software-side** motion detectors (MD). The default detector state is *disabled*, meaning that no motion information is received or passed for recording for the target channel. If you are using motion-driven recording profiles, make sure to enable motion detection for the selected channel(s).



When selecting **camera-side motion detection**, make sure to go to device Web interface to enable and configure motion detector. Settings may vary depending on device manufacturer; also, check with CBC AMERICA LLC to make sure hardware motion detection is supported for the target device.

Camera-side motion detection is recommended for most cases for two basic reasons:

- computational load is transferred from servers to devices, decreasing server load, and
- on most devices, hardware-side motion detection is performed on raw video stream, which means superior accuracy compared to software-side detector, as software only gets access to compressed stream.

Software-side motion detector is a preferable choice if:

- legacy devices without MD support are used, or
- there is a necessity to use build heatmaps - in this case, grid-like MD on the software side is helpful.

Ganz CONTROL Global Administration Guide

Channel Secret Gate on 192.168.3.4*

Channel

Details

Motion detector

Membership

Permissions

Channel configuration

Motion detector

Mode

Software (High Accuracy)

The motion detection will take place in VMS server software. Software analysis is sensitive to input image quality and availability of CPU resources, so this option is recommended for raw video frame grabber hardware.

Motion detection is based on decoding an entire video stream and processing frames, with its frequency defined by a specific time interval.

Note that this mode might involve high CPU usage due to the complexity of the computation.

Time interval

20

Time interval in milliseconds

Sensitivity

Software motion detection sensitivity

☒ Use low-resolution stream if available

Low-resolution stream will be used for motion analysis

OK Cancel

Software-side motion detection settings


The **motion detector on the software side** has two options: high performance and high accuracy:

High Performance mode: this type of analysis is performed for only key frames whose frequency can vary from several frames per second to one frame every few seconds - this is less sensitive for picture quality, but greatly affects detector operation. CPU consumption is significantly lower due to this, and it can be additionally reduced by increasing time interval between two analyzed frames.

High Accuracy mode: this mode performs motion analysis for the whole video stream, so we recommend selecting this option when you want to achieve best detection results. The lower time interval means higher precision. Keep in mind that CPU and virtual memory usage is much greater if this mode is selected.

In both modes, the **level of sensitivity** can be adjusted, as can the time interval setting which defines the frequency of frame analysis.


Regardless of which mode you select, you can further decrease the amount of server-side calculations by using a **lower-resolution stream** (if available). For example, if your main stream is 3MP and your substream is D1, the motion detection engine will spend much less system resources on D1 analysis than it would spend on a 3MP image. Note that some cameras deliver lower-resolution streams as cropped high-resolution images (not resized, as it would be expected) - in such cases, using a substream for MD analysis will produce wrong results and therefore doing so is not advisable.



Most cameras provide second stream as first stream image scaled to fit low resolution; however, some devices crop the centre of a high-resolution image to fit the small frame, and thus the substream picture appears as if it were zoomed in. Keep this in mind when you are using substream for live view and especially for software-side motion detector analysis.

Click the *Motion detection exclusions* button in order to set up **exclusion zones**. Note that these settings only cover the software-side motion detector; in order to configure the exclusions for the camera-side motion detector, go to the Web interface of the target device.

Ganz CORTROL Global Administration Guide



Set up exclusion zones for the motion detector

First, choose the **grid size** for the detector: this will define the size of the smallest detection region. Minimum grid size is 2x2 cells (resulting in four detection areas), and maximum size is 64x64 cells. Then, mark your desired **exclusion area** simply by clicking and dragging on the viewport; you can **draw** several rectangles to form a complex polygonal area. Exclusion area(s) will be highlighted light green. In order to cancel the selection, simply draw a rectangle over it.

Settings in the bottom are here to ease the configuration process:

- *Maintain aspect ratio*: displays original picture proportions, if selected, or stretches the picture to fill the viewport
- *Show motion*: shows currently present motion, if selected

In order to test the behavior of the selected grid size, enable the *Show motion* option, the click *Apply* and see how the detector works with your defined grid.


When you have finished, click *OK* to return to the main channel configuration dialog box.

Software Video Analytics

Ganz CORTROL servers include a built-in deep learning engine for video analysis (VA). This allows you to detect and classify objects, configure zones and counters, and apply rules for event triggering. Analytics is configured per

Ganz CONTROL Global Administration Guide


channel in the **Component Panel** → **Channels** → **Video Analytics** tab.



When enabled, VA overlays detected objects in Ganz CONTROL Client and provides metadata for event processing in the **Events & Actions** module.

External Metadata Sources

In addition to built-in video analytics, Ganz CONTROL can process metadata from external sources. This allows integration with camera-side analytics, third-party services, or legacy systems. All metadata received can be displayed as overlays in Ganz CONTROL Client, used for event triggering, and included in search.




Three external metadata options are available:

- **Camera-side metadata**
 - If enabled, Ganz CONTROL displays metadata generated by the device itself (edge VA). This information is also available for triggering events.
- **External metadata**
 - Enables the server to accept metadata from any external source in JSON format. The data is used for overlays, event triggers, and search.
- **External service metadata**
 - Allows the server to receive metadata from integrated external services that are configured in Ganz CONTROL. This metadata is also available for overlays, event triggers, and search


Ganz CORTROL Global Administration Guide


operations.

 **Note:** These sources are independent of the built-in video analytics engine and can be used in parallel.

Enabling Analytics

- **Enable server-side VA** – activates analytics for the selected channel. All connected Ganz CORTROL Client clients will display the metadata overlay.
- **Use low-resolution stream if available** – if a secondary video stream is configured, the detector can process it instead of the primary stream, reducing CPU/GPU load. Recommended ON for most setups.




 **Tip:** You can preconfigure VA for a channel without enabling it. This is useful if you have limited licenses but want to prepare channels in advance. Each Ganz CORTROL installation includes one generic VA channel free of charge. Specific engines, such as the PPE Detector, require a separate license. To check license use, add the Video Analytics column to the channel grid in the Ganz CORTROL Console.

Quick Setup workflow

Follow these steps to enable video analytics on a channel using recommended defaults:


- **Enable VA**
 - Go to **Channels** → **Video Analytics**.
 - Check **Enable server-side VA**.
 - Enable 'Use low-resolution stream if available'.
- **Choose a Detector**
 - In the **Detector** dropdown, select **Object Detector V2 (Performance)** (recommended for general use).




- **Adjust Detector Options**

Ganz CONTROL Global Administration Guide

- Click **Options...**
- Set **Runtime Environment** to *CPU Runtime 1.21.0* or *DirectML GPU*.
- Keep the **Accuracy** slider at its default value.





- **Configure Detection Parameters**
 - **Select Classes:** enable at least one class.
 - **Detection Interval:** 500 ms (default).
 - **Object Loss Timeout:** 6 s (default).
 - **Scene Dynamics:** Normal.
 - **Confidence Threshold:** 70%.
 - **Object Similarity Threshold:** 85%.



- **Set Up Zones and Rules**
 - Click **Configure Zones and Rules**.
 - Set **Region of interest (ROI)**, draw a zone or line, and add a rule (e.g., *Entered zone*, class = *Person*).
 - Save and link the rule to an action in **Events & Actions**.

Ganz CONTROL Global Administration Guide



 **Tip:** Start with these defaults; fine-tune thresholds and rules later in real scene conditions for the best results.

Detector Engines and options


Select the detection engine in the Detector dropdown. Only one engine can be active per channel.

- **Object Detector V1 (Legacy)**
 - CNN-based detector for people, vehicles, and animals.
 - Supported resolutions: **300×300, 320×320, 512×512, 1024×600**.
 - The **300×300 model** can run on a CPU. Larger models require an **NVIDIA GPU with CUDA Toolkit 11.2.0**.
- **Object Detector V2 (Performance)**
 - New engine optimized for speed.
 - Runs on **CPU Runtime 1.21.0** or **GPU via DirectML (DML)**.
- **Object Detector V2 (Quality)**
 - New engine optimized for accuracy.
 - Supports the same runtime options as Performance mode.
- **Personal Protective Equipment (PPE) Detector**
 - Detects safety equipment, including helmets, vests, and head covers.
 - Requires a separate license.

Legacy Object Detector V1


- **Options:**
 - **GPU Device** – choose a GPU or CPU (CPU option available only for 300x300 detector)
 - **Advanced: per process GPU Memory Fraction** – percentage of GPU RAM reserved for VA (default: 50%).
 - **Advanced: Allow GPU Memory Growth** – Yes/No. “Yes” allocates gradually; “No” reserves a memory block upfront.

Ganz CORTROL Global Administration Guide



Object Detector V2 (Performance/Quality)


- **Options:**
 - Runtime choices: **CPU Runtime 1.21.0 or DirectML (per GPU).**
 - Additional setting: **Accuracy Slider (1–16).** 1 favors performance, 16 favors accuracy.



PPE Detector

Uses the same runtime structure as described in the dedicated PPE documentation.

Ganz CONTROL Global Administration Guide



General Detector Settings

The following parameters are configured below the detector selection:

- **Configure Zones and Rules** – open the overlay editor to define zones, lines, and counters.
- **Classes** – click **Change...** to select from 12 available object categories. Multiple classes may be enabled.
- **Detection Interval** – minimum delay between detections, in ms. Default: **500 ms**.
- **Object Loss Timeout** – time in seconds before a missing object is forgotten. Default: **6 s**.
- **Scene Dynamics** – slider to adjust object speed tracking: **Slow** – **Normal** – **Fast**.
- **Confidence Threshold (%)** – minimum confidence for detection. Default: **70%**.
- **Object Similarity Threshold (%)** – similarity across frames to recognize the same object. Default: **85%**. Recommended range: **50–90%**.
- **Maximum Object Size** – restrict detection of oversized objects:
 - Enter width and height in pixels, or
 - Click Select to draw dimensions directly on the preview canvas.



Caution: Incorrect similarity or confidence values may cause over-detection (false positives) or missed objects. Adjust gradually and test with real scene conditions.

Zones, Regions of Interest, and Rules

Click **Configure Zones and Rules** to open the overlay editor. By default, only VA overlays are displayed, but you can enable **Show all** to reveal additional overlays (e.g., data sources) configured for this channel.

At the top-right corner of the editor, you will find the VA markers: **Region of Interest (ROI)**, **Counter**, **Counting Line**, and **Polygonal Zone**. Drag and drop a marker onto the video image to place it, then adjust its size and position as needed.

Region of Interest (ROI)


By default, a full-frame ROI is added to each channel. ROIs define which part of the frame is analyzed by the detector:

- **Shapes** – ROI can be a rectangle or a polygon.
- **Editing** – resize, move, or add a new ROI.
- **Polygonal ROI** – right-click the polygon border → **New** button → add a new control point. (This editing method applies to all polygonal overlays.)


Ganz CORTROL Global Administration Guide

- **Multiple ROI** – more than one ROI can be defined. In this case:
 - The outer bounding box of all ROIs is passed to the detector.
 - Areas outside ROI are masked.
 - Detector resources are focused only on visible regions.


Use Case: ROIs are ideal for streams with large areas of irrelevant activity (e.g., sky, background, empty floor). They slightly improve performance and enhance the detection of distant or small objects by focusing only on relevant regions.



Ganz CORTROL Global Administration Guide




ROI scaling and non-rectangle ROI fitting example (does not reflect the user interface; illustrates an internal system approach).

 **Important:** Zones and lines operate only within ROI. If a zone or line extends outside the ROI, detections will be considered only within the intersecting region.

Zones, Lines, and Counters

- **Add a Zone or Line**
 - Use the **polygon** icon in the top-left corner of the viewport.
 - Drag and drop into the frame to place.
- **Edit a Zone**
 - Select the zone in *Elements*.
 - Use **+New rule** to add rules, or **+New zone counter** to link counters.
 - Adjust properties in the *Properties* panel (e.g., color, opacity, object presence time).
- **Edit a Line**
 - Select the line in *Elements*.
 - Only **+New rule** is available.

Ganz CORTROL Global Administration Guide



Elements Hierarchy

In the **Elements** panel:

- Top-level elements define overlay style (e.g., **Region of interest**, **Zone**, **Line**, **Counter**).
- Sub-level elements define functional settings:
 - **ROI regions** with their shapes and masks.
 - **Zones** or **lines** with rules and counters.
 - **Counters** that may be linked to rules or reused across channels.

Rules and Counters

- **Rules**
 - Define how events are triggered (e.g., *Crossed line AB*, *Entered zone*).
 - Appear in the **Events & Actions** configurator for automation.
- **Zone Counters**
 - Reflect live object counts inside a zone.
 - Created via **+New zone counter**.
 - Zone counters **can't be reused** and are strictly connected with the particular zone.
- **Generic Counters**
 - Created once and can be reused in multiple zones or channels.
 - Useful for aggregating totals (e.g., total visitors across entrances).



Note: Overlays and counters only define conditions. To trigger actions (alarms, notifications, pop-ups), link them to rules in the Events & Actions configurator.

For each zone/line rule, you can choose one or multiple **object classes** to be tracked. You can only choose among classes that have been enabled for the current channel in the previous steps.

Available **line rules**:

- *Crossed AB* or *Crossed BA*: object has crossed the line in the specified direction
- *Crossed*: object has crossed the line in any direction

Ganz CORTROL Global Administration Guide

Available **zone events**:

- *Entered or appeared*: the object appeared in the zone either by crossing its border from outside to inside, or appeared directly inside (e.g., if the zone order is equal to the frame border, or there is a door inside the zone)
- *Leaved or disappeared*: the object departed from the zone either by crossing its border from inside out, or simply disappeared inside the zone (e.g., there is a door inside the zone)

Available counter types:

- zone counter: reflects the current number of certain objects in the zone
- counter: E&A [software counter](#)

Use the buttons below the objects and their properties to create and remove rules. Note that these rules only exist in VA configuration; in order to set up reactions, go to the [Events&Actions](#) section of Ganz CORTROL Console.

VA Configuration Examples

Example 1 – Count people entering a zone

- Place a zone marker.
- Add a rule: *Entered/appeared*, class = Person.
- Place a counter marker, bind it to a new counter.
- Save VA settings.
- In **Events & Actions**, create a new **VCA Event** for this rule.
- Add an action: Increment counter.

Example 2 – Pop-up camera when three people are in a zone

- Place a zone marker.
- Create a *Zone Counter*.
- Save VA settings.
- In **Events & Actions**, create an event: *Counter Value = 3*.
- Add action: Pop-up camera on screen.

Audio

Here, select the **audio source** for the target channel. The available options are:

- **None**: the channel will have no audio track
- **Internal**: built-in or line-in camera microphone will be used as the audio source (G.711 only!)
- **Attached**: a microphone that is physically connected to the server will serve as the audio source (server must be the one having this channel in its configuration)
 - **Audio source**: select one of the devices from the drop-down list. If the list is empty, make sure that the server has a microphone connected and that it is visible/working in the Windows Control Panel.
- **External**: use audio from another channel. Audio will be combined with the target channel video in both live and playback.

When fetching audio from the device side (**internal** source), make sure to choose the **G.711** codec. Other codecs are not supported at this point, and selecting them may result in unavailable video stream, too, when both video and audio are packed into the RTSP stream.

For audio sources that are **attached** to the server: you can use both line-in microphones, as well as ones connected via audio board, which supports multiple microphones at once. There are three important requirements here:

- the target channel and the target audio device must belong to the same server
- the attached audio device(s) must be recognized by the operating system
- the list of audio devices is retrieved live, so the target server must be online for you to apply the configuration

Ganz CORTROL Global Administration Guide

Digital Inputs

If **digital inputs** (DI) are supported for the underlying device, the available inputs will be listed here. Mark them in the list in order to allow event generation from those inputs: events can be later set up in the [E&A Configurator](#) using the *Digital input* event type. After changing the DI name, click *Apply* below for the changes to take effect: the setting will not be saved if you simply switch to another tab.

Note that the tab contents is retrieved in **real time** from the target device, therefore, it may take several seconds for the contents to become available. In case the target device is offline/unavailable, or if there is no support for DI for the selected device model, the list will be empty and a corresponding warning will appear.

Channel Street View PTZ*

Channel

Inputs

Edit input details

Title

Front gate

☒ Enabled

Inputs

☐ Title

☒ Front gate

☐ Input 2

Apply Cancel

Related items

Apply OK Cancel

Enable event generation from the camera digital inputs (DI)

Digital Outputs

You can change the state of **digital outputs** (DO) from the [E&A Configurator](#) (target action type: *Control digital output*). For the DO to be available in actions, select them here by putting a mark in the corresponding checkboxes. Optionally, you can also change the DO names. Click the *Apply* button below the output details to save the changes before moving to other settings.

For each relay output, you can also specify the desired **mode**: switch, inverted switch or pulse. This defines the command that will be sent to the device when DO action is triggered in E&A.

Note that the tab contents is retrieved in **real time** from the target device, therefore, it may take several seconds for the contents to become available. If the target device is offline/unavailable, has no DO, or if there is no support for DO for the selected device model, the list will be empty and a corresponding warning will appear. In case your device does have DO but they are not supported by software, you can still change their state from Ganz CORTROL [E&A](#) by using CGI/HTTP commands (action type: *Send HTTP request* or *Run program*). The exact command text depends on the device and can be found in the device documentation.

Ganz CORTROL Global Administration Guide

Edit output details		Outputs	
Title	Mode	Pulse time	State
Front door	Switch		Unknown
Front gate	Switch		Unknown

Mark relay outputs for further usage in E&A

Video Overlays

Here, you can create **channels shortcuts** and also choose a data provider to **embed** some **textual data** with the video. The section below explains channel shortcuts; for setup guidelines on the data overlay, please refer to the [Data Sources](#) section of this document. Video analytics visual elements are explained above.

By default, only channel shortcuts and data source overlays are displayed here. Enable the *Show all* option above the video preview to **see all visual elements** (e.g., video analytics).

Channel shortcuts are interactive video overlay elements intended for instant switching between video channels in the Ganz CORTROL Client application's live view mode. In other words, these are visual controls that appear on top of the video and clicking them will open other (pre-defined) video channels in the same viewport. These "portals" are configured in Ganz CORTROL Console and then used in the Ganz CORTROL Client application.

Video Overlay Shortcuts a.k.a Portals


Starting with version 1.25 it is possible to mark video overlay shortcuts not only as a rectangle but as a free-form polygon too. Also, it is possible to create video overlay shortcuts for:

- **Data and video channels**
- **Maps**
- **Buttons**
- **Webpages**
- **Shared layouts**

By clicking the dedicated area inside the *channel*, in the Ganz CORTROL Client, you can switch data and video channels, trigger events assigned to buttons, and switch between saved *shared layouts*.

Adding portals to channels


To add a new "portal" to the *channel*, in the Ganz CORTROL Console go to:

1. *Configuration* -> *channels*-> Select a preferred *channel* and then click the *Edit* button on top or double-click the preferred *channel*
2. Select video overlay and click *Configure video overlays* button
3. Drag the "portal" icon  to the *channel* layout view and mark the zone you want to use as a shortcut.

To assign existing resources to a shortcut, select your shortcut in the *Elements* panel, then in the *Properties* panel, click on *Resources* and assign from the available list.

N.B. User buttons assigned as video overlay shortcuts do not have any indication and work with a single click. To check if the button was actually triggered, go to the Alert tab in Ganz CORTROL Client

Ganz CORTROL Global Administration Guide



An example of the user Button video overlay in the Viewport

⚠ Make sure the video from the target channel is available before setting up the channel shortcuts in order to ensure correct shortcut placement.

The video Overlay window contains three tabs. The first tab is for the channel camera view and all the overlay markings. The Elements tab allows you to switch between added overlays, and the Properties tab contains options specific to the chosen overlay.

Shortcut Overlay Properties

Type: type of video overlay

Shape: can be rectangle or polygon

Label: optional text to display with Overlay in Ganz CORTROL Client viewport

Background color/opacity: shortcut color and its transparency

Foreground color/opacity: shortcut font color

Font/Font Size: face and size of displayed shortcut font

Resource: resource linked to Video Overlay shortcut

Data Overlay Properties

Type: type of video overlay

Line count: how many lines are allowed per video port

Timeout: how long data will be displayed since the last data input

Text color: data Overlay viewport font color

Data Source: data source connected to the selected channel

Data ID: data ID

Counter Overlay Properties

Type: Type of video overlay

Text: Optional text to display with Overlay in Ganz CORTROL Client viewport

Color: Displayed text color

Opacity: Displayed text opacity

Font/Font Size: Face and size of displayed shortcut font


Resource: resource linked to Video Overlay shortcut

To **remove** any unneeded *Shortcut*, *Counter* or *Data Overlay* - select it in the video viewport or in *Elements* tab and click the *Recycle bin* button in the panel above the video.

Ganz CORTROL Global Administration Guide

To **save** the video overlay settings, click *OK* to close the dialog box and then click *Apply* or *OK* in the *Edit channel* dialog box. If you click *Cancel* to discard changes in the *Edit channel* dialog box, adjustments in the video overlays will not be saved.

Shortcuts and *Counter Overlays* can be duplicated. To do so, select the *Overlay* you want to duplicate. At the top of the *Elements* section, you will find two buttons, one for deleting the overlay and the second for duplicating. Click on the *Duplicate* button. This will create a copy of the selected overlay.




Channel shortcut and duplicate buttons are marked with the red ellipses.

Channel Configuration

The *Channel Configuration* tab allows you to adjust advanced channel settings. Some of these can be changed via Ganz CORTROL Console but sometimes software does not cover some of the device settings, so you are also given the option to go straight to the device Web interface - simply click the *Open device in browser* button to do this.

For ONVIF channels (if device model is set to (Generic) ONVIF Compatible), there is an option to set up **imaging settings**: the corresponding button will appear next to the *Channel properties* button. Please see below for more details.

Ganz CONTROL Global Administration Guide



You can open the target device in browser or go to the software provided settings dialog box

Click *Open channel properties* to access the additional channel configuration dialog box. The available tabs depend on the device model and capabilities: for some cameras, only basic configuration options are present, while for others, advanced settings are accessible. If you see that a camera has certain capabilities that are not configurable via Ganz CONTROL Console configuration interface, go to the device's Web interface in order to change that specific setting.

- **Video Input tab:** set video transport (the available list of options depends on the device type and model; common types include HTTP, RTSP* and native transport)
- **Video Adjustment tab:** fine-tune picture settings such as brightness and contrast level
- **Substream tab:** enable second (lower resolution) stream; some integrations also support stream settings
- **Video Configuration tab:** choose streaming settings**
- **Motion Detection tab:** with some devices, the camera-side motion detector must be explicitly enabled here
- **External PTZ tab:** adjust external PTZ controller settings; communication port must match the communication port that the RS232/485 controller is connected to, and baud rate has to match the baud rate of your PTZ controller/analog PTZ camera
- **RTSP tab:** appears if RTSP transport type has been chosen; set **RTSP port** and mode (TCP/UDP/multicast***) here

*You may have to specify the RTSP port on the corresponding tab if it differs from default (port 554 is default for most devices). To do this, select the RTSP transport type and then click *Apply*: as a result, the RTSP tab will become available. For ONVIF devices, the RTSP port is set automatically.

**Remember, the higher the resolution/bitrate/quality/frame rate you set, the more storage space and bandwidth it will use when recording. These settings also affect CPU/virtual memory resource consumption for live video and software-side motion detection.

***Multicast mode availability depends on device integration.



Note that a valid administrative account login and password for the camera should be provided in *Device* settings in order to access and set the device configuration.


Imaging Settings

Ganz CORTROL Global Administration Guide

For ONVIF device channels, it is possible to adjust the image settings like brightness, saturation etc. To access these settings, open the channel for editing, choose the *Channel configuration* tab, then click the *Open imaging properties* button.

Adjust the settings, then click *Apply*. If you like the result, click *OK* to close the dialog box and exit.

Use the *Reset* button to revert the latest changes. If you save the changes and close the window, next time you open it Ganz CORTROL Console will treat the previous settings as default and will reset to them (and not some other set of values). To reset the imaging settings to the factory defaults, use the camera Web interface.



Use the low resolution stream for image preview to compare the pictures and make sure the applied imaging settings look good on both streams (e.g., make sure important elements are visible).


Dewarp

Here, you can configure generic [dewarp settings](#) or enable dewarp engine for the Panomorph Enables® lens. For details, please see the subsequent topic on dewarp setup.

Video Configuration

This tab is only available for certain device drivers like ONVIF. For other devices, go to the *Channel Configuration* tab (described above).


Here, you can select stream properties for both **main** and **secondary** video streams. The options are fetched from the device so the availability may differ depending on the vendor.

 The settings are changed on the device side, too, so make sure the target device is not configured in some other video management software in order to avoid configuration conflict.


Available settings:

- **Profile:** choose one of the video stream profiles (built-in or pre-configured on the device side)
- **Encoding, resolution, quality, GOV length*, frame rate, bitrate, bitrate mode:** choose one of the available settings according to your needs

By default, camera-side settings are used (whatever is currently set on the device side). You can override all settings or only some of them.

 Note that a valid administrative account login and password for the camera should be provided in *Device* settings in order to access and set the device configuration.

Ganz CORTROL Global Administration Guide

*Too long GOV intervals (hence, low i-frame rate) may cause recording and **playback issues**. Channels with too low i-frame rate will have a warning (orange color) in the *Monitoring* section of Ganz CORTROL Console, under *Channels*. To view this column, click the grid icon  in the upper right corner and move the columns *Main stream GOP size* and *Substream GOP size* to the left, then click *OK*.

RTSP Configuration

This tab is only available for certain device drivers like ONVIF. For other devices, go to the *Channel Configuration* tab (described above).

By default, the **default port of 554** is used for obtaining video over RTSP. Here, you can **override** the default port, and also choose between unicast and multicast. Also you can send RTSP port as a part of URL and allow to accept headers in RTSP URLs:

- **Enable RTSP port in URL:** If enabled, the RTSP port will be explicitly included in the DESCRIBE request
- **Always use ACCEPT header in RTSP URLs:** If enabled, the ACCEPT header will be added to all DESCRIBE requests

Edge Configuration

This tab is only available for certain device drivers like ONVIF. For other devices, go to the *Channel Configuration* tab (described above).

For some devices, Ganz CORTROL can fetch the recording done on the device side (on camera SD card). This tab contains some settings related to the edge stream synchronization.

7.6 Bulk Edit for Devices and Channels

For easier resource management, it has been made possible to edit certain settings of devices and channels, e.g., recording settings and motion detection, for multiple items at once. To do so, simply select more than one device or channel in the item list using CTRL+click or Shift+click (use CTRL+A to mark all) and then click the *Bulk Edit* button on the top panel. Note that the button will not be there unless at least two items are selected.

- Some settings will be grayed out, indicating that these either cannot be changed at all or specifically via bulk edit
- *{Multiple values}* text in the setting field indicates that selected items have different options, e.g., have different recording configurations
 - leave such a field untouched if you wish to keep these settings different
 - change the value of such a field to something specific using the *Change* button to assign the same setting to all selected items
- Fields containing specific values or empty fields indicate that all selected items have the same setting (often default); change the value to assign the setting to all items at once

Edit Multiple Devices

Select at least two devices in the list and click *Bulk Edit* on the top panel to bring up the corresponding dialog box. Some settings will be grayed out, indicating that these settings either cannot be changed at all or specifically via bulk edit.

Top panel buttons: + New device, Bulk edit, Assign group, View channels, [trash icon], 2 selected

Dialog box: Bulk edit

Left sidebar: Bulk edit, Details, Network

Details pane:

- Title: {Multiple values}
- Device name
- Model: {Multiple values} [Change...]
- Model
- Server: My Server [Change...]
- Server

Bottom buttons: OK, Cancel

Status bar: Recently added, 1 | Recently updated, 0 | Groups, 0 | Devices, 11 | Replication devices, 0 | Unassigned, 0

Edit multiple devices using bulk edit

For devices, you will be able to modify the following settings:

- *Details* tab:
 - **Server:** the server where the devices belong
- *Network* tab:
 - **Port:** HTTP port to connect to the device (for IP devices)
 - **Secure connection:** use HTTPS


Ganz CONTROL Global Administration Guide

- **Username and password:** user credentials to log in with

When done, click *OK* to save and close the dialog box: the settings will be applied to all the selected devices.

Edit Multiple Channels

Select at least two channels in the list and click *Bulk Edit* on the top panel to bring up the corresponding dialog box. Some settings will be grayed out, indicating that they either cannot be changed at all or specifically via bulk edit: for instance, it is impossible to change the title field this way, as each channel normally has its own name, which therefore should be edited for each channel individually.



Edit multiple channels using bulk edit

For channels, the following settings can be changed via bulk edit:

- *Details* tab:
 - **Organization***: the organization the channel belongs to
 - **Main stream recording configuration**: default recording setting for the main stream
 - **Main stream storage**: main stream recording destination
 - **Substream recording configuration**: default recording setting for the secondary stream, if available
 - **Substream storage**: secondary stream recording destination
 - **Edge** recording configuration**: set *Continuous Recording* here for proper operation
 - **Edge** storage**: recording destination for the footage fetched from the device
 - **Video lost time**: timeout for streams absence, after which the video stream is considered lost and the corresponding event is raised in the E&A engine
- *Motion detector* tab:
 - **Mode*****: choose between camera-side or software-side (high performance or high accuracy software modes available) motion detection

*Ganz CONTROL Global edition only

**Only for channels coming from ONVIF devices

***You will find more details on the motion detection modes in the *Channel Configuration* topic

When done, click *OK* to save and close the dialog box: the settings will be applied to all the selected channels.

8 Recording Profiles, Schedules, and Configurations

This section describes how to create and configure recording entities: recording profiles, schedules, and configuration.

To access the recording configuration dialog boxes in Ganz CONTROL Console, select the *Configuration* section and then choose *Recording* in the menu on the left.

There are three types of resources in the *Recording* tab:

- **profile:** choose what data streams are recorded and in what mode (continuous/alert triggered)
- **schedule:** set a recording timetable based on profiles
- **configuration:** a profile- or schedule-based recording configuration that is assigned to channels

These entities are not related to storages

The buttons on the upper panel allow to create, edit and remove recording resources.



Recording resources cannot be deleted if they are in use at the time, i.e., if a recording profile has been assigned to a recording configuration or a schedule, or if any of the recording resources have been assigned to a channel.

Create Recording Profiles

Recording profiles allow you to choose which data streams are recorded and how. Profiles are not assigned directly to channels; instead, they are used as components for recording schedules and recording configurations. You can think of a recording profile as the currently running server recording job for a channel: one profile is active at a time and profiles can change based on a schedule/event within the recording configuration assigned to the channel.



Recording profiles do not include settings like pre-recording interval: this setting is defined separately for each channel and, consequently, is defined in the recording configuration settings. This approach optimizes server memory management as the server knows exactly which channels need the pre-recording buffer.

To add a **new recording profile**, click the down arrow button next to + *New recording configuration* and select + *New recording profile*. The profile creation dialog box will appear.

Ganz CONTROL Global Administration Guide

Recording profile VideoAudioContinuous@15FPS*

Recording profile

Details

Title

VideoAudioContinuous@15FPS

Recording profile as seen by others

Continuous recording

☒ Video stream

Continuous video stream recording

☒ Limit frame rate

15

Maximum frame per second rate to video stream recording (default is 10)

☒ Audio stream

Continuous audio stream recording

☐ Motion stream

Continuous motion detection information recording

☐ Data stream

Continuous data stream recording

☐ VCA stream

Continuous VCA stream recording

Alert recording

☒ Video stream

Continuous video stream recording

☐ Limit frame rate

10


OK Cancel

Recording profile properties

This dialog box has two sections: one for continuous and one event-driven recording. Note that you can only select one mode at any time for video and audio streams: if continuous recording is selected, alert-based recording options will be grayed out.

You can use the existing built-in recording profiles as the basis when creating your own recording profiles. Also, the most popular scenarios (motion-based, continuous, no recording) are covered by the built-in profiles so you only need to create custom profiles.

To configure **motion-based recording**, enable *Video stream* in the *Alert recording* section and enable the *Detected motion triggers alert* setting. If you wish to record **still frames** at a low rate while there is no motion taking place, keep the *Video stream* option in the *Continuous recording* section enabled and set your desired frame rate, e.g., 1FPS; then set either a high FPS or unlimited FPS in the *Alert recording* section. In case you only wish to record while motion is taking place, deselect *Video stream* in the *Continuous recording* section.

 When you assign a **motion-based recording configuration** to a channel with a disabled motion detector, the software will automatically suggest enabling motion detection for the target channel. The camera-side detector is given priority; if it is not available, the software-side detector will be enabled and set to the high-performance mode. We recommend that you **review** the motion detector settings to make sure it operates as desired, especially if the camera-side detector is in use.

Setting	Description	Default Value
Title	User-defined recording profile name	[empty]

Ganz CONTROL Global Administration Guide


Video stream (continuous)	Select to enable continuous video recording	Disabled
Limit frame rate (for continuous video recording)	Set a frame rate restriction for recorded video; note that for compressed video streams (e.g., H.264) actual frame rate may differ due to compression algorithms	10 FPS
Audio stream (continuous)	Select to enable continuous audio recording	Disabled
Data stream	Select to enable data recording from the associated the data source	Disabled
VCA stream	Select to enable continuous video analytics event recording	Disabled
Video stream (alert)	Select to enable alert-driven video recording; video will only be recorded after alert generation, for the time period defined in the <i>Post-recording interval</i>	Disabled
Limit frame rate (for alert video recording)	Set frame rate restriction for recorded video; note that for compressed video streams (e.g., H.264) actual frame rate may differ due to compression algorithms	10 FPS
Audio stream (alert)	Select to enable alert-driven audio recording; the video will only be recorded after the alert generation, during the time period defined in the <i>Post-recording interval</i>	Disabled
Post-recording interval	The time interval during which alert-driven recording will be conducted after alert generation	10 seconds
Detected motion triggers alert	Motion will act as a trigger for recording; enable this setting to set up motion-based recording	Disabled

When done, click *OK* to save the recording profile: it will appear in the item list of the *Recording* section. The profile is now ready to be used for further configuration.

Create Recording Schedules

Recording schedules are **sets of recording profiles** that define what recording profiles are used depending on the day and time of the week. In other words, a schedule defines how the profiles are switched over time basis. Alike recording profiles, schedules need a recording configuration on top of them to serve as a proxy in order to be assigned to channels.

To add a new recording schedule, click the down arrow button next to + *New recording configuration* and select + *New recording schedule*. A schedule creation dialog box will appear, allowing you to enter a name of your choice for the new schedule and add the profiles to define the recording timetable.



User-defined title for the recording schedule

To create a new schedule:

1. Enter its title
2. Choose a calendar (optional) or just use a weekly schedule
3. Define the points in time when the profiles will change (using either grid or list view)
4. Save the schedule

Here are detailed explanations of what the schedule elements do and how they are configured.

Schedule Visualization

The schedule configurator has two modes: **list** view and **grid** (graphical) view. The graphical mode is used by default; you can switch between the two views by clicking the toggle button in the upper right corner.

Ganz CONTROL Global Administration Guide

List Mode

In this view, each line represents a point in time when a specific profile is activated.

Recording schedule

Details

Recording schedule Weekends Only*

Details

Title

Weekends Only

Recording profile as seen by others

Scheduled profiles

DAY	TIME	PROFILE
Monday	12:00 AM	No recording
Saturday	12:00 AM	Continuous recording

Add

Edit

Remove

OK

Cancel

Recording schedule in the list view

Click the *Add* button below to insert a new profile with a defined start time. To change an existing item in the list, double-click it or use the *Edit* button.

Scheduled profile

Schedule item setup

Day

Sunday

Day of the week

Time

2:00:00 AM

Time of the day

Recording profile

Continuous recording (22)

Change...

Description

OK

Cancel

Add profile to the recording schedule

Note that you only have to define the start time for each profile: the end time is determined by the next profile start time. For example, if you require continuous recording during weekdays and motion-driven recording during weekends, your continuous recording profile should be scheduled to start on Monday at 12 a.m. and the motion-driven one to start on Saturday at 12 a.m.


Click *OK* to save and add the profile to the schedule. Multiple profiles will be automatically sorted based on their start time.

Ganz CORTROL Global Administration Guide

Use the *Edit* and *Remove* buttons below to manage added profiles. When done, click *OK* to save; the newly created schedule will be added to the item list in the *Recording* section.

Grid Mode

Graphical schedule view is more convenient for complex timetables, where many different recording profiles or profile combinations are used.



Weekly recording schedule in the grid view

Simply **select** the desired profile in the list on the left, then **mark** the target period on the grid view. **Repeat** with all desired profiles.

💡 As you create new profiles, they are automatically assigned different **colors** and appear in the profile list.

💡 It is not necessary to fill the whole timetable. You can leave some of the grid **empty** (white): empty time periods will be analogous to the *No recording* profile and nothing will be recorded during that time.

Schedule Calendars

The core of a regular recording schedule is the **week**. In the simplest approach, you define how the profiles are switched on a weekly basis by coloring the week grid, and your Ganz CORTROL server will cycle through the week accordingly.

A more detailed approach takes into account the **whole year**. This covers non-standard weeks, when some of the weekdays should follow the recording pattern of the weekends (e.g., state holidays) or vice versa. For this, you can build a **custom calendar** with exceptions.

User defined calendar

 Latvian_holidays

Change...

User defined calendar

A schedule using a custom calendar (optional)

How to decide if you need a calendar?

Ganz CORTROL Global Administration Guide

- If you only need a typical weekly schedule throughout the year, use the weekly schedule.
- If you have a need for custom daily schedules, use a custom calendar.
- If you need to change the day type sometimes and "change Saturday into Thursday", use a custom calendar.


When you only use the regular 7-day week without a calendar, ignore the "Custom days" section.

Add Custom Calendars

User-defined calendars provide an option to define a yearly basis for the recording. While the weekly basis is simpler, having a year long calendar allows configuring special dates (e.g., holidays).

Each calendar assumes the same **weekly schedule** as its base, and then you can add exceptions by explicitly assigning the recording pattern to specific dates. You can choose that pattern from the weekly schedule (7 different days) or from the custom days (5 additional daily patterns), which you can pre-define.


You can add as many calendars as you like, use them in various recording configurations, and change them by adding/removing items at any point. When you change the day type for the current day (e.g., today is Saturday and you add a calendar entry that forces Thursday on this date), the new recording profiles are enforced immediately after you save the configuration.



The list of custom calendars

To add a **new calendar**, open the recording schedule creation dialog box, and click *Change...* next to the *User-defined calendar* option. You will see the list of existing calendars (empty by default). Click the + *New user-defined calendar* button to open the dialog window.

In the list of calendars, you can also edit the list (remove unnecessary items by clicking the *Recycle Bin* button) and open existing calendars for editing (by selecting the target calendar and then clicking the *Pencil* button). To

 If you run multiple installations in locations that use the same calendar, you don't have to create it again for every installation. Simply create the calendar, save the Ganz CORTROL configuration database file, and then [import the calendar](#) from it.

Ganz CONTROL Global Administration Guide

The screenshot shows a dialog box titled "User defined calendar Latvian_holidays*". On the left, there's a sidebar with "Details" and "Days*" (selected). The main area is a table with columns "DATE" and "DAY".

DATE	DAY
6/22/2023	Day 3
6/23/2023	Sunday
6/24/2023	Sunday
11/18/2023	Sunday

At the bottom of the table are buttons: "+ Add", "Edit", and "Remove". At the bottom right of the dialog are "Apply", "OK", and "Cancel" buttons.

A custom calendar with four exceptions

Enter the calendar name and switch to the *Days* tab. It is empty by default (which means the calendar solely operates on the normal week basis). To create exceptions:

- 1. Click the + *Add* button.
- 2. Choose the date.
- 3. Assign the day for that date.
- 4. Click *OK* to add the special day.

Repeat this process until you have entered all the desired custom calendar days. Click *OK* to save and close the dialog box: the calendar will appear in the calendar list, allowing you to assign it to your recording schedule.


The screenshot shows the "holidays*" dialog box with the "Days" tab selected. The table contains the same data as the previous screenshot. A sub-dialog box titled "Day" is open over the table. It has a "Schedule exclusion" section with "Date" and "Day" fields. The "Date" field is set to "6/24/2023" and the "Day" field is set to "Sunday". A red error message box says "'Date' field must be unique". At the bottom of the sub-dialog are "OK" and "Cancel" buttons.

Each date must be only present once in the calendar

In the list of days, click any entry and then click the *Pencil* icon to open it for editing.

Custom Days

Apart from the weekdays and weekends, you can define up to five additional alternative days and use them in your custom calendars. This feature is convenient when there are days when no daily recording pattern can be applied, e.g., early release pre-holiday days or other days with a special schedule.



Defined custom days with the recording pattern different from both weekdays and weekends

Custom days do not participate in the regular weekly schedule (without a calendar). You can assign any custom day to a particular date in your user-defined calendars.

Create Recording Configurations

Recording configurations are global recording arrangements that can be **assigned to channels** in the recording setup. Each recording configuration can be based on a single recording profile or a pre-defined recording schedule. Configurations are used as a proxy between profiles and channels, defining individual quotas and pre-recording buffers; such approach is a saver of the server memory.

To add a new configuration, click the down arrow button next to + *New recording configuration*.

Recording configuration Weekends*

Recording configuration

Details

Details

Title

Weekends

Recording profile as seen by others

Controlled by

Weekends Only (120)

Change...

Profile or schedule

Prerecording interval

10

Time interval to keep recording before alert was signalled in seconds (default is 10)

Amount quota (GB)

0

Maximum amount of data to be kept in stored archive

Duration quota (days)

5

Number of days to keep stored in archive footage

Recording configuration dialog box

Ganz CORTROL Global Administration Guide

The corresponding dialog box will appear, allowing you to enter configuration properties.

Setting	Description	Default Value
Title	User-defined recording configuration name	[empty]
Controlled by	Choose an existing recording profile or schedule for current configuration or create a new one from the sub-dialog	[none]
Pre-recording interval	Set pre-recording interval for alert-driven recording, if applicable; note that a large pre-recording interval will increase virtual memory usage. Maximum value is 60 seconds	10 seconds
Amount quota	Storage quota in GB: the maximum amount of space that can be taken up by recordings on each storage, if the maximum size is reached, the oldest footage will be deleted; set 0 to disable any limitations	0 (unlimited)
Duration quota	Duration quota in days: the maximum number of days that recordings are kept in the archive on each storage; after this, recordings will be erased; set 0 to disable any limitations	0 (unlimited)

Before setting recording limitations, make sure there is sufficient space in the server storage for all cameras. The quotas may be ignored if actual storage size is insufficient, and this will result in shorter footage durations.

Note that the maximum **pre-recording** time is 60 seconds. Larger values will be ignored by server core. Also, actual pre-recording buffer may be smaller if the server detects that it is not required (see below). The **actual buffer size** in seconds will be displayed in the *Monitoring* section, under *Streams*. It may differ from your pre-recording setting in the recording configuration. Ganz CORTROL server applies smart logic here and traces situations when larger buffer is not necessary, or even preventing the system from normal operation. Thus:

- if the currently used recording profile does not involve any pre-recording (e.g., *Continuous recording*, or event-driven with no defined E&A events), the buffer size will be reduced to 0 - this is absolutely normal, once you add any recording-triggering events, Ganz CORTROL will automatically increase the buffer size
- if there is not enough memory for all channels (the server is overloaded), the server will reduce pre-recording buffers; channels with largest frame cache size will have their buffers reduced first of all
- upon server startup, the buffer size is increased gradually for smoother start


If your pre-recording buffer size requires more memory than there available, you will see channels with top buffer size (in MB) appear marked red and with an * (asterisk) in the *Monitoring* section, under *Streams*. Also, the *Audit* section of Ganz CORTROL Console will contain events from the corresponding server stating that there is *Not enough memory to process frames*. If this happens regularly, review your server hardware using CBC AMERICA LLC provided hardware calculator and add more RAM to your server, or decrease the pre-recording interval duration wherever possible.



Note that quotas do **not** give priority to channels that are assigned configuration. For example, if you set duration quota to 10 days, it merely means that maximum allowed storage duration will be 10 days for a channel with given configuration; this will **not** cut down recording for other channels.

When you have finished, click *OK* to save and exit. The recording configuration will be added to the item list and will become available in channel recording configuration.


Ganz CONTROL Global Administration Guide



Choose a recording configuration for the channels selected

Note that you can only directly assign **configurations**, not profiles or schedules. Configurations are based on profiles or schedules (sets of profiles); please refer to the *Configure Recording Profiles* section of this document for details.

Click the + *New recording configuration* button below to create additional configurations from existing profiles/schedules at this point.



When you assign a **motion-based recording configuration** to a channel with a disabled motion detector, the software will automatically suggest enabling motion detection for the target channel. The camera-side detector is given priority; if it is not available, the software-side detector will be enabled and set to the high-performance mode. We recommend that you **review** the motion detector settings to make sure it operates as desired, especially if the camera-side detector is in use.

Ganz CONTROL Global Administration Guide

● Recording configuration Weekends*

Recording configuration

Details

Details

Title

Weekends

Recording profile as seen by others

Controlled by

Weekends Only (120)

Change...

Profile or schedule

Prerecording interval

10

Time interval to keep recording before alert was signalled in seconds (default is 10)

Amount quota (GB)

0

Maximum amount of data to be kept in stored archive

Duration quota (days)

5

Number of days to keep stored in archive footage

Add new recording configuration

Press *OK* to save and go back to the channel list: newly created recording configuration will be automatically assigned to channels previously selected.

Disable Recording

To disable recording for any channel(s), choose the *No recording* configuration, which is present in the list by default. If you have deleted it, simply create a new recording profile without any streams selected for recording and then create a recording configuration for this profile.

8.2 Archive Replication

In addition to the main recording configuration, each channel has an extra feature for the backup recording, which is called **channel replication**. The basic idea is that a channel copy - or replica - is created and can be set for recording on any server with a different recording profile and/or schedule. These kinds of channels have configuration constraints - e.g., you cannot change stream resolution - so it is only possible to affect recording settings by choosing a different recording profile and/or schedule.

The backup channel is not recorded directly from the data source (camera or other); instead, it is being replicated from the original recording that already exists on the server. This results in two important points:

- replication channel cannot contain more data than the original stream,
- replication feature is resistant to low bandwidth and connection failures.

For instance, if primary stream recording profile is set to record video only at 15FPS and based on motion, then, consequently, replication stream cannot be full-time video+audio at 25FPS due to a lack of data. Keep this in mind when configuring replication.



If you create replication channels after the main channels have been recording for some time, the replicas will copy the last **30 days** of the existing archive and the server-specific and individual quotas will be maintained from then on.

You can configure replication channels to be recorded on the same server as the source channel or on any other available server; if system architecture is distributed, especially on large-scale multi-site installations, dedicated **replication servers** are recommended. These are regular recording servers with only replication channels assigned to them.

When the **failover** mechanism is in action:

- If the source server (containing the original device aka replication source) is replaced by a failover node, and the replica is on another server (which is functioning normally), the replication process will continue as usual, provided that connection between the failover node and replication server is available.
- If the replication server goes offline and is replaced by a failover node, the replicas will pause and will not run on the failover server. Hence, you will not have an excessive archive copy. The replication process will resume once the target replication server is back. Thus:
 - It is not necessary to put pure (dedicated) replication servers into failover clusters, and
 - If a server has both normal devices and replicas, only regular devices will be covered by failover.

If replication is done from multiple servers (e.g., failover servers kicked in, or the source device was manually transferred to another server), you will see separate tracks in the playback mode of Ganz CORTROL Client. To view them all together, enable summary timeline in the application settings, and then drag and drop all tracks onto the viewing area.



If the replicated device is not assigned to any server - device will not work until it is assigned to the corresponding server. You can assign device to the server one-by-one, or selecting and editing multiple devices in a bulk.



Any number of replication channels can be created for each channel; both main stream and substream are available for recording in the replication channel settings.



Replicas are not subject to licensing; e.g., if your Ganz CORTROL license allows 100 channels, you can create any number of channel replications for each of these 100 channels. The feature itself is only available for Ganz CORTROL Global edition.


File-by-File Replication

When creating a replication channel, users now have the option to select File-by-File Replication. This mode offers distinct advantages and limitations compared to traditional replication:

1. **Speed:** File-by-file replication operates faster than standard replication but with a slight lag since only closed files are copied.


Ganz CONTROL Global Administration Guide

2. **No Alert-Based Replication:** This mode replicates whole files only; alert-based replication is unsupported.
3. **Mode Switching:** Switching between replication modes is not available. To switch from regular replication to file-by-file, create a new replication channel and delete the existing one.
4. **Data Integrity Handling:**
 - If source data contains errors, it is skipped temporarily and added to a review queue.
 - On startup, the replication process reviews the last MDAT file(s) for integrity. If issues are detected (e.g., due to an unexpected shutdown), it re-copies the previous portion to maintain data consistency.
5. **Audit Warnings:**
 - An audit warning will appear if the download speed is lower than the recording speed.
 - A critical event will be logged if storage is unavailable.
6. **Automatic Pausing:**
 - Replication pauses if storage is partially unavailable to prevent duplicate data cycles when the storage is back online.
 - To safely eject a storage disk, it must first be removed from the storage configuration.

 Files are considered identical if they have matching names, start times, and end times. If any part of the file (e.g., beginning or end) is altered, replication will create a new copy, resulting in doubled data but ensuring correct playback.

Pre-Configure Recording Profiles


Prior to creating a replication device, make sure you have arranged the necessary recording profiles and schedules and assigned them to recording configurations. A typical replication recording configuration may include low frame rate and recording during critical hours, and also may have a longer duration quota.

 A valid replication scenario could be as follows: the main stream is recorded continuously at 30FPS with audio and all available event data streams; primary replication channel has 10FPS, video+audio settings and secondary replication channel represents video at 15FPS with digital input events data.

Create Replication

The *Create replication* button is available on the upper panel in the *Channel* view, which can be accessed in two ways:

- choose the *Configuration* section and then click *Channels* in the left Ganz CONTROL Console menu - this view contains all available channels and channels groups;
- while in *Devices*, click *View channels* button on the upper panel - this view will only display device-specific channels.




TITLE	ID	DEVICE	ORGANISATION	SERVER	IP
✖ Samsung SNP-3120V on 192.168.3.11	(114)	Samsung SNP-3120V on 192...		Primary (101)	1
✖ Secret Gate on 192.168.3.4	(109)	Axis 215 PTZ on 192.168.3.4 (... Torchwood (116)		Primary (101)	1
✖ Vivotek IP816A on 192.168.3.12	(111)	Vivotek IP816A on 192.168.3...		Primary (101)	1
✖ Vivotek PZ7131 on 192.168.3.19	(110)	Vivotek PZ7131 on 192.168.3...		Primary (101)	1
✖ Vivotek PZ7131 on 192.168.3.19 [Replication]	(170)	Vivotek PZ7131 on 192.168.3...		Primary (101)	

Create replication in *Channels* view

Select one or multiple channels in the list, then click the *Create replication* button on the top panel. A small dialog box will appear, allowing you to set the destination server and recording configuration for the replication at once. You can change these settings anytime later by going to the **device and channel settings** as described below.

Ganz CORTROL Global Administration Guide




Pop-up dialog box with basic replication settings

The created replication channel will appear right next to the original channel in the full channel list (note that it may not be visible in a single-channel view or when specific filters are active). All channel settings will be duplicated, the channel name will receive a *[Replication]* tag and the device model will be set to *Generic [Replication]* type (which is unchangeable).

You can change the settings of any replica similarly to regular devices and channels.

Device Settings

To change the settings of a replication device, go to *Configuration* section and then click on *Devices* in the menu on the left. On the bottom panel, select *Replication* filter to display replication devices only (the active filter is highlighted blue; to deactivate it, click highlighted filter once again).



Use filter to show replication devices only

Select one or multiple devices (hold down *CTRL* or *Shift* to select several items at once) and click the *Assign server* button on the upper panel, then select the target server from the pop-up dialog box and click *OK* to save.


Double-click on any device or click the *Edit* button on the bottom panel to open device editing dialog box and change permissions and membership settings.

Channel Settings

To edit the replication channel settings, switch to *Channels* section; on the bottom panel, select *Replication* filter to

Ganz CONTROL Global Administration Guide

display replication channels only. Click each individual channel to open its configuration dialog box and assign recording configuration, and set organization attachments, if desired. Membership and user privileges can be set on the corresponding tabs, just as for usual channels.


 You can delete replication channels and devices just as any usual channels/devices. Note that source channels cannot be deleted until there exists at least one channel exists to replicates them.

If all the steps above have been completed successfully, your devices will now have backup recording configured. Archive recorded from replication channels can be played back in the same way as regular archive via Ganz CONTROL Client. Live previews are not available as replication only provides recording.

Smart Replication


After creating the replicated channel, you can also enable the **Smart replication** feature. This feature allows the replication of only those parts of the stream that have attached events. To set this feature, you need to:


1. Go to *Configuration -> Channels -> Your replicated channel*.
2. Click the *Edit* button on the top of the *Channels* subsection or double-click **Your replicated channel**.
3. Inside the left subsection of the pop-up window, Locate the *Replication* tab.
4. At the top of the *Replication* subsection, mark the *Enable smart replication* checkbox.
5. New input fields will appear:
Prerecording interval - The length of the video to save before the alert, in seconds.
Post-recording interval - The length of the video to save after the alert, in seconds.
Maximum number of alert events - Maximum allowed alert number in the queue if replication target is not available at the moment. New *Alerts* will not be added to the queue if limit is filled.
6. Set your pre- and post-recording intervals and confirm your input with the *Apply* and *OK* buttons.



Replication pop-up window. The full path and main features are marked with red ellipses.

After enabling *Smart replication*, you can go to the *Events & Actions* and create an *Alert* action for the replicated channel.

 **N.B.** Make sure the replicated channel *Recording profile* is set to a *Continuous recording*.


 Make sure that the source channel recording profile covers alert intervals. If there are no records in the source channel, there will be nothing to replicate, even if the attached event triggers an alert in the replicated channel.

Ganz CORTROL Global Administration Guide

Replication Events

To set replication events - go to:

1. *Events & Actions* -> *Rules*
2. On the top of the *Rules* subsection, select the server and then click the *Open Configurator* button. This will bring the *Events & Actions configurator* pop-up window.
3. Inside the *Events* subsection of the configurator, find your replicated channel and select the corresponding *Event* from the list.
4. After adding The *Event*, find the *Generate alert* action inside the *Actions* subsection for the corresponding channel and add it to the *Rule*.
5. Confirm your setup with the *OK* button.



Example of the Replication channel Events & Actions.

Now, you are ready to replicate the channel based on the corresponding events.

9 Add Users and User Groups

User management is accessible via the *Users* component of the *Configuration* section. By default, the system already features a built-in global Administrator account and built-in Administrators group.

The built-in Administrator user account and built-in Administrators group are root users with access to absolutely all the available resources. As a result, resources choice is unavailable for the Administrators group, and it is also impossible to add Administrator user to any other group.

Any users added as members to the built-in Administrators group will have the same full authority as root users.

Configuration > Users

Search

Configuration

Servers

Users

Devices

Channels

Recording

Layout templates

Configuration

Monitoring

+ New user

Edit

Assign group

✕ 1 selected

TITLE	ID	LOGIN NAME	ENAB...	EMAIL
Built-in Administrator account	(1)	admin	yes	
Built-in Administrators group	(3)			

Recently added, 0

Recently updated, 0

Groups, 1

Users, 1

Configuration -> Users

Add Users

Click the + *New user* button on the upper panel to bring up the configuration dialog box.

Details

Enter user login information here.

Ganz CORTROL Global Administration Guide

The screenshot shows a 'User jtkirk*' window with a sidebar containing 'Details', 'Membership', and 'Resources'. The 'Details' tab is active. The main area contains the following fields and options:

- User login name:** jtkirk (Account name to log into the system. Case-sensitive)
- Active:** ☒ (Remove to disable account for any connection type)
- User's full name:** James T. Kirk (Insert user's first name and last name)
- Email address:** jtkirk@domain.com (Email address for notifications)
- Set password:** ☒ (Password to log into the server and Reenter password fields are visible)

At the bottom right are 'OK' and 'Cancel' buttons.

Enter user details

The table below describes in detail the available settings.

Setting	Description	Default Value
User login name	Alphanumeric user name for login, no spaces allowed	empty
Active	Allow the user to log in via Ganz CORTROL Console and Ganz CORTROL Client: any users who have been disabled will not be able to use software	Enabled
User full name	User full name	empty, automatically filled from login name
Email address	User email address used for notifications	empty
Phone number	Phone number in international format (with country code) for 2FA	empty
Set/new password	Check to enter a password - this is obligatory when creating a new user	empty
Password never expires	User will not be prompted to change his password once in a while; enable this to ensure a permanent password for this user account (this setting can be overridden by the <i>User must change password..</i> setting in the same dialog box); otherwise, password will expire after the number of days specified in the server security policy	Disabled (not selected)
User must change password at next logon	User will be prompted to change his password upon his next logon attempt; enable this if you want to force user change the password even if his password is set to never expire	Disabled (not selected)
User cannot change password	Enable this to prevent the user from changing his password; this option is not available if user password is not permanent or if you have selected to force user change their password at next logon using the settings above	Disabled (not selected)
Organization	Choose an organization to which this user belongs	none

Ganz CORTROL Global Administration Guide

PTZ priority	Used for PTZ cameras and interactive CrossLink devices. 0 = lowest, 10 = highest	5
PTZ priority timeout	The amount of time for the PTZ controls to be locked after each user's action	10s
Override default limit of simultaneous connections	Maximum number of simultaneous connections allowed from this user account; the setting has priority over server-defined limitations; 0=unlimited	Disabled (not selected)
Set account activation time	If option is enabled and user is not Active - this will enable account at particular date and time.	Disabled (not selected)
Set account expiration time	If enabled, the user account will be automatically deactivated on the specified date at the specified time	Disabled (not selected)

*See below to learn more about how PTZ priorities work.

PTZ Priority will be used to for **PTZ control** of speed domes, and also for the control of [interactive video channels](#) (CrossLinks allowing users to control **remote Web and Desktop** applications). After each action (click), the control will be locked onto the user with the higher priority for the amount of time specified as PTZ Priority Timeout (10 seconds by default).

If two or more users try using PTZ control of a device at the same time, **PTZ priority** is used to decide who gains access first: user with a lower priority is blocked for ten seconds to allow a higher-priority user to use PTZ. If two users with the same PTZ priority have an access conflict, they will be both granted PTZ access simultaneously.

Default PTZ priority for all users, including those built-in and imported, is equal to five (medium priority). You can assign any user a higher PTZ priority (six to ten) or a lower one (four to zero) by editing individual user properties.



Some user settings like PTZ priority are not updated immediately: the user will have to log out and then back in for the changes to take effect.



Deleting a user also removes all the settings related to that user; restoring these may be time-consuming. Use the *Active* setting to temporarily block access for selected users: users not marked as **active** will be unable to perform any actions in Ganz CORTROL and can be restored with a single button click.

Ganz CONTROL Global Administration Guide

PTZ Priorities

PTZ priority is used to for:

- manual control of PTZ cameras (speed domes),
- automated PTZ control (tours and presets),
- control of [interactive video channels](#) (CrossLink devices allowing users to control **remote Web and Desktop** applications).

PTZ related user actions include manual PTZ control (mouse clicks) and the calling of PTZ presets and tours. [CrossLink](#) control involves manual interaction (mouse clicks).



PTZ tours always have zero (the lowest) priority, no matter who initiates it, so that any user can interrupt it.

After each user action, the control is locked onto the user with a higher priority for the amount of time specified as PTZ priority timeout (10 seconds by default). PTZ priority is used to decide who gains access first: user with a lower priority is blocked for N seconds to allow a higher-priority user to use PTZ. If two users with the same PTZ priority have an access conflict, they will be both granted PTZ access simultaneously.

If two or more users try controlling the **same device at the same time**:

- if both users have **the same** PTZ priority, the timeout will be ignored and each user's action will immediately take effect
- if user A has a **higher priority**, his first action will take control from user B with a **lower priority** and lock the control for the specified timeout, preventing everyone with a priority lower than A's from controlling the device; once the time is out, any user can try gaining the control again

Thus, the PTZ priority timeout is only taken into account when taking over control, and does not matter when the users have equal priorities.

Default PTZ priority for all users, including those built-in and imported, is equal to 5 (five, medium priority). You can assign any user a higher PTZ priority (six to ten) or a lower one (four to zero) by editing individual user properties.

For **PTZ preset actions** in [E&A](#), you will be asked to specify the PTZ priority when creating the action. For **PTZ tour actions**, the priority is always 0, allowing any user to interrupt the preset execution.

Ganz CORTROL Global Administration Guide

Membership

Choose which groups you want the selected user to be a member of. Every user can participate in one or multiple groups, depending on the system structure.

User John Doe*

User

Details

Membership

Resources

Membership

Selected groups			Available groups		
TITLE	ID	TYPE	TITLE	ID	TYPE
Local admins	(127)	User group	Built-in Administrators ...	(3)	User group
			Operators	(125)	User group
			Admins	(126)	User group

Remove

Add

OK

Cancel

Add the groups you want the selected user to be a member of

Manipulate the groups by double-clicking a group or using the *Add/Remove* buttons below. Use the *Search* field in the upper-right-hand corner to filter the groups available.

Resources

Each user can be granted [permissions](#) for server and channel/channel group administration. Select resources by adding at least one permission; remove them by clearing permissions using the *Clear* button below, or simply by double-clicking them in the *Selected resources* list.

User John Doe*

User

Details

Membership

Resources

Resources

Selected resources			PERMISSIONS	Available resources		
TITLE	ID	TYPE		TITLE	ID	TYPE
Central Server	(101)	Server	<input type="checkbox"/> Administer	Asoni CAM613...	(102)	Device
Asoni CAM613...	(105)	Channel	<input checked="" type="checkbox"/> ReceiveData	(Generic) ONVL...	(103)	Device
(Generic) ONVL...	(106)	Channel	<input checked="" type="checkbox"/> AccessArchive	Asoni CAM613...	(104)	Channel
Vivotek IP7131...	(112)	Channel	<input checked="" type="checkbox"/> Navigate	Vivotek IP7131...	(107)	Device
			<input checked="" type="checkbox"/> ControlDigitalOutput	Grundig GCI-K...	(108)	Device

Clear

OK


Cancel

Add resources for selected user

Click *OK* when you have finished to return to *Users*; the newly created account will be added to the item list. Use the buttons on the upper panel to edit user details at any time, to quickly assign groups and remove specified users (hold *CTRL* or *Shift* to select multiple items at once).

If there are a large number of user accounts, the *Search* field in the upper-right-hand corner and the content filters in the bottom panel can help you quickly find the accounts you are looking for.


Ganz CORTROL Global Administration Guide

 If some resource permissions are defined for some user via **user groups**, these permissions will be displayed if you open permission list of the target user: these will appear **gray** and will not be available for editing.

Add User Groups

If there are a large number of user accounts, it may be more convenient to create multiple user groups and then distribute the resources between user groups, rather than between individual users. One user can be a member of several groups.


Click the down arrow near the + *Create new user* button and select *New user group* from the drop-down list to bring up the configuration dialog box.









The screenshot shows a configuration dialog box titled "User group Remote Operators*". The "Details" tab is selected in the left sidebar. The main area has a "Title" field with the text "Remote Operators" and a label "Group name" below it. At the bottom right are "OK" and "Cancel" buttons.

New user group

In the *Details* tab, enter the group name.



The screenshot shows the same configuration dialog box, but the "Members" tab is selected. It features a search bar at the top right. Below is a table with two columns: "Selected members" and "Available members".


Selected members			Available members		
TITLE	ID	TYPE	TITLE	ID	TYPE
 John Doe	(124)	User	 Built-in Administrator a...	(1)	User
 Operators	(125)	User group	 Built-in Administrators ...	(3)	User group
			 Admins	(126)	User group
			 Local admins	(127)	User group

At the bottom of the table are "Remove" and "Add" buttons. "OK" and "Cancel" buttons are at the bottom right of the dialog.

Choose group members

In the *Members* tab, choose which users and/or user groups will become members of the target group: manipulate items by double-clicking them or using the *Add/Remove* buttons below.

Ganz CONTROL Global Administration Guide



Choose group membership

In the *Membership* tab, select the group(s) you want to include the current group as a member: manipulate items by double-clicking them or use *Add/Remove* buttons below.

Finally, you can grant resources permissions using the *Resources* tab in a similar way to adding a single user. Select resources by adding at least one permission; remove them by clearing the permissions using the *Clear* button below, or simply by double-clicking them in the *Selected resources* list.

Click *OK* when you have finished to return to *Users*; the newly created group will be added to the item list. Use the buttons on the upper panel to edit the group details at any time. If there are a large number of user accounts, the *Search* field in the upper-right-hand corner and the contents filters in the bottom panel can help you to quickly find the accounts you are looking for.


Time-based Access

Starting with version 1.26, you can limit user access options based on the **schedules**. To do so, go to:

1. *Configuration* -> *Users* -> your particular user
2. Inside the *User* pop-up window select *Time-based access* -> *Change* button
3. Pick up the existing *Schedule* from the list or create a new Schedule by pressing the *+New Schedule* button
4. confirm your choice with the *OK/Apply* buttons.

After that, user access will be limited by the applied Schedule.

Ganz CONTROL Global Administration Guide



Example of Time-based access tab

N.B. If user belongs to multiple groups and user access is enabled at least in one group - user will have access!

You can learn how to create a new [Schedule here](#).

Activate/deactivate User Accounts by Date and Time

It is possible to disable user accounts by setting up a date and time. To set timings, go to:

1. *Configuration -> Users -> affected user -> Details*
2. Scroll to the bottom of the section and mark the checkbox *Set account expiration time*.

By default, new users are created as *active* users, so if you want to set up account activation time, do the following:

1. Go to *Configuration -> Users -> affected user -> Details* and unmark the checkbox *Active* next to the *User Login Name* field.
2. Scroll down to the bottom, check the checkbox *Set account activation Time*, and set the date and time for a particular user account to be enabled.

N.B. By default, disabling the user account on the schedule does not disconnect the user automatically, and, while the session continues, the user will preserve all the provided access options.

To restrict user access instantly, you need to set up Server behavior.

Go to *Configuration -> Servers -> your server -> Security policy*, scroll down to the bottom, and mark the *Disconnect disabled users* checkbox.

That setting will ensure that any disabled user is disconnected from the server instantly no matter if the current session is still active.

Ganz CORTROL Global Administration Guide

9.1 Permissions and Membership

You can handle the user and user group **access permissions** for channels, devices, servers and other resources via the *User* and *User group* configuration dialog box -> *Resources* tab, or via resource settings -> *Permissions* tab. **Administrative permissions** are handled in the *Edit User/User group* dialog box, under the *Administration profile* tab. Most of the events that are raised as a permission is used are logged in the *Audit log* and are available in the *Audit* section of Ganz CORTROL Console.



Please note that some of the permissions may not be applicable to your software license edition.



In Ganz CORTROL version **1.6.0**, major changes were made to permission management. As a result, configuration imported from an **XML** file (from ZNSNVR) will **not** contain any user permissions: you will need to **review and set all user permissions after importing the configuration**.

Access Permissions

All the available resources are listed in the column on the right; click any item to load the permission list in the central column. Then, **mark** all the permissions you wish to grant; resources having at least one permission enabled will be automatically moved to the left column.

All permissions also affect all corresponding requests over API connections.

Permission management example

To **remove** all permissions for some resource, simply double-click it in the *Selected resources* list on the left.



It is not possible to select **multiple** resources for the permission management. You are welcome to use resource **grouping** (e.g., channel groups) for easier and faster permission management.

When permissions are inherited from some group(s), a corresponding mark will appear in the central column next to the permission type.

The following types of permissions are available (each one can be defined separately):

- **Server**
 - **Playback:** allows users to access recorded video, audio, VCA metadata and external data from the specified server for those recordings that do not have corresponding channels in the server configuration (i.e., **orphan archive tracks**)
 - **Export:** allows users to export video clips and snapshots from such recordings
- **Channel**
 - **Live:** access live video, audio, VCA metadata, external service data, external data (from *Data Sources*), send audio OUT and export snapshots from the live view mode

Ganz CONTROL Global Administration Guide

- **PTZ:** general **PTZ control**, preset and tour usage, preset and tour management OR **interactive control** of [CrossLink](#) devices
- **Playback:** access to recorded video, audio, VCA metadata, external service data, external data (from *Data Sources*), snapshot and video clip export from all playback modes, view and manage bookmarks
- **Restricted playback:** same permission set with a time limitation**
- **Uncategorized:** back up and delete archive, protect archive from deletion, remove protection
- **Push external metadata:** if this user is used for an external service connection, make sure to add this permission for the server to accept the external service metadata (e.g., analytics bounding boxes)
- **Trigger channel external event:** if this permission is enabled, the target user account can be used to trigger individual channel's [external events](#)
- **External Service Group**
 - **View live data:** see the live data coming from the external services in the target group
 - **External service search:** browse recorded external service data
- **Layout**
 - **View:** see and use the layout in Ganz CONTROL Client
 - **Manage:** delete or replace existing layouts via Ganz CONTROL Client
- **Layout Group**
 - **View:** see and use layouts from the target group in Ganz CONTROL Client
 - **Manage:** add new shared layouts from Ganz CONTROL Client and delete existing layouts
- **Visual Group**
 - **View:** see visual group contents in Ganz CONTROL Client*
- **Map**
 - **View:** see and use the map in Ganz CONTROL Client
- **Webpage**
 - **View:** see and use the webpage in Ganz CONTROL Client
- **Software Counter**
 - **Access archived VCA metadata:** see the counter in Reports in Ganz CONTROL Client
- **Video Wall**
 - **View:** see and use the video wall in Ganz CONTROL Client
 - **Manage:** change video wall contents via Ganz CONTROL Client
- **User Button**
 - **View:** see and use the target user button to viewports in Ganz CONTROL Client and in Ganz CONTROL Mobile applications

Starting from the software version 1.15.0, it is possible to grant individual rights for software counters. However, if the *Access archived VCA metadata* permission has been given for the **whole server**, the target user or user group will have access to **all counters** on that server, regardless of the individual counter permissions.



*A visual group will only be displayed in Ganz CONTROL Client if the user has permissions to see at least one visual group element.

The permission sets under **time-limited Restricted video playback and **full Video playback** are essentially the same. The difference is that restricted access only allows users to access the last N minutes/hours/days of the archive. Therefore, the two sets are mutually exclusive. The **restricted interval** is defined individually for each server in the server **storage settings**.

When you have finished, click *OK* to save and exit.

Administrative Permissions

Administrative permissions for the resources, servers and connections can be managed via *Administration profile* tab in the user management dialog box.

Ganz CORTROL Global Administration Guide



Giving a user at least one permission from the *Console* section will allow this user to log into the target server via Ganz CORTROL Console. The corresponding resources will be available for configuration and all the rest of the contents will be hidden.

The following types of permissions are available for per-user/per-user group configuration:

- **Client**
 - Login via **Monitor**: connect to the target server via Ganz CORTROL Client application
 - Login via **Monitor** without entering **login reason**: if unchecked, the user will be prompted to enter a justification (comment) before logging in
 - Login via **HTTP**: connect to the target server via Web client and from external services, including LPR and FR
 - Login via **Mobile**: connect to the target server from Ganz CORTROL Mobile and OS X app
- **Console**
 - Manage **folders, servers, users, permissions, networks, external services**: enables the user to access the configuration of the corresponding server contents
 - Manage **devices, device channels, visual groups, layouts, layout templates, video walls, maps, data sources, user buttons, shared channels**: enables the user to edit existing and create new (if applicable) resources of the given type
 - Manage recording: create and edit **recording profiles, schedules and configurations**
 - Manage Event & Action rules: create, remove and edit events, actions and all the related resources in the **Events & Actions section**, including mail servers, conditions etc., regardless of permissions for the source items
 - Access **audit log and monitoring section**: view all the information in the server *Audit* and in the *Monitoring* sections
 - Manage **auto backup**: access scheduled backup configuration
 - Start wizard: allows users to run the **quick setup wizard** via Ganz CORTROL Console for step-by-step configuration
 - **Remote upgrade**: access the remote upgrade section of Ganz CORTROL Console, set up and do the remote upgrade procedure
 - **Import configuration**: load configuration from XML (from the old product version) and import existing Ganz CORTROL database

Starting from version 1.13.0, there is an additional user permission under *Administration profile*: log into Monitor application without entering **login reason**. If this permission is granted, users will log into the Ganz CORTROL Client application as usual; if not, an additional prompt will pop up, asking them to enter a justification for logging into the server.

Membership

Users can be grouped logically to make permissions management easier. Groups can overlap, meaning that a single user can belong to multiple groups at once, and some groups can be nested - i.e., one group can contain one or more other groups. In addition to own permissions, each user inherits permissions from all the groups he is currently in.

To manage user membership from the user configuration dialog box, double-click any user. This will open the properties window, where you can switch to *Membership* tab. Here you can pick which group - or groups - this user will be a member of.

Ganz CORTROL Global Administration Guide

User John Doe*

User

Details

Membership

Resources

Membership

Selected groups		Available groups	
TITLE	ID TYPE	TITLE	ID TYPE
Operators	(125) User group	Built-in Administrators ...	(3) User group
Local admins	(127) User group	Admins	(126) User group
Remove		Add	

OK

Cancel

User membership

Double-click on groups or use the *Add/Remove* buttons below to move groups between columns. When you have finished, click *OK* to save changes and exit.

Alternatively, you can select one or multiple users from the users list, then click the *Assign group* button on the upper panel: a list of available groups will appear, allowing you to select one of the existing groups. After this, click *OK* to add selected users to the target group.

Configuration > Users

Built-in Administrator account

Search

Configuration

Servers

Users

Devices

Channels

Recording

Layout templates

New user

Edit

Assign group

2 selected

TITLE	ID	LOGIN NAME	EMAIL
Built-in Administrator account	(1)	admin	
John Doe	(124)	johndoe	johndoe@em...
Admins	(126)		
Built-in Administrators group	(3)		
Local admins	(127)		
Operators	(125)		

Recently added, 0

Recently updated, 1

Groups, 4

Users, 2

Select multiple users and assign them to a group

We strongly recommend grouping users and resources as it makes the permission management process much easier. Individual user permissions can be combined with permissions inherited from multiple groups at once.

Permission Sets and Dependencies

Permission management in Ganz CORTROL is flexible and allows each individual user permission to be enabled separately, thus giving the Ganz CORTROL administrator full control over the system. Sometimes, in order to give enough user rights for specific use case, several different permissions should be granted. This section covers some

Ganz CORTROL Global Administration Guide

examples and gives you an idea of what permissions may be related, as well as explains some peculiarities about the permission management in Ganz CORTROL.

General

Administration profile permissions to manage maps, visual groups, live podcasts etc. include access to all channels from the *Edit* dialog of these entities. For example, a user is granted permission to manage maps but does not have any per-channel permissions: when creating a map, he will be able to put channel markers on it and associate these markers with any channels on the server. At the same time, he will have no access to the channel management whatsoever.

Allow a User to Add New Devices

In order to enable a user to add new cameras or devices of other types, it is necessary to grant the following permissions from the *Administration profile*:

- *Manage devices*
- *Manage device channels*

This is necessary as devices and channels are related entities in Ganz CORTROL and a single *Manage devices* permission is not enough as new channels are created automatically alongside with the newly added devices.

The *Manage devices* permission itself allows the user to change device settings (e.g., IP address, group membership) and create new device groups.

Access Data from Third Party Services

To see the data from external services (e.g., LPR/FR recognitions, third-party integrations via HTTP API) in the live view notification panel or search the past records, the following permission sets are required:

- **Live:**
 - *View live external service data* (per-channel permission under *View live video* permission group)
 - *View live external service data* (permission for the external service group)
- **Archive:**
 - *External service search* (per-channel permission under *Video playback* permission group)
 - *External service search* (permission for the external service group)

This allows to cover the case when one channel belongs to several different external service groups.

Archive Backup

Archive backup permissions have the following logic:

- *Make archive backups* permission from the *Administration profile* allows Archive Backup Wizard login
- *Backup archive* per-server permission from the *Video playback* permission group grants access to the orphaned archive tracks (recordings that exist on the server but do not have any existing channels in the system configuration associated with them)
- *Backup archive* per-channel permission under *Video playback* permission group grants access to the footage of the target channel via Archive Backup Wizard

Snapshot Export

For a user to be able to save multichannel snapshots from the *Archive playback* mode, the *Export snapshots from playback* permission must be granted for all channels present in the layout.

9.2 Active Directory and LDAP User Import

Ganz CORTROL allows you to import users and user groups from the existing Active Directory/LDAP service database. The only thing that is left to do is to specify permissions for the imported users and/or user groups (referred to as *AD users* further in this topic).

Please keep in mind that in multi-server systems - using Ganz CORTROL Global - all recording servers must belong to the domain for the AD/LDAP imported users to be able to access their resources - streams and the recorded video archive. If some of the servers are out of the domain, external users will be unable to connect to them (this happens automatically, in background) and there will be errors instead of the video streams.

Active Directory and LDAP user import is available in the following Ganz CORTROL versions:

- Ganz CORTROL Global - fully supported for all versions
- Ganz CORTROL Server v.1.4.1 - 10 users
- Ganz CORTROL Server v.1.5.0 and newer - fully supported



AD/LDAP imported user accounts can be used to log into Ganz CORTROL Console, Ganz CORTROL Client, and Web client for Ganz CORTROL Streaming Server. These user accounts **cannot** be used in Ganz CORTROL Mobile applications at this point.

Note that it is not necessary for you to be logged into Windows under the same AD account; rather, once AD accounts are imported as external users into Ganz CORTROL, you can use any valid AD account credentials to log into Ganz CORTROL Console or Ganz CORTROL Client. Also, note that you are always required to enter the password for the AD account, even if you are logged under the same user account in your current Windows session.



If you are using [AD/LDAP](#) user accounts for the **Web login**, we strongly recommend that you [turn on HTTPS](#) for enhanced safety. Plain HTTP will work, too, but is not recommended for security reasons.



For you to be able to log into a Ganz CORTROL server with an AD user account, you must be able to log into the target server computer with the same AD account. If you are unable to do so, contact your Windows administrator and let him check the effective policies.

In order to use your imported AD account with Ganz CORTROL, type in your full domain name and user name, and then specify the password. Please see the description below on how to add your AD users into Ganz CORTROL.

Ganz CORTROL Global Administration Guide

Login

Server

localhost

IP address or host name of the server

Username

ad.mydomain.com\himmelske.danser

Username

Password

.....

Password

OK

Cancel

AD user login example

Add Active Directory and LDAP Users

In Ganz CORTROL Console, open the *Configuration* section and choose *Users* from the menu on the left; then, click the little arrow next tot the *+New user* button and choose *New external user group* from the drop-down list.

Configuration > Users

Built-in Administrator account

Search

Configuration

Fallover clusters

Users

Devices

Configuration

Events & Actions

Monitoring

Audit

+ New user

Edit

Assign group

1 selected

New user group

New external user group

	TITLE	LOGIN NAME	ORGANISATION	ENABLED	EMAIL
Built-in Administrator account		admin		yes	
Built-in Administrators group					

Recently added, 0

Recently updated, 0

Groups, 1

External groups, 0


Users, 1

External users, 0

Create new external user group from the *Users* menu section

On the *Details* tab, click the *Change* button next to the empty *External group* field in order to load the available AD group list in a separate dialog box.


Ganz CORTROL Global Administration Guide



The screenshot shows a window titled "External user group *". It has a sidebar on the left with tabs: "Details" (selected), "Members", "Membership", and "Resources". The main area is titled "Details" and contains a form with a label "External group" above a text input field. To the right of the input field is a red "X" icon and a "Change..." button. Below the input field is a label "External group". At the bottom right of the window are three buttons: "Apply", "OK", and "Cancel".

New external user group

Ganz CORTROL will automatically fetch all user groups available via your Windows AD service. Pick a group from the list of available AD user groups and confirm your choice either with a double-click or using the *OK* button below.



The screenshot shows a window titled "Available external groups". It has a search bar at the top with the text "admin" and a magnifying glass icon. Below the search bar is a list of groups under the heading "Available external groups". The list has a column header "Title". The groups listed are: Administrators, Hyper-V Administrators (highlighted in green), Schema Admins, Enterprise Admins, Domain Admins, DnsAdmins, Local WKS Admin users, DHCP Administrators, Local WKS Admin PCs, sysadmin, and jira-administrators. At the bottom right of the window are two buttons: "OK" and "Cancel".

Available AD groups

The selected user group will appear in *External group* field in the *Details* tab. Switch to the *Members* tab to view the imported user list.

On the *Membership* tab, you can choose an internal user group to contain the newly imported external user group

Ganz CORTROL Global Administration Guide

(nested grouping). All user permissions inherited from the higher level group will be applied to the members of the imported external user group and will be displayed as grayed out in the *Resources* tab.

External user group *

External user group

Details

Members

Membership

Resources

Membership

Selected groups		Available groups	
TITLE	TYPE	TITLE	TYPE
		Built-in Administrators group	User group
<div>Remove</div>		<div>Add</div>	

Apply

OK

Cancel

You can make the external user group a part of some other internal user group

If you have decided to make no nested groups or wish to add more permissions specifically to the AD user group, go to the *Resources* tab to manage the user permissions.

External user group *

External user group

Details

Members

Membership

Resources

Resources

Selected resources		Permissions		Available resources	
TITLE	TYPE	PERMISSION	INHERITED FROM	TITLE	TYPE
Hall	Video wall	<input checked="" type="checkbox"/> Administer		Global Server	Server
		<input checked="" type="checkbox"/> View		Global Server net...	Network
		<div>Clear</div>		Axis 215 PTZ on 1...	Device
				Vivotek IP816A o...	Device

Apply

OK

Cancel

Manage user permissions on the *Resources* tab

Select resources by adding at least one permission; remove them by clearing the permissions using the *Clear* button below, or simply by double-clicking them in the *Selected resources* list.

Click *OK* when you have finished to return back to *Users*; the newly created external user group as well as all users contained in that AD group will be added to the item list. Use the buttons on the upper panel to edit the group details at any time. If there are a large number of user accounts, the *Search* field in the upper-right-hand corner and the contents filters in the bottom panel can help you to quickly find the accounts you are looking for.

Edit External Users Or User Groups

After adding the external user group, you can edit the group properties as well as individual external users. In order to do this, select the target user/user group in the list and click the *Edit* button on the upper panel, or, alternatively, simply double-click the desired item to bring up the configuration dialog box.

Editing an external user group will be pretty much the same as adding a new one; individual external user settings will have some differences comparing to the regular, built-in user settings.

Ganz CONTROL Global Administration Guide

User ad\vera

User

Details

Membership

Resources

Details

User login name

ad\vera

Account name to log into the system. Case-sensitive

☒ Active

Remove to disable account for any connection type

User's full name

Vera F

Insert user's first name and last name

Email address

vera@lu.com

Email address for notifications

☐ New password

Password will not be changed

Organisation

none

Change...

Organisation to which the user belongs

PTZ priority

5


PTZ priority

OK

Cancel

Edit imported user

On the *Details* tab, the only settings available for editing will be user account status (enabled by default) and PTZ priority (which will be 5, by default). All the other properties will be grayed out as they cannot be changed via Ganz CONTROL and should be changed via Active Directory instead.



If two or more users try using PTZ control of a device at the same time, **PTZ priority** is used to decide who gains access first: user with a lower priority is blocked for ten seconds to allow a higher-priority user to use PTZ. If two users with the same PTZ priority have an access conflict, they will be both granted PTZ access simultaneously.

Default PTZ priority for all users, including those built-in and imported, is equal to five (medium priority). You can assign any user a higher PTZ priority (six to ten) or a lower one (four to zero) by editing individual user properties.

On the *Membership* tab, you can choose an internal user group to contain the AD user as a member. All user permissions inherited from the group will be applied to the target AD user and will be displayed as grayed out in the *Resources* tab. You can assign additional user-specific permissions on the *Resources* tab.

Ganz CORTROL Global Administration Guide

9.3 Anonymous User

Anonymous user is a built-in user account, which has been designed for unauthorized access to video streams via HTTP API - a very basic example of Ganz CORTROL API usage.


Briefly, here is the procedure that enables you to get video via link:

- 1. Enable Anonymous user
- 2. Grant them permission(s) to view live channel(s)
- 3. Enable resource IDs in the Ganz CORTROL Console settings
- 4. Look up server IP and port, and channel ID to form the link

The procedure is described in more details below.


The anonymous user is **disabled by default** and does not have any permissions. In order to allow HTTP access:

- **enable** the anonymous user: double-click him in the user list, mark him as active, then save;
- **add** the *View live video permission* for this user in the properties of the target channel(s).



Add permission for the anonymous user to receive live view data

Now you can use a short link to receive live video feed over HTTP from your configured channels without authorization.



Live stream received with anonymous URL

Ganz CONTROL Global Administration Guide

The link can be embedded, for example, into your own webpage to provide 'Live Cam' functionality.



HTTP **link** is built as follows:

IP:PORT/publicLive/<channel_id>/mainStream

where


- *IP* is server IP address or hostname,
- *PORT* is server HTTP port (8080 by default),
- *<channel_id>* is internal channel identifier, which can be looked up in Ganz CONTROL Console when IDs are enabled in the application settings.

Example: *192.168.1.83:8080/publicLive/184/mainStream*



This functionality requires that [Streaming Server](#) is enabled (HTTP port is not set to zero in the target server settings).

In order to see the channel identifiers in Ganz CONTROL Console, go to the application settings via main menu button in the upper-right-hand corner and choose *Settings*. In the dialog box, enable the *Show object IDs* option and save.



Enable object identifiers in Ganz CONTROL Console



Starting with Ganz CONTROL Console version 1.25, you can also use all the available permissions for the *Anonymous* user.

To add custom permissions to Built-in Anonymous user:


1. Go to *Configuration -> Users -> Anonymous* and double-click on it or click the *Edit* button.
2. Select *Resources* from the left menu and use the *Permissions* tab as with any other user.


Read more on how to manage [Permissions](#).


10 Streaming Server Configuration

The Ganz CONTROL Streaming Server allows quick and easy access to your cameras via web browser and/or native mobile applications.

Ganz CONTROL Streaming Server is a part of Ganz CONTROL software integrated into the Ganz CONTROL core. It is designed for video streaming to multiple web-browsing platforms such as Mozilla Firefox and Google Chrome. Some major Ganz CONTROL Streaming Server features are: video stream live view, archive playback, Pan-Tilt-Zoom control. The Ganz CONTROL Streaming Server optimises video streaming for web or mobile clients, to a degree dependent on connection speed and device viewing capabilities.


 Ganz CONTROL 1.27 Update: The *Server Watchdog* now automatically monitors the *Streaming Server*, enhancing system stability and reliability. This integration ensures uninterrupted streaming and improved performance, with no additional settings required.

 If you are using [AD/LDAP](#) user accounts for the Web client login, we strongly recommend that you [turn on HTTPS](#) for enhanced security.

 At this point, the recommended **browsers** (100% supported) for clients are Google Chrome and Mozilla Firefox (under any operating system).

Ganz CONTROL Streaming Server Configuration

Ganz CONTROL Streaming Server configuration on the Ganz CONTROL Console side is simple and only consists of setting up the HTTP port for streaming connections. To access the Ganz CONTROL Streaming Server setup in Ganz CONTROL Console, go to the *Configuration* section and then click *Servers* in the menu on the left; double-click the target server to bring up the configuration dialog box, and switch to the *Connections* tab.



The screenshot shows the 'Connections' configuration window for a server named 'Server Showroom*'. The left sidebar lists various configuration categories: Details*, Membership, Permissions, Connections* (selected), Watchdog, Storage, Security policy, and Audit policy. The main area is titled 'Connections' and contains the following settings:


- VMS port:** 60554
- HTTP port:** 8089
- HTTPS port:** 9099
- Enable client-server connection encryption:** ☐ (disabled)
- Enable HTTPS:** ☒ (enabled)
- Digital certificate:** SelfSignedSelfGenerated (with a 'Change...' button)

At the bottom right, there are 'OK' and 'Cancel' buttons.

HTTP and HTTPS port settings under server connections

You only need to define a HTTP port for Ganz CONTROL Streaming Server; the default port is 8080. On top of that, you can secure your connection and use a HTTPS port for the same purpose. Secure HTTP will require a valid digital certificate, either a self-generated (generate on the fly, will require trust confirmation everywhere) or issued by authority (paid, bound to your domain).


Ganz CONTROL Global Administration Guide

 Please make sure that your chosen HTTP port:

- is opened on the target server firewall;
- is properly configured for port forwarding on all intermediate network equipment, if necessary;
- is not being used by any other application or service on the target server.

If you are using HTTPS with your own **CA certificate** (bound to your domain name), remember these important guidelines for the mobile app setup:

- when connecting via local network, use server IP address
- when connecting over internet (4G etc.), use the hostname instead of IP (main domain must be the same as in the certificate)
- if port forwarding is used (local HTTPS port is different from external), enter the port number as the "Internet port" in the server connection configuration

 If you are using your own CA certificates, create a *.pem* file with your certificate chain as described here: <https://www.digicert.com/ssl-support/pem-ssl-creation.htm>

This is necessary for the certificate to be recognized correctly by all HTTP clients - Web browsers and Ganz CONTROL mobile applications. If you simply apply your CA certificate in Ganz CONTROL Console, there is a chance it is not recognized because some applications require the entire certificate chain.

Then, apply the *.pem* file as the certificate together with your key when the importing certificate into Ganz CONTROL Console.

Once you are done with the setup, click *OK* to save and close the dialog box.


Your Ganz CONTROL Streaming Server will now be set up and accessible via local - and, if used, external - IP address. You can immediately check if the connection is working: just open your browser and type: *<local IP>: <HTTP port>*; for example, server configuration for the snapshot above will require *192.168.1.83:8089*.

User Permissions for Ganz CONTROL Streaming Server

If you are going to create a non-administrative user account for Ganz CONTROL Streaming Server access (designated or combined with other permissions sets), the following user permissions should be granted in the user properties dialog box:

- for Web browser and API login: under *Administration profile > Client permissions > Login via HTTP* (includes HTTPS)
- for the Ganz CONTROL Mobile access: *Login via Mobile*
- to allow editing HTTP connection properties: *Console permissions > Manage servers* (this will automatically enable Ganz CONTROL Console login, and also grant access to other server settings)

In the *Resources* tab, select channels and features you wish to grant access to. There are separate permissions for live and archive access, PTZ, audio, and bookmarks.



PERMISSION	INHERITED FROM
<input type="checkbox"/> Console permissions	
<input checked="" type="checkbox"/> Client permissions	
<input type="checkbox"/> Login via Monitor	
<input checked="" type="checkbox"/> Login via HTTP	
<input checked="" type="checkbox"/> Login via Mobile	
<input type="checkbox"/> Log into Monitor application without entering login reason	


Ganz CORTROL Global Administration Guide

User permissions for Ganz CORTROL Mobile and Web browser login

Ganz CORTROL Global Administration Guide

10.1 Streaming Server User Interface

Ganz CORTROL Streaming Server provides HTTP connections for Web browsers and native Ganz CORTROL Mobile applications, OS X Thin Client (similar in functionality to Ganz CORTROL Mobile), as well as services that use Ganz CORTROL HTTP API, which includes CBC AMERICA LLC own external services (License Plate Recognition, Face Recognition modules) and third-party integrations. While the Web browser client functionality is very basic, Ganz CORTROL Mobile applications support many useful features, such as two-way audio, push notifications, mobile edge recording, streaming from device camera to the Ganz CORTROL server and many more.



Authentication required

When configured, Ganz CORTROL Streaming Server is accessible via browser from the server itself and from computers on the local network, and, if system is not isolated, from the Internet. This is the simplest way to make sure your Ganz CORTROL Streaming Server is running and reachable. To access the Ganz CORTROL Streaming Server, open your browser and type:

`<Server IP>:<HTTP port>`

then press *Enter*. Your browser will connect to Ganz CORTROL Streaming Server, and user authentication will be requested: enter your user name and password to proceed.



Starting with Ganz CORTROL version 1.14.0, you can also use your **AD/LDAP user accounts** for the Web browser login. The user name should be entered in the following format:

`domain.name\user.name`

The field is case-insensitive, meaning that you can use either *user.name* or *User.Name* notation.

After logging in, you will see Ganz CORTROL Streaming Server Web browser user interface:

- **left menu:** channel list and setup tabs
- **main window:** live streaming/playback area
- **upper-right-hand corner:** layout templates and layouts
- **upper-left-hand corner:** the Ganz CORTROL Streaming Server logo; click the logo to extend viewing area by minimizing the menu on the left

Access Permissions

The channel and feature availability depends on the user permissions; the built-in administrator has access to all resources. For the Web browser connections, only HTTP connection, live, archive and PTZ access permissions are applicable, as other functionality (e.g., audio) is not present.

In order to allow a user to connect to Ganz CORTROL Streaming Server, go to *Configuration* section of Ganz CORTROL Console, choose *Users*, then select the user or user group for editing and open the *Administration profile* tab:

- add the *Login via HTTP* permission to allow Web browser and/or HTTP API connections
- add the *Login via Mobile* permission to allow connections from mobile apps and OS X client

To allow channel access, add per-channel or per-channel group privileges in the *Permissions* tab:

- *View live Video:* enables live view
- *Listen live audio:* enables incoming audio (from the camera)
- *Send live audio:* send audio to camera (talk back)
- *Control PTZ:* pan, tilt and zoom controls
- *Use PTZ presets:* access to existing PTZ presets

Ganz CONTROL Global Administration Guide

- *Use PTZ tours*: access to existing PTZ tours
- *Video playback*: enables access to recorded video data
- *Audio playback*: access to the recorded audio data

Additional permissions for the Ganz CONTROL Mobile applications:

- for *User Buttons*: the *View* permission allows you to see and use the user button

User Johnny English*

User

Details

Membership

Resources

Resources

Selected resources

TITLE	ID	TYPE
Axis 215 PTZ o...	(118)	Channel

PERMISSIONS

☐ Administer

☒ ReceiveData

☐ AccessArchive

☐ Navigate

☐ ControlDigitalOutput

Clear

Available resources

TITLE	ID	TYPE
UDP IPX3302...	(117)	Device
Vivotek IP816...	(119)	Channel
Vivotek PZ71...	(120)	Channel
(Generic) ONV...	(121)	Channel
Grundig GCI-...	(122)	Channel
Samsung SNP...	(123)	Channel
UDP IPX3302...	(124)	Channel

OK

Cancel


Set user permissions in order to see channels in Ganz CONTROL Streaming Server

Channel, channel group and user button permissions can also be changed in the *Channels* section, by double-clicking the corresponding channel or channel group in the list and then selecting the *Permissions* tab.

Ganz CORTROL Global Administration Guide


Web Interface: Configuration

The menu on the left has two tabs: *devices*, which shows which channels are available, and *setup*, which contains streaming settings. Click on the titles to switch between them.



Devices

The video sources are loaded in a single list. To start streaming from a particular device, select layout template from the menu in the upper-right-hand corner, then click your desired viewport so that it is highlighted blue, and then click a device from the list.



Setup

The *Setup* tab allows you to choose PTZ control behavior and configure stream options:

- **PTZ controls:**
 - **Always:** if the camera supports Pan-Tilt-Zoom, virtual PTZ sphere will be always shown as overlay control
 - **When selected:** if the camera has PTZ capabilities, the virtual PTZ sphere will be shown when the corresponding stream is selected
 - **Never:** do not show PTZ controls at all, meaning that PTZ functionality will be disabled
- **Stream options:**
 - **Main:** only the first (main) stream, [usually] of a larger resolution will be used for all devices
 - **Secondary:** only the secondary stream (substream), [usually] of a smaller resolution will be used for all devices
 - **Auto:** the most appropriate stream will be selected automatically based on viewport size

Ganz CONTROL Global Administration Guide

Web Interface: Streams

The Web browser client allows you to view live video and to play back recorded video from the available channels. For live view mode, PTZ controls are available.

Live

To start live-streaming, select a layout template from the upper-right-hand menu (1x1, 1x2, 2x1 or 2x2), then click your desired viewport so that a blue frame selection appears around it, and then choose the target stream from the *Devices* list on the left. To replace the existing live stream, either select it and choose a device 'on top' of it, or click the *X* button in the upper-right-hand corner of the viewport to close it and then assign a new stream to this viewport.

Notice that some images may appear with horizontal or vertical black stripes at the sides: this happens because image aspect ratio is maintained instead of it being stretched to fill the viewport. When the picture size is smaller than the target viewport, there will be a black background on either sides.



Live view with overlay PTZ controls

Each live view item contains the following information and controls:

- upper-left-hand corner: stream name (static info)
- upper-right-hand corner: archive playback (if applicable), presets button (click to load preset list), *X* button (press to close the live stream and free the viewport)
- bottom-right-hand corner: PTZ mode (if applicable), stream resolution, stream codec (MP4/JPEG/WEBM) (static info) and zoom mode ON (static info)
- centre: stream picture, virtual PTZ sphere (overlay control) (if applicable)

To **pan and tilt** the PTZ-capable cameras, use overlay PTZ controls: left-click and hold in the desired direction. By default, pan/tilt mode is enabled for PTZ cameras: notice the *PanTilt* label in the bottom-right-hand corner of live view.


In order to **zoom** IN and OUT: first, scroll your mouse wheel DOWN to enable zoom mode - in the bottom-right-hand corner, a *Zoom* label will appear. In this mode, virtual PTZ sphere works for zoom only: click and drag UP (upper hemisphere) to zoom IN, and DOWN (lower hemisphere) to zoom OUT. To release zoom mode and go back to the pan-tilt sphere, simply scroll your mouse wheel UP until the *Zoom* label disappears.

For some cameras, you may notice that the further you drag the cursor from the sphere centre, the faster the camera goes: in this way, PTZ speed is controlled; however, for other cameras, only the constant speed is supported either by software or device itself, and the pan/tilt speed will remain constant no matter what position your mouse cursor is in.

Ganz CORTROL Global Administration Guide

Archive Playback

If recording is enabled for the target channel, the stream overlay controls will include an archive playback button in the upper-right-hand corner. Press the button to begin **playback**: the target stream will be displayed in single channel mode. To switch **back to live view**, press the 'eye' button in the upper-right-hand corner; this will restore your previous layout.



Archive playback view

Playback view contains the following information and controls:

- upper-left-hand corner: stream name (static info)
- upper-right-hand corner: 'eye' icon to go back to live view, X button (press to close the live stream and free the viewport)
- bottom-right-hand corner: timestamp (current time and server time zone shift)
- centre: stream picture
- centre bottom: playback controls

Overlay controls allow you to start/pause playback and jump back/forward by ten seconds, one minute, ten minutes or an hour.

Ganz CORTROL Global Administration Guide

Web Interface: Layouts

Layout templates allow you to choose viewport layout: 1x1, 2x1, 1x2 and 2x2 are currently available options.



Default layout templates


Click on any thumbnail at any time to immediately load the corresponding **layout template** on the screen. If there are any active streams, they will be discarded. If the target layout template has been already used in the same browser and cookies have not been cleared, previously used channels will be loaded; if not, an empty template will be displayed.

If you wish to **save the layout** currently being displayed, click on the 'portrait' button.



Layouts menu button

The layouts menu will appear, allowing you to save your layout under a user-defined name: enter the layout name and click the *Save* button. Note that, at this point, only Latin characters [A-Za-z] and Arabic digits [0-9] are supported for layout names; special symbols or characters from non-Latin alphabets are not allowed.



Layouts menu

From here, you can also load the previously saved layouts simply by clicking them; if your layout list is longer than the menu window, use the mouse wheel to scroll down.

The layouts are saved in your browser **cookies**, so:

- Ganz CORTROL Streaming Server layouts cannot be transferred to other browsers, user accounts or computers
- layouts are removed when browser cookie data are cleared

Ganz CORTROL Global Administration Guide

10.2 Mobile Application for Streaming Server

Ganz CORTROL Mobile app for Ganz CORTROL servers provides mobile client functionality for smartphones, tablets, and phablets. Its feature range is much wider than that of the Web browser client. You can install the Ganz CORTROL Mobile application from Play Store (for Android users) or iTunes (for iOS users). Supported OS:

- Android 10 and higher
- iOS 12 and higher

Starting with the Ganz CORTROL Mobile app version 1.19.x you need to have the Ganz CORTROL version 1.23 or higher.

Thin client for macOS has almost identical functionality. It can be downloaded from <http://ganzsecurity.com/cortrol>. Just as Ganz CORTROL Client, the mobile and macOS clients are free of charge and do not require any additional license to run. Using these, you can connect to any of your Ganz CORTROL servers, provided that Ganz CORTROL Streaming Server functionality is enabled in their settings, as described earlier.

Below, you will find guidelines on your Ganz CORTROL Mobile configuration and usage.

Getting Started


Install Ganz CORTROL Mobile from the corresponding app store, or by following a link from our website <http://ganzsecurity.com/cortrol>.

Interface Overview

Ganz CORTROL Mobile user interface is mostly intuitive, you can interact with the app by tapping or long-tapping the interface elements, and also by swiping.

In the top-left corner, you will find the **application menu**. It contains:

- *Add server*: an option to add a new server connection.
- *Share servers*: an option to share your existing server setup by sending the recipient server settings XML file.
- *Record camera*: a possibility to record offline in-app video for further upload to any server.
- *Settings*: general application settings.
- Details about the app version.




Initial application menu (horizontal layout)

Ganz CORTROL Global Administration Guide

After you connect to any server, the application menu will be replaced by the **server menu** containing server-specific resources and actions:


- *View - columns x rows*: channel arrangement for live view.
- *Events*: push notifications from the server.
- *Bookmarks*: channel bookmarks from all available servers.
- *User buttons*: any buttons for the current server.
- *Stream camera*: camera streaming option (device >> server).
- *log out* option.



Main server menu (horizontal layout)

The server menu also has a **submenu** 'three-dots (...)' button next to the server name. Apart from the *Log out* option, it allows you to edit the connection settings (e.g., change the user account) without returning to the server list. The 'three-dots (...)' button is also present in other places within the app, and it offers extra options or actions.

Finally, wherever it is impossible to place the submenu button, a 'hidden' drop-down menu is available. **Long tap** any channel in the multichannel view to see the available quick actions.

 When running in the foreground, the app will prevent your phone from going to sleep, so the display will not be switched off automatically. Keep this in mind and do not forget to exit the app or lock the device/turn the display OFF when you do not need the app anymore.

When you first start Ganz CORTROL Mobile, you will have a demo server connection present by default: feel free to use it for a tryout. You can start adding your own server connections at once but we recommend that you first review the app settings and adjust them to fit your needs.

Settings

Tap the 'hamburger' menu button in the top-left corner to bring up the main app menu, then tap *Settings*. The parameters here define global app behavior (for all servers); they are preserved as you upgrade the app but are discarded if you uninstall it.

The settings are logically grouped for your convenience. Tap a category to access the settings:


- **General**
 - *Language*: set application interface language here (matches device locale by default)
 - *Date format*: set the date presentation format you want the application to use, e.g., YYYY/MM/DD
 - *Time format*: set the time presentation format you want the application to use, e.g., HH:MM:SS (24h)
 - *Timezone*: choose between your mobile client or connected server time zone


Ganz CONTROL Global Administration Guide

- *Timeline zoom*: Pinch zoom (zoom timeline with two fingers)/Smart zoom (timeline zoom depends on the scrolling speed)
- **Streaming**
 - **Quality preference**
 - *Auto*: the most appropriate stream will be selected automatically based on the connection
 - *Main*: only the first (main) stream, [usually] of a larger resolution will be used for all devices
 - *Secondary*: only the secondary stream (substream), [usually] of a smaller resolution will be used for all devices
 - **Display video statistics**
 - *ON/OFF*: defines if the video stream properties (FPS, bitrate) are shown for both incoming and outgoing streams
 - **Decoder configuration**: choose how the incoming streams will be decoded
 - *Hardware and software*: software decoders will be used if required (**warning**: software decoding is battery intensive!)
 - *Hardware only*: hardware decoding modules available on your phone will be used automatically (recommended for battery saving)
 - *Per codec configuration*: choose decoding settings individually for each of the expected codecs
 - **Icons**: descriptive elements overlaying the video
 - *Show battery intensive decoder icon*: the icon will appear in case a software decoder is in use
- **Device camera**: settings related to your phone's camera; the first time you open this section, you will be prompted to run camera detection
 - *Camera choice and preferences for the reverse streaming (device >> server) for both live and offline recording modes*
 - *Off*: choose this if you do not plan to stream the device's video to the server
 - *Camera 1*: main mobile device camera (normally, back camera)
 - *Camera 2*: secondary camera (normally, front camera with less megapixels)
 - Resolution/FPS/bitrate/codec preference, **microphone** ON/OFF
 - Preview: camera preview with the settings defined above
 - *Detect cameras*: allow the app to retrieve your phone's camera configuration (detection may take some time, making the app unresponsive - expected behavior)
 - *Stream device GPS location with video to server*: when ON, the video streamed from the device camera will be overlaid with GPS coordinates and the device marker will be displayed on the geo maps if configured
 - **Offline video**: settings for offline video recording (for further upload)
 - *Store offline video*: choose whether you want to store the recorded files in the app directory on the internal storage or on the external storage (SD card)
 - *Offline video storage limit*: restrict the space available for recordings to 100, 200, or 500 MB, 1, 2, 5, 10 or 20 GB, or unlimited
 - *When no space left*: the app can either overwrite the oldest file(s) or stop recording new files
 - *Default video upload server*: choose a server every time you upload the video or set one of the configured servers to be the default destination
- **Device configuration: network** and other settings related to your phone (but not directly to its cameras)
 - *Allow app/widgets to use*: choose the preferred network type for the app and for the app widgets separately
 - *WiFi only*: the app will only connect to the server(s) if it is connected to a wireless network (including servers available via VPN)
 - *WiFi and mobile data*: the app will use both wireless networks and enabled data services (3G/4G)

Ganz CORTROL Global Administration Guide

- *Auto close timeout*: interval in minutes
- *Auto close application*: Off, always after timeout, After user inactivity timeout
- **Widgets**: all settings related to the app widgets (application extensions)
 - *Widget update interval*: automatically load a new frame every 30 seconds, every 1, 2, 5, 10, or 15 minutes
 - *Allow widgets to use*: WiFi only, or both WiFi and 3G/4G
 - *Panic server*: choose the default server for streaming (panic buttons are widget-like buttons that can be placed on the home screen; tapping the button will start streaming live video to the pre-defined server (device must be registered on the server)
 - *Set up panic button*: suggests to create panic button

 When enabling a camera and turning ON sound, you may be asked to confirm **permissions** for the app to access your phone's camera(s) and microphone. Select YES to grant access to these components if you wish to be able to stream video and audio from your phone to the server and clients connected to it.



Application Settings menu (horizontal layout)

To exit, tap the *Arrow* icon in the upper left corner, or use your device's *Back* button (software or hardware) or gesture.

Add a New Server

Tap the "plus" button in the bottom right corner to create a new server connection. Alternatively, you can also tap the main app menu in the top-right corner, and then select *Add server*. The following parameters should be filled in:

- *Host*: server IP or domain name from your Ganz CORTROL configuration
- *Port*: HTTP or HTTPS port to use (must match the one configured on the server side), 8080 by default
- *Username and password*: user account credentials to connect to the Ganz CORTROL server ([corresponding permission](#) to connect via mobile must be granted)
- *Server name*: user-defined connection title (the value from the *Host* field will be used automatically if you leave this field empty)

Additional options:

- *Use HTTPS*: use HTTPS over TLS instead of plain HTTP (the target [server](#) must have [HTTPS enabled](#) and configured)
- *Enable event notifications*: turn ON push notifications from the Ganz CORTROL servers (notifications should be pre-configured via [Events & Actions](#) using the *Send event to client* [action](#))
- *Trust all certificates from this session*: accept all digital certificates provided by the target server (required in case you are using a self-signed certificate on the server side)
- *Set as startup server*: turn this ON if you wish the app to connect to the target server upon startup: when

Ganz CORTROL Global Administration Guide

- started, the app will load the server list and try to connect to the selected server automatically
- *OAuth 2.0*: Allows to enable OAuth with external authentication providers.

The screenshot shows a dark-themed 'Add server' dialog box. At the top left is a back arrow icon, and at the top right is a 'Save' button. Below the header, there are five input fields: 'Host', 'Port' (with '8080' entered), 'Username', 'Password', and 'Server name (optional)'.

This screenshot shows the same 'Add server' dialog box, but with the bottom section expanded to show five toggle switches. The first toggle, 'Use HTTPS', is turned on (blue). The other four toggles, 'Enable event notifications', 'Trust all certificates from this session', 'Set as startup server', and 'OAuth 2.0', are turned off (grey).

Adding server menu options (horizontal layout)

When you are ready, tap *Save* to save the settings and exit the dialog box, or tap the "<-" *Back* to discard the changes and simply go back to the main menu.

To edit the settings for an existing server connection, tap the 'three-dots (...)' menu on the right side next to the server name, and then tap the *Edit* button that will appear in the drop-down menu. Use the *Delete* menu option to remove any existing entry.

OAuth 2.0

If you want to use OAuth2.0 as an authentication method, you need to set an **authentication provider** and **OAuth user** in the Ganz CORTROL Console and then enable this option in the Ganz CORTROL Mobile. Make sure you are logged into your mobile device with the same **user credentials** as the user added via Ganz CORTROL Console.

If your Ganz CORTROL Console is set properly, by setting **OAuth 2.0** as an **authentication method** in the Ganz CORTROL Mobile, you will see the notification with available providers at the next logon. Pick one you are going to use and follow the instructions. Depending on your OAuth provider - you may be asked to input a security code or verify your identity by the methods intended by your mobile device account security options.

Ganz CONTROL Global Administration Guide


Live View

Tap your pre-configured server in the list to establish a connection. If you are using HTTPS with a self-signed certificate, you will have to confirm that you trust the server certificate.

When you connect to a server, the **live view** mode is loaded by default. If you have already connected to the selected server previously, the most recent live view layout will appear. Each channel's name will be displayed in the top-left corner of the picture, together with video stream properties - codec, bit rate, frame rate, and resolution; stream statistics can be turned OFF via app settings (see above).

Tap any camera **live view** video to switch to the **single channel** view. Tap the "<-" *Back* button in the upper-left corner to return back to the channel list. In both multi- and single-channel views, you can **swipe** up and down to **switch** between channels. In the single-channel view, they will appear one by one. In the multi-channel view, the new portion of channels will be shown.

You can change the multi-channel **layout** by tapping the server menu in the upper left corner > *View* > choose the desired layout (1x1, 2x1, 2x2, and 3x2 options are available).



Multi-channel live view (horizontal layout)

Swipe left/right (while holding the device horizontally) or up/down (for vertical mode) to scroll the channels.

You can pinch the picture to **zoom** IN/OUT (digital zoom). A tiny picture-in-picture preview will appear in the upper left corner of the viewport. Tap it to reset the DPTZ to the 1:1 zoom level. You can navigate around the zoomed-in image by dragging two fingers over the display.

Ganz CORTROL Global Administration Guide




Single-channel live view (horizontal layout)

Tap any channel to replace the currently displayed layout with a single-channel view with extra controls.

The available controls are:


- Bottom-left corner:
 - **Camera icon:** take a snapshot. Tap to save the currently displayed frame onto your device. To find your Snapshot on the **Android** device - go to the *Photos* app -> *Library* -> *Pictures* folder, and on the **iOS** device you will be able to find the snapshot in the *Photos* app, in the most recent photos.
 - **Speaker icon:** audio IN (from the camera). Tap once to enable incoming audio (the icon will turn blue), and tap once again to stop. The icon will only appear if the target channel has sound enabled.
 - **Microphone icon:** audio OUT (talk to the remote camera). Tap once to start sending audio back to the camera (the icon will turn blue), and tap once again to stop. **Note:** you do **not** need to tap and hold the mic icon, like in the regular Ganz CORTROL Client application, simply tap once to enable audio streaming. This icon will only appear if the related functionality is available.
- Bottom-right corner - three-dots (...) menu:
 - **Show PTZ controls:** toggle PTZ controls (for PTZ-capable cameras). While having overlay PTZ controls ON:
 - tap/long tap *inside* the sphere to pan and tilt (the closer you tap to the sphere edge, the faster the PTZ speed will be).
 - tap/long tap the ends of the zoom bar to zoom IN/OUT.
 - **PTZ presets:** tap to see the list of available PTZ presets; tap any to make the camera go to the specified preset.
 - **PTZ tours:** tap to see the list of available preset tours; tap any to start the tour; tap *Stop PTZ Tour* to terminate any currently executed tour.
 - **Cast to device:** tap to cast the current channel to one of the available Chromecast devices.
 - **Create bookmark:** Create the bookmark and add the title and the description.
 - **Maintain aspect ratio:** toggle aspect ratio (original/stretch to fit); the setting is applied to all the channels.

Ganz CORTROL Global Administration Guide



Single channel options menu (horizontal layout)

Tap the picture again to switch to the **full screen** (remove extra controls). You can still swipe up/down (or left/right for the landscape screen orientation) to switch between channels.

 **PTZ Tours** button will only appear if the target camera has at least one tour configured. PTZ tours can be created and managed via the Ganz CORTROL Client application.

While in this mode, you can swipe left or right to load the previous or next channel in the list. Long tap on the free space (where there is no stream) or on the stream itself (when PTZ controls are OFF) to bring up the list of all the available channels. Swipe down and up to browse the list, and tap any channel to display it.

Server Menu


You can find the server controls in both, the upper-left corner "hamburger" menu and the upper-right corner - three-dots (...) menu. The Left and right menu offers different controls over the server. The left menu offers:

- **View - columns x rows:** tap to open layout selection. The layouts currently available are: 1x1, 2x1, 2x2, 3x2. If a larger layout has been selected, existing channels will be mapped automatically and all the extra slots will appear blank. To add more channels, tap the "Cameras" button and pick one; all the slots will become marked with blue frames, tap any of them to place the new video channel there.
- **Events:** push notifications from the target server (configurable via *Event & Action* section in Ganz CORTROL Console).
- **Bookmarks:** channel bookmarks from all the available servers.
- **User buttons:** tap a user button to trigger the action assigned to it (see below for details).
- **Stream camera:** send the video stream from your phone's camera back to the Ganz CORTROL server.
- Log out option.

You can manage Channel order and create and manage Channel sets by selecting the three-dots (...) menu from the top right corner:

- **Modify channel set:** By marking items in the checkbox list, you can select which Channels to display for the current configuration. To Save or delete your configuration - navigate to the three-dots (...) menu inside the Modify channel set and Save or Delete channel set.
- **Delete channel set:** Delete the current channel set configuration.
- **Reset channel order:** resets order in which channels are represented in the multi-channel view to default order.
- **Select another channel set:** Allows to switch between pre-configured channel sets.
- **Open single channel:** Allows to select and open a particular channel from the channel list.
- **Maintain aspect ratio:** (on/off) allows to enable/disable default aspect ratio for all the channels in the multi-channel view.

Ganz CORTROL Global Administration Guide



Multi-channel server view (Horizontal layout)

Stream Camera

It is possible to send the video captured by your phone's main or front camera back to the Ganz CORTROL server for further live view on other connected clients and also for server-side recording. To do so, you need to add your mobile device to the Ganz CORTROL configuration and then confirm it in your app.

First, go to your server configuration via Ganz CORTROL Console, go to the *Configuration* section and choose *Devices* from the menu on the left. On the upper panel, click the + *New device* button in order to create a new device; enter your desired name and set the *Model* to (*Generics*) - *External Source*, then save. Note the value appearing in the *Code* field: you will need to enter it into your app.

Next, go to your app -> server list -> tap *Settings* in the top-left hamburger menu, find the *Device camera* in the list, and choose your video preferences; the contents of each item may vary depending on your mobile device capabilities:


- **Device Camera:**
 - *Camera* -> *Configure camera*: select which camera to use (primary/secondary), set Codec, Resolution, Bitrate, FPS, and microphone.
 - *Detect cameras*: Use this if no cameras are shown in the camera menu item.
 - *GPS*: Stream device location with video to server (on/off).
 - *Store offline video*: You can pick from the list where to save offline video.
 - *Offline video storage limit*: pick from the list how much memory you want to allow for online video.
 - *When no space left*: You can decide to overwrite the oldest video or just stop the recording.
 - *Default video upload server*: Select to which server to upload the recorded offline videos.

After the camera is set for the streaming - you can start streaming to the server by selecting *Server* from the *Server list*, then go to the top-left "hamburger" menu and select *Stream camera*. You will see the video stream preview and the round button in the bottom-middle part of your device screen. Tap this button and the video will be streamed to the server. The button will change its appearance to the red dot "recording" button. To stop streaming tap on this button.


Ganz CORTROL Global Administration Guide



Streaming Camera view (horizontal layout)

 For Android 6.0 and newer, you may need to go to your mobile device's system permissions and explicitly allow Ganz CORTROL Mobile to use the camera in case you were not asked for this permission or if you have chosen to deny access to these components.


You can now manage this stream as a usual channel in Ganz CORTROL Console meaning that you can record both video and audio from it, analyze it for motion, etc. To remove this entity, simply delete the device via Ganz CORTROL Console.

 If you re-install the application on your mobile device or update it to the next major release version, you will need to go to the Ganz CORTROL Console and add your mobile device anew, basically, following the algorithm of adding a new device, or go to the device settings and click *Reset* near the *Code* field to generate a new code, then enter the new code in your app.

Panic Button

Once you have registered your phone on the server, you can set up a **panic button** on your mobile device. This button is placed on your home screen and, when tapped, **initiates live streaming** to the pre-defined server immediately - you do not need to open the app and search for the server. To set up this panic button, go to the mobile application settings and:

- define the panic server where the stream should be sent in the Application main menu -> *Settings* -> *Widgets* -> *PanicServer*.
- create a panic button and place it on the home screen.

 N.B. Each time Ganz CORTROL Mobile is updated, make sure your streaming camera is still connected to the server. If not, go to the Ganz CORTROL Console and add your device anew.


To create a *Panic button* on your **Android** device:

- tap and hold on your device home screen, on the free space until the widget dialog appears.
- find Ganz CORTROL Mobile widgets in the widget list and expand the menu.
- tap and hold the Ganz CORTROL Mobile panic button, then place it on your home screen.

To create a *Panic button* on the **iOS 12** and newer device:


1) Open your Shortcuts app (<https://support.apple.com/en-us/HT208309>). You will see the list of existing shortcuts and an option to add a new one. Tap the *Create Shortcut* button.

Ganz CORTROL Global Administration Guide



iOS Shortcut app, step 1


2) Tap Add action, or just locate the app in the *Search for Apps and Actions* field by entering the mobile app name until it appears in the list. Tap the app icon. You will see the list of actions available for that app: for our mobile application, there will be the *Panic Button* item.



iOS step 2, adding an action

Ganz CORTROL Global Administration Guide


3) Tap the *Panic Button* item. + and ... icons (Add New and Details) will appear.



iOS step 3, adding the Panic button

4) Tap the three dots (...) *Details* icon in the upper-right corner to change the panic button icon appearance and name. Tap the *Add to Home Screen* option to add the shortcut to the home screen. If you don't add it to the home screen, the shortcut will only be available from the *Shortcuts* app or from the *Today View*. Tap *Done* to exit the shortcut properties. The button will appear in the list as the newly added shortcut.


Ganz CORTROL Global Administration Guide



iOS step 4, button appearance and placement

5) Tap *Done* again to finish adding the shortcut. The newly created shortcut will appear in the list in the Shortcuts app and will become available in your *Today View* (the section that appears when you swipe to the left edge of the screen).

6) Exit the Shortcuts app. Your Panic Button will appear on the home screen: tap it to start transmitting video to the selected panic server.



Added Panic button on the iOS screen

Ganz CONTROL Global Administration Guide

Archive Playback

To switch to the playback mode, tap the *Live/Archive* switch on the top-right corner in the single channel view. You can navigate through the archive playback. In the top-middle of the screen, tap on arrows around the date to move in the steps of the whole day.

In the bottom-middle of the screen, there are standard playback symbols to play or jump to the beginning or the end of the recording, navigate by minutes, or tap on the timeline and provide year, month, date, and time if you know the exact moment you are looking for. The default value for the time step interval is 1 minute. You also can change this interval by holding +1M and -1M for a short time. The list with available time intervals will appear (5 sec, 10 sec, 1 min, 10 min, and 1 hour). Tap on your preferred time step interval to use it with a single tap.

You can adjust the playback speed by tapping the circle with the number and *_x_* symbol in the right-bottom corner near the three-dots (...). menu.

In the right part of the screen, there is Main stream/substream indicator. You can tap on it to switch between streams.




Initial view for the archive playback mode (horizontal layout)

You can find additional controls for the navigation inside the three-dots (...) menu in the right-bottom corner of the screen.

- *Jump to time*: allows to pick up the exact date and time for the playback.
- *Jump to channel events*: allows to pick the event directly from the channel event list if any exist.
- *Jump to channel bookmarks*: allows to navigate directly to the bookmark if any exist.
- *Previous and Next controls*: allows to set icons around the Play button to move by frame, bookmark, or Motion event.
- *Create bookmark*: provide an option to add a bookmark with a Title and its description.
- *Maintain aspect ratio*: (on/off) allows to maintain proportions of the video or stretch it to the proportions of the screen.

Ganz CORTROL Global Administration Guide



Archive playback menu options (horizontal layout)

Widgets

Widgets are information elements that can be placed on the home screen on Android devices and in the Today view on iOS devices. Individual channels that require frequent monitoring can be placed as Ganz CORTROL Mobile widgets with moderate or low (from twice per minute down to four times per hour) refresh rate so that you do not have to open the whole app each time you need to check the channel. For channels accessible via the Internet, this means you can monitor them even if you are in a remote location on 3G or 4G: relatively low frame refresh frequency does not use much bandwidth. You can also limit widgets to use WiFi connection only.

The general steps to add and use a widget are the following:

- add as many widgets as you need, one widget per channel,
- go to Ganz CORTROL Mobile app settings and set widget update and network usage preferences (for details, see the *Settings* section above),
- assign channels to widgets.

To add a widget on an **Android device**:

- tap on a blank space on the home screen and hold for a couple of seconds until the menus appear,
- tap the *Widgets* menu at the bottom of the screen, locate the Ganz CORTROL Mobile widget, and then drag it to the desired place. Widget of default size (2x2 cells) will appear with a *Slot not configured* message inside:
 - drag the orange borders to adjust the widget size, then tap outside the widget to exit the adjustment mode (you can change the widget position and size at any time later by long-tapping the widget and then moving it)
 - tap the widget once: Ganz CORTROL Mobile application will open, allowing you to choose the channel,
- then, in the Ganz CORTROL Mobile app:
 - go to the app settings before connecting to the server and choose how frequently the widgets will be refreshed, and also their network usage preference (see the *Settings* section above for details),
 - connect to a server of your choice, choose *Camera to widget* from the main menu, then tap a channel to choose it (all channels will be highlighted with blue frames, swipe left or right to load more channels to choose from), and then choose a widget slot from the list by tapping it, too (the slot may be empty or already contain a channel),
- go back to your home screen: the assigned channel should now be present in the widget, with the channel name in the top left corner, slot number in the bottom left corner, and last refresh time in the bottom right corner.

To replace the channel, follow steps 3-4 above; to remove the widget, simply tap and hold it until the menus appear, and then drag and drop it onto the Recycle bin icon. Tapping a widget will result in opening the corresponding app,

Ganz CORTROL Global Administration Guide

as described above.

To add a widget on an **iOS device**:

- swipe down over the Home screen, Lock screen, or Notification Center to bring the Today view screen, scroll to the bottom to reach for the Edit menu, tap *Edit*,
- locate the Ganz CORTROL Mobile app and tap the (+) sign to the left of it: the app will be added to the list above,
- tap *Done* when you have finished; the widget will appear under Widgets, allowing you to add and resize the slots - tap any slot to open the Ganz CORTROL Mobile app,
- then, in the Ganz CORTROL Mobile app:
 - go to the app settings before connecting to the server and choose how frequently the widgets will be refreshed, and also their network usage preference (see the *Settings* section above for details),
 - connect to a server of your choice, choose *Camera to widget* from the main menu, then tap a channel to choose it (all channels will be highlighted with blue frames, swipe left or right to load more channels to choose from), and then choose a widget slot from the list by tapping it, too (the slot may be empty or already contain a channel),
- go back to your Today view: the assigned channel should now be present in the widget, with the channel name in the top left corner, slot number in the bottom left corner, and last refresh time in the bottom right corner.

You can drag widgets to rearrange them in the Today view; tapping a widget will open the associated app. To remove a widget, go back to the widget list in the Today view, as described above, and tap the (-) sign next to the Ganz CORTROL Mobile name, then tap the *Remove* button. If you remove the widget and then add it anew, it will retain its view (slots).

User Buttons

User buttons are software buttons, controls used in Ganz CORTROL Client and Ganz CORTROL Mobile for manual event triggering: upon clicking or tapping a user button, the action associated with it is triggered. The action, the user button itself, and the rule that makes the user button work are all pre-configured via Ganz CORTROL Console; see corresponding sections of the server management manual for details.

If you are connected to a server that has configured user buttons and your user account has permissions to use them, the buttons will be available in the app. To access them, tap the main menu and choose the *User buttons*. Then, choose the button you want to use and tap it: the associated action will be triggered and you will receive a confirmation at the bottom of the screen.

Events

Ganz CORTROL Mobile app allows you to receive push notifications from the Ganz CORTROL server once they have been set up via Ganz CORTROL Console *Event & Action* management.

In order to do this, create an action of the *Send event to client* type via Ganz CORTROL Console and enable the *Display event in mobile application* option, then attach this action to your desired event in the *Rules* section. When creating the rule, do not forget to set the target channel for it: the notifications will appear for that particular channel and their availability can be controlled via channel access permissions. It is possible to limit the reception of the notifications to certain user profile or user group. You will find more details on how this is done in the *Events & Actions* section, under [Actions](#).

Triggered notifications will immediately appear on the mobile device(s) that have Ganz CORTROL Mobile app installed with the target Ganz CORTROL server configured (connected user account must have permissions for the target channel). The app itself may be not running: events will pop up as regular text message notifications. If the target mobile device is offline, the notifications will arrive shortly after it re-connects to a network that provides the required server connection.

Offline Camera

Ganz CORTROL Mobile app provides an option to make offline recordings and then upload them to the preferred server. The video can be recorded from the device camera in the app and stored as long as required until the server connection is available.

Ganz CORTROL Global Administration Guide

To enable this, you first need to:

- set up the target server connection in the app
- choose your camera preferences
- register your smart device on the Ganz CORTROL server as *External Model* as you would do for live streaming from the device camera
- enable Edge Recording for the newly created channel

You only have to do this once for each device (unless you re-install the app). From then on, you will be able to record as many video clips as you wish, and then upload them to the target server.

If you do not have paired your device with the server yet, go to your Ganz CORTROL server configuration via Ganz CORTROL Console, go to the Configuration section and choose Devices from the menu on the left. On the upper panel, click the + *New device* button in order to create a new device; enter your desired name and set the *Model* to (*Generics*) - *External Source*, then save. Note the value appearing in the *Code* field: you will need to enter it into your app.

Next, go to your app -> server list -> *Settings* -> *Device camera* in the list and choose your video preferences; the contents of each item may vary depending on your mobile device capabilities:

- *Camera*: back/front (primary/secondary)
- *Codec*: H.264/H.265 (depends on device capabilities)
- *Resolution*: [the actual list depends on the mobile device's capabilities]
- *FPS*: from 10 up to the maximum allowed by the device
- *Camera Microphone*: disable/enable sound

To start offline recording - go to the Channel list, tap on the top-left corner "hamburger" menu, and select the *Record camera*.

Rotate your device the way you want to hold it during the process and tap the *Start recording* button: it will turn red indicating that the **recording** is happening. Tap it again to **stop**: a **new file** will appear in the list and the camera preview will return to live.



Recording camera (horizontal view)


In the right-bottom corner of the screen - tap the *Archive* button. You will find the list of the offline recordings. To replay the recording - tap on the recording you want to replay. The video file(s) will be uploaded to the selected Ganz CORTROL server and stored as an **edge stream** for your device's channel. Do not worry if the upload is interrupted due to network issues: the upload will resume as soon as the connection to the target server is available again.

GPS Tracking

Starting from the Ganz CORTROL Mobile version 1.7 and Ganz CORTROL version 1.8.0, it is possible to send the GPS coordinates of the smart device to the Ganz CORTROL server. The coordinates are then displayed on the top of

Ganz CORTROL Global Administration Guide

the *Live* and *Recorded* video, and they are also used to trace the device on Geo maps.




GPS coordinates displayed on the top of the video stream in the Ganz CORTROL Client

Setup:

- enable GPS data in your app settings
- register your device on the server as described above in the *Stream Camera/Offline Camera* sections so that it exists in the server device/channel configuration
- create a geo map on the server via Ganz CORTROL Console
- place a camera marker on the map, set your smart device as the target *Channel*, and enable *Track location* in the *Properties* tab

Ganz CORTROL Global Administration Guide



Example of the Geo maps configuration from Ganz CORTROL Console

Now, if you move and stream video from your phone to the Ganz CORTROL server, the marker on the map will move as well, displaying your location. GPS coordinates will be shown on top of the live video stream and also when it is played back. Note that for the offline recorded stream (clips recorded and then uploaded to the server) the coordinates will not be displayed.

10.3 RTSP Streaming Server

RTSP Streaming Server

Sometimes, you must provide a live stream from the camera to the third-party software or a remote system without giving access to the Ganz CONTROL itself.

It is possible with the Ganz CONTROL RTSP streaming server. This chapter will guide you through enabling the streaming server and setting streaming for the specific channel inside the client.

You will need to:

1. Enable RTSP streaming inside Ganz CONTROL.
2. Add permission for the remote user to access this stream.
3. Provide the correctly formed streaming link to the client.

Enabling the RTSP Streaming Server

The first step is to allow Ganz CONTROL to stream video over RTSP. To do so, go to:


1. *Ganz CONTROL -> Configuration -> Servers*
2. Select the server you want to stream from and double-click it, or locate the *Edit* button at the top of the *Server* subsection and click it - this must bring the selected *Server settings* pop-up window.
3. In the left subsection of that pop-up window, locate and click the *Connections* tab, scroll to the bottom of the right subsection, and find an input field named the *RTSP port* at the very bottom of the subsection.

The default value for the *RTSP port* input field is 0, which means streaming is disabled. To enable streaming, you need to provide the port number.

The ports that the Ganz CONTROL may already occupy, so you should avoid them:

- 8080 - standard HTTP port,
- 8082/83 or 8090/92 - may be occupied by external analytics,
- 554 - standard RTSP port may be occupied by the for other purposes


The recommended port is 8554. Since the Ganz CONTROL does not use this port, this must help avoid conflicts.



Example of the recommended RTSP port settings.

Ganz CONTROL Global Administration Guide


After providing the port, confirm your selection with the *Apply* and *OK* buttons. After that, your *RTSP Streaming Server* is enabled.

 If the streaming server does not start after port is enabled, for some configurations it may be necessary to restart your Ganz CONTROL server after adding the port.

Providing Permissions to the Remote User

The server is already streaming, but you must grant permission to access the stream. To do so, go to:

1. *Configuration* -> *Users*, pick a user you want to provide access to the *RTSP stream* and double click it or locate the *Edit* button on top of the *Users* subsection and click it.
2. Inside the new pop-up window, select *Administration profile*. Find the *Login via RTSP* checkbox under the *Client permissions* section and mark it.



Adding User permissions.

Now, you can access the *RTSP stream* by providing the login and password to the client software you want to use to watch that stream. More details on *Users* can be found in the [corresponding manual section](#).

Forming Streaming Link

The way you form the link to the stream will depend on the client you use to watch the stream, but for any configuration, you will need to know:

1. Streaming server IP address
2. Port, you assigned for the RTSP streaming
3. *Channel ID* you want to stream (You can find it under *Configuration* -> *Channels*, *ID* column)

Ganz CORTROL Global Administration Guide

Configuration > Channels

admin

Search

Configuration

- Users
- Devices
- Channels**
- Recording
- Maps
- Configuration
- Events & Actions
- Monitoring
- Audit

Create channel group Edit

Assign main stream recording configuration Assign group Disable

Create replication Show video 1 selected

TITLE	ID	DEVICE
Hiki2	(134)	Hiki2 (133)
HikiEntrance	(130)	HikiEntrance (129)
HikiEntrance 1	(160)	HikiEntrance 1 (159)
I-Pro_4eyes 1	(174)	I-Pro_4eyes (173)


Load time: 57 ms Record count: 10

Recently added, 0 Recently updated, 0 Groups, 0 Channels, 9

Replication channels, 0 Detached, 0 Enabled, 9 Disabled, 0

Structured view 9 filtered

Finding Channel's ID.

 If you do not see the *ID* column inside the *Channels*, find the "hamburger" menu at the top-left side of the *Ganz CORTROL Console*, find the *Settings*, and mark the *Show object's IDs* checkbox.


Link template:

- rtsp://user:password@Server_IP:RTSP_port/channel_ID/live/stream_type (main or substream)

Link examples:

- rtsp://@127.0.0.1:8554/**130**/live/**main**
- rtsp://**user:password**@127.0.0.1:8554/**130**/live/**main**
- rtsp://**user:password**@127.0.0.1:8554/**130**/live/**substream**

Ganz CONTROL Global Administration Guide



The Streaming link example inside the VLC player.

If you want to share the stream outside your local network, you must set port forwarding for the port you like to use for streaming. Please consult your network administrator for such cases.

11 Event and Action Overview

Event and action (**E&A**) management is a component of Ganz CORTROL, which provides additional opportunities for handling surveillance system work under certain conditions. The main task is to assign flexible device/server reactions on a user-defined basis. These scenarios may work within a single server, as well as in distributed systems with Ganz CORTROL Global where events originating from one server can trigger actions on one or more different servers.

Events are entities that arise when something happens in the system - namely, when system or system component states changes, for instance, a video stream has been lost, a recording or disk error has appeared etc. These changes can be set up to trigger certain **actions** so that system administrators and/or users are notified and can react to them in a timely fashion. Additionally, there are also extra controlling entities that allow a flexible and advanced setup of event-action rules: conditions, delay times and schedules.

Using event & action management, you can specify your desired outcome for your video surveillance system's operation and determine how software reacts to any event caught on any server and how it turns them into an automated process. Send emails, activate DI/DO, interact with any other software or just bring the attention of the operator to the device that requires their immediate action. The functionality can be used not just for a single event, but on a set of sequenced events to get rid of false alarms and improve the efficiency of the surveillance system.

Possible **E&A scenarios** may be:

- sending alerts through the server based on camera digital input events;
- starting or stopping video recording based on motion in specific regions during specific hours;
- switching to some camera PTZ preset if the door sensors go off at night;
- directing the camera to a specific PTZ preset if another camera registers the same movement;
- etc, etc.

Event & action management offers the following **functionalities**:

- event & action configurator rules
- standard (default) events (available for all servers)
- standard (default) actions (available for all servers)
- custom events of certain types (configurable)
- custom actions of certain types (configurable)
- global events (server-to-server data transmission)
- delay timers (postpone actions)
- special conditions (combine several events)
- schedules (timetables)
- mail server configuration

Each of these components is described in details in the corresponding sections of this document.

Setup in Brief

Actual setup of E&A depends greatly on your system configuration, E&A usage scenarios, required automation level and other things. However, we recommend that, regardless of system scale and architecture, you stick to the following **order of E&A configuration** steps for optimum results:

1. Preliminary actions
 - a. Create a plan of your E&A scenarios on paper or in any diagramming/smart draw software - this will ensure you always have a basis to check against
 - b. Set up the your Ganz CORTROL system so that you have all the servers, devices, channels, users, external system connections, and optional elements pre-created
 - c. Pre-configure all the necessary hardware equipment (e.g., camera IO wires, external physical alarms, buttons) and connect it
 - d. Pre-configure all third-party programs/scripts/executable files, if necessary
2. Extra setup in Ganz CORTROL Console
 - a. Create User Buttons, if you are going to use them for manual action triggering
 - b. Create Maps, Layouts, PTZ Presets if necessary

3. E&A Management setup per server
 - a. Add mail servers if you are going to use e-mail notifications
 - b. Add custom events
 - c. Add conditions, if needed
 - d. Add custom actions
 - e. Create rules using all elements; add extra events/rules, if required
 - f. Add timers, schedules and conditions to the rules
 - g. Check your rule map against your initial plan from 1.1
 - h. Test your rules

Ganz CORTROL Global Administration Guide


11.1 Add Rules

All existing and added entities of E&A can be combined to create **rules** (rule map) for each server, which will define server behavior if events are triggered. This section will guide you through related features, explain the meaning and purpose of used items and provide usage examples.

The rule map is created via the **Event & Action Configurator**: to open it, go to the *Events & Actions* section in Ganz CORTROL Console and then click *Rules* in the menu on the left, then select the target server for which you wish to add the E&A setup, and then click the *Open configurator* button on the upper panel. To change the target server, click the *Change* button next to the server name and then pick one from the available server list.



The *Event & Action Configurator* will open in a new window; by default, no rules are defined.




Event & Action Configurator

You can pre-create all events, actions, conditions and schedules beforehand using the relevant menu sections in Ganz CORTROL Console, or create necessary items as you go from the configurator. Delay timers can only be created as you go for the specified rule and are not saved as independent entities.

Add and Edit Events

Choose the target item from the Events list and then click the + *Event* button below: configuration dialog box will then open with the target device pre-selected. Here you can add alerts from device digital inputs, VCA notifications and other types of events; see the detailed description of how to create events in the [Add Events](#) section.

Events are arranged by **sources**. Typical event sources are: channels, channel groups, servers, user buttons, video walls, external services.

 Built-in (default) types of events - lost/restored video, recording errors etc. - cannot be edited. This is also the case for all built-in actions.

Add and Edit Actions

Choose a target item from the Actions list and then click the + *Action* button below: the configuration dialog box will then open with the target device pre-selected. Here you can add different reactions any type of event:

- trigger device digital output
- write to OS Application log

Ganz CONTROL Global Administration Guide

- activate target device's PTZ preset
- activate main/secondary stream recording profile
- send an email notification
- run a third-party program
- etc.

See the detailed description of how to create and configure actions in the [Add Actions](#) section.

Manage Rules

To start combining events, actions and additional controls, simply follow this scheme:

- find your desired **event** in the *Events* list - use search filter on the top panel, if required
- use the < and > arrows or double-click events to add/remove them to/from the *Rules* list
- click free space of the target rule in the *Rules* list (use CTRL or Shift to select multiple ones) - the selected rows will then become highlighted green
- find your desired **action** in the *Actions* list - use search filter on top, if required
- use the < and > arrows or double-click actions to add/remove them to/from the *Rules* list, and the + button to add more than one action for a single event
- select desired actions and add auxiliary controls by clicking buttons on the bottom panel (see description below for details)

Useful tips:

- double-click a device (highlighted grey) to add **all** its events to the rule map
- to **add** an action to an existing rule, use the + button instead of the < button: the original event will be duplicated and new action will be added to the copy
- use the + button between *Rules* and *Actions* lists to add **multiple actions** of the same type to the selected rule(s)
- to clear the *Rules* list, select all rules using Shift or CTRL+A, then press < button on the left to remove all events
- use the *Expand/Collapse list* button on top of each column to hide all contents and only display node titles

The rule header displays the event source and event itself; below, related actions are listed, each with its own set of special controls. Actions of the same type are listed under the same rule header; for all other cases, the events are duplicated, resulting in a separate rule. One condition, one schedule and one delay timer can be attached to **each action**.

Platform 3/4 >> Main Gate Opened

Gate Open >> Set condition

Working Hours

Platform 3/4 >> Main Gate Opened

ALARM >> Send global event

Platform 3/4 >> Main Gate Opened

West Rd 1 >> > Activate PTZ preset > Gate

Working Hours 00:00:10 extend


Example of a rule set for the same event source

Once the rule map has been created, click the *OK* button in the bottom right corner to **save and exit**. Note that simply closing the *Event & Action Configurator* is analogous to clicking *Cancel*: no changes will be saved.

Conditions, Schedules and Delay Timers

Ganz CONTROL Global Administration Guide

For each event/action pair that is added to the rule map, additional options can be defined in the form of [conditions](#), [delays periods](#) and [schedules](#). Select one or multiple target events from the *Rules* list and then click desired control item in the bottom panel.



To remove auxiliary controls from a rule, select it in the *Rules* list and click the *Clear* button on the bottom panel. Note that all defined conditions, timers and schedules will be removed from the target rule, and it is not possible to de-attach them one by one.

Delay Timers

To add a pause timer for specific actions, select one or more of the mapped rules (use *CTRL+click* or *Shift+click* to mark multiple items) subject to delay, and then click the *Delay Timer* button on the bottom panel of the central part of the *Event & Action Configurator*.

A screenshot of a 'Set pause timer' dialog box. It has a title bar with a green icon and standard window controls. The main area is divided into sections. The first section is 'Caption'. The second section is 'Time delay', which contains a digital time input field showing '00:02:00' and a small scroll control on the right. Below the input is the text 'Set time delay for the action'. The third section is 'Pause mode', which contains two radio button options. The first option is 'Create a separate action' with the description 'A new action will be created even if there is an identical action queued.' The second option is 'Extend a postponed action' (which is selected) with the description 'No new action will be created if there is an identical action queued.' At the bottom right are 'OK' and 'Cancel' buttons.

Delay timer properties

Set the delay period for the target timer. Time can be adjusted in the following ways:

- click hours/minutes/seconds and then use the UP and DOWN arrows on the right, or
- click hours/minutes/seconds and use the mouse scroll, while still holding mouse cursor over the relevant timestamp section, or
- enter the time manually using the keyboard numpad.

Next, choose the pause mode:

- **Create a separate action:** new actions of the same type will be created regardless of the acting delay timer, and queued in the same way as the original delayed action
- **Extend a postponed action:** new events of the same type will restart the timer, postponing the resulting action for the specified amount of time

Ganz CORTROL Global Administration Guide

When you have finished, click *OK* to save and exit the dialog box. The newly created delay timer will be assigned to the pre-selected actions.



Extending an action allows you to postpone the action execution repeatedly if more events of the same type arrive within the chosen time period. For example, if incoming events are of a *Recording Error* type, there may come too much of them at once e.g. in case of a major storage issue, causing a lot of triggered actions of the same type, while only a single action may be desirable.

Say, if required action is *Write to application log*, setting a delay timer to *5 minutes + extended action* will postpone the email sending for 5 minutes every time a new recording error appears; when, at a certain point, more than 5 minutes have passed without new incoming events, a single log entry will be eventually created. The **separate action** option, on the contrary, will force logging for every single triggered event.

To remove a delay timer from rule configuration, click the timer to highlight it within the rule, and then click the *Clear* button in the bottom panel. Note that, if there are schedules and/or conditions attached to the same rule, they will be removed as well.

Schedules

Schedules are used when you wish a rule to be active based on a pre-defined itinerary. You can create any number of custom schedules via the *Conditions* section in the Ganz CORTROL Console and then use them for rule control: see [Create Schedules](#) section in this document for a detailed explanation of this.

Select one or multiple target events from the *Rules* list and then click *Schedule* button in the bottom panel.

Conditions

Conditions are supplementary variables that can allow or prevent action execution. The decision is taken based on the condition state: if the condition is **ON**, the planned action will be executed; if the condition is **OFF**, the action will not be performed regardless of the frequency of the triggered event. The condition state can be changed as a result of some other event, so an additional rule should be added to perform this task; alternatively, you can manually set and unset conditions at your will. Thus, conditions allow the activation and deactivation of rules without requiring them to be entirely deleted.


To assign a condition to the rule, choose one or multiple target events from the *Rules* list and click the *Condition* button on the bottom panel, then either select target condition from the list or create a new one.

Please read the [Conditions](#) topic of this document if this feature is new to you: it contains detailed description and usage examples.

Source and Target Channels

Some actions participating in the rule creation need a related channel to be specified so that these rules can be properly executed. For such actions, the source/target channel is specified when you create a rule involving such an action: corresponding additional buttons appear on the bottom panel or the rule map section, next to conditions, schedules and delay timers. Each action allows exactly one related channel; if you need, for instance, two snapshots to be sent via email, just add two actions of the same type and specify different source channels.

Ganz CORTROL Global Administration Guide




Use the *Snapshot Source* button to attach different snapshots to several actions of the same type

When you combine such actions with events that already are related to some channel (e.g., *Video Lost*, *Motion*, *VCA*, *DI*), that channel is selected automatically for the resulting action. For the rest of events, the channel is not set by default and you need to use the **target/source channel** buttons on the panel below the rules. Also, you can set a different channel instead of the one selected automatically by using the same buttons.

Attaching Snapshots

The *Send Email* action allows you to attach a snapshot from one channel and deliver it together with the email to the recipient. The snapshot can be taken either from the main stream or from the secondary stream (substream), if available. At the action creation time, you just enable the snapshot from either main or secondary stream, and then you will have an option to specify the source channel when creating the rule that involves such an action.

When creating the [Send Email](#) action, you can choose to attach a snapshot by selecting the necessary stream option (main/sub) from the drop-down list. The channel itself is not specified at this step as it is not known beforehand, to which channel this action will be applied in future - this makes the action universal, applicable to any target channel.



Specify a snapshot source for the target rule

Ganz CORTROL Global Administration Guide


The source channel is specified when you attach the *Send Email* action to an event, i.e., create a rule in the *Event & Action Configurator*:

- if the event in the rule has some channel as a source (e.g., motion, VCA, DI), this channel is set automatically as a snapshot source
- for events having sources other than channels (e.g., user buttons, server events), you can specify the source channel by using the *Snapshot source* button on the panel below the rule map
- you can modify the source channel by using the same button, and also disable snapshot attachment by selecting *none* as the source

Email sending rules can accept any extra modifiers just like any other rules - [delay timers](#), [conditions](#) and [schedules](#), each of them once.

Adding Target Channels to Rules

There are other actions, apart from *Send Email with a Snapshot*, that are related to channels and may use them as action targets. These are, namely, *Create Bookmark* and *Send Event to Client*.



Recording changes are logged in the notification area of the target channel

The *Create Bookmark* action requires a channel to add the bookmark to. To add bookmarks to multiple channels simultaneously, add several actions of the *Create Bookmark* type and specify different target channels for each.

The *Send Event to Client* action only needs a target channel to be specified in case the action has the *Display event in notification panel* option enabled: as a result, the pre-defined message will appear in the notification area of the specified channel (overlay area in live view, the same place where the stream errors appear - see Ganz CORTROL Client user manual for more information). Similarly to bookmarks, you can add more than one action of the same type and add different channels as targets in order to display the message in the notification areas of these channels.

Examples

Here are a few examples of the *Event & Action Configurator* usage. You will find more examples in each of the related topics.

Ganz CONTROL Global Administration Guide

Export Snapshots From All Channels

Task: upon a user button click, save a snapshot from every existing channel on one server.

Preliminary setup:

- create a [user button](#) with your desired name
- create an action: export snapshot to a specified location

The screenshot shows a software window titled "Action Export snapshot*". It has a sidebar on the left with two tabs: "Action" and "Details*". The "Details*" tab is selected. The main area is titled "Details" and contains the following elements:

- A "Stream" dropdown menu with "Main stream" selected. Below it, text says "Snapshot will be created for selected stream".
- An unchecked checkbox labeled "Enable subtitles" with the text "Enable or disable subtitles on the snapshot." below it.
- A selected radio button labeled "Export to local file" with the text "The snapshot will be exported to local file" below it.
- A "Local path" label next to a text input field containing the macro-based path: `K:\Snapshot\{ACTION_PARAMETER_TITLE}_{EVENT_TIME}.jpg`. An "Insert field" button is to the right of the input field.
- At the bottom right, there are "OK" and "Cancel" buttons.

Export snapshot to a specified location using text macros for the file name


Note that the action itself does not contain any fields for the channel to serve as the snapshot source. Thus, the action is universal and can be used repeatedly for many rules; the target channel for the snapshot is then to be specified for each rule in the E&A Configurator.

Use the text macros in the file name and/or path: this is necessary for each snapshot to have a unique name. Otherwise, the snapshots in the same directory will overwrite each other. {ACTION_PARAMETER_TITLE} here is the best option here to differentiate between channels because the originating event (user button clicked) and the action target (server) are the same for all rules. For example, here are two different applications for the same macros:

K: \Snapshot\{ACTION_PARAMETER_TITLE}_{EVENT_TIME}.jpg - each file name contains channel name (snapshot source specified at the rule creation step) and a timestamp

K: \Snapshot\{ACTION_PARAMETER_TITLE}\{EVENT_TIME}.jpg - directories with channel names are created, and all snapshots from the same source are put into the same folder and have timestamps as their names

Ganz CORTROL Global Administration Guide



Each rule has its own snapshot source

Rules:

- add the *user button click* event once, click it so that it is selected (highlighted green)
- add the *export snapshot* action multiple times for all channels using + button (the rule will be copied automatically)
- define the *snapshot source* (=channel) for each rule using the button in the bottom

As a result, when the user button is clicked in the Ganz CORTROL Client or in the Ganz CORTROL Mobile application, snapshots from all available (those having video) channels will be saved into the specified location.

Email Notification on Video Loss

Task: send an email notification when the video stream from certain channel(s) is not available for more than five minutes.

Preliminary setup:

- in the channel settings, set the video loss timeout to 300s (five minutes) for each target channel (select multiple channels and use the *Bulk Edit* button on the upper panel to modify several channels at once)
- configure a [mail server](#) with your desired parameters
- create an action: send email to the responsible person using the pre-configured SMTP server

Rules:

- the *Video lost* event from each of the target devices triggers the *Send email* action

Ganz CORTROL Global Administration Guide

RULE

Camera A >> Video lost

Gmail >> Send email to admin

Camera B >> Video lost

Gmail >> Send email to admin

Camera C >> Video lost

Gmail >> Send email to admin

Email Notification on Video Loss

Note that you do not need to create the *Video lost* event as it already exists by default for each channel.

Pop Up Channel on Video Analytics Event

Let's see how to pop up video channels if built-in video analytics (VA) trigger a line cross event. Such rules let you efficiently load operators' monitors, so that they only see relevant video instead of tons of static channels.

Task: if video analytics on Channel X detect a person crossing a line, pop up Channel A on all operators' screens.

Preliminary setup:

- Channel A: [enable VA](#), add a [crossing line](#), add a line event of the *Crossed* type with the *Person* class enabled

Rule for Channel A:

- VCA rule* with the *Line crossed* parameter triggers the *Pop up on screen* action

If you want to limit the popup to a specific video wall display, simply create an additional action of the *Popup object* type. In the action properties, you will be able to specify the video wall display and even viewport index as the channel destination.

Global Handling of Recording Errors

This example will cover a use case with a **global event**, showing how multiple servers within a single system can be involved in a more sophisticated chain of events and actions.

Task: if there are recording errors on Server A, log this event locally and also add corresponding entry to Windows Application log on the central server. The *Recording error* event is there by default and so there is no need to create it.

Preliminary setup:

- Server A: *Write to A Application log* action
- Central Server: *Write to CS Application log* action
- Global event *Recording Error on Server A*


Rules for Server A:


- Recording error* event triggers local *Write to A Application log* action
- Recording error* event triggers *Send global event* action for the *Recording Error on Server A* event


Central Server rules:


- Recording Error on Server A* global event triggers its own *Write to CS Application log* action

RULE

 **Server A >> Recording error**

 Server A >> Write to A application log


 **Server A >> Recording error**


 Recording Error on Server A >> Send global event

Rules for the Server A

Server A generates a global alert and sends it to all servers in the system.

RULE

 **Recording Error on Server A >> Global event**

 Central Server >> Write to CS application log

Rules for the Central Server

The Central Server is subscribed to the global alert and therefore reacts with the assigned action.

11.2 Default Events

Events are entities that appear when something happens in the surveillance system - namely, when the system or system component state changes. These changes can be set up to trigger certain actions so that system administrators and/or users can react to them in a timely fashion.

For each Ganz CORTROL server, there are a set of default events, which behave in an identical way on all servers and cannot be altered or deleted. These are:

- **Central Server Connected:** the connection with central server has been restored; event is available for non-central **servers**
- **Central Server Disconnected:** the connection with central server marked as unavailable because the timeout defined in the server settings has been reached; event is available for non-central **servers**
- **Disk Excluding:** one of the storage locations has been marked as unusable and has been excluded from the recording configuration; event is available for every **server**
- **Failover Activating:** a recording server has failed and has been automatically replaced by a failover node
- **Fallback Activating:** main storage has failed, server has automatically switched to fallback storage; event is available for each **server**
- **Global Event:** global (system-wide) event from one of the servers has been fired; event is available for all defined [global events](#) and on all servers with Ganz CORTROL Global
- **Motion:** motion has been detected; event is available for each **channel**
- **Motion Started:** some motion has been detected (single motion event has occurred); event is available for each **channel**
- **Motion Stopped:** no more motion is being detected; event is available for each **channel**
- **Recording Error:** problem encountered while recording video data to the storage; event is available for each **server** and for each **channel**
- **Recording Recovered:** server has recovered from the recording error; available for each **channel**
- **User Button Clicked:** user button was pressed; event is available for all created **user buttons**
- **Video Lost:** no video stream available for this specific channel for the defined amount of time, which is set in the channel settings; event is available for each **channel**
- **Video Restored:** video stream connection re-established; event is available for each **channel**
- **External Event:** for each **channel**, three custom events are available (see details below)

←

→

Events Actions > Events

Built-in Administrator account

Events & Actions	<div><div>+ New event</div><div>Edit</div><div>✕ 1 selected</div></div>		
Rules			
Events			
Actions			
Global events			
Conditions			
Schedules			
Mail servers			
Configuration			
Events & Actions			
Monitoring			

TITLE	EVENT TYPE	SOURCE
Central server connected	CentralServerConnected	
Central server disconnected	CentralServerDisconnected	
Disk excluding	Disk excluding	
Global event	Global event	
Recording error	Recording error	
User button clicked	Button pressed	
Video lost	Video lost	
Video restored	Video restored	

Recently added, 0

Recently updated, 0

Default events

Default events are available in the *Event & Action Configurator* and can be used in the same way as user-defined events, except for they cannot be edited. Events are arranged by **sources**. Typical event sources are: channels, channel groups, servers, user buttons, video walls, external services.

Ganz CORTROL Global Administration Guide

External Channel Events

External (custom) channel events are reserved for cases when you need Ganz CORTROL to react to an event originating in a third-party system not directly integrated with Ganz CORTROL. These events are triggered via HTTP API by sending a request to the system.

Event Sources

External events can originate from the following sources:

- Channel
- Channel group
- Service
- Service group

Regardless of which of these is selected as the source when configuring the rule, the actual event execution will always resolve to a specific channel defined by the external service. Macros and notifications will reflect the channel that triggered the event, not the group or service used in the rule configuration.

This expanded flexibility allows better organization of rules, especially in environments with multiple channels or services that should share the same external trigger behavior.

URL Syntax

Each of the three available events is predefined and triggered via the following endpoint structure:

```
/event/<resource_id>/external1/activate  
/event/<resource_id>/external2/activate  
/event/<resource_id>/external3/activate
```

Where <resource_id> corresponds to the channel ID. This ID can be looked up in Ganz CORTROL Console under the Channels tab (ensure object IDs are enabled under Settings > General).

Configuration	<div><div>+ Create channel group</div><div>Edit</div><div>Assign main stream recording configuration ▾</div><div>Assign group</div></div>			
Devices				
Channels	TITLE	ID	DEVICE	SERVER
	My Camera	(115)	My Camera (114)	Glo (101)

Channel ID is equal to 115 for My Camera

Example

For a channel with ID 115, assuming the server IP is 10.10.10.1 and the default HTTP port is 8080, the URLs will be:

```
http://10.10.10.1:8080/event/115/external1/activate  
http://10.10.10.1:8080/event/115/external2/activate  
http://10.10.10.1:8080/event/115/external3/activate
```

The authentication type should be **digest**, and the method must be **GET**, for example:

```
curl -v --digest -u admin:password http://192.168.1.83:8080/event/1257/external1/activate
```

(Generic) ONVIF Compatible on 192.168.3.114 (2002)	Motion II >> Unset condition	Generate alert substream
Custom event #2	(Generic) ONVIF Compatible on 192.168.3.114 >> External event 1	Pop-up on screen
External event 1	(Generic) ONVIF Compatible on 192.168.3.114 >> Pop-up on screen	Pop-up playback on screen
External event 2	(Generic) ONVIF Compatible on 192.168.3.236 >> Motion	(Generic) ONVIF Compatible on 192.168.3.236 (1993)

An event rule using an external channel event

In Ganz CORTROL Global systems:

- use the IP and port of the server, where the target channel is configured
- if the main recording server has switched to failover, use the IP and port of the failover node (channel ID remains the same)

Ganz CORTROL Global Administration Guide



When triggering the event over the Internet, make sure that the HTTP port of the target Ganz CORTROL server is reachable (open on the firewall(s) and forwarded, if required).

Ganz CORTROL Global Administration Guide

11.3 Add Events

Events are entities that appear when something happens in the system - namely, when system or system component state changes. These changes can be set up to trigger certain actions so that system administrators and/or users can react to them in a timely fashion.

In addition to the [default set of events](#), certain types of events can be added manually and customized. Continue reading to learn about event types and their settings.

To access event management in Ganz CORTROL Console, select the *Events & Actions* section and then select *Events* from the menu on the left.

To create an event, click + *New event* button on the upper panel; event configuration dialog box will open. It is also possible to add events as you go, from the *Event & Action Configurator*. Fill in the settings, then click *OK* to save and close the dialog box. The newly created event will appear in the item list under *Events* and will be available for setup in the *Event & Action Configurator*.

Once you have created an event, it is impossible to change its type, only its source and properties.

Below, you will find explanations about every available event type.



Before creating events from camera DI, VCA source, GSM modem, or external service, make sure to:

- add the resource (channel, modem, etc.) to the server configuration;
- enable alert generation in [channel settings](#) via Ganz CORTROL Console for device digital inputs (DI);
- enable and set up rules via camera Web interface for edge VCA and set up rules via channel settings for software-side Open VCA;
- set up the External Service event generation logic for external services (license plate recognition, face recognition etc.)

Without this preparation, you will be unable to create the events.

Event Access control event*

Event

Details

Select event type

Search

Available event types

- Channel related (2)
- External events (2)
- Variables and counters (4)
- Data source
- Variable value
- Other (4)

Channel variable value
Certain value reached by Open VCA counter (server-side VCA only)

Counter value
Camera-side VCA or software counter hit a certain value

Data source
Text match from data source (POS)

Variable value
Any value mapping from data sources (POS) or camera metadata (e.g., thermals)

OPC Client event
Event received from external OPC server

OK Cancel

Ganz CONTROL Global Administration Guide

Choose event type

Prior to software version 1.17.0, events and actions were simply listed alphabetically. Starting with v.1.17.0, events and action are additionally grouped for your convenience. Start typing a keyword to quickly find a specific event.

Channel Related Events

Events in this category have channels as sources.

Before creating such events - from camera DI or VCA source - make sure to:

- enable alert generation in [channel settings](#) via Ganz CONTROL Console for device digital inputs (DI)
- enable and set up rules via camera Web interface for edge VCA, or set up server-side analytics rules

Without these settings, the target channel will not have corresponding DI or VCA items available in the event settings (the item list will be empty).

Auxiliary Device Event

This type of event is similar to *VCA Event* and designates some event that happens on the device side, with the difference that the auxiliary device event comes from a non-video device. Auxiliary device events may come from alarm control panels, various sensors, audio detectors etc. These events are received directly via device integration (not via OPC/MQTT/...) and are not directly reported as DI/DO events either.

If your device falls into this category but the auxiliary event list is empty, try the *VCA event* type.

Event Satel Auxiliary device event Partition #2: arm by user*

Event

Details*

Details

Event type

Auxiliary device event

Change...

Select event type from list of possible event types

Title

Satel Auxiliary device event Partition #2: arm by user

Event name

Source

Satel

Change...

Event source

Device event

Partition #2: arm by user

Change...

Device event

Reload

Apply OK Cancel

Auxiliary device event settings

Available settings:

- **Title:** user-defined event name that will appear in the E&A Configurator
- **Source:** source device (e.g. Satel alarm control panel)
- **Device event:** event type on the device side

Digital Input

This event is triggered when a device's DI (digital input) state is changed. Before creating the event, make sure you have enabled DI event generation in the device channel's properties.

The following settings are available for *Digital Input* event:

Ganz CORTROL Global Administration Guide

- **Title:** user-defined event name
- **Source:** choose the device from which the DI event originates; event generation must be enabled in the [channel settings](#)
- **Digital Input:** select one of the DIs of the target device to serve as event trigger; the number of inputs depends on the total available and configured inputs
- **Digital Input Mode:** the binary input state to trigger alert; must conform with the DI state set up in the [channel settings](#)

The screenshot shows a web-based configuration window titled 'Event *'. It has a sidebar on the left with 'Event' and 'Details' (selected). The main area is titled 'Details' and contains the following fields:

- Event type:** A dropdown menu set to 'Digital input'. Below it is the text 'Select event type from list of possible event types'.
- Title:** A text input field containing 'Gate > Digital input >'.
- Event name:** A text input field, currently empty.
- Source:** A field showing 'Canon VB-S800D on 192.168.3.40 (123)' with a 'Change...' button to its right.
- Digital input:** A dropdown menu set to 'Input 1'.
- Digital input mode:** A dropdown menu set to 'Activated'.
- Buttons:** A 'Reload' button is located below the 'Digital input mode' dropdown. At the bottom right of the window are 'OK' and 'Cancel' buttons.

Settings for the *Digital Input* event type

VCA Event

For **camera-side VCA** and software-side **Open VCA** events. Note that this event only covers triggered VCA **rules**, and not counters. In order to set up reactions for VCA counter changes, use the *Channel variable value* event (for Open VCA) or *Counter value* event (for camera-side counters).

The available settings are:

- **Title:** user-defined event name
- **Source:** choose a channel from which the video analytics event originates; analytics rules must be enabled via the camera Web interface (some cameras have basic VCA events enabled by default, e.g. volume detection) or pre-configured using the Ganz CORTROL Console for the software-side Open VCA module (see corresponding documentation for configuration details)
- **VCA Rule:** video analytics rule to trigger event alert; may come from the camera side, Open VCA engine, or built-in VA engine; available rules depend on device model, capabilities and VCA configuration

Ganz CORTROL Global Administration Guide

⚡ Event *

Event

✎ Details

Details

Event type

VCA

Select event type from list of possible event types

Title

> VCA >

Event name

Source

🔌 Canon VB-S800D on 192.168.3.40 (123)

Change...

Event source

VCA rule

Volume Detected

VCA rule

Reload

OK

Cancel

Settings for VCA event type

If you do not see a recently created VCA event in the drop-down list, try clicking the *Reload* button: this will refresh the source event list. For guidelines on how to enable and configure Open VCA, please see the related document.

External Events

These events come from all kinds of external systems.

Event Triggered by MQTT Notification

This event is triggered by incoming MQTT messages from a third-party broker. The message may be an exact text match, or you can evaluate it using a regular expression (regex) and catch a keyword or a part of the message.

- **Title:** event name that will appear in the E&A Configurator, corresponds to the macro {EVENT_TITLE}
- **Source:** MQTT client that will subscribe to the current topic and act as event source. Leave empty if you want the event to be visible for all existing MQTT clients
- **Topic:** MQTT topic to subscribe to
- **Text:** incoming message that will trigger the E&A event. If empty, any message will trigger the event. The field cannot be empty if marked as regular expression!
- **Regular expression:** enable this option to enter a regular expression in the Text filed instead of plain text
- **QoS:** required level of quality of service

Ganz CORTROL Global Administration Guide

Event triggered by MQTT notification

Event

Details

Event type

Event triggered by MQTT notification

Change...

Select event type from list of available event types

Title

Event triggered by MQTT notification

Event name

Source

none

Change...

Event source

Topic

topic3

Message topic

Text

Message text

☐ Regular expression

If enabled, the message text will be processed as a regular expression

QoS

At most once

Quality of service for the current subscription

Apply OK Cancel

Event triggered by any MQTT message received with topic=topic3 by any MQTT client

Fields *Source* and *Text* may be left empty. Empty source means that the event will be created for every existing MQTT client. Empty message text means that the event will be triggered by any message having the defined topic; however, you cannot leave this field empty if you wish to use regex. If the Regular expression option is enabled, the Text field must contain an evaluating expression to analyze the message text.

External Service

External Service type events are messages from modules that are operating via Ganz CORTROL HTTP API and are listed in Ganz CORTROL Console as [external services](#). By default, license plate recognition and face recognition services are integrated, and any other third-party integrations can be connected.

The following settings should be defined:

- **Title:** user-defined event name
- **Source:** choose a Channel, Channel group, Service or Service group from Ganz CORTROL Console. When the rule actually fires, the real source is always the channel defined inside the external service, so all macros resolve to that channel—not to the group or service you picked.
- **Service group:** the group the external service belongs to in Ganz CORTROL Console settings
- **Target event:** service-specific result type, e.g., recognition result
 - *Known:* recognition result has a match within the external service database (black/white list in LPR, subjects' database in FR), matching any tag
 - *Unknown:* recognition result has no matches within the external service database
 - *Tags:* recognition result was found in the external service database and it has a specific tag assigned to it

Ganz CONTROL Global Administration Guide

Event: VIP license plates*

Event

Details

Event type
ExternalService
Select event type from list of possible event types

Title
VIP license plates
Event name

Source
axis
Event source
Change...

Service group
lprs
Service group
Change...

Target event
VIP
Target event

OK Cancel

External Service event from the License Plate Recognition module

Why this matters

Picking a group or service lets one rule cover every channel inside that logical container, while still logging the exact camera that triggered it. Existing pop-ups, e-mails, and audit trails continue to show the precise channel, so nothing breaks.

Quick example

Suppose you set *Source* → *Service group* = “FR Cluster East”.

If *AnyCamera-07* inside that cluster reports a “Known” face, the macros resolve like this:

%Source.Channel% = AnyCamera-07

%Source.Service% = FR-East-Node-01

%Source.Group% = FR Cluster East

Your notifications will therefore mention AnyCamera-07, even though the rule itself was attached to the service group.

External

External events are HTTP requests from third-party software: integrations, scripts, Web browsers etc. These are a basic example of Ganz CONTROL HTTP API: an **URL** is used to trigger the event.

Ganz CONTROL Global Administration Guide

Event Trigger via URL

Event

Details

Event type

External

Select event type from list of available event types

Title

Trigger via URL

Event name

Source

My Server

Change...

Event Id

666

Event Id. Only latin letters and numbers are allowed.

OK Cancel

Event triggered by an external HTTP request

For the external request to trigger an event, create the event with a pre-defined identifier on your desired Ganz CONTROL server:

- **Title:** user-defined event name
- **Source:** Ganz CONTROL server that will accept the HTTP request
- **Event ID:** alphanumeric event identifier, **only** Latin letters [a-zA-Z] and digits [0-9] allowed

The request link is built as follows:

`http://<server_address>:<http_port>/externalEvent/activate?id=<event_id>`, where

- **<server_address>** is the target server's IP address or hostname (in Ganz CONTROL Global systems, use the exact Ganz CONTROL Recorder address, not Ganz CONTROL Global server address)
- **<http_port>** is the server's HTTP port (8080 by default)
- **<event_id>** is an alphanumeric identifier of the event, which is defined at the event creation step

Example: <http://192.168.1.99:8080/externalEvent/activate?id=666>

SMS Message Received

SMS events are events triggered by short messages, which are received by [SMS \(GSM\) modems](#). You need to connect the hardware (modem) to the Ganz CONTROL server, insert a SIM card, and add the modem into Ganz CONTROL configuration in order to receive this type of events.

Available settings:

- **Title:** user-defined event name
- **Source:** existing modem hardware to accept the message
- **Phone:** sender's full phone number; if empty, the event will be triggered by SMS from any number
- **Text:** SMS text to trigger the event, case-sensitive; leave empty for any text to trigger the event
- **Regular expression:** enable if you wish to evaluate the incoming text with **regex**, e.g., use placeholders



The phone number must be in the **international format** (with leading + or 00 and a country code) for ALL numbers, even local ones. The event will not work properly without the country code.

Ganz CORTROL Global Administration Guide

Event TELIC AG SMS message received*

Event

Details*

Details

Event type

SMS message received

Change...

Select event type from list of available event types

Title

TELIC AG SMS message received

Event name

Source

TELIC AG

Change...

Event source

Phone

+37129843

Phone number

Text

stop

Message text

☐ Regular expression

When checked, text is processed as regular expression

Apply OK Cancel

Event triggered by incoming SMS

In this event type, you can use certain keywords in your messages, or set up regular expression rules to catch patterns.

Variables and Counters

Events in this category are triggered by certain **value changes**. These values can be text variables, software or VCA counters, mappings from data sources (POS or other serial text), channel metadata etc. Each event is dedicated to a specific kind of variable or counter.

- *Counter value*: for camera-side VCA counters and also software counters
- *Data source*: text match from Data sources
- *Open VCA counter value*: server-side VCA (Open VCA) counters
- *Variable value*: pre-defined variable value analysis

Counter Value

Solely for **camera-side counters** and **software counters** (server-side, NOT VCA).

[Software counters](#) can be created in Ganz CORTROL Console to count any events in the system. Camera-side counters are only available for certain integrations (e.g., Dahua with smart tools).

This event is similar to the previous one, with the difference that you do not have to set the data type, but rather simply select a pre-created counter. Counters from the cameras must be also explicitly added in Ganz CORTROL Console under *E&A > Counters > New VCA Counter*.

- **Title**: user-defined event name
- **Source**: choose one of the pre-created software or camera-side counters
- Condition: define what the counter value will be compared to
 - **Conditional operator**: choose the comparison type - greater, less, equal, etc.
 - **Value**: an integer value for the counter to be compared to

Ganz CONTROL Global Administration Guide

Event 1000 visitors hooray*

Event

Details*

Details

Event type

Counter value

Change...

Select event type from list of available event types

Title

1000 visitors hooray

Event name

Source

People IN from D-cam

Change...

Event source

Condition

Conditional operator

Equal

Conditional operator

Value

1000

Value used in condition

OK

Cancel

Event triggered when camera-side counter reaches 1000

For actions further linked to this event, you can **pass the counter value** by using the **text macro** (field) `{ADDITION_INFORMATION}` (you can insert it in any textual action by right-clicking the text area or by clicking the *Insert field* button). The format will be `[counter_name]=[counter_value]`. For example, for a counter named *Total* hitting a value of five, the macro will show *Total=5*.

Data Source

The server will monitor incoming text from [Data sources](#), triggering an event in case the specified **string** (textual value) is received. This can be used to react to certain keywords from POS terminals and any other serial data sources. The string for comparison is defined in free **text** form (not regex). The server will be looking for an **exact match**, i.e., the field is case-sensitive and all extra symbols (commas, spaces) are accounted for.

Event if POS operator is J.Winter*

Event

Details*

Details

Event type

Data source

Change...

Select event type from list of available event types

Title

if POS operator is J.Winter

Event name

Source

POS emulation

Change...

Source

Text

Winter

Text that will be triggering event

OK

Cancel

Trigger events based on incoming POS data

Ganz CORTROL Global Administration Guide

Available settings:

- **Title:** user-defined event name
- **Source:** data source to be used as event source; text from data provider will be analyzed for matches
- **Text:** case-sensitive keyword or key phrase; when an exact match is found in the text, the event will be triggered

For the event to operate, it is **not necessary** for the target data source to be bound to any channel. Associating data sources with channels only affects video overlay in the Ganz CORTROL Client application; text detection will work on the server side, and therefore the data source may be independent.

Open VCA Counter Value

This event is dedicated to Open VCA **counters** (those set up on the server side for a specific channel). Each counter value update triggers a comparison of the integer counter value to the pre-defined value. The comparison operation is carried out using two integer data types and returns true (event is triggered) if the condition is true. The available conditions are: equal/not equal, greater/less, greater/less or equal.

To react to Open VCA rules, use the *VCA Event* under channel-related events.

- **Title:** user-defined event name
- **Source:** a channel that has Open VCA enabled and at least one counter set up
- Condition: define what the counter value will be compared to
 - **Variable:** Open VCA counter name
 - **Type:** must be **integer** (other types are listed to ensure event compatibility with older software versions)
 - **Conditional operator:** choose type of comparison - greater, less, equal, etc.
 - **Value:** an integer value for the counter to be compared to

⚡ Event Current number of people in the zone = 3

Event

Details

✎ Details

Event type

Open VCA counter value

Select event type from list of available event types

Change...

Title

Current number of people in the zone = 3

Event name

Source

vca test

Source channel

Change...

Condition

Variable

Current

Variable name

Type

Integer

Value type

Conditional operator

Equal

Conditional operator

Value

3

Value used in condition

OK

Cancel

Ganz CONTROL Global Administration Guide

Event triggered if the counter named *Current* is equal to 3

For actions further linked to this event, you can **pass the counter value** by using the **text macro** (field) `{ADDITION_INFORMATION}` (you can insert it in any textual action by right-clicking the text area or by clicking the *Insert field* button). The format will be `[counter_name]=[counter_value]`. For example, for a counter named *Total* hitting a value of five, the macro will show *Total=5*.

Variable Value

If you have some **variables** set up in the E&A section, you can use E&A manager to trigger events when these variables meet some specific condition. Mostly, these variables are mappings from [Data sources](#): thus, this event supplements the previous *Data Source* event by matching **any data type** (not just text).

The second purpose of this event is analysis of **metadata** received **from cameras** (or other devices). A typical example of this is variables from **thermal cameras** containing exact temperature measurement. To use this feature, first create channel variables under *Variables* in the E&A section. Then, use them as

Event Bill total is over 100\$*

Event

Details

Event type

Variable value

Change...

Select event type from list of available event types

Title

Bill total is over 100\$

Event name

Source

Sum

Change...

Source variable

Condition

Type

Floating-point

Value type

Conditional operator

Greater

Conditional operator

Value

100.0

Value used in condition

OK Cancel

An event is raised when the *Sum* variable is strictly greater than 100.0

This event has the following settings:

- **Title:** user-defined event name
- **Source:** a channel to be analyzed for the variable (which is set in the corresponding data source profile or has VCA configured); if none selected, the event will be visible for all channels
- **Variable:** variable name, must match the mapping name in the data sources profile or the VCA counter name
- **Type:** variable type; may be integer, double or string for a data source mapping, and integer for VCA counters
- **Conditional operator:** depends on the variable type
- **Value:** value that will be compared with the variable value

For VCA counters, there are a few special requirements:

Ganz CONTROL Global Administration Guide

- type must be **integer**
- **event source** must be selected (the channel that has VCA configured, either camera-side or software side)

Other Events

Events having no special category (or, at this point, unique), are grouped under *Other events*.

OPC Client Event

Data received from OPC servers can be analyzed - compared to specified values using conditional operators - so that an event is triggered when the target OPC node value meets the defined condition.

For this type of event to work, there should be at least one [OPC server configuration](#) available with at least one data node.

Event OPC #1 has 5 or more clients*

Event

Details

Event type

OPC Client event

Select event type from list of available event types

Title

OPC #1 has 5 or more clients

Event name

Source

OPC #1

Change...

Source OPC client

Condition

Variable

@ClientCount

Change...

Variable name

Value type

Int

Value type

Conditional operator

GreaterOrEqual

Conditional operator

Value

5

Value

OK

Cancel

This event will be triggered if the target OPC server has 5 or more connected clients

Settings:

- **Title:** user-defined event name
- **Source:** [OPC client configuration](#) (connection to an OPC server)
- **Condition:** defines a requirement for the OPC data item that will trigger the event
 - **Variable:** OPC data node, must be of compatible type and have a read permission
 - **Value type:** one of the standard data types, auto detected
 - **Conditional operator:** list of possible conditional operators, depends on the data type
 - **Value:** value to compare the variable to, must match the variable value type

Ganz CORTROL Global Administration Guide

For some conditional operators, the *Value* field may be different, e.g., represent a range, a regular expression, or a bit mask. This depends on the selected data type and conditional operators available for it.

Recording Server Connected/Disconnected*

In the Ganz CORTROL Global system, when a recording server goes down, this event will be triggered on the central management server. (Built-in events only include central server disconnection and failover activation events.) You can add both connection and disconnection events, or either one, for every recording server in the system.

Settings:

- **Title:** user-defined event name
- **Source:** central management server (unchangeable)
- **Recording server:** target secondary server to trigger the event, or *Any* to enable this event for all recording servers
- **Connection event:** connected/disconnected (one at a time)

Event Any RS disconnected*

Event

Details*

Event type

Recording server connected/disconnected

Select event type from list of available event types

Title

Any RS disconnected

Event name

Source

My Server

Change...

Source server

Recording server

Any server

Change...

Recording server

Connection event

Disconnected

Connected

Disconnected

OK

Cancel

Event: recording server offline

So, if you need to get a notification about a particular server going offline or online, choose that server in the event properties. To cover all recording servers with a single event, choose *Any* in the Recording server field: if your associated action is textual (email, alert, etc.), use the {ADDITION_INFORMATION} macro to display the name of the recording server in question.

From each recording server's side, there also exist two default (built-in) events: *Central server connected* and *Central server disconnected*. You do not need to add them manually, they will appear for each existing recording server.

*This feature is only available in Ganz CORTROL Global software edition.

Scheduled Event

The server can create automatic events on a daily or weekly basis, or at certain intervals. Such an event does not have any underlying source to originate from, it is simply generated by the system in the specified moment(s) of time. Note that the time defined here is server time.

Ganz CONTROL Global Administration Guide

Event Every hour event*

Event

Details

Event type

Scheduled event

Select event type from list of possible event types

Title

Every hour event

Event name

Source

Main server

Change...

Event source

☒ Periodical

The event will be triggered periodically on specified interval

Interval

3600

Interval in seconds

☐ Scheduled

The event will be triggered according by specified schedule The event will be triggered according by specified schedule

OK Cancel

A scheduled event that occurs every hour

There are two types of automatic events: periodical and scheduled. Periodical events arise at the specified intervals, e.g., every hour or every ten minutes. Scheduled events follow the specified timetable, e.g., are triggered at 8AM every day.


For a scheduled event, you need to define:

- **Title:** user-defined event name
- **Source:** target server to generate the event on
- **Periodical:** choose this type if you need the events to be generated every N seconds
 - **Interval:** time interval in seconds between two automatically generated events, minimum interval is fifteen seconds
- **Scheduled:** choose this mode if you wish to build a timetable to serve as a basis for the event generation
 - **Event schedule:** weekly timetable for the event generation

Minimum time interval for the periodic event is 15 seconds and maximum is 86400 seconds (which is equal to 24 hours).

To add a schedule, simply click the *Add* button below and append as many items as you like. You can add multiple moments per day as well.

Ganz CORTROL Global Administration Guide



Add schedule element

Remember that you can enter the time either manually from the keyboard or by clicking the timestamp elements and then using your mouse wheel, while still hovering your mouse cursor over the element that is being adjusted. To edit any of the items, select one and click *Edit*, or simply double-click an item; to remove, select one or many (use *CTRL+click* or *Shift+click* to select multiple items, or also *CTRL+A* to select all) and then click *Remove*.

Tag Match

This event occurs when the Ganz CORTROL server receives an recognized **car number plate** or a **face** that matches one ore more internal [tags](#).

Settings:

- **Title:** user-defined event name
- **Source:** the video channel that serves as the event source (the one being analyzed)
- **Tag match mode:**
 - **No tags:** event will be triggered by items that are not tagged
 - **Any:** the item matches one or more (at least one) of the tags selected below
 - **All:** the recognition results must match all tags specified below
 - **Not any:** the event is triggered if the recognition results does not match any of the specified tags
- **Flags:** choose if you want to use LPR, FR, or both recognition results to trigger the events
- **Tags:** define the tag list, if required

Ganz CORTROL Global Administration Guide

The screenshot shows the 'Event My Camera Tag match*' dialog box. The 'Details' tab is active, showing fields for 'Event type' (Tag match), 'Title' (My Camera Tag match), 'Source' (My Camera), 'Tag match mode' (Any), 'Flags' (LPR, FR), and 'Tags'. A 'Tags' sub-dialog is open, showing a search bar and a list of tags with 'Staff' selected. The main dialog has 'Apply', 'OK', and 'Cancel' buttons at the bottom.

You can use as many tags as you need in each event.

Video Wall*

This type of event is raised when the **video wall state is changed**. This happens when objects are sent to video wall from the resources' menu in Ganz CORTROL Client, when they pop up automatically based on another event, or when users manage the video wall via dedicated tab in the Ganz CORTROL Client application. Note that events of this type are **not generated** if screen contents is changed directly via **local** screen management - drag-and-drop or double-click.

Advanced options let you specifically define the nature of that change, the video wall screen and even the target viewport.

This event can happen on three levels, depending on the defined scope:

- any part of the video wall (video wall is defined, other settings set to *any*)
- specific video wall screen (video wall and its screen are defined, leaving viewport choice to *any*)
- specific viewport in the video wall screen (all settings defined)

The triggered events for all these areas will differ slightly (see examples below).

Available settings:

- **Title:** user-defined event name
- **Source:** video wall
- **Mode:** the type of changes
 - *Updated:* **any change** in the specified location (any or a specific object has been placed on or removed from the target location)
 - *Added:* the target object has been added to the specified location for the very **first time**
 - *Removed:* the target object has been **completely removed** from the target location
- **Video wall screen:** target video wall display
- **Viewport index:** number of the port to trigger the event, set 0 (zero) for any viewport
- **Object:** any object (if *updated*), or a specific map/channel (*updated/added/removed*)

Note that the target object must be specified for *added/removed* modes: there are no events for "any object added" or "any object removed". These two modes are intended to be used with concrete objects. If you do not care, which

Ganz CONTROL Global Administration Guide

object was added or removed, use the *updated* mode.

Event Detect: City map appeared on VW Screen 2, port 9

Event

Details

Event type

Video wall

Select event type from list of available event types

Title

Detect: City map appeared on VW Screen 2, port 9

Event name

Source

Matrix Video Wall

Change...

Source videowall

Video wall screen

2 - Main

Video wall screen

Viewport index

9

Index of viewport in screen (0 - any available viewport)

Object

City

Change...

Object shown on videowall

OK

Cancel

Video wall event example

The viewports are numbered starting from 1, from top to bottom and from left to right. Zero index means the event will be triggered, when the target object appears in any viewport of the target video wall display.

Event Examples

1) An event is set to be produced when Channel S is *removed*. Depending on the defined settings, the event triggering will differ in the following way:

- if only **video wall** is defined without any details: event will be triggered after all instances of Channel S are removed. In other words, if Channel S is present several times on different video wall screens, the *Removed* event will only be triggered after the last instance of Channel S is removed, and the exact video wall screen or viewport do not matter.
- if a **video wall screen** is defined: same behavior but limited to this specific screen. If Channel S is currently displayed on other video wall screens, its presence is ignored. The last Channel S instance removed from the target screen will trigger the event.
- if a specific **viewport** is defined: the event will be triggered every time Channel S is removed or replaced by any other channel.

2) Event settings are set to maximum precision: video wall, video wall screen, and viewport are specified. In this case, the event area is limited to the **viewport**, and replacing Channel E with Channel X will trigger the following events (if they have been set up):

- *Removed* event for Channel E
- *Added* event for Channel X
- *Updated* event (no object needs to be specified)

3) The event is set to be generated when Channel Y is *added*. Consider the following scenarios:

- only video wall or video wall screen is defined for the event; the target video wall screen has a 2x2 layout, and:
 - Channel Y pops up in any viewport, filling in an empty space or replacing any other channel: event is **triggered**

Ganz CORTROL Global Administration Guide

- Channel Y pops up again in the same viewport, replacing itself (so there are no changes): event is **not triggered**
- Channel Y is then displayed in another viewport (so that it now appear in two viewports): event is **not triggered**
- video wall, its screen and a viewport index are defined:
 - every time Channel Y pops up or is placed into the target viewport, the event is **triggered**

*This feature is only available in the Ganz CORTROL Global software edition.



Removing and adding event sources again (e.g., deleting and creating edge VCA rule with the same name) may render them **unusable** if they are already included in the *Event & Action* configuration. Make sure to verify the event operability and then re-create and re-insert the event after modifying it, if necessary.

NewEvent

11.4 Global Events


Global events are alarms accessible from any server within the Ganz CORTROL Global installation - unlike normal events, which are visible only from one particular server. There are no types for global events; they are simply system-wide alerts that can be used to make one server's events trigger actions from another server.

Each added global event will be available in the *Event & Action Configurator* of every server within the system, and will be accessible in two ways:

- in the *Events* section on the left: *Global event* event
- in the *Actions* section on the right: *Send global event* action


Add Global Events

To add global events via Ganz CORTROL Console, go to the *Events & Actions* section and choose *Global Events* from the menu on the left. Click the + *New global event* button on the upper panel to bring up the configuration dialog box.



Global event details

Enter an unambiguous **title** for the global event and click *OK* to save and exit the dialog box. The newly created event will appear in the item list and will become available for usage in the *Event & Action Configurator* on all connected servers.



TITLE	ID
ALARM	(129)
Recording Error on Server A	(149)
Recording Error on Server B	(151)

List of global events

Use the buttons on the upper panel to edit, deselect and remove global events; the filters on the bottom panel will help you load recently added or recently edited items.

Usage Example

Consider a system which has three servers, one of them central. Each of the 'slave' servers has a 'panic' button

Ganz CONTROL Global Administration Guide

connected to the digital input of a camera. While each of the servers has its own local reaction for the 'panic' button configured, we also want the central server to keep the logs of 'panic' button press history.

The configuration for this use case might be as follows (local 'panic' actions omitted at this point):

- Server 1:
 - Event 1: local 'panic' camera *digital input (DI)* activated
- Server 2:
 - Event 2: local 'panic' camera *digital input (DI)* activated
- Central Server:
 - Action 1: *Write to application log*, text: "Alarm button pressed on Server 1"
 - Action 2: *Write to application log*, text: "Alarm button pressed on Server 2"
- Global events:
 - *Global Panic 1*: 'panic' button pressed on server 1
 - *Global Panic 2*: 'panic' button pressed on server 2



It does not matter which server global events are created on; they become visible on all servers after creation.

The **rules** for this configuration are as follows:

- Server 1:
 - Event 1 triggers action *Panic 1: send global event*
- Server 2:
 - Event 2 triggers action *Panic 2: send global event*
- Central Server:
 - Global event *Global Panic 1* triggers *Action 1*
 - Global event *Global Panic 2* triggers *Action 2*



The whole scheme is as follows when added to each server's configuration:

RULE

- ◀  Camera A >> Panic 1 activated
- ▶  Global Panic 1 >> Send global event





Rules for Server 1

RULE

- ◀  Camera C >> Panic 2 activated
- ▶  Global Panic 2 >> Send global event

Rules for Server 2

RULE

- ◀  Global Panic 1 >> Global event
- ▶  Central Server >> Write to CS application log
- ◀  Global Panic 2 >> Global event
- ▶  Central Server >> Write to CS application log

Rules for the Central Server

11.5 Default Actions

Each item - server, channel, or other resource - has a set of default actions that have identical behavior on all servers and cannot be altered (edited) or deleted. These are:

- **Generate Alert:** generate an alarm that can be used as recording basis in recording profiles; this action is available for each channel
- **Generate Alert Substream:** generate an alarm that can be used as recording basis in recording profiles; this action is available for each channel substream
- **Send Global Event:** send a global event notification to all servers; this action is available for each defined [global event](#)
- **Pop-up On Screen:** display the object on all Ganz CORTROL Client windows that accept pop-ups of the target object type; action is available for channels, maps, shared layouts, and servers. When triggered from a server, it is parametric—you can specify any channel, or leave the channel parameter empty so the system uses the event-source channel.
- **Pop-up Playback On Screen:** display instant playback for a channel in Ganz CORTROL Client while keeping the live view; action is available for all channels and servers (parametric in the same way as Pop-up On Screen).
- **Disable channel:** change the target channel state by disabling it; the action is visible on each server, allowing you to choose the target channel when creating the event rule
- **Enable channel:** change the target channel state by enabling it*; the action is visible on each server, allowing you to choose the target channel when creating the event rule
- **Enable device channel VA:** Turn on the Video Analytics attached to the device Channels. You must preconfigure VA inside the Channel settings to trigger this Action with the particular Channel.
- **Disable device channel VA:** Turn off the Video Analytics attached to the device Channels. You must preconfigure VA inside the Channel settings to trigger this Action with the particular Channel.
- **Toggle channel disable/enable:** change the target channel state to opposite*; the action is visible on each server, allowing you to choose the target channel when creating the event rule
- **Set Condition:** change the target condition state to *ON*; this action is available for each [condition](#)
- **Unset Condition:** change the target condition state to *OFF*; this action is available for each [condition](#)
- **Increment/Decrement/Reset:** change counter value; this action is available for each [software counter](#)
- **Send global event:** broadcast a global notification to all servers; this action is available for every [global event](#)

*Make sure your [license](#) has enough free channels for this action to work properly.

User-defined Pop-ups with empty source

You can create your own Pop-up On Screen actions without specifying a source. Such actions are automatically attached to every channel, map, shared layout, and server as parametric entries (the channel parameter behaves exactly like in the built-in Pop-up actions). This lets a single rule show the correct channel wherever it fires.

Ganz CONTROL Global Administration Guide

←

→

Events

Actions > Actions

Built-in Administrator account

Search

Events & Actions

Rules

Events

Actions

Global events

Conditions

Schedules

Mail servers

Configuration

Events & Actions

Monitoring

New action

Edit

1 selected

TITLE	ID	ACTION TYPE	TARGET
Generate alert	(46)	Generate alarm	
Send global event	(43)	Send global event	
Set condition	(44)	Set condition	
Unset condition	(45)	Unset condition	

Recently added, 0

Recently updated, 0

Default actions

When you generate an **alert** for main stream or substream, all channels having alert-based recording enabled will start recording for the duration of time period defined in the profile as **post-recording time**; after that, the profile operation will be terminated and target channel will return to its normal recording configuration.


Default actions are available in the *Event & Action Configurator* and can be used in the same way as the user-defined actions. These actions are not listed under *Actions* as they are not configurable.

Ganz CORTROL Global Administration Guide

11.6 Add Actions

In addition to the [default actions](#), certain types of actions can be added manually and customized.

To access action management in Ganz CORTROL Console, choose the *Events & Actions* section and select *Actions* from the menu on the left. In order to create an action, click the + *New action* button on the upper panel; an action configuration dialog box will open. It is also possible to add actions as you go using the *Event & Action Configurator*.



Choose action type

All available actions are grouped according to their purpose. Choose your desired action type from the list to see action-specific settings.

Channel Related Actions

Actions in this category have direct relation to channels, e.g., PTZ presets and tours, digital output (DO) state change etc.

Activate PTZ Preset

This action type allows you to make a PTZ camera go to a specific pre-configured preset. You just need to specify:

- **Title:** a user-defined action name
- **Target:** the target device which is to accept the PTZ command
- **PTZ priority:** priority to execute PTZ action with (0 = lowest, 10 = highest, higher priority will override tours and user commands*)
- **Preset:** pick one of the automatically loaded target device presets from the drop-down list (you might need to create some first via Ganz CORTROL Client)

Ganz CORTROL Global Administration Guide

Action *

Action

Details

Details

Action type

Activate PTZ preset

Select action type from list of available action types

Title

Axis 215; Activate Preset #1

Action name.

Target

Axis 215 PTZ on 192.168.3.4 (112)

Change...

Action target

PTZ priority

10

PTZ priority

PTZ preset

Preset #1

PTZ preset

Reload

OK

Cancel

Action: activate PTZ preset

*PTZ priority parameter is used when two or more simultaneous PTZ command requests (either from action or from direct user input) are sent at the same time. When this happens, request with a higher priority is fulfilled while request with a lower priority is delayed for ten seconds. Default **PTZ priority** for all actions is equal to **five** (medium priority), which also coincides with the **default per-user** PTZ priority. You can assign any action a higher PTZ priority (six to ten) or a lower one (four to zero) by editing the *Activate PTZ Preset* action properties. All PTZ tours have zero priority.

Use the *Reload* button to refresh the list of presets: this will be useful if you have created new presets while keeping the action creation dialog box open.

Activate PTZ Tour

This action is similar to the previous one but instead of activating a single PTZ profile you run a series of presets called a PTZ tour. PTZ tours must be pre-created via Ganz CORTROL Client application. For each tour, you define the order of presets and their duration.

Ganz CONTROL Global Administration Guide

Action Street View PTZ Activate PTZ tour Perimeter*

Action

Details*

Details

Event type

Activate PTZ tour

Change...

Select event type from list of available event types

Title

Street View PTZ Activate PTZ tour Perimeter

Event name

Target

Street View PTZ

Change...

Target channel

PTZ tour

Perimeter

Change...

PTZ tour

Reload

OK

Cancel

Action: activate a custom pre-configured PTZ tour

- **Title:** the user-defined action name
- **Target:** the target channel that has a pre-configured PTZ tour
- **PTZ tour:** the target PTZ preset sequence to be activated

When this action is executed, the target PTZ tour is activated and looped endlessly. You can stop the tour manually via Ganz CONTROL Client or Ganz CONTROL Mobile application. Tours that do not have the autostart property will also be stopped when the Ganz CONTROL server is restarted.

Control Digital Output

Devices having relay (digital) outputs (DOs) can have them triggered as a result of the *Control digital output* action. You are asked to enter the following details for this action type:

- **Title:** user-defined action name, by default it is > *Activate PTZ preset* >, suggesting that before and after >> arrows you can insert the camera name and DO number/target - or, alternatively, re-define the whole title according to your own naming convention
- **Target:** the target device which is to accept the digital input control command
- **Digital Output:** pick one of the available DOs of the target device to be triggered
- **Digital Output Mode:** choose whether an activation or deactivation command is sent to the target relay output

Ganz CONTROL Global Administration Guide

➤ Action Street View PTZ open gate via DO*

Action

Details*

Details

Action type

Control digital output

Change...

Select action type from list of available action types

Title

Street View PTZ open gate via DO

Action name

Target

Street View PTZ

Change...

Action target

Digital output

Digital Output 1

Digital output

Digital output mode

Activate

Digital output mode

OK Cancel

Action: change digital output state



Digital output(s) must be enabled in [channel settings](#) for the target camera; otherwise, you not will see any available DOs in the drop-down list after selecting the target device. Also, make sure that digital output operation has been allowed via device Web interface.

Device Action

This action is reserved for special device-side actions like wiper control, arm/disarm, lights ON/OFF etc. This functionality depends on the device integration.

- **Title:** the user-defined action name
- **Target:** the target channel to accept the command
- **Device action:** integration-specific device action
- **Parameter:** command-specific parameter, if required (e.g., alarm code for arming/disarming alarm panels)

Currently, device actions are only supported for few devices. If you do not see any available action for your device, try using the *Send HTTP Request* action described further: that action allows you to enter a CGI/HTTP command from device API.

The *Parameter* field is integration-specific. For example, when working with Satel devices, you can use device action to arm/disarm the panel, providing the code in the *Parameter* field.

Export Snapshot

A snapshot from the main or secondary stream of any channel can be saved as a result of an action. The file can be saved either locally (on the target server) or to a remote server (FTP).

Ganz CONTROL Global Administration Guide

The screenshot shows a window titled "Action Export snapshot*" with a "Details" tab. The "Action type" dropdown is set to "Export snapshot". The "Title" field contains "Export snapshot". The "Target" dropdown is set to "Main server". The "Stream" dropdown is set to "Main stream". The "Export to local file" radio button is selected. The "Local path" field contains "C:\MyDirectory\{EVENT_TIMESTAMP}_snap.jpg". There are "OK" and "Cancel" buttons at the bottom right.

Export snapshot to the local server

The following settings are to be defined here:

- **Title:** user-defined action name
- **Target:** the server to execute this action on
- **Stream:** main stream or substream of the target channel (the channel is to be defined at the action rule creation step)
- **Enable subtitles:** enable this setting to activate subtitles and expand additional settings
 - **Text:** subtitle text (plain text and/or macros)
 - **Position:** subtitle alignment (top/bottom, left/right, corners)
 - **Font:** subtitle font (choose from the system dialog)
 - **Colors:** background (transparent by default), foreground (text itself), shadow (text shadow)
- **Export to local file:** the snapshot will be saved to the target server chosen above using the specified path
 - **Local path:** full path and filename, e.g., C:\MyDirectory\{EVENT_SOURCE_TITLE}_{EVENT_TIMESTAMP}.jpg
- **Export to FTP directory:** the snapshot will be saved onto a different machine that is not a part of the system
 - **FTP path:** full path and filename
 - **Host:** target machine's IP address or domain name
 - **Port:** port to be used for FTP connection
 - **Username:** user account name to connect to the remote server
 - **Set password:** specify a password, if required to log into the remote server

You can include text macros in the filename, for example, insert timestamps and event source title automatically to create files with different names every time the action is executed.

Start Playing an Audio File

It is possible to send an audio file to the connected device in case it has a built-in or a connected speaker: Ganz CONTROL server can use a .wav file to send audio to the remote camera or video server.

Ganz CORTROL Global Administration Guide

Action Reception: start playing alarm*

Action

Details

Details

Action type

Start playing an audio file

Select action type from list of available action types

Title

Reception: start playing alarm

Action name

Target

Reception

Change...

Channel. If none is selected, the action will be visible on all channels.

File path

C:\sounds\alarm.wav

Audio file path

Duration

0

Duration in seconds (0 - play all).

Repeat count

3

Repeat count (0 - infinite)

OK

Cancel

Send a pre-defined audio recording to the camera

You need to specify:

- **Title:** user-defined action name
- **Target:** the channel for the sound to be sent to (if none selected, the action will be available for all channels)
- **File path:** full path to the local *.wav file that should be used for audio output
- **Duration:** the amount of time for the audio to be played (set zero to play the whole file)
- **Repeat count:** the number of times for the audio file to be repeated (set zero for the file to played non-stop)

If you need the audio to be played continuously until another event stops it, set the *Repeat count* parameter to zero and use the *Stop playing an audio file* action to terminate the playback.

Stop Playing an Audio File

This action is used as a complement for the *Start playing an audio file* action: it stops the audio transmission in case you need to force stop it earlier than specified in the *Start playing an audio file* action, e.g., if the starting action lets the audio file to be played infinitely.

The following settings are available here:

- **Title:** user-defined action name
- **Target:** target channel (leave *none* for the action to be available for any channel)

Logging

In addition to default [audit log](#), you can choose custom events to be appended to the Ganz CORTROL server audit log or to Windows application log.

Write to Application Log

The *Application log* action type allows you to write a log entry into the Windows Application log, which will be accessible via Windows Event Viewer. The log entry level is *Information* and entry source is Ganz CORTROL

Ganz CORTROL Global Administration Guide

Server. You can define:

- **Title:** a use-defined action name inside the Ganz CORTROL Console; by default it is *Write to Application log*
- **Log Message:** the message text to appear in Windows Application log

The screenshot shows a window titled "Action *". On the left is a sidebar with two tabs: "Action" and "Details". The "Details" tab is selected and highlighted. The main area of the window contains a form with the following elements:

- Action type:** A dropdown menu with "Write to application log" selected. Below it is the text "Select action type from list of available action types".
- Title:** A text box containing "> Write to application log". Below it is the label "Action name".
- Log message:** A large text area containing "Achtung!". Below it is the label "Log message".
- Buttons:** "OK" and "Cancel" buttons at the bottom right.

Action: write to application log

Use the *Insert Field* button on the right-hand side (it appears when you have clicked inside the text area) or right-click the text area and choose *Insert* to add a text macro (see *Action Parameters* further in this topic for details).

Write to Audit Log

The *Audit log* action type is similar to that of *Application log*: it allows you to write a log entry into the Ganz CORTROL own Audit log, which will be accessible via Ganz CORTROL Console, in the *Audit* section. The log entry is added in the Server audio section and its event type will be *User defined*. You can set:

- **Title:** a use-defined action name inside to be used in E&A; by default it is *Write to Audit log*
- **Log Message:** the message text to appear in the Audit log

Use the *Insert Field* button on the right-hand side (it appears when you have clicked inside the text area) or right-click the text area and choose *Insert* to add a text macro (see *Action Parameters* further in this topic for details).

Notifications

Actions in this section allow you to send all kinds of alerts to clients and also email notifications.

Highlight On Map

If your target item appears on one or more maps, you can visually accent it on the map as a result of the triggered event. It is possible to define one particular map or make the device become highlighted on all maps where it has been placed.

Ganz CONTROL Global Administration Guide

The screenshot shows a configuration window titled "Action Hall Panorama - Highlight on map". It features a sidebar on the left with "Action" and "Details" tabs, where "Details" is currently selected. The main panel contains several configuration fields: "Action type" is a dropdown menu showing "Highlight on map or all maps where corresponding Acti..."; "Title" is a text box containing "Hall Panorama - Highlight on map"; "Action name" is a text box; "Target" is a dropdown menu showing "Hall Panorama (104)" with a "Change..." button; "Action target" is a text box; "Highlight on" is a dropdown menu showing "All maps" with a "Change..." button; and "Map or all maps" is a text box. At the bottom right of the window are "OK" and "Cancel" buttons.

Action: highlight target device on a map

The following objects are supported for this action as targets:

- **Channels** (channel markers will be highlighted)
- **User buttons** (user button markers will be highlighted)

Pop Up Object On Screen

You can set up individual channels, maps and layouts to appear on a specific **video wall** display as a result of some triggered event, e.g. motion detected in certain regions. If you wish an object to pop up in all connected Ganz CONTROL Client applications without using video walls, use the built-in (default) event of the *Pop up on screen* type.

Automatic Pop-up actions (extended)

- **Built-in per-channel Pop-up / Pop-up playback** is created automatically for every channel
- **Built-in per-server Pop-up / Pop-up playback** – identical actions are added automatically for every server in Ganz CONTROL Console.
These appear in the Actions list as “*parametric*” items with one extra field — *Channel*. You can:
 - select any channel manually, or
 - leave the field empty → at run-time it is auto-filled with the event’s source channel (if the event has one).
- **User-defined Pop-up actions with empty source** – when you create a custom Pop-up (for *Videowalls*, *Map highlights*, etc.) you can now set *Source* = *None*.
 - The action is then replicated to all channels, maps and layouts, plus a parametric copy under each server (same *Channel* field as above).
 - In a rule, leaving that *Channel* parameter blank will again default to the event’s channel at execution time.

In practice:

Want a single rule that pops the triggering camera on any operator screen? Pick the built-in per-server Pop-up and leave *Channel* empty.

Need a *Videowall* tile to show whatever camera fired the rule? Create one user-defined *Pop-up with Source* = *None* and attach it.



Additional setup is required from the Ganz CONTROL Client application side:

- shared layouts should be pre-created in order to be used in action creation
- target Ganz CONTROL Client window must be allowed to accept either channels/maps or layouts

Ganz CORTROL Global Administration Guide

- target Ganz CORTROL Client window must be set to be a part of the target video wall

What you need to specify in the action properties is:

- **Title:** user-defined action name, by default it is *[channel] Pop up and object on screen [Video wall name]*
- **Target:** a channel, map or a pre-created shared layout to appear on the screen
- **Video wall:** target video wall for the object to appear on
- **Video wall screen:** a specific display in the video wall layout for your object to appear on
- **Viewport index:** the exact position of the video output cell in the grid (starting from 1, left to right, top to bottom), leave 0 to use the first available viewport

If you do not care, which viewport is used for popup, leave the viewport index parameter equal to 0. This will send the popup object to the first empty viewport; if all viewports are occupied, the object will pop up to the first non-locked one. When all viewports are occupied and locked and the viewport index is set to 0 (=any viewport), the popup will not work on that screen.

If the target viewport is set (is different from 0) but it is occupied and locked on the Ganz CORTROL Client side, the target channel will force pop up anyway, and the viewport state will stay locked.

The screenshot shows a software window titled "Action: Pop-up city map*". It has a sidebar with "Action" and "Details" tabs, with "Details" being the active tab. The main area contains several configuration fields: "Action type" is a dropdown menu set to "Pop-up an object on screen (-s)"; "Title" is a text box containing "Pop-up city map"; "Target" is a button labeled "City center" with a "Change..." button next to it; "Videowall" is a button labeled "Showroom" with a "Change..." button next to it; and "Videowall screen" is a text box containing the number "2". At the bottom right of the window are "OK" and "Cancel" buttons.

An action that will pop up a map on the specified video wall display

You can create new maps, geo maps and layouts right from the object selection dialog in case you have not created them beforehand.

Send Email

In order to send an email notification, you are requested to define the following values in the action settings:

- **Title:** a user-defined action name; by default it is *<mailserver> Send email*, you can insert the device name and target email address - or, alternatively, you can re-define the whole title according to your own naming convention
- **Target:** specify the SMTP server to be used for email sending; if none are selected, the action will be available for selection on any of the existing configured mail servers when creating a rule
- **To:** notification recipient email address
- **Subject:** email notification subject (use the *Insert field* button to add text macros)
- **Body:** email notification body text (use the *Insert field* button to add text macros)

Ganz CONTROL Global Administration Guide



[Configure your SMTP server\(s\)](#) before creating email-related actions.

Action *

Action

Details

Action type
Send mail
Select action type from list of available action types

Title
> Send email
Action name

Target
Gmail SMTP (139) Change...
Mail server. If none is selected, the action will be visible on all mail servers.

To
admin@torchwood.gov
Send to

Subject
Achtung
Subject of the email

Body
Catastrophic failure
Email body

OK Cancel

Action: send email

Send Email with a Snapshot

This action is similar to the *Send Email* action described above, with all the settings being the same plus snapshot adjustments: attach a snapshot from a channel and send it together with the email. The channel is specified when creating a rule with this action.

Additional settings:

- **Attach snapshot:** choose if you want to take a snapshot of main stream or substream of a channel and deliver it together with the message
- **Snapshot title:** user-defined file name, e.g., *Snap.jpg*, or *Snap_{EVENT_TIME}_from_{ACTION_PARAMETER_TITLE}.jpg*
- **Enable subtitles:** enable this setting to activate subtitles and expand additional settings
 - **Text:** subtitle text (plain text and/or macros)
 - **Position:** subtitle alignment (top/bottom, left/right, corners)
 - **Font:** subtitle font (choose from the system dialog)
 - **Colors:** background (transparent by default), foreground (text itself), shadow (text shadow)

The subtitles will be hard merged with the exported image.

Ganz CONTROL Global Administration Guide

Action Send mail with a snapshot*

Details

Snapshot title

Taken_from_{ACTION_TARGET_TITLE}_at_{EVENT_TIME}

Snapshot file name.

☒ Enable subtitles

Add custom subtitles to the snapshot.

Text Insert field

{ACTION_TARGET_TITLE} {EVENT_TIMESTAMP}

Text template for subtitles.

Position

Bottom

Relative position of the subtitles.

Font

Arial, 12

Text font to be used.

Background color

0, 0, 0, 0

Background color.

Foreground color

ControlLightLight

Foreground color.

Shadow color

ActiveCaptionText

Shadow color.

OK Cancel

Subtitle settings



In the *Send Email with a Snapshot* action, you only need to define whether this specific action will take a snapshot from the main or from the secondary stream. Actual channel for the snapshot to be taken from will be defined when you create a rule involving this action:

- if the source event originates from some channel, that channel will be automatically used as a snapshot source; you will be able to change the target channel using the *Snapshot source* button below the rule map in the E&A Configurator
- if the source event does not come from a channel (e.g., user button click event), you will have an option to define the target channel using the *Snapshot source* button below the rule map in the E&A Configurator

If you specify no snapshot source when creating the rule, a regular email will be sent. You will find more details on attaching the snapshot in the [Rules](#) section of this document.

Send MQTT Notification

This action uses a pre-configured MQTT Client to publish MQTT messages. You must have at least one [MQTT Client](#) in your server configuration, and a running MQTT broker to accept and broadcast the message. Message/connection settings are typical MQTT message properties; make sure your broker supports the settings you enter here.

Available settings:

- **Title:** action name that will appear in the E&A Configurator
- **Target:** pre-configured MQTT client; leave empty for the action to be available for all existing MQTT clients
- **Topic:** MQTT topic to be published
- **Text:** MQTT message text to be published

Ganz CONTROL Global Administration Guide

- **QoS:** required level of the MQTT quality of service

You can use macros in all text fields to pass parameters like {EVENT_TIMESTAMP} or {EVENT_TITLE}. To insert those, right-click the text field or use the *Insert text field* button.

Send SMS

Using this action you can send short messages to the pre-defined numbers. [GMS modems](#) must be present in the server configuration for this action to work.

You have to fill in the following:

- **Title:** user-defined action name
- **Source:** existing modem hardware to send the message
- **Phone:** the recipient's phone number in **international format** (cannot be left empty)
- **Text:** SMS text to be sent, right-click to insert text macros like {EVENT_SOURCE_TITLE}

Keep in mind the maximum possible SMS length when composing the message. Longer messages will be split into multiple SMS.

Send Event to Client

This action allows to send a push notification to all or specific client applications. This may be just a pop-up message, or an event in the channel notification area with a sound, or all of these combined.

Available settings:

- **Title:** user-defined (custom) action name that will appear in the E&A Configurator
- **Message:** notification body text (use the *Insert field* button to add text macros)
- **Display event in alerts:** mark this if you want a message to be appended to the Ganz CONTROL Client log in the *Alerts* section
- **Display a warning message box:** mark this if you want a **dialog box to pop up** on the Ganz CONTROL Client side (to be closed by the user)
- **Display event in notification panel:** the message will be shown in the **notification panel** of the live view of a specific channel (you will have to set the channel when creating the rule)
- **Display event in mobile application:** the message will be sent as a push notification to all **Ganz CONTROL Mobile clients** that have the target server configured
- **Play audio notification:** play a sound on the Ganz CONTROL Client side; sounds themselves are defined in each Ganz CONTROL Client application
 - **Audio notification:** sound notification number, from 1 to 10 (here, you just specify the number, actual sound is defined per client and may not coincide in different application instances)
- **Send event to specific user or user group:** show the notification only to a specific user or user group

Recording Related Actions

Several actions are related to recording: these can change main and secondary stream recording profiles, as well as append new items into the archive, such as bookmarks.

Activate Recording Profile

Any of the existing recording profiles can be activated for the channel of your choice as a result of a triggered event. You can separately activate **main** stream and **substream** recording: use the *Activate Recording Profile* action for main stream and the *Activate Substream Recording Profile* action for secondary stream. Enter action details as follows:

- **Title:** the user-defined action name
- **Target:** the target device for which recording is to be activated
- **Recording profile:** the pre-configured recording profile to be activated as an action; you will find profile configuration tips further in this section of the manual

The recording profiles are changed within the channel's recording configuration. Thus, for example, if the channel's recording configuration has a 3-second pre-recording duration, it will stay 3s for any recording profile you activate

Ganz CORTROL Global Administration Guide

via E&A.



The recording profile is activated permanently; to switch to a different recording profile, use another action of the same type and different target profile.

Example of emergency recording scenario: create a user button and bind 2 actions to it, one action activating continuous recording, and the other one activating no recording (will activate the recording default profile). Then, add a delay timer to the second action with a required duration, e.g., 1 minute. You will be able to trigger the emergency recording manually from both Ganz CORTROL Client and Ganz CORTROL Mobile applications.

The screenshot shows a software window titled "Action *". It has a sidebar on the left with two tabs: "Action" and "Details". The "Details" tab is selected. The main area is titled "Details" and contains the following fields:

- Action type:** A dropdown menu showing "Activate recording profile". Below it is the text "Select action type from list of available action types".
- Title:** A text box containing "> Activate recording profile > none".
- Action name:** A text box that is currently empty.
- Target:** A field showing "Axis 215 PTZ on 192.168.3.4 (120)" with a "Change..." button to its right.
- Recording profile:** A field showing "Motion Based (145)" with a "Change..." button to its right.

At the bottom right of the window are "OK" and "Cancel" buttons.

Action: activate recording profile

Recording profile activation **cannot call off** the default recording configuration (the one currently assigned to the target channel); rather, **this action can only add more** recordings. Thus, channel default recording configuration must define the minimum required recording scheme (based on a single profile or on a schedule) and E&A scenarios will add to that.

Example: a channel is set to record based on motion. There are two user buttons: one of them sets the channel to *Constant recording*, and the other sets the *No recording* profile. Triggering the first button will activate constant recording, and triggering the second button will return channel recording to its default state (which is *Recording by motion*) instead of disabling the recording at all.

Recording Triggering Examples

When channel recording profile includes **alert-based** recording, recording can be activated as a result of a *Generate Alert* type action and its engagement time is determined by the profile's *post-recording time* parameter. In this case, actual recording profile is not changed and the current recording profile is used (the one assigned to the channel through its recording configuration). The default (built-in) recording profiles have post-recording intervals of 10 seconds, which may be fine when conducting, e.g., motion-based recording (video is recorded for 10s after motion event), but may not be suitable for other types of events. In such case, you can pre-configure any number of different recording profiles and use them for action setup.

If a recording profile is triggered by an *Activate Recording Profile* type action, the recording profile used for the target channel is complemented with the profile triggered from E&A, and recording duration can be controlled using action delay timers.

Scenario 1. The camera's recording configuration is normally motion-based. The action is intended to be used for recording based on digital input events, which are triggered when someone opens main entrance door; starting from

Ganz CORTROL Global Administration Guide

that point, the video and audio streams will be recorded continuously for one minute.

- channel base recording configuration: motion-based video recording
- actions triggering recording profiles:
 - action #1 triggers a recording profile with continuous video + audio (e.g., built-in Continuous Recording profile)
 - action #2 triggers the built-in *No Recording* profile: as a result, channel recording is returned to its default (configured) state
 - action #2 is delayed for one minute using a [Delay Timer](#)

Scenario 2. The camera normally records continuous video with low FPS during the daytime, and does not record anything at night and during weekends. If camera VCA detects fire or smoke in the area, continuous recording at full frame rate will be conducted for 30 minutes.

- channel base recording configuration: based on schedule, continuous recording at restricted FPS + no recording
- action triggering recording profiles:
 - action #1 triggers continuous video recording without frame rate limitation
 - action #2 triggers the built-in *No Recording* profile: as a result, channel recording is returned to its default (configured) state
 - action #2 is delayed for thirty minutes using a [Delay Timer](#)

Recording profile Alarm Triggered Continuous Recording

Recording profile

Details

☐ Audio stream
Alert audio stream recording

Post-recording interval
3600
Length of time to continue recording after alert, in seconds (default is 10)

☐ Detected motion triggers alert
Alert is triggered by motion detector

OK Cancel

Set desired post-recording interval in the target profile

Create Bookmark

Bookmarks can be created by the server, based on any available event. This can be done either completely automatically or complemented with user input - from the users who are connected via Ganz CORTROL Client application.

Ganz CORTROL Global Administration Guide

➔ Action Create new bookmark

Action

Details

Action type

Create bookmark

Select action type from list of available action types

Title

Create new bookmark

Action name

Target

My Server

Change...

Server. If none is selected, the action will be visible on all servers.

Bookmark title

Achtung

Bookmark title

Description

Auxiliary power to the Holodeck matrices

Bookmark description

☒ Request user description

Request user description

Request timeout

300

User request timeout (seconds)

Request specific user or user group

admin

Change...

Request only specific user or user group. None - send to all.

OK Cancel

Action: add a bookmark with user confirmed description

Available settings:

- **Title:** custom (user-defined) action name
- **Target:** server to add the bookmark on (select *none* to make the action visible on all servers in the system)
- **Bookmark title:** name that will appear in the archive and also displayed to users, if user description is requested (use the *Insert field* button to add text macros)
- **Description:** extra information to be stored with the bookmark (use the *Insert field* button to add text macros)
- **Severity:** bookmark severity level (info = lowest, critical = highest); you can change the severity level colors via [server settings](#), *Bookmark policy* tab
- **Request user description:** enable this if you want to obtain bookmark description from Ganz CORTROL Client users - this comes useful when you require feedback from users and/or when the description may differ from time to time
 - **Request timeout:** defines for how long the description request will be displayed on the Ganz CORTROL Client side
 - **Request specific user or user group:** display confirmation dialog box only to the target user or user group; if not defined, the request will be sent to all connected users

Note that the target channel is not specified at this step: you will have an option to specify it using the *Target*

Ganz CORTROL Global Administration Guide

Channel button when you create a rule with this particular *Add Bookmark* action. If the source event of such a rule is channel-specific (e.g., *Video Lost*, *Motion*), the channel will be set automatically. Please see the [Add Rules](#) section for examples.

Scenario 1: fully automated

In the *Add Bookmark* action settings, do not enable the *Request user description* option. Instead, specify desired bookmark title and description. Now, when you use this action in a rule, a bookmark will be added automatically with the pre-defined description.

Scenario 2: bookmark with user confirmation

Enable the *Request user description* option and specify the bookmark title: make sure to make the title comprehensible as it will be displayed to the Ganz CORTROL Client user when prompting for the comment. Optionally, you can specify the description - it will be used when no user input is specified (users ignored or missed the description dialog box).

After you have added the action, you can go ahead and use it in the E&A Configurator: there, upon adding a rule, you will have an option to specify the **target channel** for the bookmark to be added to.

Other Actions

Actions having no special category are listed here.

External Service

For external services that have their own events (e.g., third party integrations via HTTP API), it is possible to trigger these as actions from Ganz CORTROL servers. You need to specify:

- **Title:** user-defined action title
- **External service:** external service (connected to the Ganz CORTROL system via HTTP API) to accept the data
- **Target action:** choose one from the list of available items (availability is ensured on the external service side)

This type of action is handy when you have your own service integrated via Ganz CORTROL HTTP API.

OPC Client Action

This action type uses an existing [OPC client configuration](#) to send write commands to an OPC server, thus changing values of its nodes.

Ganz CORTROL Global Administration Guide

Action OPC #1 Disable ACL File Monitoring*

Details

Event type
OPC Client action
Select event type from list of available event types

Title
OPC #1 Disable ACL File Monitoring
Event name

Target
OPC #1
Change...
Target OPC client

Action

Variable
#MonitorACLFile
Change...
Variable name

Value type
Bool
Value type

Value
0
Value

OK Cancel

Action example: change OPC node value to false

You need to define:

- **Title:** user-defined action name
- **Target:** [OPC client configuration](#) (connection to an OPC server)
- **Action:** operation to be performed with the data node value
 - **Variable:** target OPC server data node (choose one from the list), must be of compatible type and have a write permission
 - **Value type:** one of the standard data types, auto detected
 - **Value:** new value to be assigned to the variable, must match the variable value type

Run Program

The *Run program* option gives you the opportunity to define an executable file (script, batch or a GUI application) that will be launched as a reaction to defined events.

The following parameters should be specified:

- **Title:** a user-defined action name
- **Target:** target Ganz CORTROL server to execute program on
- **File Path:** full path to the executable file
- **Parameters:** input parameters, if the program launched accepts any (e.g., a batch file) (use the *Insert field* button to add text macros)
- **Run Mode:** execution mode - hidden (silent, invisible to server user), minimized (minimized to taskbar) or normal (program will run in its default state)

Ganz CORTROL Global Administration Guide

Action *

Action

Details

Details

Action type

Run program

Select action type from list of available action types

Title

Run program > open gate script

Action name

Target

Global Server (101)

Change...

Target server. If none is selected, the action will be visible to all servers.

File path

C:\opengate.bat

Executable file path

Parameters

Parameters passed to the executable

Run mode

Hidden

Run mode

OK

Cancel

Action: run third-party program

Use the *Insert Field* button on the right-hand side (it appears when you have clicked inside the text area) or right-click the text area and choose *Insert* to add a text macro (see *Action Parameters* further in this topic for details) into the *Parameters* field.

Send HTTP Request

As a result of a triggered event, HTTP/CGI requests can be sent from Ganz CORTROL servers to any third-party servers or devices that can accept such commands. The target devices can be third-party software, Web servers, cameras or different security systems hardware. This event is similar to the previous one, with the difference that here there is a single HTTP request, while using the *Run Program* action you can program multiple requests with necessary delays and internal logic.

This action supports both HTTP and HTTPS. For secure HTTP, use port 443 as default, or whichever port is configured on the remote service.

Ganz CONTROL Global Administration Guide

Action on Axis*

Action

Details

Details

Action type

Send HTTP request

Select action type from list of available action types

Title

Action name

Target

Server

Change...

Target server. If none is selected, the action will be visible to all servers.

Host

192.168.3.4

Host name or IP address

Port

80

Port number

Username

root

Username

☒ Set password

Password to log into the server

Request

/axis-cgi/ia/output.cgi?action=1%3A%2F

Insert field

Request text

OK Cancel

Send a HTTP request to open the digital output circuit on a camera

Things to be defined:

- **Title:** user-defined action name, by default it is *Send HTTP request [target host]*
- **Target server:** a server for the action to be available on; if no server is defined, the action will be available on all servers
- **Host:** an IP or hostname that will be accepting the HTTP request (in case of HTTPS - add **https://** before your IP address)
- **Port:** port number to accept the request, port 80 is default
- **Username:** a username to log into the target host, if necessary
- **Password:** a password to log into the target host, if necessary; to change the password when editing the action, put a check mark on the *Set password* and define a password below
- **Request:** HTTP command string

The resulting request link will be formed as a combination of the host and request fields with the specified port, plus username and password, if specified.

Use default port 80 for HTTP and 443 for HTTPS.

Ganz CORTROL Global Administration Guide

Use the *Insert Field* button on the right-hand side (it appears when you have clicked inside the text area) or right-click the text area and choose *Insert* to add a text macro (see *Action Parameters* further in this topic for details) to be passed as a parameter in the HTTP request.

Ganz CONTROL Global Administration Guide

SNMP Trap

This event allows Ganz CONTROL server to act as an SNMP **agent** and generate and send trap messages to a **third-party SNMP manager**.

The screenshot shows a configuration window titled "Action RS SNMP trap 192.168.15.4:162*". The window has a "Details" tab selected. The configuration fields are as follows:

- Action type:** A dropdown menu showing "SNMP trap". Below it, a note says "Select action type from list of available action types".
- Title:** A text field containing "RS SNMP trap 192.168.15.4:162".
- Action name:** An empty text field.
- Target:** A button with a server icon and the text "RS (162)". To its right is a "Change..." button. Below it, a note says "Target server. If none is selected, the action will be visible to all servers."
- Host:** A text field containing "192.168.15.4". Below it, a note says "Host name or IP address".
- Port:** A text field containing "162". Below it, a note says "Port number".

At the bottom right of the window are "OK" and "Cancel" buttons.

SNMP trap type action

You need to define:

- **Title:** user-defined action name, by default it is *[server] SNMP trap [host] [port]*
- **Target:** Ganz CONTROL server for the action to exist on; if none selected, the action will be visible on all servers
- **Host:** target SNMP manager address
- **Port:** target port
- **Community:** SNMP community expected by the SNMP manager
- **Trap ID:** automatically generated ID
- **Message:** text message to be sent

Use the *Insert Field* button on the right-hand side (it appears when you have clicked inside the text area) or right-click the text area and choose *Insert* to add a text macro (see *Action Parameters* further in this topic for details) to be passed as a parameter.

Action Parameters (Macros)

Actions that handle text information (log messages, send emails and run third-party program) can accept macro commands. Currently, the available parameters are:

- {EVENT_ID} - internal identifier of the triggered event
- {EVENT_TITLE} - user-defined name of the triggered event
- {EVENT_SOURCE_ID} - internal identifier of the event source
- {EVENT_SOURCE_TITLE} - user-defined name of the event source
- {EVENT_UTCIME} - event UTC time
- {EVENT_UTCATE} - event UTC date
- {EVENT_TIME} - event local time
- {EVENT_DATE} - event local date
- {EVENT_TIMESTAMP} - event UTC timestamp in a system-independent format YYYY-MM-DD hh:mm:ss.ms

Ganz CORTROL Global Administration Guide

- {EVENT_TIMESTAMP_UNIX_MS} - event timestamp as Unix Epoch time
- {ADDITION_INFORMATION} - extra information for *Disk Excluding*, *Fallback activating* and *Recording Error* events
- {ACTION_ID} - internal identifier of the action
- {ACTION_TITLE} - user-defined name of the action
- {ACTION_TARGET_ID} - internal identifier of the action target (usually, a server)
- {ACTION_TARGET_TITLE} - user-defined name of the action target (usually, a server)
- {ACTION_PARAMETER_ID} - internal identifier of the additional action parameter (e.g., target channel defined in the rule)
- {ACTION_PARAMETER_TITLE} - user-defined name of the additional action parameter (e.g., target channel defined in the rule)
- {VALUE} - number plate value from the *Tag Matched* event
- {CHANNEL_RECORDING_ID} - channel recording identifier, as displayed in the channel details when IDs are enabled in the Ganz CORTROL Console app settings; channel ID is used

Example of a text string containing a macro: "{EVENT_TITLE} event occurred on {EVENT_UPDATE} at {EVENT_UTIME}".

Event sources are listed for every rule in the *Rules* section of *Events & Actions*; typically, these are servers, devices and other resources capable of generating events (e.g., user buttons). **Action parameter** is a supplementary item added to the rule, e.g., *target channel* for the text notification, *source snapshot* for the attaching snapshots to emails or exporting them.

The {ADDITION_INFORMATION} macro has support for parameters. These depend on the originating event. For example, for **LPR events**, try the following ones:

- {ADDITION_INFORMATION:Plate} for the license plate number;
- similarly, use Speed for the estimated vehicle speed
- and Confidence to get the recognition accuracy,
- Info1/Info2 fields are available for the CBC AMERICA LLC LPR external service.

For the **face recognition** events, additional parameters may be equal to Subject and Tag, as well as SubjectSimilarity (if a person was found in the DB)

When you have finished, click *OK* to save and close the dialog box. The newly created action will appear in the item list under *Actions* and will be available for configuration.

11.7 ONVIF Generic Events

Custom ONVIF Events


Introduction

You can create custom rules based on ONVIF camera-generated events inside Ganz CORTROL Console *Events & Actions*. To do so, you need:

1. ONVIF compatible camera connected via ONVIF driver to the Ganz CORTROL,
2. Understanding of the camera events,
3. Basic knowledge of the ONVIF standard XML responses generated by your cameras.

Although ONVIF is a set of rules that standardizes video monitoring hardware and software - the range of available options is extensive, and different cameras may have very different capabilities. In the context of this manual, we will focus on integrating this wide range of varying camera capabilities into the Ganz CORTROL and fully utilize your camera potential.

The scheme below represents the cameras sending Event data to the Ganz CORTROL.



Multi-channel camera sending XML data via HTTP and RTSP protocols. At the server, data is received from each camera head to the dedicated channel.

This event data is sent via RTSP and HTTP in XML format and adheres to the ONVIF-defined standard. Both streams may represent the same or different events, and you must invest your attention to get out the most from your setup.

User Defined Events

To begin with the ONVIF-based custom event creation, you must add a camera via the Generic ONVIF driver. You can find how to add your devices in a [corresponding part of this manual](#).


1. After adding a device, find the *Channels* inside *Ganz CORTROL Console* -> *Configuration* sub-section.
2. Find the corresponding channel and open it in a pop-up window by double-clicking on its name or selecting it and pressing the *Edit* button on the top of the channel list subsection.

Ganz CONTROL Global Administration Guide

3. Find the *User defined events* in the pop-up window at the bottom of the right subsection.

You will see the empty subsection with three buttons on the top. +*New* drop-down button, grayed-out *Edit* button, and *Notification messages* button. You can create a New generic event by clicking the +*New* or *Notification Messages* buttons. Both options will bring the new *Messages* pop-up window with the list of received notification messages in XML format. Received data represented in a table-like form with columns:

- **Time** - Received notification server timestamp (MM/DD/YYYY HH:MM:SS)
- **Source:**
 - Notification service** - data stream received via HTTP
 - MetaStream** - data stream received via RTSP
- **Message** - Received data in XML format. The Message column is updated in real-time as the data is received.
- **Matches** - if you have already created a generic event filter, you will see an indication for the events with exact matches for that existing filter.



The Messages pop-up window. All the columns marked with the red ellipses.

Locate the event you want to use as the prototype for the filter, click on it, and then click on the +*New* button on the bottom-left part of the pop-up window. You may find the same event inside both - *Notification service* and *MetaStream* data. For such cases, our recommendation is to use *MetaStream*. This stream is sent together with the video stream, so it is easier to notice any instability the third-party factors may cause.

N.B. You can find your camera capabilities in the manufacturer's manual or the Conformance Products - [ONVIF webpage](#).

This will bring the Generic event pop-up window.

You will see the following fields inside the Details tab:

- **Type** - Event type (in this case - *GenericEvent*), non-editable.
- **Message source** - *Notification service/MetaStream*, non-editable
- **Title** - the only field that the user should fill in. The display name of the created event. Editable.
- **Id** - Event identifier. The field will be completed automatically after the event is saved. You can identify the event inside log files by this ID.
- **Enable** checkbox - enable event processing. Uncheck it to stop processing the event.

The only field you should fill inside the *Details* subsection is the *Title* field - add a meaningful name that will allow you to recognize this event inside the *Events & Actions Configurator*.

Ganz CONTROL Global Administration Guide

The screenshot shows a software window titled "Generic event HikiEntrance_tooBlurry". On the left is a sidebar with "Item" and "Mapping" sections. The "Details" section is active, showing a form with the following fields: "Type" (GenericEvent), "Event type", "Message source" (MetaStream), "Message source", "Title" (HikiEntrance_tooBlurry), "Variable name", "Enable" (checked), "Id" (1c640c6c-e45f-4521-808c-51712ba08226), and "Event identifier". The "Title" field is circled in red. At the bottom right are "OK" and "Cancel" buttons.


Generic event Details subsection. The only Editable field is marked with the red ellipse.

VCA event mapping

The next step is to map data. Inside the Item subsection, locate the *Mapping*; this will bring the *Mapping* options. You will see three subsections:

- **Notifications message** - the most-right subsection of the *Mapping* section. Provide a detailed view of the selected message.
- **Items** - represents the mapped portions of the *Notification message*. You may create multiple items - only exact matches will be processed (similar to the && conditional operation).
- **Condition** - the left subsection of the *Mapping* section. This subsection allows adjustments to the *Items* created in the *Items* subsection. You will find the following interface elements:
 - **Name** field - You can edit this to make the Items subsection more readable. Provide a meaningful name for the *Condition* Item.
 - **Select node** button - which will bring a pop-up screen with the notification message. Use it if you want to change the part of the message your item is based on.
 - **Evaluate** button - Evaluate if the created *Item* matches the current condition. Use it if you manually adjusted *XPath* or *Text* fields to avoid errors. Values: "true" - if the Item condition matches the Notification message; "false" - if *XPath* value or *Text* does not have an exact match.
 - **XPath** input field - represents the path to the *Item* conditional value in the context of the *Notification message* tree; may contain variables.
 - **Text** input field - represents the value that must match to meet the event's trigger condition.
 - **Regular Expression** checkbox - mark it if REGEX is used for conditioning.
 - **Case sensitive** checkbox - by default, condition matching is registry case-independent. Mark this checkbox only if you need registry case-dependent conditioning.
 - **Save/Apply changes** button - Save changes before switching to the next *Item* or confirming event with the **OK** button at the bottom-right corner of the *Mappings* subsection.
 - **Cancel button** - Cancel current changes made to the selected Item.

Ganz CORTROL Global Administration Guide




Mappings example. Full path to the Mappings subsection is marked with the red ellipses.

Blurry mainstream Custom VCA Event scenario

At first glance, Generic events may seem complicated, but they provide an unprecedented level of elasticity if needed or allow the creation of simple event triggers from otherwise incompatible devices. The example below will create a generic event based on the ONVIF camera's mainstream blurriness.

1. Ensure the camera is connected via the ONVIF driver and the Camera analytics is up and running.
2. Go to *Configuration -> Channels -> 'Your Channel'* and double-click on it.
3. At the bottom of the right section, find *User defined events*, select it, then on the top of the right subsection, click the *+New* button -> *New generic event*.
4. Locate relevant event. In the example case, this will be an event sent via Metastream containing information on the image quality. Click on the *+New* button at the *Messages* window's bottom-left side.
5. In the provided example the event is named "HikiEntrance_tooBlurry." Click on the *Mapping*. You will see already created *Item* based on the event topic.
6. For Example, the camera has both mainstream and substream, and the mainstream is found under the *Message/Source/VideoSource_1*. To evaluate only mainstream, you need to create one more *Item*.
7. At the *Notification Message* subsection, locate *Message/Source* and click on the node; then, in the *Items* subsection (the one in the middle), click the *+New condition* button. You can change the *Item* name to something more meaningful, like in the provided example, "MainStream," and confirm the adjustment with the *Create* button..
8. Now, the system knows "where to look." All that's left is to tell the system what it must look for. Create one more *Item* from the *Message/Data* node. In the provided example, you need to evaluate if the image is blurry, so you are looking for the value - "true." Select the *Data* node, Click the *+New condition* button, rename the *Item* as "TooBlurry," and confirm it with the *Create* button.
9. Confirm Generic Event with the *OK* button, then confirm it again with the *Apply* button under the *User defined events* subsection.

Ganz CORTROL Global Administration Guide




Notification message example. Red ellipses mark the "nodes"; Values used in the example above are marked with the transparent red marker.

From now on, you are ready to build *Actions* based on the blurriness of the camera mainstream. To do so:

1. Go to the *Ganz CORTROL Console* -> *Events & Actions* -> *Events*
2. At the top-left part of the *Events* subsection, find the *+New event* button and click it.
3. Find the *VCA event* (Stands for Video Camera Analytics) from the pop-up window and confirm with the *OK* button.
4. Add the *Event Title*, which will be displayed inside the configurator. Name it "blurry entrance cam."
5. Click the *Change* button on the right side from the *Source* field and select the camera you used to create that generic event.
6. To bring a custom event to its full potential, you must add the *VCA rule*. Click the *Change* button and find your generic event name in the pop-up window. It will likely be at the bottom of the list. Confirm your selection with the *OK* button, then click the *Apply* and the *OK* buttons to save your event.
7. Go to the *Rules* subsection and open the configurator. The goal is to log this event to the server, generate an alert, and pop up the channel inside the *Ganz CORTROL Client*.

Ganz CORTROL Global Administration Guide



Example of the actionable Rule based on Generic VCA event form the described example.


That's it. All the Actions are now available for your event. This way, very complicated scenarios might be created, starting with basic notifications for the simple analytics event and up to very specific conditioning for the VCA value for the particular case.

Import/export custom events

Once the event is mapped, it is possible to export it. To do so, go to:

1. *Configuration -> Channels -> Your channel -> User defined events*
2. Select your *Event* and click the *Export* button at the top of the window.

Ganz CONTROL Global Administration Guide



3. Confirm your selection with the Ok button and save the json file on your disk.

To import event, go to:

1. *Configuration -> Channels -> Your channel -> User defined events*
2. Select your *Event* and click the *Import* button at the top of the window.
3. find saved json file and confirm it with the *Ok* button.



Although it is possible to import any custom event to any ONVIF compatible camera, it will be working only with the cameras that sends exactly the same notification messages.


11.8 Delay Timers

Delay Timers are optional control mechanisms used to define how and when specific actions are executed after an event is triggered. Unlike conditions and schedules, delay timers are not pre-configured globally; instead, they are defined per rule using the **Event & Action Configurator**.

Setting the Timer

To apply a timer to one or more actions:

1. Open the *Rules* section.
2. Select the desired rule(s).
3. In the *Event & Action Configurator*, select one or more events (use Ctrl+click or Shift+click to select multiple).
4. Click the *Timer* button in the bottom panel to open the *Set Timer* dialog box.



Action delay time

Specify how long the system should wait before executing the action after an event is triggered.

- Set the delay using the keyboard or scroll over the time fields (hours, minutes, seconds).
- This delay applies individually per action.
- Maximum delay interval is 24 hours.

⚠ N.B. Server restart will reset the Action delay timer!!!

A screenshot of the 'Set timer' dialog box. It has a title bar with a green icon and the text 'Set timer'. Below the title bar is a section titled 'Timer settings'. Under this section is a label 'Action delay time' followed by a time input field showing '00:00:01'. Below the input field is a small text label 'Time delay before executing the action'.

Delay Mode

Choose how the system responds to multiple identical events while a delay is active:

- **Run after each event:** Every new event schedules its own delayed action, even if one is already in progress.
- **Restart delay on new event:** If an action is already delayed, the timer is reset. Only one action will be executed once the delay expires without new matching events.

Delay mode

Choose how to handle repeated triggers during the delay period:


- ☐ Run after each event
Run a delayed action for every event separately.
- ☒ Restart delay on new event
Reset the timer if triggered again during the delay. Only one action runs.

Ganz CONTROL Global Administration Guide

Action cooldown interval

Defines the **minimum interval** between consecutive executions of the same action.

- If a new event is triggered within this period, it is ignored.
- This is useful to prevent excessive action execution during high-frequency event bursts.



Behavior Scenarios

Below are common configuration examples that illustrate how timer settings affect action behavior.

☐ Postpone

- **Action delay time:** Set
- **Delay mode:** Run after each event
- **Action cooldown interval:** Not set

Each event triggers its own action after the specified delay.

Best used when every event deserves a delayed response.

Example: Each motion detection sends an alert after 10 seconds, even if many occur.

☐ Extend

- **Action delay time:** Set
- **Delay mode:** Restart delay on new event
- **Action cooldown interval:** Not set

The delay is restarted with each new event. The action is only executed once no new events arrive during the whole delay period.

Ideal for merging bursts of repeated events into a single action.

Example: Repeated recording errors postpone log writing until errors stop.

☐ Cooldown only

- **Action delay time:** Not set
- **Delay mode:** Run after each event
- **Action cooldown interval:** Set

The first matching event triggers the action immediately.

Subsequent events within the cooldown interval are ignored.

Use this to limit the frequency of repeated actions.

Example: One alarm is triggered per minute, even if multiple events occur.

☐ ☐ Postpone + Extend

Ganz CONTROL Global Administration Guide

- **Action delay time:** Set
- **Delay mode:** Restart delay on new event
- **Action cooldown interval:** Optional

The timer is restarted on every new event, and the action will execute only after no matching events occur during the full delay.

Cooldown can add an extra pause before the rule can trigger again.

Best for suppressing noisy event periods and reacting only once things calm down.

Example: Send a single alert 30 seconds after people stop entering a restricted area.

☐ ☐ **Postpone + Cooldown**

- **Action delay time:** Set
- **Delay mode:** Run after each event
- **Action cooldown interval:** Set

Each event triggers a delayed action, but once the action is executed, further actions are blocked for the cooldown interval.

Useful when a delayed response is needed, but you want to prevent repeated execution.

Example: Lock the door 10 seconds after access is denied, but don't retry for 1 minute.

11.9 Understanding Conditions

Conditions are auxiliary controls for event/action rule operation: these are **condition variables**, 'locks' for the defined event/action mappings.

Each condition can only be in one of two states: **OFF** or **ON** (0 or 1, *false* or *true*, to put it in terms of formal logic). When applied to a rule, the condition serves as an additional clause for the action execution: the action will only be performed if attached condition is ON, and is never performed if condition is OFF - regardless of whether the event has been triggered. The condition **state** can be manipulated using the *Set condition* and *Unset condition actions* (these exist by default for each and every created condition), which, in their turn, can be set off by some other events.

The conditions are available in the *Event & Action Configurator*: click the *Conditions* button in the bottom part of the *Rules* section to load the existing condition list or create a new one.

Add Condition

To add, remove and manage the conditions in the Ganz CORTROL Console, go to the *Events & Actions* section and choose *Conditions* from the menu on the left. Conditions can be also added as you go from the [Event & Action Configurator](#).

Click the + *New condition* button on the upper panel to bring up the condition configuration dialog box. Here you have to:

- enter an comprehensible **title** for the condition - usually, the best ones are those which express a state, e.g., camera offline, motion present, door opened etc.
- choose the **target server** - conditions, as non-global events, are local and operate within a single server
- set condition **default state**, i.e., the state it is in before it is set or unset for the first time; this can be either ON or OFF

Condition Gate Opened*

Condition

Details

Title

Gate Opened

EventCondition name

Server

Global Server (101) Change...

Server

Default state

Off

The initial value that EventCondition takes at sever startup

OK Cancel

New Condition dialog box

When you have finished, click *OK* to save and close the dialog box; the newly created condition will appear in the item list and will become available in the *Event & Action Configurator*.

Use the buttons on the upper panel to edit and remove the conditions; the filters on the bottom panel will help you load recently added or recently edited items.

Condition Usage Examples

Consider a system that has three cameras installed: *Camera A* overlooking area A, *Camera B* overlooking area B that is just next to area A, and *Camera C*, which is a supplementary PTZ device and can be turned to view both areas and even more, and overlooks area C by default. If a person walks into area A, he/she will be detected by *Camera A's*

Ganz CONTROL Global Administration Guide

video analytics; if he moves on, he will enter area B and the security guard will see him on *Camera B*.

Now, imagine that *Camera B* suddenly goes offline. The security guard is OK with that, until there is someone in area B; he notices some motion in area A and takes control of *Camera C*, and makes it overlook area B, but the person of interest is long gone by that time, and there is no footage of him being present in area B. So, the task is to automate the process so that *Camera 3* serves as a backup while *Camera B* is offline; the configuration in such a case may look as follows:

- Event 1: *VCA*, source: *Camera A*
- Event 2: *Video Lost*, source: *Camera B*
- Condition: *Camera B Offline*, default state: *OFF*
- Action 1: make *Camera C* go to preset *Area B*
- Action 2: *Set Condition*, target: condition *Camera B Offline*

Rules:

- Event 2 triggers Action 2 (that switches the state of condition *Camera B Offline* to ON)
- Event 1 triggers Action 1 upon the condition *Camera B Offline*

Thus, Action 1 (go to the PTZ preset) is only actually triggered then and then only if *Camera B Offline* condition state is ON, which is not possible while *Camera B* is online.

Now, we need this to work both ways, i.e., we want to return *Camera C* to its home position and reset condition state back to *OFF* when *Camera B* comes online again. New configuration elements will be added:

- Event 3: *Video Restored*, source: *Camera B*
- Action 3: *Unset Condition*, target: condition *Camera B Offline*
- Action 4: make *Camera C* go to preset *Area C*

Rules:

- Event 3 triggers Action 3 (that switches condition state to OFF)
- Event 3 triggers Action 4

These new rules ensure that, once *Camera B* is streaming again, *Camera C* will go back to its original position, thus terminating it as a backup device; and the condition is *OFF*, meaning that the triggering of *VCA* rules in area A will not make *Camera C* move.

The whole setup in *Event & Action Configurator* is as follows:

RULE

Camera A >> VCA: motion in Zone1

Camera C >> Activate PTZ preset > Area B

Camera B Offline

Camera B >> Video lost

Camera B Offline >> Set condition

Camera B >> Video restored

Camera B Offline >> Unset condition

Camera B >> Video restored

Camera C >> Activate PTZ preset > Area C

Sample rules

11.10 Counters, Indicators and Variables

Apart from actions, events and rules, the *Event & Action* section of Ganz CORTROL Console contains additional resources, which can be used for building even more versatile automated scenarios.

Software Counters

Software **counters** are entities that contain a certain integer value, which can be altered based on some occurred event. These can be used in Ganz CORTROL, for example, to count events that do not originate from VCA and therefore cannot be accounted for using VCA counters.

Counters can be created in the [Events & Actions](#) section of Ganz CORTROL Console, under the *Counters* subsection. Each one has a title and a server where it resides (as the *Event & Action* scenarios are defined per server; use global events to transfer events from one server to another - for Ganz CORTROL Global installations).

Reports can be then built based on the software counter values, along with VCA counters: [automatic reports](#) are available for configuration in Ganz CORTROL Console, and manual reports can be created in the Ganz CORTROL Client application. Both modes also permit report export in PDF format.

Add and Remove Counters

To add, remove and manage the software counters in the Ganz CORTROL Console, go to the *Events & Actions* section of Ganz CORTROL Console and choose *Counters* from the menu on the left. Click the + *New counter* button on the upper panel to bring up the counter configuration dialog box. Here you have to:

- The *Title* field: Provide a meaningful name to your counter
- The *Server* field: counters are non-global entities, so select the server you wish the counter being attached
- The *Reset Value* field: You can input here the initial value for the counter after reset
- The *Value Limit* field: You can limit counter value with this field
- The *Enable Auto Reset* checkbox: By marking this checkbox, you enable automatic counter reset when it reaches the value from the *Value Limit* field

The screenshot shows the Ganz CORTROL Console interface. The top navigation bar indicates the current path is 'Events > Actions > Counters'. On the left sidebar, the 'Counters' option is highlighted. The main panel shows the 'Counter OneToHundredCounter*' configuration dialog box. The dialog box has a 'Details' tab selected. The fields are as follows:

- Title:** OneToHundredCounter
- Server:** Global Server (with a 'Change...' button next to it)
- Reset value:** 1
- Value limit:** 100
- Enable auto reset:** ☒

At the bottom of the dialog box, there are buttons for 'Apply', 'OK', and 'Cancel'. The 'New counter' button in the top left of the dialog box is circled in red. The 'Change...' button next to the Server field is also circled in red. The 'Reset value' field contains '1' and the 'Value limit' field contains '100', both circled in red. The 'Enable auto reset' checkbox is checked and circled in red.

Ganz CORTROL Global Administration Guide

Adding counter with auto reset feature

In the *Permissions* tab, you can grant **access** to this counter's **data** to individual users and user groups. Anyone with the rights to access archived VCA metadata for the target counter will have it in the Ganz CORTROL Client application in the *Reports* section. If the *Access archived VCA metadata* permission has been granted for the **whole server**, the target user or user group will have access to **all counters** on that server, regardless of the individual counter permissions.

When you have finished, click *OK* to save and close the dialog box; the newly created counter will appear in the item list and will become available in the *Event & Action Configurator*. You can create any number of software counters.

Use the buttons on the upper panel to edit and remove the counters; the filters on the bottom panel will help you load recently added or recently edited items.

How to Change Counter Values

Counter values can be changed based on any event in the [Event & Action](#) scenarios, when building rules. Counter value changes can be a separate action or an additional one to serve for counting the number of times when the rule was triggered.

There are three **built-in actions** that are available by default for any created counter:

- **Increment:** increase counter value by one
- **Decrement:** decrease counter value by one
- **Reset:** set the counter's value to zero

The initial state of any newly created counter is zero.

Manage Counter Data

Internal Ganz CORTROL counters can be removed at will at any point: select all redundant counters and click the *Recycle bin* button on the upper panel.

However, only software (user-created) counters can be deleted in this way. Counters originating from VCA cannot be deleted in this way, as they exist in the VCA configuration (either camera-side or server-side video analytics). Those entities do not even appear in the list in the *Counters* section. To view them, press the *Manage data* button on the upper panel: an additional dialog box will pop up, displaying **all counters**, both user-defined and VCA imported.

Events & Actions

Rules

Events

Actions

Global events

Conditions

Schedules

Counters

OPC

Indicators

+ New counter

Edit

Manage data

✖ 1 selected

TITLE	SERVER
MotionCounter	My Server

Counters

Counters

Search

Delete data

✖ 1 selected

TITLE	SERVER	CHANNEL	STATUS
MotionCounter	My Server	MotionCounter	
Counter 0	My Server	UDP IPX3302HD on 192.168.3.53	
Counter 1	My Server	UDP IPX3302HD on 192.168.3.53	Deleted
Counter 2	My Server	UDP IPX3302HD on 192.168.3.53	

Hidden menu with data for all counters

Here, you will see **all counters** with **some value**, including those, which have been removed from VCA configuration and are therefore out-of-date. Select the unnecessary items and press *Delete data* above: all information about the target counter will be then removed from the database:

Ganz CORTROL Global Administration Guide

- for software counters, this means that only the past counter values are wiped out; the counter itself stays in the list (you can remove it from the list as described above)
- for VCA counters, the counter itself is deleted from the database, too (but not from the VCA configuration)



Removing the software counter's data reset it to zero.

Removing VCA counter's data will reset only counter state on the server. Camera counter's value will not be reset!

If there are no new incoming data for the removed counter, it will disappear from *Reports* shortly - both in Ganz CORTROL Console and Ganz CORTROL Client. If it still exists and Ganz CORTROL continues receiving data from the target counter, it will re-appear in this list automatically. So, in other words, the *Manage data* dialog box reflects the current state of the counter's database.

Usage Example

Consider a use case where it is required to count how many times during the day the office door was unlocked; the door is opened by an access control module, which is also wired to the digital input of a camera so that the system is notified when the door is unlocked.

Required E&A items in this case are:

- Event 1: *Digital Input*, source: corridor camera
- Event 2: *Scheduled event*, type: scheduled, every day 12:00AM
- Counters: *HowManyTimesDoorWasOpened*
- Action 1: *Increment*, target: counter *HowManyTimesDoorWasOpened*
- Action 2: *Reset*, target: counter *HowManyTimesDoorWasOpened*

Events 1&2 are not default and should be added, and the counter has to be created as well. Actions associated with the counter will be added automatically so there is no need to create these.

Rules

RULE

Reception >> Reception door opened
 DoorOpened >> Increment

Global Server >> Scheduled every midnight
 DoorOpened >> Reset

Rules that control the counter state

The final set of rules for this scenario looks as follows:

- Rule 1: Event 1 triggers Action 1
- Rule 2: Event 2 triggers Action 2

Thus, every time the door is opened, this event is accounted for by the software counter; the counter is reset based on schedule every midnight. Using the counter data, it is possible to build a [report](#) and see, for example, most and least popular times, the average number per week etc.

Indicators

Indicators are objects with several **states**. These states (conditions) can be changed based on any events in the *Event&Action Configurator*. Indicators can be placed on **maps**, thus helping you build an interactive dashboard.

You can create indicators in the *Events & Actions* section of Ganz CORTROL Console, under *Indicators*, then place

Ganz CORTROL Global Administration Guide

them onto maps - either regular or geo maps. The indicator state and color can be then changed based on E&A events: once you create an indicator, it is automatically added to the *Actions* section of the E&A Configurator and actions for changing its state are created.

Indicator states	
Edit indicator state details	Indicator states
Title	TITLE
Not a soul here	▶ Not a soul here (default)
Color	▶ A car or two
0, 0, 0	▶ You'll be home for dinner
	▶ Should have stayed late today..
	▶ Why don't you take a bus?!

Example of an indicator

Create and Manage Indicators

To add, remove and manage the indicators in the Ganz CORTROL Console, go to the *Events & Actions* section of Ganz CORTROL Console and choose *Indicators* from the menu on the left. Click the + *New indicator* button on the upper panel to bring up the counter configuration dialog box.

The following settings are available here:

- **Title:** user-defined name
- **Server:** Ganz CORTROL server, to which the indicator belongs (related actions will be only available in the target server E&A Configurator)
- **States:** 5 different indicator conditions with custom names and colors

When adjusting the state details, do not forget to hit the *Apply* button for the changes to take effect.

Change Indicator State

The indicator state can be changed based on any event in the [Event & Action](#) scenarios, when creating rules. The indicator state can be changed as a separate action, or it can be combined with any other one, thus helping visualize the state of other items.

There are five **built-in actions** for every indicator that allow to set the indicator to any of its states. If you only need two or three, simply do not trigger other conditions. The actions will appear automatically after you create the indicator.

Ganz CORTROL Global Administration Guide

▶ J45 Traffic intensity

Change Indicator State

▶ Why don't you take a bus?!

Change Indicator State

▶ Not a soul here

Change Indicator State

▶ A car or two

Change Indicator State


▶ You'll be home for dinner

Change Indicator State

▶ Should have stayed late today..

Maps

When placed onto maps, indicators change their color and display the comment according to their state. Both regular and geographic maps have an **indicator marker** available on the panel above the map, alongside with other markers. Thus, you can build interactive panels that will reflect the condition of the system.



A map with two indicators on it

Usage examples

Depending on your needs, indicators can help in many different scenarios.

Use case #1: external sensors are sending temperature data. Based on the value, the indicator state is set to very low/low/normal/high/very high.

Use case #2: [conditions](#) are used throughout the system for door status (open/locked). The indicator is used to visualize the condition state (in this case, only 2 out of 5 states are involved).

Variables

Variables in Ganz CORTROL are entities having a certain value that changes over time. Create variables if you wish to set up reactions (via [E&A](#)) to certain variable values, e.g., certain temperature readings from thermal cameras.

To access the variables management in Ganz CORTROL Console, choose the *Events & Actions* section and switch to *Variables* in the menu on the left.

Variables differ by source. Currently, there are two groups of sources: devices (IP cameras or other) and [data sources](#).

Channel Variables

Some device integrations support receiving certain variable values from cameras. For example, some thermal

Ganz CONTROL Global Administration Guide

devices send the temperature measurements as floating point numbers. In order to "catch" the data on the server side, simply create variables for these cases. Afterwards, you will be able to use these variables in events: for example, trigger events if the value is greater or less than certain threshold.

To create a new item, click the **+ New channel variable** button on the upper panel. In the dialog box, choose the source channel and fill in the settings.

- **Title:** user-defined variable name
- **Channel:** source channel (device integration must be supporting variables, please contact cortrol@cbcamerica.com for details)
- **Variable:** choose one from the list of available items (if none are available, the device has none or the integration does not support variables)
- **Variable type:** variable data type

For most variables, the data type is fixed, so you only need to choose the variable source and give it a name.

The screenshot shows the 'Variable AntiCovid*' dialog box with the 'Details' tab selected. The 'Title' field contains 'AntiCovid'. The 'Channel' dropdown is set to 'Thermal on Entrance'. The 'Variable' dropdown is set to 'Temperature'. The 'Variable type' dropdown is set to 'Floating-point'. A 'Select variable' dialog box is open, showing a list of available variables with 'Temperature' selected. The 'Select variable' dialog box has a search bar and a table with columns 'Id' and 'Variable name'. The table contains one row with 'Temperature' in both columns. The 'OK' button is highlighted.

Temperature variable from a thermal camera

Click **OK** when done; the newly created variable will be appended to the list.

After you have added the channel variable, use the *Variable value* [event](#) to define the value range you want to trigger the event-action rules.

Data Source Variables

Data source variables are based on the pre-defined [data source](#) mappings. First, create some regex mappings for your data sources as described in the corresponding section of this document. Then, create a data source variable in the *Variables* subsection by clicking the drop-down arrow on the upper panel and selecting the **+ New data source variable** option.

The following settings are to be defined:

- **Title:** user-defined variable name
- **Data source:** choose one of your existing (pre-configured) data sources
- **Variable:** choose one of the pre-configured mappings
- **Variable type:** choose the data type of the selected variable (for further comparison in events)
- **Data ID:** enter your POS identifier in case the data source delivers data from multiple terminals or other sources

The *Data ID* field is optional and is only required if your data source has combined streams from multiple sources. If there is only one data stream, leave the *Data ID* field empty.

Ganz CONTROL Global Administration Guide

Variable Sum

Variable

Details

Details

Title

Sum

Variable title.

Data source

POS emulation

Data source.

Variable

Sum

Variable.

Variable type

Floating-point

Value type of the variable.

Data ID

Data ID.

Select variable

Available variables

	Id	Variable name
	Sum	Sum

OKCancel

OK

Cancel

A new variable from a data source mapping

Click *OK* when done; the newly created variable will be appended to the list.

After you have added the data source variable, use the *Variable value* [event](#) to define the value range you want to trigger the event-action rules.

11.11 Tags and Subjects

Ganz CORTROL offers a possibility to create **tags and subjects** for LPR and FR black/white lists, respectively. You can use these in combination with the Event&Action rules to roll our desired automated scenarios. Tags and subjects in Ganz CORTROL Console are not exported or imported to/from tags and subjects in LPR/FR services; they can act as a supplement or a replacement of these.

💡 Tags and subjects here are not synchronized or somehow related to those in Ganz CORTROL LPR or FR modules. If you already have tag lists in the LPR module, you can continue using it with E&A events.

💡 At this point, is it only possible to add tags and subjects from Ganz CORTROL Console. The option to add tags from the Ganz CORTROL Client application only refers to external LPR/FR service tags.

The recognition itself may run on an edge device (e.g., ANPR camera) or be provided by an external service. The idea is that the recognition results are received by Ganz CORTROL and then matched with the local tag/subject database.

Subjects are expected license plate or facial recognition results. For ANPR, a subject is a car number plate, and for FR each subject is a person.


Tags are used as marks for the LPR/FR subjects. One or more subjects with the same tag form a **list**, and you can use tags to trigger events and event chains. Each tag can be used for all types of services, which is convenient, for example, to handle access for a group of people and their cars.

Create Tags

To create tags in Ganz CORTROL Console, switch to the *Events&Actions* section. Choose *Tags* on the left, then click the *+New tag* button on the upper panel.

For each tag, you can choose:

- **Title:** user-defined tag name that will appear in rules and in Ganz CORTROL Client
- **Color:** will also appear in Ganz CORTROL Client to mark entries with this tag
- **Flags:** choose if you want to use this tag for FR lists, LPR lists, or both



Tags can be used for LPR or FR, or both services

When finished, click *OK* to save and close the dialog box. The newly created tag will appear in the item list; you can edit any tag by double-clicking it in the list, or by selecting a tag and clicking the *Edit* button on the upper panel. Remove tags by selecting one or more items and then clicking the *Recycle bin* icon on the upper panel.

Create Subjects

Ganz CORTROL Global Administration Guide

Creating subjects is similar. To create subjects in Ganz CORTROL Console, switch to the *Events&Actions* section. Choose *Subjects* on the left, then click the *+New LPR subject* or *+New FR subject* button on the upper panel.


For each subject, the following settings are available:

- **Title:** user-defined tag name that will appear in rules and in Ganz CORTROL Client
- **Color:** will also appear in Ganz CORTROL Client to mark this subject's recognitions (if the subject is tagged, the subject color will be replaced by tag color)
- **Pattern:** exact plate number or a mask (e.g., D* to match all plates starting with D and having any length)
- **Mask:** enable this to enter a mask instead of the exact match in the pattern field above

Patterns for masks: use * for any number of unknown characters, and ? for exactly one unknown character. For example:

- F* will match all license plates of any length starting with F
- F????? will match all license plates starting with F with a total length of 6 characters
- F?* means there's F and then one or more unknown characters

Use query **testing** (see below) to check if an expected recognition value is "caught" by the mask.



Create a new LPR subject using the car plate number

When finished, click *OK* to save and close the dialog box. The newly created subject will appear in the item list; you can edit any subject by double-clicking it in the list, or by selecting a subject and clicking the *Edit* button on the upper panel. Remove subjects by selecting one or more items and then clicking the *Recycle bin* button on the upper panel.

Add Tag Matching Events

A special event type is available for the built-in tags. This event is triggered **when a recognition result has a matching tag** profile: this may mean one of the required tags is present or absent, and other scenarios.

To add the **tag matching event**, switch to the *Events* subsection and click *+ New event* button on the upper panel. Set the event type to *Tag match*. The following settings are available:

- **Title:** user-defined event title that will appear in the *E&A Configurator*
- **Source:** a channel that will serve as a recognition source
- **Tag match mode:** choose what kind of match you want (see more detailed explanation below)
- **Flags:** choose one or more if you want this tag event to be triggered for specific recognition type
- **Tags:** choose a set of tags that will be used for comparison

Recognition may be LPR or FR and it may run on the camera side or as an [external service](#).

Ganz CONTROL Global Administration Guide

Event License plate matches any existing tag*

Event

Details*

Details

Event type

Tag match

Change...

Select event type from list of available event types

Title

License plate matches any existing tag

Event name

Source

ANPR

Change...

Event source

Tag match mode

Any

Tag match mode

Flags

☒ LPR ☒ FR

Tag usage flags

Tags

Engineers Managers Guests VIP

Change...

Tags

OK Cancel

An example of a tag matching event with LPR recognition

Possible tag **match modes**: event will be triggered if..

- **NoTags**: recognition result does not have any tags (the license plate/subject is not present in the database)
- **Any**: recognition result tag matches one or more tags in the list (at least one)
- **All**: recognition result matches all defined tags (possibly more, but at least those listed)
- **NotAny**: doesn't match any of the specified tags

For example: in the snapshot above, the event is triggered when recognition result matches *Engineers*, *Managers*, *Guests*, or *VIP* tag.

Create Rules

As soon as you have created tag-based events, you can match them with any actions to create automated scenarios in the [Event & Action Configurator](#).

[Rule](#) examples:


- open a gate based on staff car entering (action: change DO state, prerequisite: DO wired to the gate)
- notify operators with a sound (action: send event to client, option: play audio notification, prerequisite: audio notifications enabled on the client side)

Test Tags and Subjects

From the *Subjects* section, you can **check if the whole scenario works** for a specific **recognition result**. Simply click the *Test* button on the upper panel, enter the desired parameters, and click *Run*. The test query is not bound to any specific subject entry so it does not matter which item is selected in the item list.

The test validates if the entered recognition value has any matching subjects and, therefore, tags, and also checks if it triggers any events. Events are only checked if there are active rules using these events!


Ganz CORTROL Global Administration Guide



A test that would show which subjects and events would be triggered if the recognition result is equal to EHZ123


As an example, let's see the test results for the test above. The dialog box with the results will have several tabs.

In the *Subjects* tab, all matching **subjects** will be listed. In the example here, E-plate matches the recognition result because this subject is defined as a mask E*, matching any license plate starting with E.



Pattern EHZ123 corresponds to one subject named E-plate

In the *Tags* tab, all matching **tags** will be listed with their corresponding colors.



Pattern EHZ123 matches two tags

Ganz CORTROL Global Administration Guide

Finally, in the *Events* tab, you will see, which **events** would be triggered by the test pattern.

Matches	
Matches	Events
Subjects	Search
Tags	New query
Events	TITLE
	License plate matches any existing tag

Pattern EHZ123 would trigger one active event

Note that the event list will be empty if there exist some relevant events but there are no rules using them!

12 Other Resources and Functionality

Apart from the main video management system resources - video channels - Ganz CORTROL provides miscellaneous types of auxiliary resources and object types like maps and user buttons, and video walls for Ganz CORTROL Global edition.

This chapter contains documentation on additional resource types, their properties, and related tools.

12.1 Webpages and CrossLink Channels

Ganz CORTROL servers can work with several types of **interactive resources** - meaning that the user can not just watch and record the feed, but also control its contents from the Ganz CORTROL Client application. These resources are called CrossLink channels. CrossLinks can provide a direct interactive interface to SCADA, access and flight control, radars and lidars, other VMS software, and other applications. This means a straight-away front-end integration without any additional implementation.

CrossLinks require a special license and are represented by **interactive web applications** and by **interactive desktop applications**. Depending on the setup, these allow capturing, recording, and controlling the remote contents in an intuitive manner.

CrossLink Types

How to choose the required resource type based on your use case scenario:

- webpage device: the interactive device is created on the server side (like for any camera) to allow live & recording
- direct webpage: there is no device on the server side, live Web contents goes directly to Ganz CORTROL Client, allowing multiple independent sessions
- remote desktop: the interactive [device](#) is created on the server side (like for any camera) to allow live & recording
- non-interactive webpage device: static video feed to the server for recording and non-interactive display (does not require CrossLink license, just a regular channel)

Basically, you need to determine whether you want to

1. Have a remote **Web interface** (website, Web server) or a **workstation**.
2. In case it is a Web application, choose if
 - a. The user should only be able to **control** the remote contents, or
 - b. It also needs it to be **recorded** on the server side.

Below, you will find more detailed information about each type and step-by-step configuration guidelines.

Prerequisites

For all interactive contents, you need a special [license channel type](#) called **CrossLink**. The required number of CrossLink channels is added to your license alongside regular channels and VA channels. There are two different types of **CrossLink licenses**:

- **Basic**: interactive Web with or without recording
- **Advanced**: interactive Remote Desktop (server-side device)

Advanced CrossLink license includes Basic CrossLink options as well, meaning you can use an Advanced CL license for creating a Basic CL item (webpage).. For non-interactive Web devices, a regular channel license is used, and there is no need to obtain a CL license of any kind.

Feature	Regular Channel	CrossLink Basic	CrossLink Advanced
Display and record live web pages without user interaction	+	+	+
Display interactive webpages	-	+	+
Record interactive webpages as channels	-	+	+
Display and record interactive desktop applications as channels	-	-	+

For every remote **workstation** you wish to add under CrossLink Advanced, you need to install any **VNC server software** on the remote side and ensure its accessibility via given IP/host and port. (For Mac computers, simply enable it in the settings.)

We strongly recommend using [visual groups](#) for CrossLink Advanced channels, so that the users can differentiate

Ganz CORTROL Global Administration Guide

between video streams and interactive contents.

CrossLink Basic: Interactive Web Device


CrossLink Basic provides access and interaction with **Web applications**. These may be websites, device interfaces, or Web services, and you can stream and record any of these. Special device model, *(CrossLink) Interactive URL*, is reserved for this. Each device of this kind uses 1 (one) CrossLink Basic channel license.


To create an interactive web device in Ganz CORTROL Console, go to the *Configuration* section in the bottom left panel, choose *Devices* on the left, then click the + *New device* button in the upper panel to bring up the item creation dialog box.

In the model list, choose the **(CrossLink) Interactive URL** model. Then, switch to the *Uri* tab and fill in the settings:

- **Address***: full target URL
- **Username**: if required
- **Password**: if required

*Note that **redirects** from the specified domain are not allowed. Therefore, the specified link must not be a shortened URL (e.g., youtu.be/, or goo.gl/).

 No redirects from the specified domain are allowed for security reasons.



Enter the target URL for the Interactive URL device

Click *Apply* to save the settings, then switch to the corresponding channel using the *Related items* button in the bottom left corner or the dialog box.

Basic channel settings are the same as for the traditional channels with the following elaboration:

- recording can be configured for **both main and secondary** streams
- **audio** is not available
- remote control **permission** is granted using the *PTZ Control* permission
- **video parameters** can be set up in the *Video configuration* tab:
 - choose between JPEG (higher quality, bigger size) and VP8 (smaller recording size at the expense of picture quality) **compression**
 - select **resolution** (but be careful when combining VP8 with lo-res and low bitrate, it may make the text unreadable)
 - set bitrate and target frame rate

Use VP8 cautiously as it may decrease image quality dramatically, and render the text unreadable on smaller resolutions. Larger resolutions will increase CPU usage on the server side and may produce sluggish image display. The main advantage of using VP8 is that it uses much less storage space thanks to compression, so the recommended usage profile would be to use one stream with VP8 for recording, and another one with JPEG for live view and interaction. You will be able to switch between streams in the Ganz CORTROL Client application.

Ganz CORTROL Global Administration Guide

💡 When setting VP8 with a specific bitrate, keep in mind that it will be the maximum possible bitrate, not the target bitrate.

Channel Youtube Interactive Device*

Channel

Video configuration

Video analytics

Audio

Inputs

Outputs

Channel configuration

Video overlays

Dewarp

Video configuration*

Related items

Apply OK Cancel

Main stream

Profile

Main profile

Profile name configured on device.

Encoding

VP8

Used video codec, either Jpeg, H.264 or Mpeg4.

Resolution

1920x1080

Configured video resolution.

Substream

Profile

Sub profile

Profile name configured on device.

Encoding

JPEG

Used video codec, either Jpeg, H.264 or Mpeg4.

Resolution

1280x720

Configured video resolution.

Stream settings in the CrossLink channel settings

There is also a **dedicated tab** with CrossLink-specific settings. The following settings are available here:

- **Ignore certificate errors:** if enabled, invalid certificates will be ignored, and the page will be opened even if something is wrong with the site certificate (only do this if you trust the page certificate!)
- **Auto refresh interval:** enable this if the remote Web contents is dynamic and you want the page to be refreshed even without user interaction

As Web contents poses certain threats, we do not recommend ignoring certificate errors unless you trust the page completely. Also, the following **rules** will apply to **browsing**:

- **no redirects** from the specified **domain** (sub-domains are allowed)
- **no pop ups** (including floating windows and new pages opened in a new tab)
- **no downloads** or **copy-paste**

Keep this in mind when configuring your interactive URL device. You will get a corresponding error message in the **channel's notification panel** in Ganz CORTROL Client if some of these restrictions are activated.

Example: the link to *youtu.be* will not work as it is a shortened link and it redirects to another domain, *youtube.com*. Use the full URL in the device configuration.

CrossLink Basic: Interactive Web


If you do not need to record the web contents, but would rather like to **access the Web page directly** from Ganz CORTROL Client, you do not need to add a device: instead, simply create a Webpage in Ganz CORTROL Console, and it will go directly to the Ganz CORTROL Client application. This item requires one CrossLink Basic license.

You can use this type of resource for:

- configuration of IP cameras
- configuration of any Web services
- remote control of any non-integrated, or advanced setup of integrated devices
- providing variety of resources while in kiosk mode (operator instructions etc.)

To create the webpage, go to the *Configuration* section of Ganz CORTROL Console, choose *Crosslinks* on the left, then click the *+ New Crosslink* button on the upper panel.

Ganz CORTROL Global Administration Guide



Enter Crosslink channel name and target URL

Settings:

- **Title:** webpage name that will appear in Ganz CORTROL Client
- **Icon:** Select an icon shown in client
- **Address:** full webpage URL (no shortened links!)
- **Ignore certificate errors:** if enabled, invalid certificates will be ignored, and the page will be opened even if something is wrong with the site certificate
- **Allow file download:** the webpage will accept remote file downloads and save them in the Library if the checkbox is marked.
- **Allow file upload:** If enabled, the Crosslink will allow to upload files to the remote server.
- **Allow prompts:** Allows pop-up dialogues inside the *CrossLink* tab.
- **Allow URL popups:** Allows URL popups inside the *CrossLink* tab.
- **Show in a dedicated tab:** Show in a dedicated tab: if the checkbox is marked - the webpage will disappear from the viewport, and the new item in the Main menu will appear.
- **Hide:** To allow redirects between first level domains you may need to add both websites as a *Crosslink*. Then, you can hide the second *Crosslink* by marking corresponding checkbox.

Click **OK** to save and close the window. The newly created webpage will appear in the list. Your Ganz CORTROL Client application will now have an extra section in the *Resources* panel (on the left) containing webpages.

As Web contents poses certain threats, we do not recommend ignoring certificate errors unless you trust the page completely. Also, the following **rules** will apply to **browsing**:

- **no redirects** from the specified **domain** (sub-domains are allowed)
- **no pop ups** (including floating windows and new pages opened in a new tab)
- **no downloads** or **copy-paste**

Keep this in mind when configuring your webpage. You will get a corresponding error message in the **Alerts** tab in Ganz CORTROL Client if some of these restrictions are activated.

Example 1: you cannot configure the webpage to google.com and let the user search: they will be unable to navigate to a specific result as it involves domain change.


Ganz CORTROL Global Administration Guide

Example 2: you can add a Wiki webpage and let user choose the language, as it will redirect them to the third-level domain (say, en.wikipedia.org or de.wikipedia.org), which is OK.

CrossLink Advanced: Remote Desktop

On top of the previous features, CrossLink Advanced adds the opportunity to remotely control any workstation from Ganz CORTROL Client. The target machine may run Linux or macOS, the one requirement is that the remote party must have VNC server software (any) up and running.

Using one CrossLink Advanced license, you can configure any of the interactive channels - be it a webpage, webpage channel, or a remote workstation channel.

 Be careful when you grant access to this kind of device, as it gives the user **full control** of the remote PC. You may want to use **additional security**, e.g., ask user for a password on behalf of the OS.

Usage examples:

- remote access to Linux workstations with non-integrated software
- access to other VMS software running on an older or embedded version of Windows
- recording of operator workstations running Ganz CORTROL Client or any other software

Each Remote Desktop channel will use one CrossLink Advanced license. If your license only includes Basic CrossLink channels, you will not be able to add a new device of this kind.


Add Device

To create an **remote desktop** controlling device in Ganz CORTROL Console, go to the *Configuration* section in the bottom left panel, choose *Devices* on the left, then click the + *New device* button in the upper panel to bring up the item creation dialog box.

In the model list, choose the **(CrossLink) Remote Desktop** model. Then, switch to the *Network* tab and fill in the settings:

- **Host:** target machine IP or hostname
- **Port:** the port for VNC connection (5900 by default)
- **Secure connection:** enable to use HTTPS (must be enabled in the VNC server settings), or leave empty for insecure connection
- **Password:** enter the password, as defined on the remote side

Use the *Ping device* button below to check the remote workstation availability.





The screenshot shows the 'Configuration' section of the Ganz CORTROL Console. On the left, a sidebar lists various configuration categories: Users, Devices (selected), Channels, Recording, Maps, Layout template, Layouts, Video walls, User buttons, Visual groups, Webpages, Live podcasts, Data sources, and Mail servers. The main panel displays the 'Device XLink Advanced - Office PC*' configuration dialog. At the top, there are buttons for '+ New device', 'Edit', 'Assign group', 'View channels', and a trash icon. Below these, a '1 selected' indicator is shown. The dialog is divided into two tabs: 'Device' and 'Network'. The 'Network' tab is active, showing fields for 'Host' (192.168.1.84), 'Port' (5900), 'Secure connection' (checked), and 'New password' (masked with dots). Below these fields are buttons for 'Open device in browser' and 'Ping device'. At the bottom of the dialog, there are 'Apply', 'OK', and 'Cancel' buttons.

Enter the connection settings matching the remote VNC server configuration

Ganz CORTROL Global Administration Guide

When you have finished, click *OK* to save and exit; the newly created device share will appear in the item list, and its channel also immediately appear in the Ganz CORTROL Client application(s) for eligible users.

 If your created *Remote Desktop* device does not work and you think all settings are correct, install a local VNC client on the Ganz CORTROL server and see if you can reach the remote machine this way.

To edit any of the previously created devices, double-click it in the item list or select any with single mouse click and then hit the *Edit* button on the upper panel. Use the *Search* field in the upper-right-hand corner to quickly find the existing items, and the *Disable* button to **disable and enable** channel sharing. Use the  recycle bin button in the upper-right-hand corner to remove one or multiple items: hold *CTRL* or *Shift* to select several items at once, or *CTRL+A* to select all.


Filters in the bottom panel allow you to load recently added/modified items.

Channel Configuration

Most of the channel settings are the same as for the traditional channels with the following elaboration:

- recording can be configured for **main stream** only, as there is no secondary stream
- **audio** is not available but you can combine the video with audio stream from a camera (use the *External* option in the *Audio* tab and choose the source channel)
- remote control **permission** is granted using *PTZ Control* permission
- **video parameters** can be set up in the *Video configuration* tab:
 - choose between JPEG (higher quality, bigger size) and VP8 (smaller size at the expense of picture quality) compression
 - select resolution (but be careful when combining VP8 with lo-res and low bitrate, it may make the text unreadable)
 - set bitrate and target frame rate

Frame rate will be **dynamic** during remote control and recording, meaning that FPS will be low while nothing happens, but it will grow if the remote user starts doing something or if there is video playback.

 Optimal interactive video configuration for most use cases is JPEG @1080p.

Output Area

CrossLink Configuration is a dedicated tab for CrossLink-specific settings. Currently available settings include **cropping** setup, which allows you to select the region that will be displayed in the Ganz CORTROL Client application. In other words, you can crop the whole incoming image and only show/record a specific area. This comes useful, for example, when the remote workstation has multiple displays. Cropping affects both Ganz CORTROL Client **display and recording**.


Crop rectangle

X	<input type="text" value="0"/>	Y	<input type="text" value="0"/>
Width	<input type="text" value="0.5"/>	Height	<input type="text" value="1"/>


Crop rectangle in relative coordinates.

By default, the output area is full - X=0, Y=0, Width=Height=1. The coordinates and size are relative. Crop examples:

- Full image: X=0, Y=0, Width=1, Height=1
- Display 1 of 2: X=0, Y=0, Width=0.5, Height=1
- Display 2 of 2: X=0.5, Y=0, Width=0.5, Height=1

 If the remote workstation is configured to ask for a **password**, and you intend to control it remotely from Ganz CORTROL Client (not just record), make sure you can see the right display.

Ganz CORTROL Global Administration Guide

 Remote control does not allow to send **system key combinations** (e.g., CTRL+Alt+DELETE) to the remote workstation; local OS will catch these key combinations. Therefore, make sure to disable the “Press Ctrl+Alt+Del to Log on” option on remote Windows workstations.


Non-Interactive Web Device

If you want to record and use non-interactive webpages in Ganz CORTROL Client, use a special device driver type called [HTML Source](#). These represent static webpages, which are available for recording as any other channels, and are visible in the Ganz CORTROL Client application. As this type of device is non-interactive, no CrossLink license is used: HTML source devices require a **regular channel license**.

Usage examples:

- Display media contents for marketing purposes
- Digital signage
- Statistics and dashboards

To create a non-interactive page, create a new device and set its model to **HTML Source (view only)**, then assign it to the desired server. Similarly to interactive webpage, set the **target address** in the *Uri* tab. The user will be unable to navigate away from this address, so make sure you specify the full and exact URL. If the target page requires **authentication**, enter the username and password in the device properties.



The screenshot shows the 'Device Static Webpage' configuration window. The sidebar on the left has 'Uri' selected. The main panel has a 'Uri' tab with the following fields:

- Address:** A text box containing the URL `https://youtube.com/embed/PQdBUExxCoo?autoplay=1&mi`.
- Username:** A text box for the username to access the resource.
- New password:** A checkbox and a text box for setting a new password. Below the text box, it says 'Password will not be changed'.

At the bottom of the window, there are three buttons: 'Related items' (with a dropdown arrow), 'Apply', 'OK', and 'Cancel'.

Available settings for the static webpage device

Next, click the *Related items* button and switch to the channel edit dialog box.

As the webpage contents will be static in the Ganz CORTROL Client application, you need to take care of the **contents transition**. To force refresh contents from the Ganz CORTROL side, use the auto refresh parameter in the channel properties.

In the *HTML source configuration* tab, you can edit the following **settings**:

- **Ignore certificate errors:** if enabled, invalid certificates will be ignored, and the page will be opened even if something is wrong with the site certificate
- **Auto refresh interval:** enable this if the remote Web contents is dynamic (e.g., graphs) and you want the page to be refreshed without user interaction (set 0 to disable auto-refresh)

There is no need to set auto-refresh for video contents; however, you may wish to enable video auto-replay.

In the example here with YouTube streaming, the video is looped by adding URL parameters; the final link will look as follows:

<https://www.youtube.com/embed/VIDEOID?autoplay=1&mute=1&loop=1&playlist=VIDEOID> - video added in such a way will be played on repeat indefinitely.

This link is formed by clicking the *Share* button next to the YouTube video and adding the parameters. This ensures

Ganz CORTROL Global Administration Guide

that nothing but the video is displayed in the viewport (no comments or other stuff present in the regular YouTube page). Similarly, if you wish to use video from other websites, make sure to provide the exact link to the video itself, not to the whole page containing the video.


12.2 Visual Groups

Device, channel and map groups are used solely for management and are only accessible in Ganz CORTROL Console.; in order to set up resource arrangement for Ganz CORTROL Client, **visual groups** are used. They allow custom grouping for *Channels*, *Buttons*, *CrossLinks* and *Maps* displayed in the connected Ganz CORTROL Client applications. You can create single-level or **multi-level** (nested) visual groups by putting them inside one another. Nested visual groups will also appear in the *Resources* section of the Ganz CORTROL Client application.

 Single Visual Group can be used simultaneously for multiple different resources - e.g. you can add a *Channel*, *Button* and *Map* to the same group to organize Ganz CORTROL Client layout.

Starting from software version 1.17.0, visual groups are also available in the [Archive Backup Wizard](#).


To access visual group management in Ganz CORTROL Console, go to the *Configuration* section in the bottom left panel and select the *Visual Groups* component in the menu on the left.



Configuration -> Visual groups

Click the + *Create visual group* button in the upper panel to bring up visual group creation dialog box.

Ganz CORTROL Global Administration Guide




Enter title for the new visual group

In the *Details* tab, enter a user-defined name for the target visual group. This name will appear in connected Ganz CORTROL Client applications.

You also can select custom *Icon* that will be displayed in Ganz CORTROL Client.

Switch to the *Members* tab to choose resources for this group. You can create nested visual groups (i.e., group inside group) - they will appear as a tree in the Ganz CORTROL Client application.



Choose channels to participate in this group

Double-click items or use the *Add/Remove* buttons below to manipulate resources; use the *Search* field in the upper-right-hand corner to quickly find entries in the list.

Ganz CORTROL Global Administration Guide

Visual group Suspicious Places*

Visual group

Details

Members

Permissions

Permissions

Selected users

TITLE

ID

TYPE

kenny

(119)

User

eric

(120)

User

PERMISSIONS

☒ View

☐ Administer

Clear

Available users

TITLE

ID

TYPE

kyle

(121)

User

stan

(122)

User

OK


Cancel

Add user permissions for the target visual group

Switch to the *Permissions* tab to allow user access to this visual group. There are two available permissions types:

- **View:** users have access to this resource in Ganz CORTROL Client
- **Administer:** user are permitted to edit this group via Ganz CORTROL Console

When you have finished, click *OK* to save and exit; the newly created visual group will appear in the item list.

To edit any of the previously created visual groups, double-click it in the item list or select any with single mouse click and then hit the *Edit* button on the upper panel. Use the *Search* field in the upper-right-hand corner to quickly find the existing items; the filters in the bottom panel allow you to load recently added/modified items. Use the  recycle bin button in the upper-right-hand corner to remove one or multiple visual groups: hold *CTRL* or *Shift* to select several items at once, or *CTRL+A* to select all.

12.3 Layout Templates

Layout templates are arrangements of empty viewports. These can be later filled with channels and maps in your Ganz CORTROL Client application and later saved as layouts. Each template can be used any number of times for creating both local or [shared layouts](#).

You can create your own, **custom layout templates** and then use them in any Ganz CORTROL Client applications connected to the target server.

To access layout templates via Ganz CORTROL Console, go to the *Configuration* section in the bottom left panel and select the *Layout templates* component in the menu on the left. Use the *Search* field in the upper-right-hand corner to filter existing items; press *Refresh* button to reload the item list.

Configuration > Layout templates

Search

Configuration

Servers

Users

Devices

Channels

Recording

Layout templates

Configuration

Monitoring

+ New layout template

Edit

1 selected

TITLE	ID	MATRIX	VIEWPORTS
1+2	(117)	2 × 2	3
1+4+bundle	(118)	8 × 4	21

Recently added, 2

Recently updated, 0

Layout templates

Click the + *New layout template* button on the upper panel to bring up the configuration dialog box.

Ganz CONTROL Global Administration Guide

Layout template 1+4+bundle*

Layout template

Details

Details

Title

1+4+bundle

Layout template name

Grid size

8

x

4

= 32

Viewports base grid: vertical x horizontal, maximum 100

1	2	3	4
5	6	7	4
8	9	10	11
12	13	14	14
15	16	17	
18	20		
19	21		

Merge

Unmerge

1 of 21 viewport(s) selected

OK

Cancel

Create new custom layout template

Enter the template **name**, choose **grid size** and then **modify the grid**, if desired: you can select multiple cells at once with your mouse and then use the *Merge* and *Unmerge* buttons below to create custom cell combinations. Note that you can only create rectangular regions, not just any polygonal areas.

- For corridor view cameras, merge several cells vertically, so that the image fits the target viewport without much stretching/distortion
- For surround view cameras or 180/360-degree dewarp, merge a row of cells

When you have finished, click the *OK* button; the newly created layout template will appear in the item list and it will also appear in any connected Ganz CONTROL Client applications after synchronization.

Use the *Edit* button to alter any template at any time: modifications will immediately be synchronized with Ganz CONTROL Client after you save the changes and modified templates will be available for use. However, if the modified layout was already in use, its current output will not be altered, allowing you to save the old layout in Ganz CONTROL Client. Drag and drop the new layout template to the Ganz CONTROL Client live view display to load the updated template version.

12.4 Shared Layouts

Layout is a pre-configured viewport configuration with channels assigned for live view and archive playback.

Layouts are created in the Ganz CORTROL Client application by filling a layout template with video channels. There are two main groups of layouts: **local**, which are created and stored locally on the same computer where the Ganz CORTROL Client is installed, and **shared**, server-side layouts, which are kept on each server and are available for all users that are connected to the same server from other client computers. If the license or server policy limits the number of max client connections to 1, layouts can still be shared between non-concurrent client connections from different machines.

Layouts themselves are created via Ganz CORTROL Client application but layout sharing should be pre-enabled from Ganz CORTROL Console. In order to make server users able to share and access this resource, **shared layout groups** should be pre-created on the server side. Groups are used for handling user permissions and also for logical arrangement of the shared layouts.



If **no layout groups** exist in the server configuration, layout sharing will be disabled for the target server from the Ganz CORTROL Client side.

To create a new group in Ganz CORTROL Console, open the *Configuration* section and choose *Layouts* from the menu on the left. Click the + *New layout group* button in the upper panel to bring up the shared layout group creation dialog box.

New shared layout group

In the *Details* tab, enter a user-defined name for the target layout group. This name will appear in all connected Ganz CORTROL Client applications when creating a shared layout.

Use the *Members* and *Membership* tabs to create nested groups; *Members* tab will also allow you to manage group contents after some layouts have already been created.

In order to **allow access** to specific shared layout groups for selected users, go to the *Permissions* tab:

- *Administer* permission grants access to the layout group in Ganz CORTROL Console and allows the user to share layouts via this group (put new layouts into target group)
- *View* permission allows users to see the contents of the group, i.e., shared layouts, when they connect to the target server from the Ganz CORTROL Client application, and use these layouts in Ganz CORTROL Client



All users with the *View* permission will be able to see and use the shared layouts from the target layout group. However, visibility of the contents of each layout will depend on each user's channel and map permissions.

Shared layouts can be used in *Layout Sequences* in Ganz CORTROL Client independently or combined with regular layouts as well.

12.5 Video Walls

The Ganz CORTROL Video Wall offers improved configuration options and functionality, as well as the ability to easily manage large-display installations. This is vital for operating large-scale video surveillance systems, especially when the ability to easily examine the area and quickly react to alarm events is essential. Video wall configuration using Ganz CORTROL is very flexible and it allows you to set up video output of virtually any physical display combination.

Video wall setup with Ganz CORTROL is very easy and similar to layout template creation: templates are constructed via Ganz CORTROL Console and then assigned an actual layout/channel view from Ganz CORTROL Client.

To access video wall management in Ganz CORTROL Console, choose the *Configuration* section in the bottom-left-hand panel and then select the *Video Walls* component from the menu on the left.

Create Video Wall

Click the + *New video wall* button on the upper panel to bring up the configuration dialog box.

On the *Details* tab, enter settings for the target video wall profile:

- **Title:** user-defined video wall name
- **Server:** choose where the video wall will be available (leave **none** for Ganz CORTROL Global - recommended option for most cases)




By default, all video walls run on the Ganz CORTROL Global server. We recommend that you leave your video walls attached to the **central management server**, unless you have clear reasons to move them to another server. Below, you will find details and limitations of storing video walls on Ganz CORTROL Recorder machines.

Then, select the video wall **grid size** by choosing the number of rows and columns from the drop-down lists; the maximum total number of viewports is 100 (10x10 layout), and maximum number of rows/columns can be up to 20. The viewport layout below will immediately reflect the changes, with display numbering for your convenience. Once you have chosen the video wall size, you can apply the following **adjustments** to the layout using the buttons below:

- **Merge** viewports: select a rectangular area containing multiple cells by clicking and dragging (selected cells will be highlighted light green as a result), then click the *Merge* button
- **Remove** viewports: if your video wall is irregular (not strictly rectangular in shape) or if you wish to pass over some displays, select one or several cells and click *Remove* to exclude these viewports from the grid
- **Add** viewports: this action is the opposite of removing viewports; click an empty area and click *Add* to insert a viewport


Ganz CORTROL Global Administration Guide



Video wall layout and details

Click any viewport to change its name using the *Properties* section on the right-hand side. Thus, each display belonging to the video wall can have both a number and a title for users' convenience.

Once the viewport configuration is ready, switch to the *Membership* tab to add the target video wall profile to existing video wall **groups**. Manipulate groups by double-clicking items in either columns, or by using the *Add* and *Remove* buttons below. Each video wall can participate in one or multiple groups.



Choose group(s) for the target video wall profile to be a member of

On the *Permissions* tab, choose users and users groups to **view** and **administer** target video wall profile. *Administer* permission allows users to change video wall layouts via Ganz CORTROL Client; *View* permission only allows them to view the existing video wall layouts assigned by other users.

Ganz CORTROL Global Administration Guide

Video wall Showroom*

Video wall

Details

Membership

Permissions

Permissions

Selected users

TITLE	TYPE
John Doe	User
HQ	User group

PERMISSIONS

<input checked="" type="checkbox"/> Administer
<input checked="" type="checkbox"/> View

Clear

Available users

TITLE	TYPE
Johnny English	User
SEO	User group

OK

Cancel

Assign user privileges

When done, click *OK* to save and close the dialog box. Newly created video wall profile will appear in the item list and will become available for configuration in Ganz CORTROL Client. The video wall list contains information on grid size and the total number of viewports for each item.

Use the buttons on the upper panel to edit, remove and quickly assign group membership to the selected video walls (use CTRL+click or *Shift+click* to select multiple items at once). The bottom panel allows you to filter recently created/updated items.

Create Video Wall Groups

Video walls, as well as other resource types in Ganz CORTROL, can be organized for easier management. To create a group for video walls, click the down arrow near + *New video wall* button and choose *New video wall group* from the drop-down list.

On the *Details* tab, enter the video wall group title.

Video wall group Hall S31*

Video wall group

Details

Members

Membership

Permissions

Details

Title

Hall S31

Group name


OK

Cancel

Enter a name for the target video wall group


Switch to the *Members* tab to choose existing video wall configurations to be included into the target group. Manipulate items either by double-clicking them in either columns, or by using the *Add* and *Remove* buttons below. Each video wall can participate in one or multiple groups.

Ganz CORTROL Global Administration Guide



Choose members for the target group

On the *Membership* tab, select other video wall groups that should include the target group as a member (nested groups).



Choose group membership

Finally, the *Permissions* tab lets you choose users and users groups to view and administer video walls for the target group. *Administer* permission allows users to change the member video wall layout via Ganz CORTROL Client; *View* permission only allows them to view the existing video wall layouts assigned by other users.

Once you have finished, click *OK* to save and close the dialog box. The newly created video wall group will appear in the item list. Use the buttons in the upper panel to edit/remove groups (use *CTRL+click* or *Shift+click* to select multiple items at once). The bottom panel allows you to filter the recently created/updated items.

Video Walls on Recording Servers

Starting from the software version 1.15.0, it is possible to assign video walls to Ganz CORTROL Recorder computers - instead of running them on Ganz CORTROL Global. Ganz CORTROL Client instances acting as video wall clients still need to be connected via Ganz CORTROL Global address (they will switch to local streaming automatically once the connection to the central server is lost).

This option has been added for deviant use cases, where the central management server is [often] unavailable from the Ganz CORTROL Recorder locations, while it is still necessary to preserve the video wall functionality locally. Such a configuration has certain limitations; for most cases, you can leave the video wall running on your central server and use [mirroring](#) to ensure central server functionality during its downtime.

Advantages:

- the video wall contents is available for all Ganz CORTROL Client workstations adjacent to the recording server, which hosts the video wall
- the video wall tab is available on these "local" Ganz CORTROL Client stations and it is possible to change the current video wall state manually
- E&A rules on the "host" recording server work for the "local" video wall

Ganz CONTROL Global Administration Guide

- if the "local" recording server fails, the video wall will continue to run on the "local" failover node

Limitations (for the moments when there is no connection to Ganz CONTROL Global):

- it is impossible to change startup layouts/sequences for such a video wall
- this video wall will be unavailable for all "external" Ganz CONTROL Client stations (as well as other resources)
- it will be impossible for this video wall to accept "external" E&A triggers via global events

In other respects, such "local" video walls do not differ from regular ones, which are stored on the central management server. You can change the *Server* property of any video wall via Ganz CONTROL Console at any time, moving the video wall configuration to another server at any time.

Ganz CORTROL Global Administration Guide

12.6 Maps

Maps are resources that allow you to use an image of the building plan or some area and place interactive markers on it. Cameras, doors, user buttons, and other items put on maps can then be clicked in the Ganz CORTROL Client application to provide the desired interaction and facilitate the operators' work. Links to other maps help create multi-layered building plans for better navigation.

To access map management via Ganz CORTROL Console, select the Configuration section from the bottom-left-hand menu and then click Maps in the menu on the left.

Two types of maps are available at this point: maps based on user image, and geo maps.

Create Map

Click the + New map button on the upper panel to bring up the map configuration dialog box.

Map Cafe del Mar

Map

Details

Membership

Permissions

Marking

Title

Cafe del Mar

Map title

Organisation

none

Change...

Organisation to which the map belongs

Map image

Select image...

Select image of the desired plan in PNG, JPG, TIF, BMP or static GIF format. Please note, the system will reproduce the provided image without scaling or effects. The best results will be with 16:9 images of approximately 1600x900 pixels.

Apply OK Cancel

Map details

On the map Details tab, enter a user-friendly name for your new map, then select the organization it represents, if applicable, and upload a picture that will be used as plan basis. All major raster picture formats are supported: JPG/JPEG, BMP, PNG, TIF/TIFF and GIF.



There are the following limitative requirements for the pictures loaded as maps:

- picture resolution should be less than 8.25MP
- file size should be less than 5MB

Files not meeting these limitations will be rejected.


Place Camera Markers

Switch to the Marking tab to place cameras on the map.


Manipulate your map image by zooming IN and OUT with the mouse wheel, dragging the picture with the left mouse button and using the Reset and Fit buttons below. Reset shows non-zoomed 100% size picture (or a picture


Ganz CORTROL Global Administration Guide

fragment, if it is larger than the window), and Fit zooms your picture so that it fits into the preview window.



Map marking

To place a camera marker, drag the  camera icon from the upper-left-hand corner and drop it on the scene. Camera markers will allow you to pop up channels by double-clicking the markers in Ganz CORTROL Client. They will also have a red mark on them in the Ganz CORTROL Client application if the target channel is offline (if the Video lost event has been triggered): the channel's Video loss parameter is used as a timeout, which is 15s by default. The following actions are possible:

- select the camera by clicking the  camera icon on the plan (and not the blue sector representing the viewing area)
- move the camera around by dragging it (the sensitive area is within the pink circle)
- change coverage sector by dragging two pink dots on the sides of the blue sector: drag to the sides to adjust the vertical angle up to fisheye (full circle)
- correct camera position: drag central pink dot to the sides to rotate camera, drag to/from the centre to change radius
- remove the marking by selecting it and pressing the Delete button on your keyboard or the recycle bin button on the upper panel

The properties window on the right enables you to:

- choose target channel for the currently selected marking
- view information about marking angles and radius
- turn ON/OFF displaying of coverage area
- change the marker icon color and size
- adjust the marker title color and size


Camera Marker Binding with Indicators

You can attach indicators to cameras in order to change the camera cone color on the map's viewport according to the preset Indicator.

Ganz CORTROL Global Administration Guide

First, you need to create the Indicator itself, then set up rules for the previously created Indicator, and then you can attach the previously created Indicator to the camera. After that, your Camera cone color will change according to your rules set for the Indicator.

1. Go to Configuration -> Maps -> Your particular map
2. In the map window, select Marking from the left menu
3. Drag and drop the camera icon from the menu over the viewport
4. On the top of the Properties menu, select the Channel you want to attach to the already placed camera icon.
5. At the bottom of the Properties menu, select the previously created Indicator.




An example of how-to attach an indicator to the camera

Other Markers

Several other marker types turn your map into a fully featured control panel. To place any marker, drag the corresponding icon from the upper-left-hand corner and drop it onto the scene.




Marker types: channel, map, user button, layout, door, indicator, webpage, data channel, polygon, security system item


It is also possible to add map markers and use them as shortcuts to other maps: target maps will pop up when corresponding map markers are double-clicked in Ganz CORTROL Client. To place a map marker, drag the  map icon from the upper-left-hand corner and drop it onto the scene.

Click a map marking and use the properties window on the right to browse for a map that you wish to be a target for the current shortcut. Remove markers by selecting them and then hitting the Delete button on the keyboard.

Ganz CORTROL Global Administration Guide



Map markers

In the same way you can also add user buttons  to your map and trigger assigned actions by double-clicking the buttons in Ganz CORTROL Client. Select your desired user button on the map and then use the properties section on the right to bind a user button to the marking.

Similarly to individual channels, it is possible to place layout markers for shared layouts to be displayed when double-clicked on the map in Ganz CORTROL Client. The target shared layout and the icon style can be defined in the properties section on the right.

Door markers are intended to be bound to doors from the [access control](#) integration: door statuses are then displayed on the map in the Ganz CORTROL Client application. The target door and icon styles for different door states is to be defined in the properties section on the right.


The Security system item marker will change its icon to the corresponding Item when dropped on map and will display status of the connected Item.

Finally, indicators are multi-state entities that can [change their state](#) - and, therefore, their colors on the maps - based on events. These may be temperature ranges, condition states, or any other system component states that have related events.

Polygon (Indicator zone) marker

You can draw a free-form *polygon*, attach to *indicator* to change color correspondingly or combine this marking with the *user button*. The *polygon* will be displayed in Ganz CORTROL Client with the attached functionality.


Ganz CORTROL Global Administration Guide



Polygon marking combined with the indicator and user button

Copy Markings/Indicators

You can duplicate any indicator on Maps. To do so, select the indicator/marking you want to copy. At the top-right corner of the Marking section, you will find two buttons: one for deleting the indicator/marking and the second for duplicating. Click on the duplicate button. This will create a copy of the selected overlay.




Example of the Camera marker copy inside the Maps. Duplication button and the Camera indicator are marked with the red ellipses.

Marker Customization

Each marker has a customizable icon, size, color, outline, and the same options are available for its text label.

Ganz CORTROL Global Administration Guide

You also may change the label position by changing Title placement field. To edit the marker, click the marker on the map: its properties will appear on the right. As you change the properties, the changes will be immediately reflected.




A custom channel marker with customized text label size and appearance

Marking Arrangement

By default, you can place camera markings and other icons freely. But, for some purposes, using a grid for marker arrangement can be useful. For example, when you do not use an actual map but rather create a control panel with action buttons, and when the number of markers is big, use grid arrangement to facilitate the creation process.

While in the Markings section of the map management, click anywhere on the background (not an icon). If a marker was selected, the selection will disappear, and you will see map properties on the right. In the properties section, mark the corresponding option to enable it:

- Show grid: will show the grid lines; all added markers can only be placed at intersections
- Lock grid: if enabled, the grid size will be locked at the current zoom level, and zooming the image in/out will zoom the grid as well



Map markers attached to the grid

Membership And Permissions

Just as other resources, maps can be grouped and assigned user permissions.

Ganz CORTROL Global Administration Guide

Map Section 31*

Map

Details

Marking

Membership

Permissions

Membership

Selected groups		Available groups	
TITLE	TYPE	TITLE	TYPE
Sector 31: public areas	Map group	Sector 31: restricted area	Map group
		Sector 31: facilities	Map group

Remove

Add

OK

Cancel

Map membership

In the Membership tab, you choose groups for this map to become a member of: select groups by double-clicking items in both columns or by using the Add/Remove buttons below.

Map Section 31*

Map

Details

Marking

Membership

Permissions

Permissions

Selected users		PERMISSIONS	Available users		
TITLE	ID	TYPE	TITLE	ID	TYPE
Johnny English	(119)	User	<input checked="" type="checkbox"/> Administer	James Bond	(120) User
			<input type="checkbox"/> View	Jimmy Neutron	(121) User
				Supervisors	(122) User group

Clear

OK

Cancel

Map permissions

Permissions tab enables you to choose the users and user groups that will have access to this resource. Select at least one permission to select a user/user group; uncheck all manually or using Clear button below to deselect. Administer permission means user will be able to see, open and edit map via Ganz CORTROL Console, and View only allows user to load the map in Ganz CORTROL Client.

When you have finished, click OK to save and close the dialog box. The newly created map will appear in the item list of the Maps section.

Use the buttons on the upper panels to perform item-specific actions: remove, edit and quickly assign map group; the filters on the bottom panel will help you switch between recently created/updated items and display maps/map groups only.

Create Geo Map

It is also possible to use a world map instead of user-defined pictures to put the markings on it. To create a new geo map, click the drop-down arrow near the + New map button and select New geo map to bring up the geo map creation dialog box.


Geo map functionality requires that constant Internet connection is present in order the world map to be loaded from the remote server. Internet connection is required from Ganz CORTROL Client as well to load the map and present it to the end user.

Geo map creation is similar to the creation of a regular map, with the difference that you do not need to specify the image to be used: instead, the world map is loaded from the server provided by CBC AMERICA LLC. You just need

Ganz CORTROL Global Administration Guide

to find the right place on the map by zooming IN/OUT and moving the map:

- use your mouse wheel to zoom IN and OUT
- click and drag with your left mouse button to move the map around




Markers on a geo map

Markers of all available kinds can be placed on the geo map in the same manner as with the regular map, and the rest of the tabs also provide the same functionality.

Create Map Group

Map groups can be used for easier management in Ganz CORTROL Console. Note that map groups are not displayed in Ganz CORTROL Client; to group maps and geo maps in Ganz CORTROL Console, use [Visual Groups](#).

Click the drop-down arrow near the + New map button and select New map group to bring up the map configuration dialog box.



Map group details

Enter group name on the Details tab and proceed with selecting maps for this group on the Members tab.

Ganz CORTROL Global Administration Guide

Map group Sector 31: classified*

Map group

Details

Members

Membership

Permissions

Members

Selected members		Available members	
TITLE	ID TYPE	TITLE	ID TYPE
Section 31	(117) Map	Sector 31: public areas	(136) Map group
Sector 31: restricted area	(147) Map group	Sector 31: facilities	(148) Map group
<div>Remove</div>		<div>Add</div>	

OK

Cancel

Choose members for the target map group

You can select both maps and map groups to be members of any map group.

Map group Sector 31: classified*

Map group

Details

Members

Membership

Permissions

Membership

Selected groups		Available groups	
TITLE	ID TYPE	TITLE	ID TYPE
		Sector 31: public areas	(136) Map group
		Sector 31: restricted a...	(147) Map group
<div>Remove</div>		<div>Add</div>	

OK

Cancel

Map group membership

On the Membership tab, choose groups to contain target map group as a member, thus creating nested groups.

Map group Sector 31: classified*

Map group

Details

Members

Membership

Permissions

Permissions

Selected users			Available users	
TITLE	ID TYPE	PERMISSIONS	TITLE	ID TYPE
Johnny English	(119) User	<input checked="" type="checkbox"/> Administer	James Bond	(120) User
		<input checked="" type="checkbox"/> View	Jimmy Neutron	(121) User
		<div>Clear</div>	Supervisors	(122) User group

OK

Cancel

User permissions for map group

Switch to the Permissions tab to assign user privileges for the target map group. Select at least one permission to select user/user group; deselect by unchecking manually or by using the Clear button below to remove all. Administer permission means user will be able to see, open and edit all maps in this and nested groups via Ganz CORTROL Console, and View only allows user to load the maps in Ganz CORTROL Client.

When you have finished, click OK to save and close the dialog box. The newly created map group will appear in the item list in the Maps section. Use the buttons on the upper panels to perform item-specific actions: remove, edit and quickly assign map group; filters on the bottom panel will help you switch between recently created/updated items and load maps/map groups only.

Ganz CONTROL Global Administration Guide

12.7 User Buttons

User buttons are visual controls used in Ganz CONTROL Client and Ganz CONTROL Mobile for manual event triggering. Once you create a user button, it will become available in the [Event & Action Configurator](#) and you will be able to **assign actions** to the *User button clicked* event.


After a user button has been created and associated with at least one action, you will be able to use it in the following ways:

- bind the user button to a channel or channels so that it appears as a live video overlay control in the Ganz CONTROL Client application
- place the user button marker onto [maps](#)
- trigger it from the Ganz CONTROL Client application from the user button list, from any map or from the channel overlay controls
- [highlight it on a map](#) or all maps where the corresponding marker is present
- trigger it from the Ganz CONTROL Mobile application

To access user button management via Ganz CONTROL Console, select the *Configuration* section from the bottom left menu and then click *User buttons* in the menu on the left.

New User Button

Click the + *New user button* on the upper panel to bring up the configuration dialog box. On the *Details* tab, enter a name for the resource and choose organization attachment.



Enter title for the user button

Switch to the *Membership* tab to choose groups for this user button to become a member of: select groups by double-clicking items in both columns or by using the *Add/Remove* buttons below. Apart from grouping, this tab allows you to bind user buttons to particular channels.



Starting from the software version 1.5.0, user buttons can be **bound to one or more channels** for their presentation in Ganz CONTROL Client. This means that once such a channel is put into a viewport, the related user button automatically appears with it. The same user button can be also manually put into other viewports and also removed from the bound channels in the live view without any limitations. Multiple user buttons per channel are allowed.

In order to set this up, open the target user button for editing, go to the *Membership* tab and add the desired channel(s) from the right-hand column (the same one that contains user button groups).

The *Permissions* tab allows you to choose which users and user groups will be privileged to have access to this resource. Select at least one permission to select the user/user group; deselect by unmarking manually or using the *Clear* button below.


When you are finished, click *OK* to save and close the dialog box. The newly created user button will appear in the item list. Use the buttons on the upper panels to perform item-specific actions: remove, edit and quickly assign user button group; filters on the bottom panel will help you switch between recently created/updated items and load user

Ganz CORTROL Global Administration Guide

buttons/button groups only.

New User Button Group

For easier management, user buttons can be grouped together. Click the drop-down arrow next to the + *New user button* and select *New user button group* to bring up the configuration dialog box.



Enter the title for the user button group

Switch to the *Members* tab to choose resources for this group. Double-click items or use the *Add/Remove* buttons below to manipulate resources; use the *Search* field in the upper-right-hand corner to quickly find entries in the list.

Using the *Membership* tab, you can choose groups for this user button to become a member of; select groups by double-clicking items in both columns or by using the *Add/Remove* buttons below.


Permissions tab allows you to choose users and user groups privileged to have access to this resource. Select at least one permission to select the user/user group; deselect by unchecking manually or using the *Clear* button below to remove all permissions.


When you have finished, click *OK* to save and close the dialog box. The newly created user button will appear in the item list. Use the buttons on the upper panels to perform item-specific actions: remove, edit and quickly assign user button group; filters on the bottom panel will help you switch between recently created/updated items and load user buttons/button groups only.

12.8 Dewarp For Fisheye Cameras

Fisheye lens is an ultra-wide-angle lens that produces a wide panoramic image at the cost of strong visual distortion. Usually, devices with such lenses capture a 360-degree geometrically distorted image and projects it as a circle within the image frame. Fisheye lens can be either built-in by design or purchased separately and installed on your desired camera. Ganz CORTROL dewarp feature allows to correct the perspective and obtain several "normal" views from a single distorted fisheye picture.

In order to access dewarp settings via Ganz CORTROL Console, open the *Configuration* section and choose *Channels* from the menu on the left. Find the channel you wish to dewarp in the list (use *Search* or filters, if necessary) and double-click it in order to open it for editing (alternatively, use the *Edit* button on the upper panel to open the dialog box), then switch to the *Dewarp* tab.

 Please note that the location of dewarp settings has changed starting from the product version 1.5.0. For previous software versions, the corresponding settings can be found in the general *Channel Properties* dialog box.



Dewarp settings

You have the following options here:

- **Regular lens:** choose this option if you wish to disable the dewarp engine (selected by default)
- **Immervision Enables® lens:** choose this option if your camera has a Panomorph lens installed (you can check this in the camera specification)
- **Fisheye lens:** choose this option if your camera has a regular 360-degree view lens
- **Fisheye lens (large resolution):** dewarp engine optimized for image resolutions of 6MP+

If your fisheye image has a resolution of **6 megapixels or higher**, it is better to use the last option in the drop-down list - fisheye lens **optimized for high resolutions**. This mode will provide smoother DPTZ experience with the dewarped image. If your graphics card supports **OpenCL version 1.2** or higher, this dewarp driver will use GPU (you can check this in your video driver properties, or request info from the video card manufacturer). Otherwise, more CPU time will be required, compared to the basic fisheye mode. We recommend that you do not use this driver for smaller resolutions, as it may use more CPU yet there will be no difference for the user.

Ganz CORTROL Global Administration Guide

For devices having a Panomorph lens, choose the lens model from the drop-down list - you can find this information in your camera specification or request it from the device manufacturer. You do not need to define any parameters manually in this case; rather, you only need to choose your camera mounting position, and the dewarp engine will automatically produce a correct dewarping result.



Note that the dewarp engine will fail to operate if you choose a wrong Panomorph lens model. Check with your camera documentation and manufacturer for the precise lens model information.

For a generic fisheye lens, you are requested to define the fisheye sphere size and camera position by using the **overlay controls** and settings on the right side:

- **Hemisphere diameter:** click and drag any of the small pink circles on the overlay sphere to change its size and align it with the actual fisheye sphere in the picture
- **Horizontal** and **vertical** centre: automatically positioned in the picture centre, to change it click and drag the small pink circle inside the sphere
- **Mounting** direction: select camera mounting position from the drop-down list (wall/ceiling/floor)

For your convenience, the defined parameters are also displayed in the numeric form on the right side of the dialog box. Use the button below the preview to **reset** all dewarp settings to the default ones.



In case you change the stream resolution at some point, its **aspect ratio** may also be changed and this will affect dewarp operation. Therefore, check the dewarp settings after changing the resolution and adjust the parameters, if necessary.



Note that all **dimensions** are given not in pixels but in reference to the video stream size, therefore, **relative values** are used instead of absolute ones.


When finished, click *OK* to save the changes and close this dialog box and return to the general channel configuration. Dewarp results will immediately become available in the Ganz CORTROL Client application; you can find the details on usage in the corresponding section of the Ganz CORTROL Client documentation.

12.9 Audio

Ganz CORTROL is capable of receiving audio streams from cameras, recording and playing them back, as well as sending audio back to the cameras from Ganz CORTROL Client stations. It is also possible to bind an external audio source to a video channel.

There are a few conditions stipulating audio feature availability:


- the target device should be capable of sending/receiving audio
- relevant additional equipment should be plugged into the device (microphone and/or speakers), if necessary (if these are not built in by design)
- one-way or two-way audio should be enabled and set up on the device side so that it is available via device Web interface
- G.711 should be selected as audio codec on the target device side
- audio should be enabled in the channel settings via Ganz CORTROL Console (see below)
- feature should be supported by Ganz CORTROL integration for the target device (see the list of supported devices and features provided by CBC AMERICA LLC)
- in order to send audio to the device, Ganz CORTROL Client workstation must have a microphone connected to it - either a built-in or an external one
- if you plan to use an external audio source, relevant audio capturing equipment should be plugged into the server, to which the target device is connected, and enabled via Windows audio settings

 G.726 and AAC audio codecs, which are often implemented on the camera side, are not supported at this point, so please always select the **G.711** option. Setting other codecs on the device side may result in Ganz CORTROL being unable to decode the incoming video stream.

Enabling Audio

If you plan to use camera-side audio and have not checked audio configuration on the camera side yet, go to the device Web interface and adjust the audio settings, then make sure that audio is operable in the browser preview (you may need to install an ActiveX control in order to get it working; please check with your device's user guide for tips and browser requirements).

To **enable audio** for your desired device in Ganz CORTROL Console, open the *Configuration* section and choose *Channels* from the menu on the left. Then, open your target channel for editing - either by double-clicking it or by selecting it with a single click and clicking the *Edit* button on the upper panel. In the channel properties dialog box, switch to the *Audio* tab by selecting it on the left.



Access *Audio* tab in the channel properties

Here, you have 4 options. Depending on your selection, additional fields may appear.

- **None**: **disable** audio functionality for the target channel (default), no additional settings
- **Internal**: enable audio reception **from the device** side and sending the reverse audio to the device
 - choose an audio input from the drop-down list, if the target device has multiple ones
 - if there are none configured or available on the device side, the list will appear empty (this also refers to cases when audio is not supported for the selected device)

Ganz CORTROL Global Administration Guide


- *Attached*: use an external audio source **connected to the** same **server** as the device, from which the target channel originates
 - choose an audio input device from the drop-down list, if the target server has multiple ones connected to it
 - all microphones recognized by Windows will appear here
- *External*: use **another channel's audio** as audio for the current channel (see below for more details)
 - choose a channel to serve as audio source

When you have chosen your preferred option, click *OK* to save and close the *Channel settings* dialog box. You should now be able to listen to live audio, record it along with the video stream and talk back to your camera via Ganz CORTROL Client and Ganz CORTROL Mobile applications.

Combining Video and Audio Sources

Ganz CORTROL allows channels to use audio coming from a different channel in case the target channel does not have its own incoming audio, or in case you wish to combine audio and video data from different sources. Such combinations are used for both live and recording. A common example of this method is to use audio from intercom channels in combination with nearby video cameras.

In order to do this, double-click the target channel (the one without audio) in the channel list to open it for editing, then choose the *Audio* tab on the left.



The screenshot shows a window titled "Channel Floor II Office*" with a sidebar on the left containing "Channel", "Permissions", "Motion detector", "Audio*", "Inputs", and "Outputs". The "Audio" tab is active, showing "Audio source" as a dropdown menu with "External" selected. Below this is the text "Audio source that will be used for the channel." followed by "External audio source" which has a text box containing "Coffee Bar" and a "Change..." button. At the bottom of the window are "Apply", "OK", and "Cancel" buttons.

Choose another channel as audio source

Choose *External* from the drop-down list, then select a channel to be used as the new audio source: click the *Change* button to see the list of channels and choose the one that you want audio to be coming from. Hit *Apply* or *OK* to save your changes.





Audio must be configured for the channel used as an external audio source via channel configuration as described earlier. Both cameras and audio-only devices (intercoms) can be used as external audio sources.

Ganz CORTROL Global Administration Guide

12.10 Live Podcasts


Ganz CORTROL channels can be shared by streaming over RTMP and thus be used for live casting - either with popular streaming services or with your own RTMP server. This manual covers examples of how to set up live streaming for Youtube and Wowza live casts - working with other RTMP servers is similar.

-  Before sharing a channel, check its settings and make sure that:
- the channel is enabled in the configuration and video is available,
 - stream codec is **H.264** (other codecs will not work!),
 - if you want to use substream and/or audio, make sure you have enabled them in the channel properties.

 Ganz CORTROL Server free edition only allows 1 (one) podcast per server.

To access **shared channel management** in Ganz CORTROL Console, go to the *Configuration* section in the bottom left panel and select the *Live Podcasts* component in the menu on the left.

Click the + *New live podcast* button in the upper panel to bring up the shared channel creation dialog box.



Sharing a channel for Youtube live streaming

First, choose where you are going to stream the channel: it can be a specific public service or generic RTMP streaming to a service that is not listed, including your own RTMP server; depending on your choice, settings may vary to suit the specific service. Then, enter streaming configuration.

Ganz CORTROL Global Administration Guide


The table below explains the settings in details.

Setting	Description	Default value
Sharing type	Choose between Youtube, Wowza or generic RTMP streaming	Generic RTMP
Channel	Target channel to be streamed	[none]
Use substream	When not enabled, main (higher resolution) stream will be used; enable this option if you want to cast the lower resolution stream	Disabled
Enable audio	Enable this option to include sound for the shared channel, works both for main and secondary streams	Enabled
RTMP URL	Full URL to be used for casting, the link is normally provided by the RTMP streaming engine	[empty]

Youtube Live Streaming

Youtube live casting can use RTMP streams from your Ganz CORTROL server for further streaming.

In order to set up live streaming with Youtube, log in to your account on youtube.com and go to [Creator Studio tools](#) -> Live streaming -> Stream now. If you have never created any live casts before, you may have to verify your account - just follow the guidelines on the website.

 You need to have a valid Youtube (Google) account in order to be able to use this type of streaming, and comply with Youtube live streaming conditions. CBC AMERICA LLC is not responsible for the third-party service operability and policies.


Scroll down to the *Encoder Setup* section: you will need the link and the secret stream key in order to build the RTMP link.

In Ganz CORTROL Console, open the *Shared Channels* section and add a new shared channel, fill in the settings as follows:


- **Sharing type:** Youtube
- **Channel:** target channel from the list of existing channels
- **Use substream:** up to you
- **Enable audio:** up to you
- **RTMP URL:** `rtmp://<server_URL>/<stream_key>`, where
 - `rtmp://` indicates that RTMP protocol will be used for streaming
 - `<server_URL>` is Server URL link provided by Youtube, e.g., `a.rtmp.youtube.com/live2/`
 - `<stream_key>` is Stream Name/Key generated by Youtube in the form of `xxxx-xxxx-xxxx-xxxx`

Wowza Streaming

Alike Youtube, Wowza streaming engine can receive video feeds from Ganz CORTROL server and stream them out to any device. You need to install Wowza Streaming Engine first and then configure live streaming as described below.

 Ganz CORTROL does not include any installation files or licenses for Wowza Media Systems software. Wowza engine is used as a third-party agent capable of receiving RTMP streams; all installation, setup and management of this engine is to be handled by you or your Wowza administrator, and CBC AMERICA LLC is not responsible for the third-party engine operability and policies.

First, go to your Wowza Streaming Engine Manager and create a **new application** of the *Live* type.

 Once you have created a new application, go to the *Source Security* settings of that application in your Wowza Streaming Engine Manager and set **RTMP Sources** security to **Open** (no authentication). This is required as Ganz CORTROL currently does not support authentication for RTMP streaming.

Then, go to Ganz CORTROL Console, open the *Shared Channels* section and add a new shared channel, then fill in

Ganz CORTROL Global Administration Guide

the settings as follows:


- **Sharing type:** Wowza
- **Channel:** target channel from the list of existing channels
- **Use substream:** up to you
- **Enable audio:** up to you
- **RTMP URL:** `rtmp://<ip>:<port>/<app_name>/<stream_name>`, where
 - `rtmp://` indicates that RTMP protocol will be used for streaming
 - `<ip>` is Wowza Streaming Engine server address - either IP or domain name
 - `<port>` is target (remote) RTMP port, 1935 by default
 - `<app_name>` is the name of the application you have created in Wowza
 - `<stream_name>` is a custom name for the RTMP stream (can be any name, use underscores instead of spaces), will appear in Wowza automatically

When you have finished, click *OK* to save and exit; the newly created channel share will appear in the item list and Ganz CORTROL server will attempt to stream the data to the target URL at once. If you wish to pause the streaming, use the *Disable* button on the top panel. After sharing the channel, you should be able to view the stream on the RTMP server side and start the casting, if it has not started automatically.



If you have trouble receiving the stream on the RTMP server side, check the following:

- make sure all used software is allowed through the firewall(s),
- restart the RTMP server,
- refresh connection list on the RTMP server side or refresh the webpage;
- remove the shared channel in Ganz CORTROL Console and try sharing the channel anew.

To edit any of the previously created channel shares, double-click it in the item list or select any with single mouse click and then hit the *Edit* button on the upper panel. Use the *Search* field in the upper-right-hand corner to quickly find the existing items, and the *Disable* button to **disable and enable** channel sharing. Use the  recycle bin button in the upper-right-hand corner to remove one or multiple shares: hold *CTRL* or *Shift* to select several items at once, or *CTRL+A* to select all (actual original channels will not be affected).



When you remove the original channel (with or without its originating device), all shared channels based on it are removed from the configuration automatically as well.

Filters in the bottom panel allow you to load recently added/modified items.

12.11 Data Sources and Data Channels

This part of the manual covers the feature of data sources in Ganz CORTROL. Data sources are a means of retrieving textual data from a serial source, such as a Point of Sale (POS) terminal. You can receive information in textual form from various **third-party serial data providers** like intercoms, bank machines, and a multitude of other devices capable of delivering data strings over the following connection types:

- UDP port (remote connection)
- TCP port (remote connection)
- COM port (direct hardware connection to the server)

As a result, you get textual information, which you can store, analyze, react to, run queries to, and visualize in Ganz CORTROL Client.


The following entities exist in Ganz CORTROL Console for this feature configuration:

- **Data source:** defines how the data are retrieved from the external source
- **Data source profile:** describes how the data are parsed and extracted on the Ganz CORTROL side
- **Database:** keeps the extracted data
- **Data channel:** displays the data from the database and allows detailed DB search in Ganz CORTROL Client

Data channels require an additional [license](#).

General Concept

Ganz CORTROL servers receive serial data from the defined sources, splits it into transactions and individual lines of text, extracts and stores keywords and values, combines the text with the video streams, and allows advanced search across the database.



The diagram shows the data flow between data entities

Simplified configuration steps for the data reception from data sources can be briefly described as follows:

1. Create a **data source**, then
2. Create a data source **profile**, then
3. Link them together, and then
4. Assign the data source to the desired **channel(s)**,
5. (optionally) Set up **variables** if you wish to react to certain keywords.

Ganz CORTROL Global Administration Guide

⚠ Make sure that **the time precisely matches on both the server and client sides or the data source may not be displayed properly in the client application's live mode. If the system is disconnected from the internet, you may set a local NTP server or just adjust the time manually.**

Gathered data are then stored and displayed embedded with the video stream from the channel(s) you choose to associate with it.

Starting from Ganz CORTROL version 1.23, there are additional entities available that allow building more complex scenarios: **databases** and **data channels**. These are not mandatory for receiving the serial data, yet they provide advanced means of storing and searching the data. Hence, you may find databases and data channels most useful when working with an abundance of complicated text like POS transactions, plus when there is a necessity to run complex textual queries on the data from the Ganz CORTROL Client side.


- With **databases**, you can store your selected data (a part of the data stream) in a database with further refined search in the Ganz CORTROL Client application.
- **Data channels** display text from data sources as a separate channel without underlying video, creating a convenient representation of the textual feed.

Ganz CORTROL Client also has a special playback mode featuring advanced database search.

Take the following steps to set up your **advanced setup** involving databases and data channels:

1. Create a data source (or multiple data sources), and
2. Add a data source profile,
3. Link them together,
4. Create a database,
5. Map variables from the data source profile to the DB, and
6. Add a data channel (or multiple) linked to the data source(s).

In this more complex scenario, you can still use variables to trigger events in the [Event & Action](#) scenarios.



Data profiles shape how data from data sources are stored and presented in the form of data channels

Data Visualization

Data sources, data profiles, variables (mappings), and databases are configured in Ganz CORTROL Console. For users to access your data in Ganz CORTROL Client, you can:

- Combine data with existing video channel(s) so that the text overlays the video in Ganz CORTROL Client. No additional entities are required, the text overlays existing video channel(s) and the combination is displayed in Ganz CORTROL Client in the same viewport.
- Add data channel(s) to create a visualization for the transactions. Data channels will be displayed in a separate viewport but you can link them logically to video channels.

The first method is simpler and has usability restrictions. Data channels, on the other hand, provide additional

Ganz CORTROL Global Administration Guide

functionality, but require a special license to operate. Both are described below in details.

Below, you will see how these entities are set up in Ganz CORTROL Console. For Ganz CORTROL Client part, please see the Ganz CORTROL Client user manual chapter on data sources.

Add Data Source

First, go to the *Configuration* section of Ganz CORTROL Console and choose the *Data Sources* component from the menu on the left. Then, click the + *New data source* button on the upper panel to open the data source creation dialog box.

Give your data source a comprehensive name. Then, choose the server that is going to be accepting the serial data. Leave the *Data source profile* field **empty** for now and select the desired transport for the data connection. You will need to return here and choose the profile after you create the profile itself.

There are three possible connection types: UDP port, TCP port and COM port.

TCP/UDP Connection

Choose this option if your data provider is configured to feed the textual data into a specific TCP or UDP port.

The screenshot shows a window titled "Data source UDP Data Source". On the left is a sidebar with two tabs: "Data source" and "Details". The "Details" tab is selected. The main area is titled "Details" and contains the following fields:

- Title:** A text box containing "UDP Data Source".
- Server:** A dropdown menu showing "My Favourite Server" with a "Change..." button to its right.
- Data source profile:** A dropdown menu showing "UDP Profile" with a "Change..." button to its right.
- Data source type:** A dropdown menu showing "Udp".
- Port:** A text box containing "4060".

At the bottom right of the window are "OK" and "Cancel" buttons.


New data source of UDP type

You simply need to specify the incoming port for the server to listen to in the settings here. Make sure the port is opened on all intermediate firewalls and not used by any other software on the server machine.

COM Port Connection


Choose this connection type if your data provider is connected directly into the Ganz CORTROL server's COM port.

Ganz CONTROL Global Administration Guide



New data source of COM port origin

For this configuration, you need to match the serial connection settings with those used from the device side. Normally, this can be checked via Windows Device Manager for your target COM port.



COM port settings in the Windows Device Manager properties

The following serial port settings should be specified:

- **COM port:** serial port to read the data from, choose from the list of active ports
- **Baud rate:** information transfer rate (9600 by default)
- **Data bits:** the number of bits transmitted over the serial interface (8 by default)
- **Stop bits:** the number of bits to specify the end of a byte; if you select data bits to be 6, 7, or 8, then the default value is 1 and the other available choice is 2; if you select data bits to be 5, then the only correct

Ganz CORTROL Global Administration Guide

choice for the stop bits is 1.5

- **Parity:** how the parity is checked (no parity by default)

Other serial port parameters are not required for the Ganz CORTROL server.

Click *OK* to save and close the data source creation dialog box. The next step is to create a data source profile to help the server determine how the textual data should be parsed.

Add Data Source Profile

On this step, you will load a portion of the serial text from the data source configured as shown above, and set up how the text will be parsed. That includes breaking the text into lines and transactions, and adding variable mapping.

In the *Data Sources* section, click the little arrow next to the data source creation button and choose the *+ New data source profile* from the list. In the *Details* tab, enter a custom name for your data source profile and switch to the *Configuration* tab.

It is now necessary to use an example of the data strings to set up the profile. This part of the setup is the same regardless of what type of data source you have.

You can either use the **actual data source** you have configured on the previous step, or use a **text file** that contains the lines of data in the expected format (note that the same encoding should be used). Use the buttons on the right side of the text field to load the sample from either source. Use the *Stop* button to finish displaying new text from the data source (do this if you see that the loaded data lines are sufficient to facilitate the configuration process); use the *Clear* button to erase whatever is in the preview window before loading a different file or strings from a data source.

Data source profile POS example

Details

Configuration

Encoding

Western European (Windows)

Character encoding

Line ending

CR+LF

Line ending

☒ Remove non-printable characters

Remove non-printable characters

2023.01.26 17:11:44 POS0002 walnuts 0.000 8.49 0.00

2023.01.26 17:11:44 POS0002 Keyed, Product Code 03689

2023.01.26 17:11:44 POS0002 Total: 51.06

2023.01.26 17:11:44 POS0002 Tender type: 1 Tender name: CASH, amount: 51.06

2023.01.26 17:11:44 POS0002 Total discounts given with VAT 0.00

2023.01.26 17:11:44 POS0002 Shop ID 00001, POS ID POS00002

2023.01.26 17:11:44 POS0002 Operator Katherine Troia, Transaction ID 00032164

2023.01.26 17:11:44 POS0002 Transaction End

2023.01.26 17:11:44 POS0002 Transaction End time 2023.01.26 17:11:44

2023.01.26 17:11:44 POS0001 Transaction Start

2023.01.26 17:11:44 POS0001 Transaction Start time 2023.01.26 17:11:44

2023.01.26 17:11:45 POS0002 Transaction Start

2023.01.26 17:11:45 POS0002 Transaction Start time 2023.01.26 17:11:45

Load from data source...

Load from file...

Save raw data to file...

Clear

Stop

Test

Mappings

Variable

Product Code

Mapping name

Text

^.+Product Code (\\d+)

☒ Regular expression

Text is regular expression

☐ Case sensitive

Text is case sensitive

☒ Write to database

RecordDetail.ProductCode

The variable will be written to the database

Apply changes

Cancel

+ New

Mappings

TYPE	NAME	TEXT	REGULAR EXPRESSION	CASE SENSITIVE	DATABASE FIELD
	BeginTransaction	Transaction Start time	no	yes	
	EndTransaction	Transaction End	no	yes	
	GetId	^.+POS(d+),*	yes	yes	
	HeaderEnd	Transaction Start time	no	yes	
	DetailBegin	^.+POS(d+ (?!(Keyed)),*)	yes	yes	
	DetailEnd	Keyed, Product Code	no	yes	
	FooterBegin	Total:	no	yes	
Variable	Operator	^.+Operator (, +), Trans.*	yes	no	Record.Operator
Variable	Transaction ID	^.+Transaction ID (\\d+),*	yes	no	Record.TransactionId
Variable	Total	^.+Total: (\\d+\\,\\d+),*	yes	no	Record.Total
Variable	Product Code	^.+Product Code (\\d+)	yes	no	RecordDetail.ProductCode
Variable	Pos	^.+(POS(d+),*)	yes	no	Record.Pos
Variable	Product	^.+POS(d+ (?!(Keyed),[\\, +]) \\d+\\,\\d+ \\d+\\,\\d+)	yes	yes	RecordDetail.Product
Variable	Amount	^.+POS(d+ (?!(Keyed),[\\, +]) \\d+\\,\\d+ \\d+\\,\\d+)	yes	yes	RecordDetail.Amount
Variable	Price	^.+POS(d+ (?!(Keyed),[\\, +]) \\d+\\,\\d+ \\d+\\,\\d+)	yes	yes	RecordDetail.Price
Variable	ProductTotal	^.+POS(d+ (?!(Keyed),[\\, +]) \\d+\\,\\d+ \\d+\\,\\d+)	yes	yes	RecordDetail.ProductTotal

OK

Cancel

Load a text sample to configure the data source profile

Based on the loaded sample, set the required parameters on the left:

- **Encoding:** pick the correct encoding to ensure your text is readable
- **Line ending:** choose what character(s) represent the end of the line, available options are:
 - CR - carriage return
 - LF - line feed

Ganz CORTROL Global Administration Guide

- CR+LF - both together
- Custom - user-defined symbol or group of symbols

If line delimiter in use is one of the standard non-printable ones (LF, CR or CR+LF) but you are not sure, whichever is used, press the *Detect* button for the software to identify automatically, which delimiter is present in the pre-loaded text. If you know that the provided serial data does not include any standard delimiters, choose the *Custom* option in the drop-down list and define your own delimiting character.



It is crucial that these settings exactly match the source settings. In case of a slight mismatch, your text may still appear readable but the lines may not be split correctly, causing errors in mappings.

Mappings

Mappings are pre-defined character combinations expected in the data flow. Typically, mappings are defined by regular expressions, which are used to extract required values of all sorts from the incoming text: identifiers, keywords, surnames, codes, etc.

Built-in Mappings

Ganz CORTROL server splits the incoming text into transactions. Each transaction has a certain structure, which can be visualized as follows:

```
-BEGIN TRANSACTION

//header starts here
<transaction fields are captured (e.g. POS ID, Cashier Name etc)>
-HEADER END

-BEGIN DETAIL
//item details
<detail1 fields are captured ( e.g. Item, Price, Quantity etc)>
-DETAIL END

-DETAIL BEGIN
//next item details
<detail2 fields are captured ( e.g. Item, Price, Quantity etc)>
-DETAIL END

-FOOTER BEGIN
//footer
<transaction fields are captured (e.g Total )>
//footer ends here

-END TRANSACTION
```

The CAPS text in the visualization defines the marks for the Ganz CORTROL parser that help it to split the text correctly. For each transaction and for each detail it is necessary to mark both beginnings and ends. For the transaction header, it is enough to mark the header end because the transaction beginning serves as the header start. For the footer, it is enough to mark the the place the footer starts, as the footer automatically ends with the transaction. All of these marks are mandatory if you plan to use data channels and databases.



Each incoming serial text stream is split into transactions (each of which has a header and a footer), and each transaction may contain a number of details (transaction items). Further, in databases, you create separate tables for transactions and transaction items.

There are several built-in mappings (existing by default and non-removable) that help you define these BOUNDARIES:


- **BeginTransaction:** specify text that designates the beginning of the data block (transaction)
- **EndTransaction:** the very last data line of the expected data block
- **GetID:** use a regular expression to determine and extract the data ID of each line (skip this if you only

Ganz CORTROL Global Administration Guide

have a single data stream)

- **HeaderEnd:** the text that marks the end of the header section, details are expected after it
- **FooterBegin:** the text that designates the beginning of the footer section, and the end of recurring details
- **DetailBegin:** how each detail (item) starts
- **DetailEnd:** how each detail (item) ends

All of these mappings can be plain text or regular expressions, except for GetID, which must be a regular expression because it must capture variable values.

 Determining the Data ID is important if you have multiple data streams coming from a single data source (e.g., multiple POS terminals). In order to split the text between video channels and/or data channels, you need to set the GetID mapping here, and further define the actual Data ID in the video overlay and in the data channel settings.

For the transaction start and end, you can specify **regular expressions** (regex rule) to define the start/end pattern instead of static text. You can also copy and paste the strings for transaction start and end directly from the sample preview field.

2023.01.26 17:11:44 POS0001 Operator Katherine Troia, Transaction ID 00032161 ¶

2023.01.26 17:11:44 POS0001 Transaction End ¶

2023.01.26 17:11:44 POS0001 Transaction End ¶

2023.01.26 17:11:44 POS0002 walnuts 0.000 ¶

2023.01.26 17:11:44 POS0002 Keyed, Product ¶

2023.01.26 17:11:44 POS0002 Total: 51.06 ¶

2023.01.26 17:11:44 POS0002 Tender type: 1 ¶

2023.01.26 17:11:44 POS0002 Total discounts ¶

2023.01.26 17:11:44 POS0002 Shop ID 00001, ¶

2023.01.26 17:11:44 POS0002 Operator Kath ¶

2023.01.26 17:11:44 POS0002 Transaction End ¶

2023.01.26 17:11:44 POS0002 Transaction End ¶

2023.01.26 17:11:44 POS0001 Transaction Start ¶

2023.01.26 17:11:44 POS0001 Transaction Start time 2023.01.26 17:11:44 ¶

Auto scroll

Transaction begin

Header end

Detail begin

Detail end

Footer begin

Transaction end

Mark the text and right-click to choose the mapping (only for non-regex mappings)

For the non-regex mappings, you can simply highlight the target text in the preview field, right-click it, and choose the mapping to bind the text to.

Custom Mappings


Additionally, you can create any number of mappings of the **user variable** type. These mappings use regular expressions to extract specific pieces of data into a variable, i.e. map variable text into pre-defined value containers. Custom variables have two usage scenarios:

- variables allow you to extract the text and store it in the database. For this, you need to create the database with the desired fields, and then bind mappings to the DB fields.
- E&A event *Variable Condition*. Variables can be used, for instance, to detect exceptions in the cash operation in case the data source is a Point-of-Sale system.

To create a **new variable**, click the + *New* button in the *Mappings* section, fill in the settings on the left and click *Apply changes*. The following settings are available:

- **Type:** variable (cannot be changed)
- **Name:** user-defined variable title
- **Text:** a regular expression that defines what character combination should be extracted into the variable
- **Case sensitive:** enable this if uppercase/lowercase is important (disabled by default)
- **Write to database:** map the variable to a database field for storing and search (if you are not planning to use databases and data channels, ignore this option)

Ganz CORTROL Global Administration Guide

 If you do not have a database yet, you can still create all the required variables at this step. After you add the database at a later point, bind it to the data source that feeds data into this data source profile, and you will have an option to map variables to the database fields.

Test


Lines

Search

LINE	DATA ID	FLAGS	TEXT	VARIABLES
0	0002	Variable, DetailBegin	2023.01.26 17:11:34 POS0002 ice cream 2.000 0.23 0.46	Pos="POS0002", Product="ice cream", Amount="2.000", Price="0.23",
1	0002	Variable, DetailEnd	2023.01.26 17:11:34 POS0002 Keyed, Product Code 09835	Product Code="09835", Pos="POS0002"
2	0001	Variable, DetailBegin	2023.01.26 17:11:35 POS0001 wild rice 2.000 17.30 34.60	Pos="POS0001", Product="wild rice", Amount="2.000", Price="17.30",
3	0001	Variable, DetailEnd	2023.01.26 17:11:35 POS0001 Keyed, Product Code 03305	Product Code="03305", Pos="POS0001"
4	0002	Variable, DetailBegin	2023.01.26 17:11:36 POS0002 borscht 3.000 4.62 13.86	Pos="POS0002", Product="borscht", Amount="3.000", Price="4.62",
5	0002	Variable, DetailEnd	2023.01.26 17:11:36 POS0002 Keyed, Product Code 00652	Product Code="00652", Pos="POS0002"
6	0001	Variable, DetailBegin	2023.01.26 17:11:40 POS0001 fennel 0.000 15.34 0.00	Pos="POS0001", Product="fennel", Amount="0.000", Price="15.34", ProductTotal="0.00"

Test of a configured set of variables

Load some text and then use the **Test** button to **check if your settings work**: if everything is fine with the setup, lines should be detected correctly, transaction start and end marked as such and variables extracted as specified.

 Use the **Test** button to verify your mappings. The variables extracted from the sample text will display on the right. If your regex rules do not work as expected:

- make sure your line ending setting is correct
- verify the regex expressions using a third-party parser (e.g., regex101.com)
- load a new portion of text and test again

Click **OK** to save and close the profile configuration dialog box.

Now, **go back to your data source settings** and specify the newly created data source profile that was missing in the initial configuration. You can use a single data source profile for different data sources. In this way, you link the two together, ensuring that the data received from the data source is passed to the data source profile for further analysis.

Video Overlay


You can put the serial text over the video so that they appear together in the Ganz CORTROL Client application. The text will be also available for simple search in the special tab, Data Sources, in Ganz CORTROL Client.

Under *Configuration*, go to the *Channels* section and pick a channel that needs to be associated with the a data source. Double-click the channel to open it for editing and switch to the *Video overlays* tab. Click the *Configure video overlays* buttons to bring up an additional dialog box.

Here, different kinds of video overlays can be configured. The *Data overlay* element is already present by default - it is the pink frame overlaying your video.

On the right side, you will have the available **settings**. Click the *Change* button and select one of your pre-created **data source** for this channel. If the serial data are currently arriving, you will see the text appear in the frame. Then, adjust the settings on the right to define where and how the text should appear on top of the video stream.


Ganz CORTROL Global Administration Guide



Set up overlay text alignment in the viewport

Use the visual control - the pink rectangle - to specify the **text output area** within the video stream viewport. There are other types of video overlay elements available in the same window, but the one you need is called *Data overlay* and it exists by default, so you do not have to add it. There are also numerical coordinates on the right side of the preview for your reference: you do not have to edit them manually.


Also, note that the visual control cannot be removed from the configuration; if there are no data to display, this element simply will not exist in the Ganz CORTROL Client application. The visual control is only present in this configuration window for your convenience. There is exactly one *Data overlay* element per viewport, meaning that each channel can only have text output from a single data source.

 Make sure the video from the target channel is available before setting up the text overlay in order to ensure correct text placement.

Additional settings:

- **Line count:** set the desired number of text lines to be fitted into the overlay area (default value is 20); this will affect the text font size
- **Timeout:** the amount of time in seconds for every line of data to stay on the screen at maximum (older text will disappear and text will be shifted upwards)
- **Text color:** choose a color for the overlay text from the standard palettes (default is white)
- **Data ID:** data source identifier, if present (leave empty if not used)

In the *Data ID* field, you can enter the source identifier in case the serial data are being **split** between two or more channels; leave the field **blank** if this channel is the only destination for all the data received from the selected data source.

 If there are data from multiple devices combined in a single *Data source* feed so that the text comes from the same IP and port via the same protocol, it is possible to use the **Data ID** field in the *Data source profile* configuration to differentiate between the transactions based on their source identifier and split the text between multiple channels for further overlay.

Example: if the feed contains serial data from multiple Point-of-Sale terminals and their identifiers look like *POSxxxx* where *xxxx* contains the terminal number so that the identifiers are POS0001, POS0002 and so on, the following **regular expression** can be used to extract these IDs: `^.+?(POS\d+).+`

In this case, the *Data ID* field in every channel configuration is to contain the actual POS ID: POS0001, POS00023, POS6592 etc.

Ganz CORTROL Global Administration Guide

When ready, click *OK* to save and close the data overlay dialog box, then click *OK* to save and close the channel configuration window.

Now your textual data from the data provider will be displayed overlaying the video stream in Ganz CORTROL Client and both live view and in the instant/regular archive playback mode in case the corresponding option is enabled in the recording profile for the target channel; also, it will be possible to search through the recorded data.

💡 If you wish the serial data to be available in the video **playback** mode in Ganz CORTROL Client application, make sure to set the *Data stream* to be recorded in the corresponding recording profile.

The overlay text will only be visible in live view and regular/instant playback, and will not be displayed in other views (e.g., smart search). In order to export video from the archive with the text overlay, use MKV file format + VP8 compression + hard or soft subtitles.

If you do not wish to combine the serial data with video, check an alternative method described below. It uses databases to store the serial data instead of the video archive, and provides a dedicated visualization in the form of a data channel.

Time Series Databases

Data received from the data sources can be stored in the databases of a proprietary type, which use the time series database principle. Time series databases are optimized for simple write and search operations, effectively holding a large quantity of the serial data that arrive over time (and are usually written in a series and not injected somewhere in the middle).


Each database (DB):

- is bound to one or more data sources,
- receives data from these data sources as defined by mappings in the data source profile,
- writes the data locally (on the same server with the data source), and
- performs search based on user queries from Ganz CORTROL Client and returns the requested information.

💡 You can add any number of databases but they will only operate when you have data channels, which are subject to [licensing](#).

Create New Database

To add a new database via Ganz CORTROL Console, make sure you are in the *Configuration* section > choose *Data Sources* on the left > click the down arrow next to the + *New..* button and choose the *New time series database* option.



Add a new database via top panel in the *Data sources* section

In the new DB dialog box, fill in the database settings.

In the *Details* tab:

- **Title:** user-defined database name that will appear in Ganz CORTROL Client

Ganz CORTROL Global Administration Guide

- **Enable:** if marked, the database will be available for write & read
- **Maximum number of days:** entries older than the specified number of days will be removed
- **Writable interval:** the maximum age of a new entry, older entries will be discarded

The data are normally written to the database real-time. However, if there are delays in the synchronization due to network availability issues or other reasons, you may want to write older entries. For this purpose, each database has a limited **writable interval**, during which it will accept new entries with non-real-time timestamps. Keep this interval shorter if you prefer a faster DB, and set a longer interval if you know that some of the data may arrive with a significant delay (e.g., from remote locations). Default value: 1 day, max value: 99 days.

Time series database Gastronome&Boulangerie*

Time series database

Details

Details*

Membership

Database

Title

Gastronome&Boulangerie

Time series database title

☒ Enable

Enable or disable the database

Maximum number of days

365

Maximum number of days to keep in the database (1..366)

Writable interval

01d.00:00:00

The maximum amount of time during which the data can be written to the database. Default interval is 1 day

Apply OK Cancel

Database settings in the Details tab

In the *Membership* tab, you can put the database into one of your **visual groups** for a more convenient presentation in Ganz CORTROL Client.

After you have set the general settings, switch to the *Database* tab. Here, you need to create the **database structure** using the following guidelines:

- each database can have **2 (two) tables**
 - the first table stores so called transactions (larger chunks of information the serial data are broken into)
 - the second table holds transaction items (repetitive individual elements of the transaction)
- each of the two tables can have up to **32 fields**, for example:
 - transaction fields (main table): POS ID, door ID, transaction ID, operator's name, total, etc.
 - transaction item fields (details table): product ID, product name, amount, subtotal, etc.
- fields that have repetitive values from a fixed list (e.g., operator's name or item name) can have **reference tables**. For such fields, their values are replaced by keys in the main table, while longer textual values are kept in the reference table, speeding up the DB operation.

When you create a new DB, it offers you to create the **main table** first:

- **Title:** user-defined table name that will appear in Ganz CORTROL Client. The title may contain a wide range of characters: non-Latin alphabets (e.g., Cyrillic letters), white spaces, and special characters.
- **Alias name:** internal table name that may only contain Latin letters [A-Za-z] and numbers [0-9].

After changing the settings, click *Apply changes*: your table name will appear in the DB structure on the right.

After that, use the down arrow net to the + *New field* button on the right to add the second table (details table) using the same logic. After you have done that, or if you only plan to have one table, use the + *New field* button to **add fields** to both tables:

- **Title:** user-defined field name that will appear in Ganz CORTROL Client. The title may contain a wide range of characters: non-Latin alphabets (e.g., Cyrillic letters), white spaces, and special characters.
- **Alias name:** internal field name that may only contain Latin letters [A-Za-z] and numbers [0-9].

Ganz CORTROL Global Administration Guide

- **Data type:** choose if the value will be stored as text/integer/long/double. Textual fields can have reference tables.
- **Create reference table:** for text fields only; mark this option if you know that the data field value belongs to a finite list of values (e.g., operator's name). Do not use this option if the field value is [mostly] unique.

Time series database Gastronome&Boulangerie

Time series database

Details

Membership

Database

Database

Database schema

Edit table details

Table type

Main table

Table type

Title

Cheque

Table display title

Alias name

Transaction

Alias name must contain only latin and numeric characters

Apply changes

Cancel

+ New field

Fields

Cheque (Transaction: Main table)

Operator (Operator: Text)

Pos (Pos: Text)

Transaction Id (TransactionId: Text)

Total (Total: Double)

Transaction Item (TransactionDetail: Detail table)

Product (Product: Text)

Product Code (ProductCode: Text)

Amount (Amount: Double)

Price (Price: Double)

ProductTotal (ProductTotal: Double)

Apply

OK

Cancel


An example of a time series database structure: DB will accept transactions and transaction items from a POS machine

Note that you do not have to describe everything you expect to receive from the data source, but rather just the values you want to store and search in Ganz CORTROL Client.

After having created all the tables and all the fields, click *OK* to save and close the dialog window. The newly created time series database will appear in the list in the *Data Sources* section. Note that the database will only appear in the *Monitoring* section of Ganz CORTROL Console and in Ganz CORTROL Client after there are some actual data written to it. For this, you need to create at least one data channel and link it to the same data source.

Data Channels

Data channels are a way to visualize the serial data received from data sources without combining it with the video in one viewport. Thus, you get your data displayed neatly in a separate viewport next to the video channels.

 Data channel must be paired with a time series database in order to operate!

Create Data Channels

To create a new data channel in Ganz CORTROL Console, go to the Data Channels section under Configuration. On the top panel, click the + New Data Channel button

Ganz CORTROL Global Administration Guide

Data channel POS0001

Data channel

Details

Members

Membership

Permissions

Details

Title

POS0001

Data channel name

Data source

POS emulation (235)

Change...

Data source

Data ID

0001

Data ID

Main stream recording configuration

☒ Continuous recording (32)

Change...

Recording configuration assigned to the main video stream (includes supplementary streams by default)

Main stream storage

POSdata

Change...

Target storage for the main stream recording

Recording identifier

989AED55-B3E8-4778-B026-DAAEF63B0B43

Unique recording identifier of the current channel

Apply

OK

Cancel

Data channel settings: source and recording

In the *Details* tab, fill in the following settings:

- **Title:** user-defined data channel name that will appear in Ganz CORTROL Client
- **Data source:** the source of the text to be displayed
- **Data ID:** the actual identifier of the data stream extracted by the mapping **GetID** (defined in the data source profile)
- **Main stream recording configuration:** how the data will be recorded (main stream only)
- **Main stream storage:** destination storage

Not that it is mandatory to fill the Data ID field if your data source has the GetID mapping defined. When the data source parser encounters a GetID variable value, it searches across all data channels for the target data channel and writes the corresponding data to the database. If the GetID mapping is defined but there is a data channel with an empty Data ID field, this data channel will not have any data fed to it.

Data channel POS0001*

Data channel

Details

Members*

Membership

Permissions

Members

Search

Selected members

TITLE	ID	TYPE
<div>Office_I</div>	(130)	Channel
<div>Cashier</div>	(189)	Channel

Remove

Available members

TITLE	ID	TYPE
<div>Zavio D6330 on 192.1...</div>	(132)	Channel
<div>Zavio B6220 on 192.16...</div>	(134)	Channel
<div>Zavio P6210 on 192.16...</div>	(138)	Channel

Add

Apply

OK

Cancel

Make video channels members of your data channel in the *Members* tab

Ganz CORTROL Global Administration Guide

In the *Members* tab, you can **pair** the data channel with two types of resources:

- **channels:** one or more video channels that will pop up together with the data channel when you search across the database and get results from this data channel
- **user buttons:** paired [user buttons](#) will appear in the data channel viewport, next to its name, so that you can click them to trigger the related event

By making video channels members of the data channel you facilitate the textual search in Ganz CORTROL Client. For example, if your data channel is a POS terminal, It would make sense to pair data channels to video channels that face the cashier's desk.

Membership	
Search	
Selected groups	Available groups
TITLE	TITLE
TYPE	TYPE
👁 Riga	👁 Indoor-Riga
Visual group	Visual group
🖨 Store-001	👁 Outdoor-Riga
Data channel group	Visual group
Remove	Add
Apply OK Cancel	

Put data channels into groups and visual groups

In the *Membership* tab, similarly to the regular channels, you can put your data channels into groups (for permission handling) and visual groups (for grouping on the Ganz CORTROL Client side).

Finally, in the *Permissions* tab, just as for any other resource, you can define access permissions for your users and user groups.




For efficient permission management, use groups for both resources and users.

Data channels are similar to video channels, hence the **permission list is very similar:**

- **View live video:** permissions related to the live streaming (Live tab in the Ganz CORTROL Client application)
 - **View live external data:** data channels essentially consist of external data, so this permission allows access to the live view of the data channel
 - **Export snapshots from live:** allows the user to save snapshots by clicking the corresponding button in the live viewport containing the data channel
- Advanced archive management: administrative actions
 - **Back up archive:** access this channel via archive backup wizard
 - **Delete archive:** remove parts of the archive via Ganz CORTROL Client application's Playback mode (this action must be [additionally enabled](#) in the [storage management](#))
 - **Protect archive from deletion:** allows marking pieces of the archive, protecting them from removal, via Ganz CORTROL Client application's Playback mode
 - **Remove archive protection:** remove protection marks from the parts of the archive via Ganz CORTROL Console [application's Monitoring section](#) (*Archive statistics* > *Protected intervals*)
- **Search in database:** allows Ganz CORTROL Client users to search across the time series database recordings (data recordings) for this channel via Ganz CORTROL Client application's Playback mode
- **Video playback:** access this channel via Playback mode in Ganz CORTROL Client (either full access or restricted interval, not both at a time)
 - **Access archived external data:** channel playback
 - **Export video:** allows to export parts of the data channel's archive in a video container
- **Restricted video playback:** same as for the video playback but considering the *Recent archive interval* setting value in the storage settings


Ganz CORTROL Global Administration Guide



Available permissions for the data channels

Usage Tips for Data Sources and Data Channels

There may be various flexible scenarios for data channels. Typically, those are used for POS terminal representations, but the data source/channel feature is NOT limited to POSes.



Data sources/channels may be used for storing data from parcel tracking, door locks with card readers, ANPR numbers, industrial weighing, etc.

1. In the multi-server environment of Ganz CORTROL Global, you can create multiple data sources, each belonging to a different server, and then bind them to the databases with the same name.
 - From the point of view of the data storing, each server will have its own data source and data channel, and its own database but with the same data structure.
 - From the Ganz CORTROL Client point of view, the search will be across a big single database, making it transparent for the user.

This approach is good if your data sources and data channels belong to the same collection, and the database name covers them all.

Example: in a chain store there are 10 small stores, each one has a small recording server and a POS machine attached to it. You need to create:

- 10 data sources (for each of the POSes),
- 1 data source profile (because all POSes are the same),
- 1 database (local copies will be created on each Ganz CORTROL Recorder automatically),
- 10 data channels to visualize and allow search across all servers.

For the Ganz CORTROL Client users - managers who run POS queries - all data entities will be transparent, for they will just request the information from the DB.

2. Similar scenario is possible within a single server.

Configuration Import and Export


You might want to reuse existing data source configurations because the data sources may be the same in other installations. Ganz CORTROL Console offers a way to import and export the configuration of the data source profiles and related time series database structure.

Ganz CORTROL Global Administration Guide

To export items:

- To export a **database**: click the database in the list in the *Data sources* section, and click the *Export* button on the top panel.
- To export a **data source profile + database**: click the profile in the list in the *Data sources* section, and click the *Export* button on the top panel.
- To export a **data source profile** without the database: click the profile in the list in the *Data sources* section, and click the *Export* button on the top panel, then remove the selection from the database.

In the small window that pops up, make sure the desired items are chosen, then click OK to proceed. You will be offered to save the configuration into a *.json file using the standard Windows *Save As..* dialog.



Export both the data source profile and the mapped database

To **import** items: in the Data sources section, click the down arrow next to the + New item button, and choose the *Import* option. You will be offered to locate the *.json file that contains the configuration using the standard Windows *Open file..* dialog. Click *OK* to load the target file into your Ganz CORTROL server configuration.

In the small window that pops up, choose the desired items, then click *OK* to proceed: the items will appear in the *Data sources* section and you will be able to edit them as usual.

Note that you will need to create data sources and data channels to complete the setup.

Ganz CORTROL Global Administration Guide

12.12 Reports

Ganz CORTROL Console application provides an opportunity to send automatic reports. There are two types of them:

- Reports based on the counter data, which has been recorded with the video stream(s). Depending on the collected information context, these reports can be used, for example, to estimate the average number of customers during specific hours, compare the number of passing cars to the number of trucks etc. Counter information is collected from Ganz CORTROL video analytics, camera-side counters (for certain manufacturers) and [software counters](#).
- Reports based on the [facial recognition](#) (FR) module data. These include the counted detections (by tag) and miscellaneous estimators (age, gender, temperature, sentiment, etc.).

The report configuration process is similar to the manual procedure of reporting in the Ganz CORTROL Client application, with the difference that here the settings are defined once and then are used by the Ganz CORTROL servers for automatic report generation.

There are three report types: **bar**, **line** and **pie** diagram. Regardless of the chosen type, all reports are based on the **counters** and have configurable report interval and days and times of interest. Counter values are compared for the given period and with the specified scale, and the results are then reflected in the chart of the selected type. Reports can be configured to be created **automatically** on a **daily**, **weekly** or **monthly** basis and then **emailed** to the specified email address.



Regardless of the report settings, the report will be emailed after the selected report interval has ended.

Example 1: the report interval is previous day with time filter set to 8AM to 6PM. The report will be emailed next day 12:01AM.

Example 2: the report interval is previous week with only working days selected (weekends deselected). The report will be emailed 12:01AM next Monday, i.e., when the week is over.

Prerequisites

Reporting in Ganz CORTROL Console is primarily aimed at automatic report sending via email. In order to achieve this, you need to **configure** a [mail server](#) for the emails to be sent through, according to the steps explained in the [corresponding section](#) of this document. You can do this prior or after the report setup. If you need a one-time report for a custom time interval, you are welcome to use the reporting function in the Ganz CORTROL Client application.

For a counters report to be created successfully, there must be some counter data present in the database. You can use Open VCA, camera-side VCA (for certain manufacturers) or [software counters](#). Open VCA setup in Ganz CORTROL is described in a separate document provided by demand.

For the FR report to be created, you must have at least one channel being analyzed by [facial recognition](#) module for the specified period, and the target FR service must be connected.

Report Configuration

In order to start report setup, go to the *Configuration* section of Ganz CORTROL Console and choose *Reports* from the menu on the left. Press the + *New report* button on the top panel to bring up the report configuration dialog box. There are two options: **new counters report** and **new external service report**. These two types differ slightly.

Reports Based On Counters

This type of report is based on camera-side VCA, Open VCA, or [software counters](#). The configuration options are similar to those in Ganz CORTROL Client when you create a graph in the *Reports* section.

Ganz CONTROL Global Administration Guide

Report: DailyCustomers*

Report

Details

Counters

Title

DailyCustomers

Reprot title

Report interval

PreviousDay

Reprot interval

Week days filter

☒ All days ☒ Sun ☒ Mon ☒ Tue ☒ Wed ☒ Thu ☒ Fri ☒ Sat

Week days filter

Time fitler

8:00:00 AM > 6:00:00 PM

Time filter

Chart type

☒ Bar chart ☐ Line chart ☐ Pie chart

Chart type

Aggregation by

Hour

Aggregation by

OK Cancel

Edit counters report dialog box

Specify the **reporting criteria** in the *Details* tab; the following settings are available:

Setting	Description	Default Value
Title	User defined title for the report	[empty]
Report interval	Time interval to be represented in the report; can be previous day, week or month	Previous day
Week days filter	Days of the week to be included in the report (e.g., ignore weekends)	All days
Time filter	Target audit interval to be analyzed for each of the selected days	12AM > 12AM (whole day)
Chart type	Diagram type: bar, line or pie	Line chart
Aggregation by	Scale factor for the target diagram - results can be presented for months, weeks, days, hours or minutes (also, the data can be aggregated by counters if the selected chart type is pie diagram)	Day
Value	Counter value to be taken for each report time interval on the X axis (day etc.): <ul style="list-style-type: none"> Absolute: actual counter value Relative: difference compared to the previous interval Average: arithmetic mean of the given interval Minimum: minimal value during the given interval Maximum: maximal value during the given interval 	Absolute
Sum counters	Choose whether you want each counter to be represented separately or all counters are to be added up (for bar and line type diagrams only)	Disabled
Show labels	Display value labels on the chart	Disabled

Ganz CORTROL Global Administration Guide

File type	Choose whether you want the report to be in PDF or CSV format	PDF
Automatic	Generate the report and send it automatically to the specified email	Disabled
Mail server	A pre-configured SMTP server to be used for email sending (the setting is revealed when automatic report sending is enabled)	[none]
To	Email recipient the report to be emailed to; enter exactly one valid email address here (the setting is revealed when automatic report sending is enabled)	[empty]

Next, switch to the *Counters* tab: here, you can select the required counters from the list.

The screenshot shows a window titled 'Report DailyCustomers*'. On the left is a sidebar with 'Report', 'Details', and 'Counters' (selected). The main area is titled 'Counters' and contains a list of counters with checkboxes. The 'enter' counter is highlighted in green. The 'OK' and 'Cancel' buttons are at the bottom right.

The list of counters available for report

All the counters available in the system are listed here - from Open VCA, camera-side VCA (for certain manufacturers) and [software counters](#) as well - in case their data are present in the database.



For the exact list of supported camera-side VCA counters, kindly contact our support engineers at cortrol@cbcamerica.com.

When ready, hit the *OK* button in the bottom to save the report configuration based on your selected criteria. To edit and remove reports, use the corresponding buttons on the upper panel.

Reports Based External Service Data

This type of report is based on the data received from [external services](#) (specifically, **detections and attributes from the facial recognition** module instances). The configuration options are similar to those in Ganz CORTROL Client when you create a graph in the *FR* section. The logic is analogous to that of the counters reports, yet the settings are a bit different.

Specify the **reporting criteria** in the *Details* tab (other settings like target week days are available in the *Filters* tab). The following settings are available:

Setting	Description	Default Value
Title	User defined title for the report	[empty]
Report interval	Time interval to be represented in the report; can be previous day, week or month	Previous day
Chart type	Diagram type: bar, line or pie	Line chart

Ganz CONTROL Global Administration Guide

Group by	Main report values (targets): can be tags, temperature, age, sentiment, or gender estimation	Tag
Aggregation by	Results can be aggregated by months, weeks, days, hours or minutes (for bar and line type diagrams only)	Day
Sum values	Choose whether you want each target group to be represented separately or all values are to be added up (for bar and line type diagrams only)	Disabled
Show labels	Display value labels on the chart	Disabled
File type	Choose between PDF or CSV	PDF
Automatic	Generate the report and send it automatically to the specified email	Disabled
Mail server	A pre-configured SMTP server to be used for email sending (the setting is revealed when automatic report sending is enabled)	[none]
To	Email recipient the report to be emailed to; enter exactly one valid email address here (the setting is revealed when automatic report sending is enabled)	[empty]

The choice between absolute/relative/min/max/avg value is not present here; all values are **relative**, i.e., the chart reflects the value change since the previous aggregation interval.

Next, switch to the *Channels* tab: here, you can select the target channels. The report will include the recognition data from the specified channels.

On the *Filters* tab, you can limit the report sample range by (de)selecting various options. The filters include days, time of the day, and attributes from the external service detections:

- **Tags** from FR
- Temperature range from the readings that were received by FR (works for certain camera integrations; please refer to our for the exact vendor list)
- **Age, gender, and sentiment** estimators
- **Week days:** select **days of the week** that you want to be included in the report (e.g., ignore weekends) (all days are selected by default)
- **Day time interval:** choose the target **audit interval** to be analyzed for each of the days in the selected report interval

When ready, hit the *OK* button in the bottom to save the report configuration based on your selected criteria. To edit and remove reports, use the corresponding buttons on the upper panel.


Report Preview

After you have created a report, you can check how it will look like by using the *Preview* and *Test* buttons on the upper panel. The **preview** button will generate a report and display it on your screen; the **test** option will create a report and email it to the specified address in PDF format immediately. In either case, the report preview will be based on its configured time interval, so, if you get an empty report, make sure that counter data are present for the previous day, week or month, whichever specified.



When you have created a new report and wish to test it, please wait about 10-30 seconds before pressing the *Test* button: this time is required to retrieve the counter information from the database.

Ganz CORTROL Global Administration Guide



Report preview

On each diagram, the **horizontal axis** (X) represents time in the specified scale, and the **vertical axis** (Y) reflects counter values. The counter values for each time interval are calculated based on the selected setting and can reflect absolute, relative, average, minimum or maximum counter value for the given interval. In the **pie diagram** type, each sector can represent either a time interval or a counter, depending on the aggregation setting parameter.

Ganz CORTROL Global Administration Guide

Each chart also contains a **legend** that provides information about colors used in the diagram:

- if you have selected to analyze every counter separately, each counter will be represented with its own color and the legend will reflect counter titles
- if you have chosen to sum the counter values:
 - bar diagram will have just one column for each interval, every column consisting of specified counters and its total height reflecting the total
 - line diagram will contain graphs for each individual counter and the total
- pie chart will reflect the counter sum for each time interval if aggregation by time intervals is chosen, so the legend will contain timestamps; if aggregation by counters is selected, the pie will reflect the proportion of the counter values for the whole selected audit interval

Apart from the diagram itself, each report in PDF format will also contain a table with the reference counter values.

Report Status Monitoring

Report execution status can be tracked from the *Monitoring* section of Ganz CORTROL Console, by choosing *Reports* in the menu on the left.

Monitoring	TITLE	STATUS	REPORT STATUS	EXECUTION TIME	NEXT EXECUTION TIME	STATUS TIME	INFORMATION
DailyCustomers	Normal	NotExecuted				1/5/2018 2:02:38 PM	
WeeklyCustomers	Normal	NotExecuted			1/7/2018 12:00:00 AM	1/5/2018 2:02:38 PM	

Recently added, 1

Recently updated, 0

Critical, 0

Report status

If a report has been sent at least once (by schedule, not as a test), the last execution time is shown here. For the reports that are currently set to be emailed automatically, the next (scheduled) execution time is also displayed.


Math Behind Counters

Different **counter value** settings will produce different results, so you need to understand which value to select in order to get the appropriate result. Below, you will find some details on how **these values are calculated** inside Ganz CORTROL.

For each and every selected interval, five counter values are calculated: **absolute, relative, min/max, and average**. The minimal internal interval is equal to **1 (one) minute**; no matter how the counter value changes during that minute, these five values are recorded into the database. For longer periods (hours, days, etc), these values are calculated using the intermediate results.

In the snapshot below, there is an example of how the counter value might change during one minute, and what values are calculated based on these changes.

Ganz CORTROL Global Administration Guide



An example of counter changes within report interval with corresponding peak values

For correct report results, it is also essential to keep in mind whether the counter in question is increment-only, or if it is both incremented and decremented based on some events.

1. Absolute

Absolute counter value is its exact value at the **end** of the measurement period. E.g., If the interval is 1h, the absolute counter value is equal to the absolute counter value for the last minute of that hour.

Usage examples:

- increment-only: estimate the total people flow, e.g., incoming customers
- increment/decrement: current number of people in the zone/building

2. Minimum and maximum

Here, Ganz CORTROL simply takes the min and max value from the aggregation interval. For longer intervals, min/max are selected from the list of min/max of smaller periods (regular min/max function).

Note that min/max has nothing to do with absolute value: the counter value may peak inside the aggregation period with the total change (absolute value) being zero. The latter, of course, is only possible for the counters that are both incremented and decremented over time. For increment-only counters, max value will be equal to absolute value.

3/4. Relative

Relative counter value is the sum of all relative changes for the given period, or, even simpler, the difference between the current absolute value and the previous one. Relative value shows how much the counter value has changed for the given period compared to the previous one.


5. Average

Average counter value is counted as weighted arithmetic mean, with the duration serving as weight.

Simple arithmetic mean would not be as useful as it does not take into account the value duration.

Consider the two examples in the snapshot below: two counters have the same absolute and relative values for the given period. Their arithmetic mean would be very similar (25 vs 26.6), while it is obvious that the first (green) counter value stayed higher for a longer period, and this should be taken into account.

Ganz CORTROL Global Administration Guide



Example of two counters with the same absolute values and different average

Usage example: average number of customers in the store per hour, average check total for estimating effectiveness.


Audit Reports

Details

You can aggregate Audit events and send Audit reports to the dedicated e-mails. To do so, go to:

1. Ganz CORTROL Console -> Configuration -> Reports
2. Click on the Arrow down symbol besides the + New counters report button and select the New audit report from the dropdown.
3. Inside the new pop-up window, add a meaningful Title
4. Set a Minimum report interval (5 minutes—100 days): Reports will be sent if something happens and the previous report was sent before the current interval.
5. Mark the Enable empty report checkbox to get reports even if no Audit events happened at the provided time interval.
6. Set the Empty report interval (5 minutes—100 days) to receive system health confirmation within the provided interval.
7. Mark the Automatic checkbox if you want reports to be sent automatically
8. Select the connected Mail server to send e-mails. Review the corresponding section of this manual to learn how to add an e-mail server to the Ganz CORTROL.
9. Add an e-mail address to receive reports.

Ganz CONTROL Global Administration Guide



Audit Report Details tab


Audit Events

Several categories of *Audit event* types can be monitored via *Audit reports*. *Audit events* include:

- Server events
- User Events
- Uncategorized


You can expand each category by clicking on the *Arrow* symbol to review and include preferred *Audit event* information in the aggregated *Audit report* by marking checkboxes before Event types. You can also include all the available *Audit events* by marking the checkbox at the top of the *Audit event* list.

Ganz CONTROL Global Administration Guide



Audit events window example.

To test your setup, confirm your settings with the *OK* button, Select your *Audit report* from the list, and click the *Test* button from the top panel. You should receive your *Audit report* shortly after.



Troubleshoot

If you do not receive any reports, check if:

- The mailing server information is correct, and the service is still available (for example, Gmail can't be configured as the mailing server starting with January 2025)
- You have *Audit events* to report, or an *Empty report* is enabled, and the report interval is completed.
- *Report interval* is greater than 5 minutes and less than 100 days
- The *Automatic* checkbox is marked.

12.13 Manage Mail Servers


Several Ganz CORTROL components require an SMTP server in order to be able to send emails to a specified address. Specifically, these are:

- email sending [actions](#) in [E&A](#) and automatic [reports](#)
- [two-factor authentication](#) on top of the regular login

A **pre-configured mail server is required** for these features to be operational.


You can add one or multiple different outgoing SMTP servers to send notification emails through them. You can use/set up your own SMTP server, if your organization already has one and/or it is affordable for your organization; alternatively, free Internet services can be used for this purpose. Note that there are not any default (pre-configured) mail servers.

After adding a mail server configuration, you can verify it by using the *Test* button in the upper panel.

 SMTP servers provided by popular free services and/or ISPs usually have limitations on the number/frequency of emails going through them daily. Make sure you check with SMTP service provider to learn about this.

Mail Server Setup

To access mail server setup via Ganz CORTROL Console, open the *Configuration* section and select *Mail servers* from the menu on the left. Click the + *New mail* server button on the upper panel or double-click an existing mail server from the item list to open the configuration dialog box.

 Prior to Ganz CORTROL version 1.7.0, mail server configuration was accessible via *Events & Actions* section of Ganz CORTROL Console.

Mail server Gmail SMTP*

Mail server

Details

Details

Title

Gmail SMTP

Mail server name

Host

smtp.gmail.com

Host name or IP address

Port

587

Port number

Username

some.account@gmail.com

Username

☒ Set password

.....

Password to log into the server

Security mode

TLS

Security mode

OK


Cancel

SMTP server settings

Ganz CORTROL Global Administration Guide

Setup here is similar to configuring an email client. The table below contains detailed information on the available settings.

Setting	Description	Default Setting
Title	User-defined mail server name	[empty]
Host	Outgoing SMTP server IP address or hostname	[empty]
Port	Outgoing SMTP server port; common ports are 25 and 587, and 465 for encrypted connections	0
Username	Enter valid user account details to log onto the target SMTP server	[empty]
Password	Enter valid user account details to log onto the target SMTP server	[empty]
Security Mode	Logon authentication type according to the SMTP server configuration requirements (STARTTLS, SSL (TLS version 1.2), or no security)	none
Sender	Email address on whose behalf emails will be sent	[empty]
Aggregation* Count	Max number of notifications to be aggregated into a single email	10
Aggregation* Time	Max time period in seconds during which notifications are collected together to be sent in a single email	10

 *Email aggregation can be used to accumulate alert notifications and send them in bunches rather than one at a time. This decreases SMTP server load and does not 'spam' your notification inbox, making it easier to search and analyze alerts, and is thus especially useful if the number or frequency of events is high.


Maximum [time/number of occurrences] in this context means that it will not be exceeded under any circumstances. The actual time or number of occurrences may be either max or less - depending on which aggregation parameter is triggered first.

Example: aggregation time is set to 60 seconds and aggregation count - to 15. If the notifications arrive frequently, and 15 items are collected in under one minute, the email will be sent immediately. If there is just 1 or 2 notifications but 60 seconds have passed, an email will be sent, too.

Click **OK** to save mail server settings; newly created configuration will appear in the item list. Your mail server is now ready to be used for sending notifications and reports.

Verify Mail Server Configuration

Use the **Test** button in the upper panel to verify your mail server configuration.



Test mail server configuration by sending a test email

To perform the test:

1. Choose one of the Ganz CORTROL servers to send the email from

Ganz CORTROL Global Administration Guide

2. Enter the test recipients's email address
3. Enter the email subject and body
4. Click OK

You will see a popup window with the test result and error text, if any.



Some mail servers require additional settings to be changed on the server side to allow third-party applications to send emails through their SMTP service. For example, Google security requires that you log into your account via a browser using the server that will be utilizing the SMTP service in order to enable account access from that computer.


If you can successfully use SMTP settings to send emails from the same computer, Ganz CORTROL will also have no trouble sending your notifications.

12.14 Manage GSM Modems

Apart from email servers, Ganz CORTROL supports GSM modems. These modems with your pre-installed SIM cards can send and receive SMS (short messages), which can be used for the following scenarios:


- send custom SMS notifications from Ganz CORTROL servers
- use SMS verification for 2FA
- receive SMS to trigger internal Ganz CORTROL events

If the modem doesn't work in, please try with a third-party app/utility. If the external utility does not work, Ganz CORTROL servers will also be unable to work with that modem. Microsoft offers a free tool called Microsoft Messaging, which you can get in Microsoft Store.


 Modem hardware may apply delays (60+ seconds) for SMS receiving. Please make sure that resulting SMS read frequency from the mobile operator is acceptable for your scenario.

Connect and Set Up Modems


First, plug in your GSM modem as instructed in its manual - usually, modern devices use a USB connector and a virtual COM port. The modem should appear in the Windows Device Manager - if the drivers are installed automatically, you will see it appear under *Ports > Modems*, occupying one or several serial ports. Check the **modem properties** to view the occupied port. Some of the ports may be hidden; you can view the hidden entries by clicking the Device Manager main menu > *View > Show hidden devices*. Normally, you will not have to do this, as active (non-hidden) modems will be used in Ganz CORTROL.



Modem properties in the Windows Device Manager

 If you are unplugging the modem, make sure to connect it to the same USB port next time; otherwise, the modem may use a different COM port, and will stop working because the Ganz CORTROL Console settings cannot be updated automatically. If you do insert the modem into a different physical port, make sure to check the new port and re-select it in the modem properties in Ganz CORTROL Console.

Then, in Ganz CORTROL Console, in the *Configuration* section, choose *GSM Modems* on the left. In the upper panel, click the + *New GSM modem* button to open the dialog box, and enter the modem settings. All COM parameters must match those on the modem side.



Ganz CORTROL Global Administration Guide

New GSM modem configuration

Available settings:

- **Title:** user-defined modem name that will appear across Ganz CORTROL Console
- **Server:** Ganz CORTROL server that has the modem hardware attached to it
- **COM port:** choose the port used by the target modem
- **Baud rate:** must match the modem setting
- **Data bits:** must match the modem setting
- **Stop bits:** must match the modem setting
- **Parity:** must match the modem setting
- **SMS mode:** choose TEXT mode unless you need (and know how) to use special characters that are only supported in PDU mode (GSM7 encoding only)
- **SMS encoding:** [GSM7](#) (special ASCII for GSM) or USC2 (special version of Unicode for GSM)

For correct COM port, check the modem port under *Modems* in the Device Manager as displayed above; depending on the modem driver, there may be multiple ports, including hidden ones. Some of these are usable by Ganz CORTROL, and some may be auxiliary: after creating the modem, use the *Test* button in the upper panel to test the connection and check if you have picked the right one.



If you use GSM-7 (ASCII) and your message shows full of ? of other odd characters, try switching to USC2.

After filling in the settings, click *OK* to save: the newly created modem connection will appear in the list. Click the *Test* button to verify the connection: if the status retrieval fails, try selecting a different COM port. If none of the ports work, ensure that the serial port settings (baud rate etc.) match the settings on the modem side exactly.

The *Test* dialog box has two functions:

- modem status: verified automatically
- test SMS: enter phone number and text to send the message



Ganz CORTROL pings the modem every 30 seconds for the status update, and every 3 seconds for new messages. If you experience delays in message reception, these are most probably introduced by the modem hardware, and are not related to Ganz CORTROL server setup. Use the modem with 3rd party tools and compare the delay to verify.

To test against a specific phone number, enter the phone number - either in the international format (including the country code using either + or 00 prefix), or without the country code if the number is local for the SIM operator. Click *OK* to attempt sending the short message. If the number is incorrect, you will get a failure notification. If everything is fine, you will get a success message, and the message will arrive shortly (usually, instantly) to the target phone.




Wherever you need to enter a phone number in Ganz CORTROL Console, we recommend that you do it in the international format: first + (or 00), then the country code, and then the number itself. The number must not include any spaces, dashes, or parentheses.

Example:


- number in the local format: (555) 555-0155
- the same number converted into the international format: +15555550155

Ganz CORTROL Global Administration Guide




Modem status check and test SMS

The billing for the messages will be as per your SIM card plan.

 **CBC AMERICA LLC** is not responsible for any losses due to additional mobile operator fees. It is solely your responsibility to keep track of and control the message flow and the event frequency in case the SMS is sent based on an E&A event.

If you respond to that test SMS, the modem will receive it and you will see it appear in the modem status summary under *Last messages*. The exact time of the message reception may vary depending on the modem hardware and settings; Ganz CORTROL does not introduce any additional delays.

Important! Make sure your modem does not go to sleep. To do this, go to the Windows Device Manager, find your modem under Modems, and check the *Power Management* tab for related settings. Do not allow the PC to turn OFF the modem to save power.



Modem power settings in the Device Manager

Ganz CORTROL Global Administration Guide

Configured modems will appear in the corresponding tab of the *Monitoring* section.

Receive SMS

Once you add a modem, you will be able to receive SMS and use it for event triggering on Ganz CORTROL servers.

Modem Events

To create an SMS event, switch to the *Events & Actions* section of Ganz CORTROL Console, and choose *Events* on the left (you can also create new events right from the [E&A Configurator](#)). In the top panel, click the + *New event* button, then select the *SMS message received* event type in the dialog box, and then fill in the rest of the settings:

- **Title:** user-defined event name
- **Source:** existing modem hardware to accept the message
- **Phone:** sender's full phone number*; leave empty for any number
- **Text:** SMS text to trigger the event, case-sensitive; leave empty for any text to trigger the event
- **Regular expression:** enable if you wish to evaluate the incoming text with **regex**, e.g., use placeholders

*The phone number must be in the **international format** (with leading + or 00 and a country code) for ALL numbers, even local ones. The event will not work properly without the country code.

Event TELIC AG SMS message received*

Event

Details*

Details

Event type

SMS message received

Change...

Select event type from list of available event types

Title

TELIC AG SMS message received

Event name

Source

TELIC AG

Change...

Event source

Phone

+37129843

Phone number

Text

stop

Message text

☐ Regular expression


When checked, text is processed as regular expression

Apply OK Cancel

Event triggered by incoming SMS

Click *OK* to save and close the dialog box. The newly created event will appear in the list.

Once you have created the event, you can use it to build event rules in the [Event & Action Configurator](#), as usual. For example, you can send SMS to trigger [start/stop recording](#), to [open doors](#) and gates, or to create alarms and bookmarks.



Please note that modems may introduce **delays** when receiving SMS due to periodic SMS reading approach (messages are received from the mobile operator at certain intervals). Please test your modem hardware and ensure that the resulting SMS reception frequency is acceptable for your event scenario. The Ganz CORTROL software does not add any delays and is not responsible for the delays on the hardware side.

Send SMS

Ganz CORTROL Global Administration Guide

Similarly, modems can send SMS to the pre-configured phone numbers. Ganz CORTROL servers can utilize this in two scenarios:

- send messages based on the triggered events - E&A **actions**
- send codes via SMS for two-factor authentication (**2FA**)

Note that you cannot create actions or 2FA notification providers without actually having a working modem, so make sure to add and test the modem first.

Modem Actions

To create an SMS sending action, switch to the *Events & Actions* section of Ganz CORTROL Console, and choose *Actions* on the left (you can also create new actions right from the [E&A Configurator](#)). In the top panel, click the + *New action* button, then select the *Send SMS* action type from the *Notifications* group in the dialog box, and then fill in the rest of the settings:

- **Title:** user-defined action name
- **Source:** existing modem hardware to send the message
- **Phone:** the recipient's phone number*
- **Text:** SMS text to be sent, right-click to insert text macros

*If the phone number does not have a country code defined, the local country code of the SIM card operator will be appended to the number. If you want to guarantee the number correctness and the message delivery, please enter the number in the international format with a country code and a leading +/00.

The screenshot shows a configuration window titled "Action TELIC AG Send SMS*". The window is divided into a left sidebar and a main content area. The sidebar has a "Details" tab selected. The main content area has a "Details" header. Below the header, there are several fields and buttons:

- Action type:** A dropdown menu showing "Send SMS" with a "Change..." button next to it. Below the dropdown is the text "Select action type from list of available action types".
- Title:** A text input field containing "TELIC AG Send SMS". Below the field is the text "Action name".
- Target:** A dropdown menu showing "TELIC AG" with a "Change..." button next to it. Below the dropdown is the text "GSM modem. If none is selected, the action will be visible on all GSM modem."
- Phone number:** A text input field containing "+37129843". Below the field is the text "Phone number".
- Text:** A text input field containing "{EVENT_SOURCE_TITLE} triggered an event: {EVENT_TITLE} at {EVENT_TIME}". To the right of the field is an "Insert field" button.

At the bottom of the window are three buttons: "Apply", "OK", and "Cancel".

Action: send SMS notification

Depending on your modem settings and chosen language, each message may be split into several ones. Before setting up the notifications on production servers, verify the setup and make sure you are getting the desired results.

Two-Factor Authentication (2FA)

Before enabling 2FA:

- add a valid modem and test it
- ensure all users who will use 2FA have a valid and full phone number specified in their [account properties](#) in Ganz CORTROL Console

The phone number setting is new (comes with the modem support) so you will need to go to each [user's properties](#)

Ganz CORTROL Global Administration Guide

and enter their phone number to make sure they can receive SMS for the verification.

User unicorn*

User

Details* 1

Membership

Resources

Administration profile

Details

Email address

unicorn@exists.today

Email address for notifications

Phone number

+1555050505

Phone number for notifications

User's phone number and email for 2FA notifications

To set up 2FA, go to your Ganz CORTROL [server settings](#) (for Ganz CORTROL Global systems - go to the [central management server properties](#), as this is a system-wide setting) > *Two-Factor Authentication* tab > add a new notification provider and specify the rest of the settings as described in the [corresponding chapter](#) about 2FA.

12.15 Control Panels

Overview

Ganz CORTROL introduces Control Panels – a powerful feature that enables real-time monitoring of system states, device statuses, and various metrics directly within the viewport. These panels are configured in the Ganz CORTROL Console and displayed in the Ganz CORTROL Client, offering a concise and interactive overview of system health and performance.

A Control Panel consists of one or more monitoring items, which can be grouped, assigned to users, and displayed dynamically inside the Monitor layout. You can create different panels for different use cases, such as server load monitoring, offline device tracking, or user interaction logs.

Configuration in Console

To configure Control Panels:

- Go to the *Configuration; Control Panels*.
- Click the *New Control Panel* to create a new panel.
 - Fill in the *Details* tab by adding a meaningful *Title*
 - You can also enable or disable monitoring operations by checking the *Enable* checkbox.

Control panel Global CPU load

Control panel

Details

Title

Global CPU load

Control panel name


☒ Enable

Remove to disable all operations for this control panel

Apply OK Cancel

- In the panel settings, switch to the *Items* tab.
- Click *Add* to include the desired monitoring items.
- To manage the particular *Control Panel* access, optionally assign:
 - **Members**
 - **Memberships**
 - **Permissions**
- You can also group panels using the *Assign group* for organized management.

Ganz CONTROL Global Administration Guide



Supported Monitoring Items

- **Server:** Online, CpuLoad, MemoryLoad, NetworkLoad, OfflineDeviceChannels (count), DisconnectedServers (central only, count)
- **Device Channel:** Online, VideoLostTime
- **Event Action:** Condition ON/OFF
- **User Button:** Press
- **Indicator:** State
- **Counter:** Value
- **Variable:** Value (Central Server or Ganz CONTROL Server only)

Each item is represented with appropriate type indicators (e.g., text, icon, value) and updates in real-time based on system state.

12.16 Quick Access

Quick Access feature simplifies Ganz CONTROL Client control via CCTV keyboard or standard keyboard by adding a custom ID to dedicated resources. By creating *Quick Access* IDs, it is possible to assign numerical or any other custom values to frequently used resources or items.

Currently, it is possible to set *Quick access* ID for resources such as:


- Video channels
- Data Channels
- Maps
- Buttons
- Web pages
- Shared layouts

Adding Resources:

To add any resource to *Quick Access*, go to:

- *Configuration* → *Quick access* → *New quick access item*
- Select the existing resource
- Provide an ID of your own choice
- Press the *OK* button

After that, you can reach assigned resources in the Ganz CONTROL Client in the *Quick popup* window.




An example on how-to create Quick Access ID for the MQTT event trigger Button

Using Quick Access items in Ganz CONTROL Client:

After creating a *Quick Access ID* for the resource or item, you can call for it in the Ganz CONTROL Client. To popup resource, change layout, or trigger button – launch the *Quick popup* window ([ctrl+f] using a standard keyboard or dedicated search button on your CCTV keyboard), write a particular ID in the search field, and confirm your input.

Ganz CORTROL Global Administration Guide



Quick Access use case in the Ganz CORTROL Client application

12.17 Create Schedules

Starting with version 1.26, you can find **Schedules** at the bottom of the **Configuration** section. You can create your Schedules and use them for the **Users** and **User groups** or **Events & Actions** schedules later. In previous Ganz CORTROL versions, You can find Schedules under the Events & Actions section.

You can also create or reuse existing *User-defined calendars* for special days based on the particular calendar date and override the regular schedule with exclusive scenarios.

Configuration > Schedules

admin

Search

Configuration

MQTT clients

Reports

Access control

Quick access

Schedules

Configuration

Events & Actions

Monitoring

Audit

+ New schedule

Edit

1 selected

TITLE	ID
Always	(168)
Common 5/8 schedule with t...	(349)

Recently added, 1

Recently updated, 0

Load time: 8 ms

Record count: 2

Configuration->schedules. Buttons from left to right: + New schedule (creates the schedule); Edit (edit selected schedule); Bin (delete selected schedule); Selected (deselect selected schedules)

Please be aware that *Recording Schedules* use their **own schedule type**. How to create *Recording Schedules* is described in the corresponding manual section.

Create new schedule


To create a new schedule, go to:

1. Configuration -> Schedules -> New schedule button. A Schedule pop-up window will appear.
2. Fill in the Title field to identify your newly created schedule later.

You will see the *Grid View* in the *Schedule Editor* field by default. The grid view has two separate sections - **Weekdays** and **Custom days**.

You can mark the table by clicking and holding your mouse button while moving the mouse inside the table with the step of 15 minutes. Marked time means that the schedule is active on those days at that particular time.

Ganz CONTROL Global Administration Guide



Schedule pop-up window. Grid view. Regular and custom days are marked with red ovals

You also can switch to the List view by pressing the button *List view* from the right side over the *Schedule editor* field. You can create multiple entries inside the *List view* and edit details later inside the *Grid view* by selecting the particular entry and clicking the *Grid view* button.

Ganz CONTROL Global Administration Guide

Schedule Common 5/8 schedule with the dinner breaks

Schedule

Details

Title

Common 5/8 schedule with the dinner breaks

Recording profile as seen by others

User-defined calendar

2023 Country-specific days off (348)

Change...

User-defined calendar

Schedule editor

Grid view

DAY FROM

TIME FROM

DAY TO

TIME TO

Monday	10:00 AM	Monday	1:00 PM
Monday	2:00 PM	Monday	6:00 PM
Tuesday	10:00 AM	Tuesday	1:00 PM
Tuesday	2:00 PM	Tuesday	6:00 PM
Wednesday	10:00 AM	Wednesday	1:00 PM
Wednesday	2:00 PM	Wednesday	6:00 PM
Thursday	10:00 AM	Thursday	1:00 PM
Thursday	2:00 PM	Thursday	6:00 PM
Friday	10:00 AM	Friday	1:00 PM
Friday	2:00 PM	Friday	6:00 PM
Day 1	2:00 PM	Day 1	6:00 PM
Day 2	10:00 AM	Day 2	2:00 PM

Add

Edit

Remove

Apply

OK

Cancel

Example of the schedule List view

To add a schedule scenario using the *List view*:

1. Find the *Add* and *Edit* buttons on the bottom-left side inside the *Schedule editor* field. Click on the *Add* button. One more pop-up window named *Schedule item* must appear.
2. Inside the *Schedule item* pop-up window, you find dropdowns: *Day from* and *Day to*, and the Time input fields: *Time from* and *Time to*.
3. Select the **weekday** you want to start your scenario and the day you want to set as the endpoint of the schedule using dropdowns.
4. Setup the "*Time from*" and "*Time To*" in your new schedule scenario, and press the *OK* button to confirm. Time settings apply to each day selected from the dropdowns.

Ganz CONTROL Global Administration Guide

Schedule item

Schedule item setup

Day from ▼ Sunday Day of the week

Time from ▲▼ 12:00:00 AM Beginning of the period during which the event will be fired

Day to ▼ Sunday Day of the week

Time to ▲▼ 12:00:00 AM End of the period during which the event will be fired

OK Cancel

Schedule item pop-up window

You also can set a *Custom day* inside the *Schedule item* pop-up window. Pick Day 1, 2, 3, 4, or 5 from the "Day from" dropdown menu, set the timeframe, and press the *OK* button to confirm.

Weekday schedule

The **weekday** schedule will repeat itself indefinitely, based on days of the week, unless you override it by the *User-defined calendar*.

Custom days Schedule


Section **Custom Days** works differently. You can create five different schedule scenarios that later on can be applied to override the regular schedule. You can utilize it with *User-defined calendars*.

User-defined calendars


There may be special calendar dates that don't fall into the regular schedule scenario. For such occasions, create or reuse a *User-defined calendar*.

1. Inside the *Schedule* pop-up window, click the "Change..." button from the right side of the *User-defined calendar* field.
2. "User-defined calendars" pop-up window will appear. If you already have some predefined calendar - you can reuse it by selecting it from the list and confirming with the OK button.

Ganz CONTROL Global Administration Guide



User-defined calendar pop-up window. Available controls right to left and top to bottom: Pencil icon (edit selected calendar); Bin icon (delete selected calendar); List of available calendars; +New user-defined calendar button; OK/Cancel buttons

 **N.B.** This calendar will override your regular schedule on the dates you have set up inside the calendar. All other dates will be executed on your weekday schedule scenario.


To create the new *User-defined calendar*:

1. Click on the *+New user-defined calendar* button on the bottom-left of the pop-up window. The new pop-up window will appear.
2. Add the *Title* to identify the created calendar later.
3. In the left panel of the User-defined calendar window, select the *Days* tab and click the *+Add* button.
4. Select the *Date* from the dropdown menu inside the *Day* window. Click on the *Day* field and find the day from the list.
5. Confirm your choice with the *OK* button.

You can select days from the regular schedule (for example, to make a particular Saturday a working day, pick any working day schedule scenario) or use the five custom days we saw earlier. We can use **Custom days** inside the calendar to create five different custom scenarios to override our regular schedule on a calendar basis.

When you complete setting up your custom scenarios for the calendar-based schedule, confirm your new calendar inside the parent pop-up window with the *Apply* and *OK* buttons.

Ganz CORTROL Global Administration Guide




Example of the particular User-defined calendar and Day pop-up, windows opened

13 External Services

External modules are modules that have been integrated with Ganz CORTROL, including these, which have been designed to work with Ganz CORTROL - license plate and face recognition engines. They operate either independently or based on streams received from Ganz CORTROL server, and Ganz CORTROL server can receive event metadata from these modules and then use these events for Event & Action configuration, as well as provide the opportunity to view these events in both live and investigation mode in the Ganz CORTROL Client application.

All the external modules can be connected using the same logic, the main important steps being as follows:

1. Prepare channels to be used for the target external module
2. Install the target external module
3. Connect to the Ganz CORTROL server from the external module and enable HTTP notifications in it, if such an option is explicitly available - this will make the external service automatically appear in Ganz CORTROL Console
4. Create a group for external services in Ganz CORTROL Console and add your external service to the group
5. External service will now be available for E&A configuration and its events will be visible in Ganz CORTROL Client



Important notice for Ganz CORTROL Global systems: prior to Ganz CORTROL version 1.15.0, external services only operate via central management server.


Starting with 1.15.0, you can link external services **directly to recording servers** (Ganz CORTROL Recorder instances). Note, however, that this functionality will not be covered for failover servers in case the target Ganz CORTROL Recorder goes offline. When your external service is linked to Ganz CORTROL Global, streaming will automatically switch from/to failover.

This works for all kinds of external services, except for [Camio](#), which is integrated in a slightly different way.

This administrator's manual covers an example on how to connect to the LPR (License Plate Recognition) module. Other external services are added in a similar way, the only difference being the external module interface. Also, you will find more details in LPR/FR own user guides.

Install External Module

Start LPR installation by double-clicking the installation package, and go through the wizard's steps. Activate LPR using your purchased LPR license and run the software with empty configuration.



Please use LPR version 2.x with Ganz CORTROL. If you already have an older LPR installation that works with ZNSNVR, you will need to re-install it to make it work with Ganz CORTROL or use a separate LPR installation.

Set Up External Module



In the LPR module, add a new server connection and enter your Ganz CORTROL server connection details. Make sure that the target HTTP port is reachable and that the user account has the *Login via HTTP* permission granted.

License Plate Recognition

Servers

Channels

Servers

HOST	PORT	USER	STATUS	ADD
192.168.1.83	8085	admin	Connected	 


Ganz CORTROL Global Administration Guide

Add new server connection via LPR Web interface

Then, add your desired channels for LPR analysis and set up license plate recognition as usual. For details on the setup, please refer to the LPR user manual.

Add External Service

In Ganz CORTROL Console, go to the *Configuration* section and choose *External Services* from the left-hand-side menu. On the upper panel, press the + *New external service group* button; in the dialog box, enter a group name and click *OK* to save. The newly created group will appear in the item list.




External services group

After you have set up LPR to send VMS notifications, as described above, the target service should automatically appear in the *External Services* list. Double-click it to bring up the service settings:

- **Title:** you can either keep the default (auto generated) name, or change it
- **Server:** target server for the external service to connect to (must match server address in the external service configuration)
- **Group:** add it to the group you have just created

Click *OK* to save and close the dialog box.

In the additional tabs - *Events and actions*, *Related resources* - you will see some relevant data, all in one place. *Events and actions* will display actions linked to the target service events, while *Related resources* will reflect the list of channels used by target service (in this case, LPR).



LPR service with its corresponding External Service group

Ganz CORTROL Global Administration Guide

From now on, your configured external service will become available in the [Event & Action Configurator](#), and its event streams will also become available for investigation in the Ganz CORTROL Client application. Please refer to the Ganz CORTROL Client and LPR user guides for details on the investigation mode.

Ganz CONTROL Global Administration Guide

13.1 Security systems



N.B. Starting with the Ganz CONTROL 1.30 **Access Control** tab is renamed to the **Security Systems** tab and provides extended functionality.

Ganz CONTROL is integrated with several Security systems, including Access control Systems and Alarm and Security panels. The Ganz CONTROL server can receive events from and send requests/commands to third-party security systems software.

!! Please ensure you use the Security System connection when obtaining the license—your license must include the relevant option. Without it, you will be unable to create a security system connection.

The current integration includes the following Security systems:

- **Access controls** that can be added **without any restrictions**:
 - Keri Doors.NET
 - Feenics
 - Visual Access System (GSF Corporation)
 - Roger RACS 5, Paxton
 - Inner Range Integrity
 - EntraPass Kantech
- **Security systems** that require a checkbox '**Security system integrations**' in the license:
 - Gallagher
 - Satel INTEGRA
 - RISCO LightSys
 - Generic Adapter
- **Access controls** that require a checkbox '**NEDAP AEOS Support**' in the license:
 - NEDAP AEOS

Ganz CONTROL can obtain and allow to interact with:

- **Doors:** Can get and set statuses, get related events from the Cardholders list
- **Partitions:** will depend on the system manufacturer
- **Zones:** will depend on the system manufacturer
- **Outputs:** Can Activate/Deactivate

The Ganz CONTROL Client application also provides searchable and actionable information about doors, events, cardholders, partitions, and zones.

Integrations with different security systems are more or less similar. However, there are nuances in configuration. For the specific details, please consult the Security system-specific manual. If you encounter any difficulties with the setup, feel free to contact our support engineers at cortrol@cbcamerica.com.

Adding a Security System

Details Tab

To add a new security system, go to:

1. *Console -> Configuration -> Security systems*
2. Click the **+New Security System Configuration** button
3. Inside the *Details* tab, you will see some fields common to all *Security Systems* and some exclusive to the specific manufacturer requirements. Common fields are:
 - **Title:** Add a meaningful title to your Security system
 - **Security system type:** Select the system you want to connect (all the other fields may vary depending on this selection).
 - **Merge checkbox:** If checked, it merges multiple connected systems into one tab inside the Ganz CONTROL Client app.
4. Also, most of the Security systems will have fields for the

Ganz CONTROL Global Administration Guide

- **Host:** Security system IP address
- **Port:** Security system connection port
- **Username/password:** Security system credentials

5. For the Security system-specific fields, please consult a particular manual.

The screenshot displays the 'Configuration > Security systems' page. In the left sidebar, the 'Security systems' menu item is highlighted. The main content area shows the 'Details' tab for a security system named 'keri'. The fields are as follows:

Field	Value
Title	keri
Security system type	Keri Doors.NET
Host	123
Port	8080
Username	
Password	
Enter password	<input type="checkbox"/>
Merge	<input checked="" type="checkbox"/>

The 'Apply' button at the bottom right is highlighted.


Security systems details tab example with the Keri Doors.NET Access Control.

Provide the complete settings for your specific *Security system* and confirm them with the *Apply* button. If all the fields are filled correctly, the Ganz CONTROL server will get available *Items* and *Configurations* from the *Security system*.

Configuration Tab

After the *Security system* is connected, go to the *Configuration* tab and configure the visibility of the Security system *Actions* and *Statuses* in Ganz CONTROL Client. To do so, Click on the particular item inside the middle section of the window and mark or unmark the *Show in monitor* checkbox. *Statuses* also allow to set the *Severity levels* that will be displayed in the Ganz CONTROL Client app.


Ganz CORTROL Global Administration Guide



RISCO output configuration example.

You can map different colors for the *Severity levels*. To do so, go to:

1. *Configuration -> Server -> Edit particular server*
2. Find the *Security System* tab in the new pop-up window and map the colors you want for each *Severity level*.



Color scheme settings inside the Server security systems.

Adding Security system Items

The next step is to add *Security system Items* such as *Doors, Zones, Partitions*, etc. To do so, go to:

- *Configuration -> Security Systems*

Ganz CORTROL Global Administration Guide

- Select the system from which you want to import items and click the *Arrow down* symbol beside the *+New security system configuration* button.
- Select the *Import security system items* to import all the available items in bulk.

Configuration > Security systems

Configuration

- MQTT clients
- Modbus clients
- Reports
- Security systems**
- Quick access
- Schedules
- Temporary permissions
- Configuration**
- Events & Actions
- Monitoring

+ New security system configuration Edit Disable 1 selected

- New door
- New partition
- New zone
- New output
- Import security system items**

	ID	TYPE	SECURITY SYSTEM
	(272)		Gallagher (270)
	(279)		Gallagher (270)
	(141)		Access control (117)
Post office entrance	(140)		Access control (117)
Access control	(117)	Paxton	
Gallagher	(270)	Gallagher	
keri	(291)	Keri Doors.NET	
RISCO	(278)	RISCO LightS...	
ZONH 001	(280)		RISCO (278)
PARTITION 1	(284)		RISCO (278)
EEOAOΣ 2	(285)		RISCO (278)

- Mark all the items you want to add inside the new pop-up window and confirm with the *OK* button.

Available security system items

Items

TITLE

- Doors
 - Paxton Door 2 (2)

OK Cancel

- This will bring a new pop-up window where you can configure each Item by selecting it in the left tab and fill in corresponding fields inside the middle tab.
 - **Title:** you can add a custom title for the item
 - **Use default title checkbox:** If marked, server defaults will be set as a Title.
 - **Add security system title:** If marked, the security system title will be used.
 - **Channel:** allows to map Items with the particular Channel

Ganz CONTROL Global Administration Guide

Import security system items

Edit

Details

Details

Title
(Multiple values)

Security system item title
☐ Use default title ☐ Add security system title

Security system
Access control (117) Change...

System ID
(Multiple values) Change...

Channel
none Change...

Apply Reset 2 items


Security system items

Search

TITLE	SYSTEM ID	SECURITY SYSTEM	CHANNEL
Paxton Door 1	Paxton Door 1 (1)	Access control (117)	none
Paxton Door 2	Paxton Door 2 (2)	Access control (117)	none

OK Cancel

You also can add *Security items* one by one by selecting the *New door*, *New partition*, *New zone*, and *New output* options from the *+New security system configuration* button drop-down menu.



With this approach, you can select the *Security system* directly when adding an *Item*.

1. Click on a particular *Item* (Door, Zone, etc.) you want to add,
2. Inside a new pop-up window, add a meaningful *Title*, select *Security system* from which to add *Item*, and give Ganz CONTROL a bit of time to populate lists (minute or less).
3. Click the *Change...* button beside the *System ID* field and select your *Item* from the new pop-up window.

Ganz CORTROL Global Administration Guide

Partition *

Partition

Details 3

Permissions

Details

Title

Security zone title

Security system

none

Change...

Security system

System ID

Change...

Security zone system ID

Channel

none

Change...

Channel

Apply

OK

Cancel

Monitoring

You can view the current states of all the added items in the Ganz CORTROL Console application:

- Switch to the *Monitoring* section and select *Security systems* from the list on the left.

← → Monitoring > Security systems

admin

search

Monitoring

User sessions

Video walls

Data sources

External services

Reports

Security systems 1

OPC

Configuration

Events & Actions

Monitoring

Audit

Export to CSV

1 selected

TITLE	ID	STATUS	STATE	STATUS TIME
Door 3	(272)	Unknown		
Door 4	(279)	Unknown		
Exit to the parking	(141)	Unknown		
Paxton Door 1	(295)	Normal	Open, Unlocked	2/24/2025 2:59:48 PM
Paxton Door 2	(296)	Normal	Open, Locked, Held open	2/24/2025 2:59:48 PM
Access control	(117)	Normal	Connected	2/23/2025 11:05:56 PM
Gallagher	(270)	Unknown		
keri	(291)	Critical	Disconnected	2/21/2025 11:07:30 AM
RISCO	(278)	Unknown		
ZQNH 001	(280)	Unknown		
PARTITION 1	(284)	Unknown		
EEOΔOΣ 2	(285)	Unknown		

Recently added, 2

Recently updated, 0

Critical, 1

Warning, 0

Load time: 126 ms Record count: 12

Use the *Search* field at the top right corner to filter the *Item lists*. You can refresh the *Item list* by clicking the corresponding button or *F5*.

Events and Actions

Events

After the necessary connection and Item have been added, it is possible to use their status changes as *Events* in the *E&A Configurator* and also send commands to the *Security system* server as Security system-related actions.

To add *Events and Actions* in Ganz CORTROL Console:

- switch to the *Events & Actions* section and choose *Events* on the left;
- click the *New <item>* button to add a new entry.

Ganz CORTROL Global Administration Guide

- Alternatively, you can add new events/actions directly from the *E&A Configurator* by clicking the + *New <item>* button at the bottom of the leftmost and rightmost columns.

Available events:

- Door event
- Security output event
- Security partition event
- Security system event
- Security zone event

Actions

Similarly, you can send notifications to the *Security System* servers based on Ganz CORTROL events. To do so, go to the *Ganz CORTROL Console -> Events & Actions -> Actions*, and create a new one by pressing the +*New action* button on the upper panel. Alternatively, press the + *New action* button on the *E&A Configurator*. The List of available *Actions* is:

- Door action
- Security output action
- Security partition action
- Security system action
- Security zone action

As a target, specify the *Security system* configuration added earlier. The specific *Item* for this action will be chosen at the *Rule* creation step, allowing you to use this *Action* for many different items within the same *Security system* configuration.

E&A Rules

Once you have created necessary *Events and Actions*, combine them into *Rules* in the *E&A Configurator* for *Security system* items-related actions. Selected *Item* status changes will trigger *Events* in Ganz CORTROL, and *Actions* triggered by internal Ganz CORTROL *Events* will change the *Item* state, which will also be reflected in the *Security system* UI.

Maps

Maps

Apart from the dedicated *Security system* sections in Ganz CORTROL Console, it is also possible to place item markers onto *Maps* (either regular ones or geo maps). Markers on the *Map* will reflect the *Item* state.

To do this, select *Maps* in the *Configuration* section of *Ganz CORTROL Console* and create a *Map* or open an existing one. On the *Marking* tab, place as many markers as you need (**Security System Items looks like a shield icon**) from the top panel. Click any *Marker* to edit its settings on the right side of the dialog box: assign *Linked Resource* to it and adjust colors and icons for different statuses.

For more details, please see the *Maps* section of this document.

Ganz CORTROL Global Administration Guide

Map British Museum Upper Floor*

Map

Details

Membership

Permissions

Marking*

Marking

Reset

Fit

Properties

Title	RISCO (278)
Linked resource	RISCO (278)
Icon	
Icon color	<input type="text"/>
Icon size	100%
Icon outline	<input checked="" type="checkbox"/>
Title color	<input type="text" value="0, 128, 0"/>
Title size	100%
Title outline	<input checked="" type="checkbox"/>
Title placement	Right
Color source	RISCO (278)

Apply

OK

Cancel

Example of the Maps with added security elements.

Ganz CONTROL Global Administration Guide


13.2 Gallagher

Ganz CONTROL has several integrations with third-party [access control](#) software suites. This part of the documentation provides details on how to make Ganz CONTROL work together with your **Gallagher Command Centre**.

The integration ensures two-way information exchange between Ganz CONTROL servers and access control software servers:

- Ganz CONTROL server receives **events**, **door** list and status, and **cardholder** list
- in Ganz CONTROL Console, you can see door status, add them to maps and geo maps, as well as create door-related events and actions
 - E&A events help monitor the changes in the door status
 - E&A actions and maps allow you to change the door status (lock/unlock)
- in Ganz CONTROL Client, you can search door and cardholder events for the desired period

The details below will help you set up Ganz CONTROL to work with the Gallagher software. It is presumed that you already have the Gallagher Command Centre up and running, and are familiar with its initial configuration process. For details on the Gallagher software setup, please see its own supporting documentation.


 This article explains how to connect Gallagher with the Ganz CONTROL. For the backward integration - please contact our representatives for the plugin and consult the Gallagher documentation.

Gallagher Configuration

For the two servers to be able to communicate, a few things should be first set up on the Gallagher side. The integration operates over secure HTTP, therefore, from Gallagher's point of view, Ganz CONTROL will act as a REST API Client. The steps here describe the necessary settings in the Gallagher software.

Run Gallagher Configuration Client and log in using your username and password.

In the panel containing the main menu, go to *File > Server Properties*, and select *Web Services* on the left. Here, turn ON the *Enable REST API* setting, and specify a **HTTPS port** for server-to-server communication.




The screenshot shows the Gallagher Configuration Client window. The 'Web Services' tab is selected in the left sidebar. The 'Enable REST API' checkbox is checked. The 'Server Base Port' is set to 8904. The 'Device Identification' is set to 'API Key with pinned client certificate'. The 'Status' shows 'Data Port: Running on 8904'. The 'Do not require pinned client certificates' checkbox is unchecked. The 'Enable Mobile Client Web Services' section is also visible, with 'Server Base Port' set to 8901 and 'Device Identification' set to 'TLS Client Certificate'. The status for this section is 'Data Port: Stopped'. The window title is 'Gallagher Configuration Client'. The menu bar includes File, Monitor, Manage, Report, Wizards, Configure, Window, and Help. The system view is set to 'System Operator on W10-SG' and the date/time is '8/13/2019 12:16 PM'. The bottom buttons are OK, Cancel, and Apply.

Enable REST API and specify a HTTPS port

Ganz CORTROL Global Administration Guide


Next, go to the main menu *Configure > Services & Workstations*. In the dialog box that appears, right-click anywhere and select *New > REST Client*.



Add a new REST API Client

All settings here are up to you or default, except for those in the *API Key* tab. Here:


- Copy the **API Key** from the read-only field and paste in into Ganz CONTROL Console later, as described below
- Drag and drop your desired **operator*** into the *REST Client Operator* field from the main menu *Manage > Cardholders*
- Copy the *Client Certificate Thumbprint* from Ganz CONTROL Console (see below)




Copy API key from the REST API Client settings to Ganz CORTROL Console

Ganz CONTROL Global Administration Guide

The certificate thumbprint is hard-coded into Ganz CONTROL and CBC AMERICA LLC is responsible for it renewal. You do not have to obtain your own certificate; simply copy the alphanumeric string from the Gallagher configuration dialog box in Ganz CONTROL Console.

 *For the REST API integration to work properly, the cardholder acting as operator here **must have** the **Advanced user privilege**.

The rest of the settings here are default/up to you.



Drag cardholder to the REST API Client settings

Ganz CONTROL Server Configuration

The rest of the setup will be on the Ganz CONTROL Console side. Ganz CONTROL server must have a Ganz CONTROL Global or a Ganz CONTROL Server license applied to it for you to have the Security System tab. If you are running Ganz CONTROL Global, make sure to connect to the central server, and use a privileged user account.

Create New Gallagher Connection

In your Ganz CONTROL Console, open the *Configuration* section and choose the *Security system* component on the left. Click the *New security system* configuration button on the upper panel and fill in the settings in the dialog box.

- **Title:** user-defined service name, which will appear in Ganz CONTROL Console
- **Security system type:** Gallagher
- **Host:** IP or hostname of the Gallagher server
- **Port:** server base port from the REST API settings (as specified above)
- **API key:** copy from Gallagher configuration, as shown above
- **Client certificate thumbprint:** copy and paste it into Gallagher REST API Client settings, as described above
- **Use Integration License:** Mark the checkbox if you already have an integration. If you can't connect to the Gallagher with both marked and unmarked checkboxes, please contact our support.
- **Merge:** enable this option if you have multiple access control systems and you want to have them all in a single tab in the Ganz CONTROL Client application

Ganz CONTROL Global Administration Guide

Access control GALLAGHER

Access control

Details

Details

Title

GALLAGHER

Access control title

Access control type

Gallagher

Access control type

Host

192.168.1.151

Host name or IP address

Port

8904

Port number

API key

DE9A-6F44-142C-4FDD-C0EA-6303-C60E-EA83

API key generated by Gallagher Command Centre

Client certificate thumbprint

AA A5 57 1C F4 B3 D4 90 DB 83 31 83 3A 36 05 1D 03 98 EE 10

Copy thumbprint to Gallagher Command Centre to allow access

OK

Cancel

Create new Gallagher access control connection

When done, click OK to save the settings and close the dialog box. The newly created connection will appear in the list. Use the buttons on the upper panel to alter the connection details and to disable it temporarily, if required.

Add Doors

Once the Gallagher connection is created, you can start adding **doors**. To do so, stay in the same section of Ganz CONTROL Console (*Configuration > Security System*), click the drop-down list icon (down arrow) next to the *New access control* configuration and select the *New door* option. A dialog box will pop up, allowing you to enter the door configuration.

Note that an active connection to the target Gallagher instance must be present for Ganz CONTROL to be able to retrieve the current door list.

The following settings should be specified for each door:

- **Title:** user-defined door name, which will appear in Ganz CONTROL
- **Security System:** select your Gallagher connection from the list
- **System ID:** door identifier in the access control software; select one from the list
- **Channel:** select one of your video channels to associate it with the target door (they will appear linked in Ganz CONTROL Client)

If the door list appears empty, check that:

- the doors are present in the Gallagher configuration
- you have added a REST API Client wit a privileged operator, and that it has the certificate thumbprint copied from Ganz CONTROL Console, as described above
- you have copied the correct API key from that REST API Client into the Gallagher configuration in Ganz CONTROL Console

Ganz CORTROL Global Administration Guide

Door Door 1

Door

Details

Permissions

Details

Title

Door 1

Door title

Access control

GALLAGHER

Change...

Access control

System ID

566

Door system ID

Channel

(Generic) ONVIF Compatible on 192.168.3.230

Change...

Channel

OK

Cancel

Add a new door

Use the *Disable/Enable* button on the upper panel to temporarily turn OFF the connection and restore it. The recycle bin button will remove doors and/or access control connection entries from the Ganz CORTROL configuration.

To see the **status of the doors** you have added into the Ganz CORTROL server configuration, go to the *Monitoring* section of Ganz CORTROL Console and select the *Security system* component on the left. You will be able to see the **current** door lock **state**, as well as related **alert flags**. Pay attention to the status **update time**. If a door status shows *Unknown*, it means either the Gallagher service is not connected, or the door may have been removed from the Gallagher configuration.

Monitoring > Access control

admin

Search

Monitoring

Reports

Access control

OPC

Configuration

Events & Actions

Monitoring

Audit

Export to CSV

1 selected

TITLE	STATUS	OPEN STATE	LOCK STATE	ALERT FLAGS	STATUS TIME
Door 1	Normal	Closed	Locked	None	8/9/2019 12:16:59
Door 2	Normal	Closed	Unlocked	None	8/9/2019 12:16:59
Door 3	Normal	Closed	Unlocked	None	8/9/2019 12:16:59
Door 4	Normal	Closed	Locked	None	8/9/2019 12:16:59
Door 5	Normal	Closed	Locked	None	8/9/2019 12:16:59

Recently added, 0

Recently updated, 0

Critical, 0

Check door status in Ganz CORTROL Console

Use Doors in Ganz CORTROL


After you have added Gallagher doors to the Ganz CORTROL server configuration, there are several applications for them.

Add Doors to Maps

You can place **door markers** onto maps and geo maps. These markers will reflect the current **door status** in the

Ganz CORTROL Global Administration Guide

Ganz CORTROL Client application, and provide interactive **actions** upon single or double click.



Add door markers to maps or geo maps

To put a marker onto the map, **drag and drop** it from the panel above. In the settings on the right, select the **target door** from the list. You can also adjust the **marker appearance** for each door state by selecting the target icon and its color.

Events & Actions

Ganz CORTROL [Event & Action Manager](#) (E&A) provides support for both door events (status changes) and actions (change door state).

Changes in the door status are sent from Gallagher to Ganz CORTROL. You can set up different reactions for different codes via Ganz CORTROL E&A. Later, these events can be used for building rules, e.g., for logging the events in Ganz CORTROL, bookmarking them, automatically interacting with other system components etc.

Ganz CORTROL Global Administration Guide

Event Door 2 Door event*

Event

Details*

Details

Event type

Door event

Select event type from list of available event types

Title

Door 2 Door event

Event name

Source

Door 2

Source door

Code

2500

Access control code

Available access control codes

Code	Description
25007	Start of lockdown
25008	End of lockdown
25001	PPD Emergency Opening
25002	Intrusion

OK Cancel

Add door event in E&A

To create a new **door event** in Ganz CORTROL Console, go to the *Events & Actions* section > *Events* > click the + *New event* button on the upper panel. In the appeared dialog box, fill in the settings:

- **Event type:** Door event
- **Title:** user-defined event name to be used in E&A Configurator
- **Source:** select a door from the list
- **Code:** desired door status change code received from Gallagher, select one from the list

Thus, such events will be triggered each time the corresponding code is received from Gallagher. One event corresponds to one code from a specific door: create multiple events if required.

Action TEMP unlock door*

Action

Details*

Details

Action type

Door action

Select action type from list of available action types

Title

TEMP unlock door

Event name

Target

GALLAGHER

Change...

Target access control configuration

Code

TempUnlock

Code

OK Cancel


Add door action in E&A

Correspondingly, door action can be created from the *Events & Actions* section > *Actions* by clicking the + *New action* button from the upper panel. Available settings:

- **Action type:** Door action
- **Title:** user-defined action name, which will appear in E&A Configurator

Ganz CORTROL Global Administration Guide

- **Target:** your Gallagher connection
- **Code:** select the desired action from the list
 - *Lock:* change the door state to *Locked*
 - *Unlock:* change the door state to *Unlocked*
 - *TempUnlock:* open (unlock) the door temporarily, then lock it back after ~5s

 The *Lock* and *Unlock* actions will only operate if the target door is the only **one** in the target **access zone** in Gallagher configuration. If there are multiple doors in the same access zone, these actions will still be available in Ganz CORTROL Console but will not actually work. For **multi-door** areas, use the *TempUnlock* action (open the door and close it automatically after a short timeout).

Finally, go to the *Events & Actions* section > choose *Rules* on the left > select the server and then click the *Open configurator* button on the upper panel to bring up the E&A Configurator dialog box.



Here, you can use all your [events](#) and [actions](#), including those related to Gallagher, to build [automated scenarios](#). Every rule can also have modifiers: a [delay timer](#), a [condition](#), and a [schedule](#).

Rules

RULE



Uniview IPC6222ER-X on 192.168.3.237 >> FR: Staff member

GALLAGHER >> TEMP unlock door

Working hours only  target door  Door 3

OPEN DOOR >> User button clicked

GALLAGHER >> GALLAGHER Door action OPEN

 target door  Door 1

Door 2 >> Door 2 OPENED

(Generic) ONVIF Compatible on 192.168.3.229 >> Pop-up on screen

Door 2 >> Door 2 OPENED

(Generic) ONVIF Compatible on 192.168.3.230 >> Pop-up on screen

00:00:03 extend

Create rules using door events and actions

Example: you can temporarily unlock a door by clicking a user button, or make it open automatically when a face from the staff database is recognized.

Gallagher in Ganz CORTROL Client

Once your Gallagher service is paired with Ganz CORTROL, you will see a new tab appear in the Ganz CORTROL Client application. If you do not, make sure you are connected to the correct Ganz CORTROL server.

Switch to the *Security systems* tab to start working with its contents. Similarly to other [access control](#) integrations, there are three subsections related to the access controls:

- **Events:** all events received from Gallagher
- **Doors:** the door list and related actions
- **Cardholders:** the list of cardholders

Note that the door list here will be loaded according to the user permissions. There are two user permissions for each door resource in Ganz CORTROL Console:

- *View:* see the door and its status in Ganz CORTROL Client
- *Door actions:* have the Lock/Unlock/Temporarily Unlock buttons in Ganz CORTROL Client

Ganz CORTROL Global Administration Guide

Apart from this permission management via Ganz CORTROL Console, you can hide the *Security System* tab from all users via Ganz CORTROL Client Restrictions (main menu *Tools > Administration Tool*).

Events

This section is almost identical to the *Event Trail* section in Gallagher Command Centre. Here, you will find door **events** - status changes, lock/unlock operations etc. - as well as other Gallagher events, such as: database maintenance notifications, configuration changes (e.g., new cardholder added), etc.

Enter the search **time range** and **criteria** in the bottom and click *Search*. The results will appear as a list. Use the *Reset* button to **discard** any entered criteria and use the default search settings (any event type, past 24h).

TIME	EVENT	DOOR	CARDHOLDER
8/9/2019 12:14:44	Operator requested Open Door override. Operator "LastnameOFF,...	Door 3	
8/9/2019 12:14:36	Door Access Zone State Change. EU Office #3 changed to Free No...	Door 3	
8/9/2019 12:14:36	Door Access Zone Override Started. Override started, EU Office #3...	Door 3	
8/9/2019 12:14:36	Door Access Zone State Change. EU Office #3 changed to Free No...	Door 3	
8/9/2019 12:14:36	Door Access Zone Override Started. Override started, EU Office #3...	Door 3	
8/9/2019 12:13:57	Operator requested Open Door override. Operator "LastnameOFF,...	Door 3	
8/9/2019 12:13:45	Operator requested Open Door override. Operator "LastnameOFF,...	Door 3	

Search interval: 8/8/2019 12:23:54 to 8/9/2019 12:23:54. Reset

Search for events in the specified interval.

Door: Door 3. Event: Full or partial event title. Cardholder: Full or partial cardholder name or a part of it. Search. 51 event(s) found

Door: Door 3. Event: Door Access Zone Override Started. Override started, EU Office #3 change to Free No PIN at Door 3. Time: 8/9/2019 12:14:36. View door events

Gallagher events in the Ganz CORTROL Client application

Click any event in the list to see **details** on the right. If the clicked event is related to a door, you will see the linked channel's video appear in the **instant playback** mode. Click the *View door events* button below to view the target door events for the past 24h.


Doors

This tab contains the **list of doors** retrieved from Gallagher. Each door will have its current state reflected in the *Status* tab.

Click any door to see more details on the right:

- see the live video from the associated video channel
- click the *Lock*, *Unlock*, or *Temporarily Unlock* buttons to perform the corresponding action (similarly to E&A actions, *Lock/Unlock* will only work for single door zones)
- click the *View door events* button to switch to the *Events* tab: target door events for the past 24h will be shown automatically

Ganz CONTROL Global Administration Guide




Door list in the *Access Control* tab

Cardholders

You will see all existing **cardholders** fetched from Gallagher here. As there are no cardholder associated actions, the extra details here will be the name and picture.

Click the *View cardholder events* button to switch to the *Events* tab and see the related events for the past 24h. Use the *Refresh* button in the bottom to **reload** the cardholder list and details - this comes useful if there have been changes on the Gallagher side, which have not been synchronized with Ganz CONTROL yet.



List of cardholders

Maps

If you have created **maps** with **door markers** on them, you will be able to use these maps in the *Live* and *Playback* tabs, as usual. Each door marker, when clicked (or double-clicked, depending on your application setting), will provide an opportunity to lock, unlock, or temporarily unlock the target door. This functionality is identical to door actions in E&A and door buttons in the *Security system* tab.

Ganz CORTROL Global Administration Guide

13.3 Camio


Camio video analytics is a cloud service that can do intelligent video analytics based on the provided video stream. Its integration with Ganz CORTROL is built using REST API. To link Ganz CORTROL server to your existing Camio account, add it as an [external service](#) by following the steps below.


Ganz CORTROL already has the Camio cloud service address. All you need to do is make sure you have added your Camio box to the service Web interface, then add the service connection in Ganz CORTROL Console and configure a channel (or channels) to be processed. Ganz CORTROL will then receive analytical events and will also allow searching the result database. The architecture is such that your Ganz CORTROL server connects to the Camio cloud service. Then, Camio boxes accept H.264 RTSP streams from Ganz CORTROL for video analysis. Whenever there is an event, the box sends it to the Camio cloud service, and then it is forwarded to the Ganz CORTROL server.

The steps described below will help you connect to Camio from your Ganz CORTROL server and take advantage of its video analytics. Note that this document does not provide detailed details on Camio services. For elaborate Camio configuration and usage guidelines, please refer to its own supporting documentation and/or technical support.

Prepare Camio

Log into your Camio account via Web browser and add a **box**. You can do this by clicking your account name in the upper right corner and then by clicking the *Register Box* button. This will allow you to add Ganz CORTROL channels in Ganz CORTROL Console later.


 Your Camio **box** must be in the **same network** as your Ganz CORTROL Server or Ganz CORTROL Global server.



Camio Web interface

One more preliminary step here is to generate a **token** for the Ganz CORTROL connection. To do this, click your account in the upper right corner and go to *Settings > Integrations*, then click the *Generate Token* button in the API section. Save your token somewhere: you will need to enter it when creating a Camio connection in Ganz CORTROL Console. If you forget/lose the existing token, you will have to generate a new one, and all current connections using the old token will cease to function.

Ganz CONTROL Global Administration Guide




The screenshot shows the 'Integrations' page in the Camio web interface. Under the 'API Client' section, there is an 'Application Settings' form. The form includes fields for 'Client ID', 'Client Secret', 'Application Name', 'Application Description', 'Website URL', and 'Redirect URI'. The 'Website URL' and 'Redirect URI' fields are both populated with 'http://82.193.82.11:7905'. A green 'Save' button is located at the bottom right of the form. Above the form, there is a 'Developer OAuth Token' field with a 'Regenerate Token' button.

Ganz CONTROL server address and HTTP port in the Camio Web interface settings

From the Ganz CONTROL server side, make sure you have the external server address (**Internet address**) specified, internet HTTP **port** enabled (different from zero) and opened on the firewall/router. A simple test to check if the configuration is valid is to try entering your Ganz CONTROL server URL into the browser address bar: you should be able to see the streaming server interface. Use this **address and port in the Camio Web** interface to pair it with Ganz CONTROL server.

Example: if your Ganz CONTROL address is 82.193.82.11 and internet HTTP port is set to 7865, enter <http://82.193.82.11:7865> into your browser (better test it from another computer, and another network) and verify that you can see the Ganz CONTROL Web client. If successful, use the same address for Camio Web.

 Make sure that your **port forwarding** setup works and that your Ganz CONTROL server is **reachable** from the **Internet** via **HTTP**. (You should be able to open the Ganz CONTROL Web UI from other PC over the Internet, otherwise, Camio will be unable to connect, and it will not work.)

In other words: Camio can connect to Ganz CONTROL servers only using the HTTP API, which is available at the same URL as the Ganz CONTROL Web interface. So, in order for the system to function correctly, specify the Ganz CONTROL Web interface URL and the HTTP port in the Camio settings under API Client, on the same screen where the token is generated.

Add External Service

The next step is to add Camio **connection** into the Ganz CONTROL server configuration. This integration supports Camio as an [external service](#), with a slight difference: external services like LPR and FR appear in Ganz CONTROL Console automatically while Camio service must be added **manually**. For Ganz CONTROL Global systems, Camio works only with the central server, and not with any of the recording servers directly.

Connect to your Ganz CONTROL server via Ganz CONTROL Console. Open the *Configuration* section and select *External services* on the left. Add a new connection by clicking the *New Camio service* button on the top panel.

Ganz CORTROL Global Administration Guide

The screenshot shows a window titled "External service Camio Service 1*". On the left is a sidebar with "Details*" selected, and below it are "Cameras" and "Events" options. The main area is the "Details" tab, which contains the following fields:

- Title:** A text box containing "Camio Service 1". Below it is the label "External service title".
- Group:** A dropdown menu showing "Camio Group". To its right is a "Change..." button. Below the dropdown is the label "Group to which the external service belongs".
- Token:** A text box containing "8Sv399x5JVmBxj8BtlbzTyc-FoCLYrgt". Below it is the label "Token".
- Public URL:** A text box containing "http://82.193.82.1:17901". Below it is the label "Public URL".

At the bottom right of the dialog are "OK" and "Cancel" buttons.

Create a new Camio service connection

The following settings are to be specified here in the *Details* tab:

- **Title:** user-defined service name, which will appear in Ganz CORTROL Console and Ganz CORTROL Client
- **Group:** external service group, mandatory*
- **Token:** copy and paste the token generated in the Camio Web interface (as described above)
- **Public URL:** external Ganz CORTROL address (IP/hostname and HTTP port) for the Camio cloud connection**
- **Server:** local IP address of the Ganz CORTROL Server server (this field is ONLY for Ganz CORTROL Server)

*You will need to create an external service group to put the Camio connection into. The group is necessary for the permission management and also ensures that the service appear in the Ganz CORTROL Client application. Without the group, your Camio connection will not be visible in Ganz CORTROL Client. If there are multiple Camio connections, you can either create a new group for each one, or put all similar external services into one group. Do not mix different external services by putting them into one group.

**Simply forward your Ganz CORTROL server HTTP port to an external port, and/or open this HTTP port on your router firewall. Camio services are not available without the Internet connection, as the company only provides cloud services.

When done, click *OK* to save and close the dialog box. Your new Camio connection will appear in the list. To check the service status, go to the *Monitoring* section in Ganz CORTROL Console and select *External services* on the left.

Add Channels For Analysis

Camio can use HTTP connection with or without authorization, and Ganz CORTROL can work with either option.

1) To set up a connection **without authorization**: Ganz CORTROL has a special built-in *Anonymous user* account for such situations. All you need to do is **enable** the **anonymous user** and then allow him to receive **live video** for the required channel(s).


- Enable the **anonymous user account**: *Configuration > Users > select anonymous in the list > Edit* (or double-click the user in the list) > *Enable > OK*.
- Add **permission**: *Configuration > Channels > click target channel > Edit* (or double-click it in the list) > *Permissions > select the anonymous user account on the right > grant the View live video permission*.


2) A more secure way is to specify the Ganz CORTROL **user** and use **digest authentication** with Camio. For this, specify the internal Ganz CORTROL **user name** and **password** in the camera details (see below).

Back in the *Configuration* section > *External services*, double-click your Camio service, or select it and click *Edit* on the upper panel. Select the *Cameras* tab on the left.


Ganz CORTROL Global Administration Guide

Here, click the **+New** button and **fill in the camera details**. Basically, you need to bind an existing Ganz CORTROL channel to one of your Camio boxes. To do this, first select the channel, and then specify the Camio box by selecting it from the list. Click **OK** to save and close the dialog box.

 Camio only supports H.264 RTSP streams. HEVC (H.265) or JPEG streams will have an error in the service Web interface and will not be analyzed.

 Make sure the channel name does **not** have any special characters, especially **backslashes**, otherwise Camio will be unable to parse the channel name.

If the box list appears empty, double-check your Camio connection parameters: the token may be incorrect. If the connection does not work and you know the token is correct, try generating a new token via service Web interface and then pasting the new token into Camio connection in Ganz CORTROL Console.



External service Camio*

External service

Details

Cameras*

Events

Cameras

Edit camera details

+ New

Cameras

CHANNEL

CAMIO BOX

1080p Emul (105)

Test #2

Channel

Camio box

Test #2

Username

Username to access the device

☒ Enter password

Password to access the device

Apply changes

Cancel


OK

Cancel

Add video channels to be sent to Camio for analysis


Next, make sure your Camio channel is set to **continuous recording** in Ganz CORTROL Console.

Then, go to the Camio Web interface: your channel will appear **live** in the *Boxes* section. This will happen **automatically**, you do **not** need to add the camera manually in the Web interface.

 If you did everything right, your channel will appear on Camio Web **automatically**. Do not add it in Camio UI!

All is left to do is select a **plan** for the target channel (you may have to purchase it from the Camio provider). If the channel is inactive, click the ON/OFF toggle button on the right to activate. The ON position (green) indicates that the channel analysis is activated.

Ganz CORTROL Global Administration Guide



*Configuration result: if everything is correct, the channel will appear in Camio Web UI as the **first** one in the list*

Next to the channel title, you will see its **status**: if the video is coming through, the status should be *Online*. If you disable the channel in Ganz CORTROL Console or there is no actual video, the channel status will appear as *Offline*. Click the *Stream stats* under the live preview to see the video parameters. If something is wrong (e.g., stream codec is not supported), you will see a red exclamation mark: click on it to see more information.



Some channels may not have the live preview video alongside with the ON/Online status, no errors, and video presence in Ganz CORTROL Console and Ganz CORTROL Client. This does not depend on Ganz CORTROL. Usually, this does not affect video analysis and you are able to see the search results. For troubleshooting this and other Web-related issues, kindly contact Camio support.


Camio will now start analyzing your video stream and send the results back to Ganz CORTROL. You can also search the event archive on the service Web.

Web Search

On Camio Web, click the *Search* button below the channel live preview to enter the search mode. The Web search for your Ganz CORTROL channels works in the same way as for any other channels in Camio.

If Web search does not work, kindly contact Camio technical support.

Ganz CORTROL Global Administration Guide



Use Web based search for your channel

Ganz CORTROL Client Search


The current integration allows searching the Camio events from the Ganz CORTROL Client application.

Open your Ganz CORTROL Client application and connect to any Ganz CORTROL server that is linked with Camio. You will see an extra tab on the upper panel named after your Camio external service group.

The search logic is similar to that for other external services:

- in the *Resources* panel on the left, click the + (plus) icon next to the channels you wish to see results from: the **selected** channel(s) will be marked **blue**
- in the right-hand-side panel, enter the **search parameters**:
 - **Query**: text tag to search for, e.g., car, human, truck, also colors
 - **Search interval**: the time range to be searched for events

When ready, hit *Search*. If there are any **results** for your request, they will appear in the list below and in the grid in the central area. Click any picture to play back the corresponding portion of the video archive. The video clip will be played in a loop.




Camio event search in Ganz CORTROL Client

You can change the grid size by selecting it from the drop-down list below the grid. The available options range from 1x1 and up to 6x6. The single viewport option will provide you will fully functional instant playback, and the rest of

Ganz CORTROL Global Administration Guide

the options (2x2..6x6) are similar to the result preview in *Smart Search* mode., allowing you to add bookmarks, export the result video clips, and switch to the regular playback mode.

Use the arrows |< and >| to load the previous/next portion of the results. You can also do the same by browsing the result list: upon clicking a result from the faraway time range, the target results and its neighbors will be placed onto the preview area.

 If the search produces **no results** at all, try the same request on Camio Web: if there are no results on the **Web**, too, kindly contact Camio technical support.


You can also **save** the list of your **search results** by clicking the *Export CSV* button in the bottom right corner.

Events & Actions

Ganz CORTROL E&A Manager provides a powerful mechanism to automate things in your CCTV ecosystem. There are **Camio-specific events** supported by current integration that include reactions to certain keywords. The whole configuration is done via Ganz CORTROL Console. First, you pre-set the **keywords** (tags) of interest in the Camio service settings, and then set up events using these tags in the Event & Action Configurator. These events can be later added to E&A rules, as usual.

Preliminary event setup: in Ganz CORTROL Console, go to the *Configuration* section > *External services* > open your Camio service for editing > switch to the *Events* tab.

Click the + *New* button and enter a keyword or a keyword combination that should trigger the event. Click *Apply changes* to save the current entry, or click cancel to discard the changes. To add another one, click the + *New* button again and repeat. To remove any entry, use the recycle bin button in the upper right corner (also works for several items selected using *CTRL+click*).



Camio event preparation

Main setup: switch to the *Events & Actions* section > choose *Events* on the left. Click the + *New event* button on the top panel to bring up the dialog box.

Set event type to *External service* and fill in the parameters:

- **Title:** user-defined event name
- **Source:** video channel that serves as the event source
- **Service group:** select your Camio service group
- **Target event:** choose one of the keyword sets you have specified earlier

If the group list is empty, make sure you have followed the steps above to create both external service and a group for it, and that one field above you have selected a channel that is actually used by that service group. And, if the event list is empty, follow the steps above to add the keywords of interest in the external service settings.

Ganz CORTROL Global Administration Guide

Event Red car departing - Camio*

Event

Details*

Details

Event type

External service

Select event type from list of possible event types

Title

Red car departing - Camio

Event name

Source

_Test Camio 2 1

Change...

Event source

Service group

Camio Group

Change...

Service group

Target event

none

house gray vehicle

volkswagen orange brown

black departing

red departing

black approaching

pedestrian human walk

street road lane infrastructure


car luxury

OK

Cancel

New Camio event

When done, click *OK* to save and close the dialog box. The newly created event will appear in the list, and also in the E&A Configurator (for the server containing the target channel). Now you can use this event for building your automated scenarios.

 Events from Camio service arrive with a **30-60s delay**. This does not depend on the Ganz CORTROL software. Please keep this in mind when configuring rules with Camio events.

13.4 Inner Range Integrity

Ganz CORTROL is integrated with a number of **Security systems**. Ganz CORTROL server can receive events from and send requests/commands to third party access control software.

Ganz CORTROL obtains the **list of doors**, their **statuses** (opened/closed, locked/unlocked), **cardholder list** and relevant events, and enables you to lock and unlock the doors based on internal Ganz CORTROL server events (e.g., user button pressed) and also from the Ganz CORTROL Client application. Information about doors, their events and cardholders is searchable from Ganz CORTROL Client application as well.

Supported functionality overview:

- Receive events, door list and their status, list of cardholders (users)
- Change door status by sending corresponding commands back
- Live door status with linked video channels
- Interactive markers on the maps and geographical maps
- Notifications and other actions based on door events
- Search event history based on doors, cardholders, and time
- Set up mobile app notifications
- Lock and unlock doors from the mobile application

Integrations with different access control software are similar. However, there may be nuances in configuration. If you encounter any difficulties with the setup, feel free to contact our support engineers at cortrol@cbcamerica.com.

Ganz CORTROL Configuration with 3rd Party Access Control

This topic briefly describes the configuration necessary to make use of the access control software integrations with Ganz CORTROL software.

Prerequisites

- Preinstalled **Inner Range Integrity** instance.
- For the configuration, you must enable Inner Range Integrity Communications Handlers. For the additional info - please consult the **Inner Range Integrity REST XML Web API V2 documentation**.
- Your firewall settings must be preconfigured to allow communication between Ganz CORTROL and Inner Range Integrity instance.

Add Security System Configuration

In Ganz CORTROL Console, open the *Configuration* section and choose *Security System* in the menu on the left. Here, you need to create a connection to the **Inner Range Integrity** server: click the *New security system configuration* button on the upper panel and fill in the settings, then click *OK* to save:

- User-defined **title**
- **Type**: select your access control software name
- **Host**: access control server IP address (required for some types)
- **Port**: access control server port (Default port for the Inner Range Integrity is: 80)
- **Username and password** to connect to the access control server. Use the *Password* and the *Username* you set up inside the Inner Range Integrity instance. Please make sure that you are using the correct *Authentication* (Basic or HTTPS) type and *User* (Default Operator or other specific configuration). If inconvenient - consult with the Inner Range Integrity **REST XML Web API V2 documentation**
- **Path Prefix**: By default the Path Prefix is set to '*restApi*', but check your Inner Range Integrity settings
- **Connection timeout/Temporary unlock time**: set intervals in seconds
- **Secure Connection**: mark the checkbox for the HTTPS connection type
- **Merge**: enable this option if you have multiple access control systems and you want to have them all in a single tab in the Ganz CORTROL Client application

Ganz CONTROL Global Administration Guide

Access control *

Access control

Details

Details* 2

Folder

Permissions

Path prefix

restApi

Path prefix

Connection timeout

10

Connection timeout in seconds [1..60]

Temp. unlock time

10

Temp. unlock command time in seconds [1..3600]

☐ Secure connection

Use HTTPS connection

☒ Merge

Display access control items in Luxriot EVO Monitor on the same tab or multiple tabs

Apply OK Cancel

Access control configuration example with specific Inner Range Integriti fields.

Add Doors

Next, click the arrow next to the *New security system configuration* button and select *New door* in the drop-down list. Choose the access control configuration created on the previous step.

Door the Doors*

Door

Details

Details* 1

Permissions

Title

the Doors

Door title

Access control

Inner Range Integriti (481)

Change...

Access control

System ID

Change...

Door system ID

Channel

none

Change...

Channel

Apply OK Cancel

Adding new door.

Click the *Change* button next to the *System ID* field to view the list of available doors: if the access control configuration is correct, Ganz CONTROL server will successfully fetch it from the server. Choose the required door and click *OK*.

Ganz CORTROL Global Administration Guide

System Id	Title
Odd1b740-98fd-4bc9-832f-ba0484849805	Reader 1.0
1d59deea-ea46-402d-b487-3c84a5495e31	Reader 4.48
385df5ef-ffc7-4e50-ba42-6014fa25691c	Reader 2.16
9a1cc330-6965-47e2-946c-01f062bef89d	Reader 3.32

OK

Cancel

Example of the list of the available doors

If you wish to bind a video channel to a door, choose a channel in the corresponding field. This channel will appear when viewing events from that door in the Ganz CORTROL Client application, and the event list will be bound to the recorded footage.

Monitoring

For all the doors that have been added it is possible to view their current states in the Ganz CORTROL Console application: to do so, switch to the *Monitoring* section and select *Security systems* in the list on the left.

Monitoring > Access control

Monitoring

Servers

TITLE	STATUS	OPEN STATE	LOCK STATE	ALERT FLAGS	STATUS TIME
Back Door	Normal	Closed	Locked	None	2/19/2018 15:59:16
Front Door	Normal	Opened	Locked	ForcedOpen, HeldOpen	2/19/2018 15:59:16

Door status monitoring

The following information is available:

- **Open state:** opened/closed
- **Lock state:** locked/unlocked
- **Alert flags:** additional information, if any
- **Status time:** last status update time

Use the *Search* field in the top right corner to filter the door list, and the *Refresh* button (or F5) to reload it.

Maps

Apart from the dedicated *Security systems* sections in Ganz CORTROL Console, it is also possible to place door markers onto maps – either regular ones or geo maps. Markers on the map will reflect door open state and lock state.

To do this, select *Maps* in the *Configuration* section of Ganz CORTROL Console and create a map or open an existing one. On the *Marking* tab, place as many markers as you need – the ones looking as doors – from the top panel. Click any marker to edit its settings on the right side of the dialog box: assign a door to it and adjust colors

Ganz CORTROL Global Administration Guide

and icons for different door statuses.

For more details, please see the [Maps](#) section of this document.

Events and Actions

After the necessary connection and door(s) have been added, it is possible to use the door status changes as events in the *E&A Configurator* and also send commands to the access control server as door related actions.

To add events and actions in Ganz CORTROL Console, switch to the *Events & Actions* section and choose *Events* or *Actions* on the left; click the *New <item>* button to add a new entry. Alternatively, you can add new events/actions right from the *E&A Configurator* by clicking the + *New <item>* button in the bottom of the leftmost and rightmost columns.

There are two events related to the access control integration:

- *Security system event*: items not related to doors but still coming from the access control side (vendor-specific; e.g., other components' status change)
- *Door event*: codes related to door status (i.e., bound to specific nodes)

Door Event

This event category is triggered when the specified code is received from the access control server. Choose the target door as the event source here (the door must be added to the Ganz CORTROL server configuration beforehand), then select the code you wish to set up the reaction for.

Event Back door OPEN2long*

Event

Details*

Details

Event type

Door event

Select event type from list of available event types

Title

Back door OPEN2long

Event name

Source

Access Door 1

Source door

Change...

Code

Door Open Too Long Alarm

Access control code

Change...


OK

Cancel

Door event

The **code list** is retrieved from the access control software and contains possible event types that can be received and understood by Ganz CORTROL server. Choose the one you want to set up a reaction for.


Ganz CORTROL Global Administration Guide



Door codes Example

Security System Event

The exact list of event codes here depends on the vendor; some access control integrations may not support this kind of message.



Access control event.

Actions

Similarly, you can send notifications to the access control servers based on Ganz CORTROL events. To do this: in Ganz CORTROL Console, choose *Actions* in the Events & Actions section and create a new one by pressing the *New action* button on the upper panel. Alternatively, press the + *New action* button on the *E&A Configurator*. You will need the *Door action* type.

Ganz CORTROL Global Administration Guide

◆ Action Inner Range Integriti Door action*

Action

Details*

Details

Action type

Door action

Change...

Select event type from list of available event types

Title

Inner Range Integriti Door action

Event name

Target

Inner Range Integriti (481)

Change...

Target access control configuration

Code

Unlock

Code

Apply

OK

Cancel

Door Action example.

As a target, specify the access control configuration added earlier. The specific door for this action will be chosen at the rule creation step, allowing you to use this action for many different doors within the same access control configuration.

Available **action codes** here are: lock, unlock, temporarily unlock, and lock down (standard access control door states). Once the action is triggered, the corresponding command will be sent to the third party access control module.

E&A Rules

Once you have created necessary events and actions, combine them into rules in the *E&A Configurator*. For door related actions, remember that you need to specify the target door by using the *Target door* **button** in the bottom of the middle column.

Selected door status changes will trigger events in Ganz CORTROL, and actions triggered by internal Ganz CORTROL events will change door state, which will also be reflected in the access control UI.

13.5 External Metadata

Any external system can send **analytics metadata** to Ganz CORTROL servers. These may be individual cameras with edge analytics, or third-party analytics engines; these can operate independently but it makes sense to send the metadata along with the analyzed video stream to the Ganz CORTROL server. The Ganz CORTROL server can then **overlay** the metadata in both **live and archive** playback, use the data for for the [Event & Action rules](#), as well as provide the opportunity to **view and search** these events based on the various recognition attributes.

A simple example of such integration is: ANPR camera sending license plate recognition results with the video stream.

At this point, Ganz CORTROL servers support two metadata classes: LPR and FR (license plate and facial recognition).



This functionality does not require previous integration or API connection of the external service.

Prerequisites

You will need to configure the external analytics source to send the metadata in JSON format over HTTP/HTTPS. The only accepted type is an array of JSON objects named "objects" containing the following properties:

- **x** and **y** - relative coordinates, [0; 1], float
- **width** and **height** - relative object size, [0; 1], float
- **classId** - internal Ganz CORTROL class identifier, string
 - 4 = FR, 17 = LPR
- **id** = object ID, string; used to distinguish between objects and to ensure correct moving object drawing across frames; if not specified and there are multiple objects, they will not be drawn correctly
- **className** - optional user-defined class name, string
- **accuracy** - recognition accuracy, optional, [0; 1], float
- **value** - mandatory parameter, recognition value (plate number or Subject name/surname), string
- **attributes** - optional value attributes delimited by comma, e.g., car color, make, model, year etc., string

If the data are even partially incorrect, the server will return an error. If everything is OK, you should expect the *HTTP/1.1 204 No Content* response.

If **classId** is not equal to 4 or 17, the metadata will be accepted and displayed as overlay but you will be unable to **search** it.

Example

```
{
  "objects": [
    {
      "x":0.15,
      "y":0.4,
      "width":0.5,
      "height":0.6,
      "id":"01",
      "classId":"4",
      "className":"Face",
      "value":"Guy Julius Caesar",
      "accuracy":"0.95"
    },
    {
      "x":0.25,
      "y":0.09,
      "width":0.2,
      "height":0.17,
      "id":"LPR0013",
      "classId":"17",
      "value":"桂GZ1729",

```


Ganz CORTROL Global Administration Guide

```
    "attributes": "silver, серый, Honda, sedan, 2007"
  }
}
```

Configuration in Ganz CORTROL Console


The Ganz CORTROL servers accept metadata automatically starting from software version 1.21.0.


The metadata are partially stored and displayed in the **archive**, and is represented by a wide semi-transparent line on the archive timeline. Namely, all **bounding boxes** (colorful rectangles) are stored in the video archive. The rest of the data - recognition results, attributes, etc. - are stored in a **separate database**. Without the database, you will only be able to see the data overlay in playback, without event values and properties.


 The external recognition data are stored as follows:


- **bounding boxes**: in the video archive, always
- events data with **values and attributes**: in a separate database, if the [DB is enabled](#) in the server settings

In Ganz CORTROL Console, you can change the **database** that will be used for storing metadata. By default, a [built-in database](#) (SQLite) is enabled for all clean installations. To change the database settings (limits etc.), go to the *Configuration* section > choose *Servers* on the left > select *External databases* tab > click *Change* > select a


database and click the *Edit*  icon.

 A built-in VA metadata database is enabled for all **new/clean installations** of any Ganz CORTROL server. For software upgrades, **no database** is selected (*none*) for enhanced compatibility, but you can enable it manually.

To check the DB configuration, in the *Configuration* section > *Servers*, scroll horizontally and check the *Recognition history DB* column. If there is no such column, add it to the displayed columns by editing the item grid using the *Edit columns* button  in the upper right corner.

Configuration	<div><div><div><div></div></div><div>New server</div></div><div>Edit</div><div>Assign group</div><div><div></div></div><div>✖ 1 selected</div><div><div></div></div></div>						
Servers	TITLE	LOCAL VMS PORT	LOCAL HTTP PORT	INTERNET IP	INTERNET VMS PORT	INTERNET HTTP ...	RECOGNITION HISTORY DB
Networks	FRRS	60554	9090		60555	9191	
External services	My Server	60554	8080		60554	8080	 Built-in

Configuration status of the Recognition history database for two servers: none and built-in

To verify that the **data are recorded** into the database, switch to the *Monitoring* section > choose *Servers* on the left > check the *Recognition history DB* field. If there is no such column, add it to the displayed column list by configuring the table using the *Edit columns* button  in the upper right corner.

Monitoring	<div><div><div><div></div></div><div>Export to CSV</div></div><div>Details</div><div>✖ 1 selected</div><div><div></div></div></div>							
Servers	TITLE	RY	PROCESS PHYSICAL MEMORY	NETWORK LOAD	NETWORK TRANSFER RATE	FREE SYSTEM DISK SPACE	RECOGNITION HISTORY DB	INFORMATION
Devices	FRRS							
Channels	My Server	300.75 MB	3.6%	36.42 Mb/s	16.40 GB	Normal		

Recognition history database status in the Monitoring section of Ganz CORTROL Console

External Metadata Display in Ganz CORTROL Client

The metadata are displayed as **video overlay** - colorful bounding boxes with parameters - in live and regular/instant playback, as well as in 1x1 view in the dedicated external service tabs. In the middle of the rectangle, object **value** will be displayed. (X) in the corner means that the metadata source is external, and it is accompanied by other parameters (e.g., **className**).

Ganz CORTROL Global Administration Guide

You can perform the **object-based search** in the dedicated tabs (LPR, FR) using the panel on the right-hand-side:

- **Search interval:** start and end of the search period
- **Plate:** enter full or p*rtial value
- **Attributes:** one of more attributes to search for
- **Tag:** Ganz CORTROL [tag](#), if configured



If there is no configured VA database, there will be no dedicated tab and you will be unable to perform value-based search.

Attribute search can be performed in two modes:

- **OR:** use commas or spaces between attributes to include results that have ANY of the listed attributes
- **AND:** use + between attributes to display results that have ALL attributes

For example, entering "black sedan" will display all black cars and all sedans, while searching for "black+sedan" will only output black sedans.

The screenshot displays the Ganz CORTROL software interface. The main window shows a video feed with two detected objects: a car (labeled 'GZ1729') and a person (labeled 'Guy Sp...'). The search panel on the right includes fields for 'Search interval' (2/15/2022 06:38:37 AM to 2/17/2022 06:53:37 PM), 'Plate' (GZ1729), and 'Attributes' (silver, серый, Honda, sedan, 2007). A table at the bottom shows the search results, with one event found. The table has columns for TIME, CHANNEL, PLATE, and ATTRIBUTES.


TIME	CHANNEL	PLATE	ATTRIBUTES
2/16/2022 3:46:27 PM	test	桂GZ1729	silver,серый,Honda,sedan,2007

External metadata event search in the LPR tab

13.6 OPC Client

Ganz CORTROL servers can act as OPC clients and connect to different OPC servers, which communicate with various industrial hardware devices. In this way, Ganz CORTROL servers support thousands of devices from different manufactures without even knowing what those devices and their models are at any particular moment of time: OPC servers take care of that. Once the connection is established, Ganz CORTROL can receive data from OPC servers, compare it to pre-defined values and trigger events based on specific changes in these values; also, Ganz CORTROL can send commands to change the data on the OPC servers, which, in their turn, pass the commands to the hardware devices.


This topic describes how OPC client functionality is configured and used within Ganz CORTROL.

 OPC servers provided by different vendors can be used with Ganz CORTROL. The present document does not cover OPC server installation and configuration, as well as related Windows settings necessary for valid OPC client-server connection setup: these are vendor-specific and can be found in the OPC server documentation.

OPC Functionality

Any Ganz CORTROL server can connect to a third-party OPC server, thus acting as an **OPC client**. These connections are then used within the [E&A Configurator](#) to create events and actions based on OPC data (variables): events compare the variable contents to pre-defined values in a specified way; actions change the variable contents to a pre-defined value.

Communication with OPC servers can be maintained in one of two ways: **synchronous** and **asynchronous**. When in synchronous mode, Ganz CORTROL server polls an OPC server and receives updates with the latest data set as a result; this happens every few seconds. In the asynchronous mode, Ganz CORTROL server "subscribes" to the updates and then waits for a list of updated items from the OPC server.

 Asynchronous reading and writing is a preferred method and is typically more efficient. However, some modifications of Windows security policies and DCOM permissions might be required for this connection mode to work, and these are vendor- and use-case specific. Please follow the guidelines in your OPC server documentation carefully to ensure the operability: there are no settings on the Ganz CORTROL side that could affect your OPC server connection availability.

Before getting to OPC setup on the Ganz CORTROL side, install and configure your OPC server with hardware devices, and adjust Windows settings (if required). Configuration instructions below imply that you have done so and a remote OPC server with some data is reachable and operational.

Create and Manage OPC Client

OPC client configurations are located in this section as main OPC integration purpose is event and action scenarios (rules). In your Ganz CORTROL Console, switch to the *Events & Actions* section and choose OPC in the list on the left.

To add a new configuration, click the + *New OPC client configuration* button in the upper panel.

Ganz CORTROL Global Administration Guide

◆ OPC client config OPC #1*

OPC client config

Details

Details

Title

OPC #1

OPC client title

Server

Global Server

Change...

Server

Host

192.168.1.120

Host name or IP address

Prog Id

{F8582CF2-88FB-11D0-B850-00C0F0104305}

Prog Id

Username

tester

Username to access the access OPC server

☒ Enter password

...

Password to access the access OPC server

OK


Cancel

New OPC client configuration


The table below details the available settings.

Setting	Description	Default value
Title	User-defined configuration name	[none]
Server*	Ganz CORTROL server that will act as OPC client (you will be unable to change the server once it has been set!)	[none]
Host	OPC server host name or IP address	[none]
Prog ID**	OPC server program ID, vendor-specific	[none]
Username	User name from the Windows account to connect to the OPC server computer	[none]
Password	Password from the Windows account to connect to the OPC server computer	[none]

Fill in the settings and click *OK* to close the configuration dialog box and save.



*Once you assign the OPC client configuration to a **server**, the *Server* field will become grayed out, meaning that you **cannot change this setting anymore**. In other words, it is impossible to move an OPC client configuration between servers. To do this, you will need to create a new OPC connection for another server.



The **Prog ID parameter is mandatory and it is supplied by your OPC server. Typically, it is available in the OPC server settings; check your OPC server configuration manual for the exact information.


The newly created profile will appear in the list. Select it and hit the *Test* button on the panel above to **validate** the configuration; the following **responses** may be received:

- *OPC client test passed:* asynchronous connection with the configured OPC server has been successfully established
- *Code 22020100 (asynchronous data mode not available):* connection established successfully but only synchronous mode is available
- *Code -2147023174 (OPC server is unavailable):* connection unavailable due to invalid OPC client settings (e.g., incorrect target host name or IP), Windows settings or connectivity issues

Ganz CORTROL Global Administration Guide

- *Code -2147024809 (parameter is incorrect)*: incorrect OPC client configuration (e.g., no username was entered while expected)
- *Code -2147024891 (access denied)*: OPC server denied connection due to lack of permissions (e.g., invalid user name and/or password was used)
- *Code -2147221164 (class not registered) or code -2147221005 (invalid class string)*: typically, incorrect program ID format or program ID itself

The first two responses indicate successful connection with synchronous or asynchronous read/write mode; other codes mean no connection has been established so it is necessary to review the settings and troubleshoot. Other codes may appear as well in case of miscellaneous Windows configuration and/or connectivity issues.



OPC client test detected that synchronous connection mode is available

Use the *Disable/Enable* button on the upper panel to disable the OPC client temporarily and then enable it again: this is useful when OPC server is offline so Ganz CORTROL audit log is not flooded with errors. You can create any number of OPC clients and any number of events and actions based on them.

Events and Actions

Once you have created an OPC server connection, Ganz CORTROL server can retrieve the list of existing data items (nodes) from the OPC server and work with it. All the available nodes, their attributes and their values are listed when you create an event or an action of the *OPC Client* type.

Events allow you to create conditions - react to specific changes in the node values by applying conditional operators: for example, if variable type is Boolean, you can check if it is equal to 1 (=true) or 0 (=false). For other variable types, there are other (corresponding) conditional operators.

Ganz CORTROL Global Administration Guide


OPC nodes


OPC nodes							
NAME	OPC DATA TYPE	DATA TYPE	UNITS	ACCESS RIGHTS	QUALITY	DESCRIPTION	VALUE
#MonitorACLFFile	Boolean	Bool		Readable, Writeable	Good		True
@ClientCount	32-bit Unsigned Int...	Int		Readable	Good		4
@Clients	Array of Strings	None		Readable	Good		
Configured Aliases							
test	32-bit Integer	Int		Readable, Writeable	Good		0
Simulation Items							
Bucket Brigade							
Random							

OKCancel

OPC nodes retrieved from an OPC server

Actions triggered from Ganz CORTROL servers send write commands to the OPC server, in this way replacing the node value with the pre-defined one. Value of the nodes, which have non-compatible types or do not have the write permission, cannot be changed.

 **OPC data types** are converted to standard data types for further use in Ganz CORTROL: for example, both 16-bit and 32-bit integers are converted to the *Int* (integer) type. Some of the data types are not converted (e.g., currency, date&time, miscellaneous arrays) so it is not possible to use them as variables in the events and actions.

 Pay attention to the **access rights** of the nodes: for events, it is enough to have the read permission; for actions, the node must be writable, otherwise you will not be able to select it as the target action variable.

For detailed information on the creation of [events](#) and [actions](#), please refer to the corresponding topics of this document.

13.7 MQTT Clients

MQTT (MQ Telemetry Transport) is an OASIS standard messaging protocol for the Internet of Things (IoT) that describes how IoT devices (embedded devices, sensors, industrial controllers, etc.) communicate over the Internet. MQTT features clients and brokers; Ganz CORTROL servers have the ability to host MQTT clients, which can connect to existing third-party MQTT brokers, subscribe to topics and publish their own MQTT messages.

On each Ganz CORTROL server, you can create MQTT client(s), and then use it connect to MQTT broker(s) and subscribe to the desired topic or topics, and publish messages. Thus, Ganz CORTROL MQTT clients act as regular MQTT clients, "talking" to the MQTT brokers of your choice. The Ganz CORTROL server installation does not include an MQTT broker, nor does CBC AMERICA LLC provide such modules as an extra. Before using this functionality in Ganz CORTROL, you need to have a running broker with connected devices.

Create an MQTT Client

To create a new MQTT client in Ganz CORTROL Console, go to the *Configuration* tab and choose *MQTT Clients* on the left. On the upper panel, click the + *New MQTT Client* button to open up the dialog box.

MQTT client HiveMQ test client*

MQTT client

Details*

Details

Title

HiveMQ test client

MQTT client name

Server

Global Server

Change...

Server

Broker host

51b72cda61b54c9c9a5a8a2eb47a74b7.s2.eu.hivemq.cloud

Host name or IP address

Broker port

8883

Port number

Client name

MyMQTestClient

Client name

Username

mqtt_admin

Username

☒ Set password

.....

Password to log into the server

Protocol version

3.1.1

Protocol version

☒ Clean session

Clean session

Apply

OK

Cancel

The available settings are summarized in the table below. Note that the connection settings here must match the allowed connection profile in the MQTT broker configuration. For example, if your broker does not support insecure connections, you must enter relevant secure connection settings matching those on the broker side.

Setting	Description	Default value

Ganz CORTROL Global Administration Guide

Title	User-defined client name that will be used everywhere in Ganz CORTROL Console	[none]
Server	Ganz CORTROL server, to which the MQTT client will be bound. If none are selected, the client will be available on all servers in the Ganz CORTROL Global system	[none]
Broker host	MQTT broker host name or IP address for the client to connect to	[empty]
Broker port	MQTT broker port to be used for client connection	[empty]
Client name	MQTT client name that will be broadcasted. Broker settings may require this field to be set explicitly or allow it to be empty.	[empty]
Username and password	User name and password to authenticate (leave blank if broker allows anonymous connections, allow_anonymous is true)	[empty]
Protocol version	Must be supported by MQTT broker; older version, 3.1.1, is more likely to be supported	3.1.1
Clean session	If enabled, the broker will not queue messages for the Ganz CORTROL server while it is offline	Enabled
Keep alive interval	A ping message will be sent to broker at least at this interval if there is no other traffic occurring	30 seconds
SSL/TLS version	Choose the secure protocol version or leave an insecure connection	none
Certificate	For secure connections, enter the contents of the ca.crt certificate file here (copy from the broker certificate)	[empty]
Enable last will and testament	The message to be sent by broker to other clients in case of a disgraceful disconnect. Specify the message itself, the message topic, QoS*, and choose whether the message should be retained** by broker.	Disabled

*QoS - quality of service - has three levels:

- At most once: no delivery guarantee
- At least once: guarantees that the message is delivered at least once
- Exactly once: highest guarantee, safest and slowest QoS

**The retain flag tells the MQTT broker to always keep the last received message from the client and forward it to every new subscriber. You can retain the LWT message to notify other clients about your MQTT client status.

```


907
908 # listener for mutual authentication
909 listener 8883
910 protocol mqtt
911 require_certificate false
912 allow_anonymous false
913
914 cafile C:\Program Files\mosquitto\certs\ca.crt
915 certfile C:\Program Files\mosquitto\certs\server.crt
916 keyfile C:\Program Files\mosquitto\certs\server.key
917 #tls_version tlsv1.2
918 tls_version tlsv1.3
919
920 password_file C:\Program Files\mosquitto\passwords
921 #per_listener_settings false
922
923
924 #acl_file C:\Program Files\mosquitto\my_acl.acl
925

```

Ganz CORTROL Global Administration Guide

Mosquitto MQTT broker configuration file example

After entering the MQTT client configuration, click *OK* to save and close the dialog box. The newly created client configuration will appear in the list. However, the actual MQTT client will **not** be created not to waste the systems resources: Ganz CORTROL server will create the MQTT client after you use it in an event rule.

 The MQTT Client will only appear in the Monitoring section when there exists a related active (enabled) rule involving an event or an action bound to that client.

Use MQTT Client to Trigger Events


Once you have created one or more MQTT clients, you can use them to subscribe and publish messages to the topics of your choice. For each topic of interest, you need to create one event or action and choose the previously created MQTT client as agent.

To create a new event: in the *Events&Actions* section of Ganz CORTROL Console, under *Events*, add a new event and set its type to *Event triggered by MQTT notification*. Fill in the settings as you would do for your usual MQTT client when subscribing to other clients' messages:

Available settings:

- **Type:** Event triggered by MQTT notification
- **Title:** event name that will appear in the E&A Configurator, corresponds to the macro {EVENT_TITLE}
- **Source:** MQTT client that will subscribe to the current topic and act as event source. Leave empty if you want the event to be visible for all existing MQTT clients
- **Topic:** MQTT topic to subscribe to
- **Text:** incoming message that will trigger the E&A event. If empty, any message will trigger the event. The field cannot be empty if marked as regular expression!
- **Regular expression:** enable this option to enter a regular expression in the Text field instead of plain text
- **QoS:** required level of quality of service

If you don't know what the exact incoming message will be but you know the format, feel free to enter a **regular expression** in the *Text* field.



Event MQTT_test Event triggered by MQTT notification

Event

Details

Source

MQTT_test

Change...

Event source

Topic

topic2

Message topic

Text

topic2

Message text

☐ Regular expression

When checked, text is processed as regular expression

Apply OK Cancel

Create a new MQTT client event

After you create the event and use it in an active (enabled) rule, the created MQTT client entity will appear in the *Monitoring* section of Ganz CORTROL Console under *MQTT Clients*.

Ganz CORTROL Global Administration Guide

Monitoring > MQTT clients

admin

Monitoring

Servers

Devices

Channels 1

Export to CSV

Details

1 selected

TITLE	STATUS	SERVER	ERROR	STATUS TIME	ADDITIONAL INFORMATION
MQTT_test	Normal	Global Server		07/09/2022 11:29:14	

Active MQTT Client with running normally

If the MQTT client configuration is invalid, the broker is not running/available, or there are other issues, you will see the corresponding error in the *Monitoring* section of Ganz CORTROL Console. For example, if the broker connection settings are incorrect, the MQTT client status will state that it cannot connect to the broker.

Monitoring > MQTT clients

admin

Search

Monitoring

OPC

Indicators

GSM modems

MQTT clients 1

Export to CSV

Details

1 selected

TITLE	ID	STATUS	SERVER	ERROR	STATUS TIME	ADDITIONAL INFORMATION
MQTT_test	...	Critical	Global Server [...]	Mqtt client could not connect to broker	07/09/2022 18:40:59	No connection could be made becau... No connection could be made because the target machine actively refused it [system:10061]

Error: MQTT client cannot connect to the broker using current settings

You will also see a relevant message in the *Audit log*, in the *Server* section.

(1389)	07/09/2022 18:40:45	Global Server (101)	MQTT Client disconnected	Mqtt client could not connect to broker	[Resource Id]=MQTT_test (112);
--------	---------------------	---------------------	--------------------------	---	--------------------------------

Send MQTT Messages

If you wish to send MQTT messages to for other MQTT clients in your system, all you need to do is create an action of the corresponding type in the Event & Action Configurator, and then use it in a rule.

To create a new action in Ganz CORTROL Console, choose *Actions* in the *Events&Actions* section, then click the + *New action* button on the upper panel. Fill in the settings:

- **Action type:** Send MQTT notification
- **Title:** action name that will appear in the E&A Configurator, corresponds to the macro {ACTION_TITLE}
- **Target:** MQTT client pre-configured on the current server; leave empty for the action to be available for all MQTT clients
- **Topic:** MQTT topic
- **Text:** MQTT message text to be published (right-click to insert macros)
- **QoS:** required level of the MQTT quality of service

Ganz CONTROL Global Administration Guide

Action MQTT notification - camera offline*

Action

Details*

Details

Action type

Send MQTT notification

Change...

Select action type from list of available action types

Title

MQTT notification - camera offline

Action name

Target

MQTT_test

Change...

MQTT client. If none is selected, the action will be visible on all MQTT clients.

Topic

cameras

Message topic

Text

{EVENT_SOURCE_TITLE} is offline

Message text

QoS

Exactly once

QoS

Apply

OK

Cancel

Click *OK* to save and close the dialog box; the newly created action will appear in the action list. In the E&A Configurator, the action will appear in the right-hand column, under the MQTT client defined as the action target. If you have not specified the client, the action will appear for every existing and new MQTT clients in your Ganz CONTROL Console configuration.

13.8 Modbus

Introduction

Modbus, or MODBUS, is a client/server data communications protocol in the OSI model's application layer. This protocol allows DI/DO devices to connect to the Ganz CORTROL, create Events based on the Device Input, and *Actions* based on the Device Output.

Modbus setup

To set up a device, you need to go to:

1. *Configuration* -> *Modbus clients*
2. Click the + *New Modbus client* button at the top of the *Modbus clients* subsection. This action will bring a new pop-up window.
3. Fill the *Title* input field with a meaningful name, select the *Server* the device is connected to, and provide the *Device IP address* in the *Host* input field
4. You must also know what port the device uses.
5. If you need to provide a **Unit identifier/slave address**, you can fill out the *Device identifier* field; otherwise, leave it value 0.
6. Confirm your setup with the *Apply* and *OK* buttons.

The screenshot displays the 'Configuration > Modbus clients' interface. The left sidebar has 'Configuration' selected, and 'Modbus clients' is highlighted. The main panel shows a 'New modbus client' button and a list of existing clients. A 'Details' window is open for a client named 'modbus client'. The fields in the 'Details' window are: Title (modbus client), Modbus client name, Enable (checked), Server (Global Server (101)), Host (192.168.3.115), Port (502), and Device identifier (1). The bottom buttons are Apply, OK, and Cancel.

Modbus client pop-up window.

Modbus event setup

After adding the device, you can create events and actions based on the device's DI/DO signals.

1. To create an *Event*, go to the *Events & Actions* -> *Events*.
2. Click on the + *New event* button at the top of the *Events* subsection.
3. You will find the Modbus device events under *External events* -> *Event triggered by Modbus device*. Please select it and press the *OK* button.

Ganz CONTROL Global Administration Guide

4. Fill in the *Title* input field with a meaningful name.
5. Click the *Change...* button in front of the *Source* field and select your connected device.
6. Select *Discrete input* from the *Data model* dropdown menu.
7. The *Address* field allows configuring which particular input (DI port/channel) will trigger the event (modbus port/channel number, such as 0, 1, etc..).
8. The *Value* field allows configuring the state of the contact. Allowed values for the DI is 0 (OFF) or 1 (ON).
9. Confirm your setup with the *Apply* and *OK* buttons.

The screenshot displays the 'Event modbus client Event triggered by Modbus device*' configuration window. The main window has a 'Details' tab and a 'Details*' section on the left. The 'Event type' field is set to 'Event triggered by Modbus device' with a 'Change...' button. The 'Title' field contains 'modbus client Event triggered by Modbus device'. The 'Source' field is set to 'modbus client (147)'. The 'Data model' dropdown is set to 'Discrete output'. The 'Address' field is set to '0'. The 'Value' field is set to '0'. A pop-up window titled 'Select event type' is open, showing a list of available event types. The 'Channel related (3)' section is expanded, and the 'Event triggered by Modbus device' option is highlighted with a red circle. The 'External events (5)' section is also expanded, showing options like 'Event triggered by MQTT notification', 'External service', and 'External'. The 'OK' and 'Cancel' buttons are at the bottom of the pop-up. The main window has 'Apply', 'OK', and 'Cancel' buttons at the bottom.

Event pop-up window with the Modbus device settings

Additional Modbus Event Configuration Options

In the Modbus Event setup, you can further configure events using the following options:

Data Model:

- **Input Register:** Choose to trigger events based on the state of an Input Register.
- **Holding Register:** Choose to trigger events based on the state of a Holding Register.

Mode:

Use the Mode dropdown to select the criteria for triggering the event:

- **All bits:** Trigger if all bits meet the condition.
- **Any bit:** Trigger if any single bit meets the condition.
- **Exact value:** Trigger when the register value exactly matches the specified condition.

HEX Mask Fields:

Ganz CONTROL Global Administration Guide

AND Mask: Specify a HEX value for the AND mask.

OR Mask: Specify a HEX value for the OR mask.

NOT: A checkbox to invert the mask logic.

Register-Specific Fields:

For Input Register and Holding Register types:

- **Size:** Choose either 16-bit (1 word) or 32-bit (2 words).
- **Conditional Operators:** Operators such as Greater Than, Less Than, etc., can be chosen before the value field.
- **Value Fields:** Fields that change based on the selected operator:
- **Value:** Specify an exact value.
- **Bit Mask:** Apply a bitwise mask.
- **Range:** Define a range by setting Start and End values.

Coil-Specific Conditional Operators:

For Coils (Discrete Outputs), available operators are limited to:


- Equal
- Not Equal

Modbus action setup

To complete the Modbus device setup, you also need to create an *Action*. To do so, go to:

1. *Events & Actions -> Actions*
2. Click the + *New action* button on the top of the *Actions* subsection
3. Inside the new pop-up window, locate *Notifications -> Control Modbus device* and click the *OK* button
4. Fill in the *Title* field with the meaningful name
5. Select your device as the target device inside the *Target* input field.
6. The *Address* field allows you to set a device particular DO port/channel (modbus port/channel number, such as 0, 1, etc.).
7. The *Value* field allows to set the value that will be sent to the selected address. Available DO values: 0 (OFF) or 1 (ON).

Ganz CONTROL Global Administration Guide



Actions pop-up window with the Modbus device settings

Additional Modbus Action Configuration Options

For Modbus Actions, additional configurations can be made based on the device's output type:

Data Model:

Options:

- Discrete Output (Coil): For discrete output actions.
- Holding Register: For actions based on holding registers; includes a Size option for specifying 16-bit or 32-bit configurations.

Now, you are ready to implement rules for the Modbus device.


14 Health Monitoring

Ganz CORTROL provides **health monitoring data** for servers, devices and channels, stream recording, as well as **live status** of connected user sessions and other resource information, including external services. In the *Archive statistics* section, it is possible to view the stream details and also **un-protect** footage that has been locked via Ganz CORTROL Client application.

To access live reports in Ganz CORTROL Console, choose the *Monitoring* section in the bottom-left-hand panel and switch between components using the menu on the left. Use the *Search* field in the upper-right-hand menu to filter the records; press the *Refresh* button or **F5** on your keyboard to **reload** the item list. The statistics are not refreshed automatically, so do not forget to reload the list in order to obtain the most recent information.

The contents of any subsection in *Monitoring* can be exported in **CSV** (comma-separated value) format using the button on the upper panel.

The *Details* button (available for some of the sections) on the top panel allows you to view **detailed information about important events** related to the target resource. For example, you can view the list of recent connection and VCA license errors for every channel. The details are discarded after each server reboot.


Each section here contains a number of **columns** with miscellaneous information. Not all of them are available by default; to modify the displayed details and their layout, use the grid icon  in the upper right corner: an additional configuration window will pop up. You can hide the fields you do not need, and also freeze the leftmost columns for convenient horizontal scrolling. Hidden fields cannot be used for search or sorting.

All information written in plain black is informative. When things go wrong, there are two levels of errors here: **critical** and **warning**. Critical errors are marked **red**; those usually indicate important stuff like missing main stream video, no connection to services etc. Warnings are **yellow** and are used to highlight minor issues like missing secondary stream, too long GOP period, or not enough space on the disk. You can ignore warnings by right-clicking the selected items and selecting *Ignore > (preference)*. This helps if the warning is irrelevant, e.g., if you do not use substreams. Critical errors cannot be ignored as they need to be fixed for correct server operation.

Further in this chapter you will find a brief description of each information field.

Servers

This section includes information about connection and synchronization between the central server and the rest of the servers, as well as each server status and system load.



TITLE	ID	CONNECTED	SYNCHRONIZED	STATUS	CONNECTION ...	CONNECTION TEXT	SYNCHRONIZA...	SYNCHRONIZATION TEXT
Central Server	(101)	yes	yes	Success	0	The operation completed successfully	0	The operation completed successfully

Servers live monitoring

For each server, the following information is displayed:

- **Title:** server name
- **Status:** current server status (*Critical* status, indicating an unreachable or otherwise "bad" server, is also marked with red with the corresponding error description in the *Synchronization* column. *Warning* status, similarly, will have orange highlight, check *Details* for more information.)
- **Connection:** connectivity status
- **Synchronization:** configuration and audit sync status, including errors (if present)
- **Configuration:** indicates if the central server has successfully applied current configuration to the

Ganz CORTROL Global Administration Guide

connected server

- **Status update time:** last sync/connection attempt timestamp
- **Version:** server software version (version differences may cause sync issues!)
- **Failover cluster:** failover cluster name, if applicable
- **Failover status:** if applicable
 - *Not in cluster:* target server is not a part of any failover cluster (may be a mirror server, the central server itself, or a recording server not belonging to any clusters)
 - *Normal:* target server is a part of a failover cluster
 - *Unknown:* undefined; this status may appear in case of incompatible database version or corrupt configuration
- **Failover server:** current failover node that is acting instead of the target server; if none, server is operating on its own (for regular recording servers only)
- **Failover configuration:** original recording server configuration assigned to the target failover node; if none, failover node is idle (only for failover servers)
- **Connected/disconnected time:** status change timestamp
- **Configuration load duration:** how long it took for the server to load the configuration on startup
- **CPU load:** CPU utilization of the target server, %
- **Process uptime:** amount of time elapsed since the last service (re-)start, DD:HH:MM:ss
- **Process CPU load:** CPU load from Ganz CORTROL service on the target server, %
- **Memory load:** current memory utilization of the target server, %
- **Total physical memory:** amount of RAM installed on the target server, GBytes
- **Available physical memory:** amount of free physical memory on the target server, GBytes
- **Process virtual memory:** amount of virtual memory used by Ganz CORTROL service, MBytes
- **Process physical memory:** amount of physical memory used by Ganz CORTROL service, MBytes
- **Network load:** maximum network interface load of the target server (i.e., if the server has multiple interfaces, utilization of the most loaded one will be shown), %
- **Network transfer rate:** total bandwidth utilization of the target server (if server has multiple interfaces, aggregated bandwidth from all interfaces is displayed), MBytes per second
- **Free system disk space:** total amount of free space left on the disk, where OS is installed (system disk, usually C:)
- **Information:** any additional information, if any, will be displayed here

Machine load statistics are updated every five seconds but are not refreshed automatically when the *Monitoring* section is open; press *F5* on your keyboard to refresh the section contents.

Monitoring > Servers

admin

Search

Export to CSV Details 1 selected

TITLE	STATUS	CONNECTION	SYNCHRONIZATION	CONFIGURATION	STATUS UPDATE TIME	VERSION	FAILOVER CLUSTER	FAILOVER
FRRS	Normal	Connected	Synchronized	Applied	2/11/2021 5:03:15 ...	1.18.0.18734		Not in c
My Server	Warning	Connected	Synchronized	Applied	2/11/2021 5:03:17 ...	1.18.0.18734		Not in c

My Server

Notifications

DATE	SOURCE	OPERATION	RESULT
2/11/2021 5:03:53 PM	External audit	CheckConnection	Error 0x80131509
2/11/2021 5:03:33 PM	External audit	CheckConnection	Error 0x80131509

Close


Example: server has a warning because of the error in the external database connection

Note that all the columns will be present for all servers but for some server types some fields may be not applicable and will be therefore always empty: e.g., failover related details are not shown for the central server and its mirror,

Ganz CORTROL Global Administration Guide

as well as for the recording servers that are outside failover clusters.

To verify the **connection quality** between Ganz CORTROL Global and any Ganz CORTROL Recorder, go to that [server settings](#) in the *Configuration* tab, choose *Connections* tab in the server settings, and scroll to the very bottom.



Recording server connection test

For any Ganz CORTROL Recorder server, you can **test the connection** with the target Ganz CORTROL Recorder by using the *Test* button in the bottom of this tab. This comes useful when:

- you are adding the server without autodiscovery and helps you avoid issues like port mismatch, but mostly when
- you need to verify the connection quality, resolve synchronization issues, connection drops, or low/unstable speed

The test is performed using different size packets (including large) and helps troubleshoot network issues when the connection can be established and maintained with small packets but larger ones are dropped).

Devices

The device summary provides configuration update status and the time of the last communication between the server and device, as well as shows, to which servers the devices are attached.

The following fields are available:

- **Title:** device name
- **Status:** current device condition
 - *Normal:* the device is functioning properly
 - *Unknown:* the device's channel is disabled, or the device core has not been loaded yet (may appear shortly after server startup)
- **Server:** current server that has this device assigned (may be regular recording server or failover)
- **Devices/model:** device type or model
- **Status update time:** last sync/connection attempt timestamp

Ganz CORTROL Global Administration Guide

- **Information:** additional information, if any, will be displayed here (usually, errors; normally, the field is empty)
- **Host:** device IP address or hostname
- **Port:** device HTTP/HTTPS port (from device settings, used to exchange service information, not data)

Monitoring > Devices

Monitoring

Servers

Devices

Channels

User sessions

Audit journal

Configuration

Monitoring

TITLE	ID	SERVER	DEVICES/MODEL	TIME	CONFIGURA...	CONFIGURATION UPDATE RESULT TEXT	STATUS
■ (Generic) ONVIF Compatible ...	(103)	Central Server (101)	ONVIF Compatible	11:57:44 AM	0	The operation completed successfully	Success
■ Asoni CAM613 on 192.168.3...	(102)	Central Server (101)	CAM613	11:57:44 AM	0	The operation completed successfully	Success
■ Grundig GCI-G1536F on 192...	(109)	Central Server (101)	GCI-G1536F	11:57:44 AM	0	The operation completed successfully	Success
■ Grundig GCI-K0622D on 192...	(108)	Central Server (101)	GCI-K0622D	11:57:44 AM	0	The operation completed successfully	Success
■ Grundig GCI-K1627D on 192...	(111)	Central Server (101)	GCI-K1627D	11:57:44 AM	0	The operation completed successfully	Success
■ Vivotek FD8154 on 192.168...	(110)	Central Server (101)	FD8154	11:57:44 AM	0	The operation completed successfully	Success
■ Vivotek IP7131 on 192.168.3...	(107)	Central Server (101)	IP7131	11:57:44 AM	0	The operation completed successfully	Success

Recently added, 0

Recently updated, 0

Groups, 0

Devices, 7

Devices live monitoring

Ganz CORTROL Global Administration Guide

Channels

The channel monitoring section contains details about channel streams. Wherever relevant, there is information about both main and secondary video streams in separate columns.

Channels can have critical errors (red) and/or **warnings** (yellow). Warnings usually appear due to minor issues - e.g., missing substream, too big GOP length etc. You can **ignore** them by right-clicking item(s) and selecting *Ignore warnings > (preference)*. If you want the warnings to be shown again, right-click the items and select *Reset warnings*. To **reset** all warnings, go to the Ganz CORTROL Console application settings (main menu > Settings) and select the corresponding option.

Monitoring > Channels

Monitoring

Servers

Devices

Channels

1

3

Streams

Export to CSV

Notifications

✕

1 selected

TITLE	STATUS
<div><div></div><div>(Generic) ONVIF Comp...</div></div>	Normal
<div><div></div><div>(Generic) ONVIF Comp...</div></div>	Normal
<div><div></div><div>(Generic) ONVIF Comp...</div></div>	Normal

1 critical error and 3 warnings for channels in the Monitoring section

The Channels section has the following columns in the main area table (some are hidden by default):

- **Title:** channel name
- **Server:** the server currently handling the target channel's device
- **Device:** the name of the underlying hardware piece for the target channel
- **Device model:** underlying device type
- **Organization:** if the channel belongs to an organization, if will be displayed here
- **Status:** current channel condition (e.g., Disabled means the channel has been turned OFF in the *Channels* section)
- **Status update time:** timestamp of when the channel status was last checked
- **Online:** shows channel uptime in percents compared to the total server run time
- **Video loss duration:** shows if the video stream is not available; if yes, for how long the video stream has been lost
- **Kbit/s:** stream bit rate (Kbits per second), separate columns for the main and secondary streams
- **FPS:** stream frame rate (frames per second), separate columns for the main and secondary streams
- **Resolution:** frame size in pixels, separate columns for the main and secondary streams
- **Codec:** stream compression, for both main and secondary streams, separate columns for the main and secondary streams
- **GOP size:** key frame interval, for both main and secondary streams (only if recording is activated), separate columns for the main and secondary streams
- **Recording:** recording status ON/OFF (activated/not activated)
- **Recording error:** if any
- **Frame cache:** the amount of memory allocated for pre-recording of the target channel (total for all channel streams)
- **Stream storage:** destination storage, for main, secondary, and edge streams
- **Information:** additional information, if any, will be displayed here (usually, errors; normally, the field is empty)

Ganz CONTROL Global Administration Guide

- **Motion detection mode:** currently used motion detection setting (disabled/camera-side/software-side high accuracy mode/software-side high performance mode)
- **IP:** device IP address or hostname
- **Port:** device HTTP/HTTPS port (from device settings, used to exchange service information, not data)
- **Jitter:** frame latency; shows delay (in milliseconds) between expected and actual frame arrival time, separate columns for the main and secondary streams
- **Error:** the latest error related to the channel (same as in *Details*, reset upon server restart)
- **Error date:** the latest error timestamp
- **VA Enabled:** video analytics status
- **VA Detector result:** video analytics response (successful/error)
- **VA Device:** device used for video analytics
- **VA Requested detection rate:** detection frequency interval preset
- **VA Actual detection rate:** actual detection rate
- **VA Average detection time:** average time spent on detection
- **VA Average processing time:** time spent on data processing
- **VA Processed frame count:** how many frames were analyzed
- **VA Skipped frame count:** how many frames were skipped
- **VA Processed frame rate:** how many FPS attached video streams have
- **VA Skipped frame rate:** how many FPS skipped
- **VA Detected frame rate:** actual attached video stream FPS
- **VA Decoder result:** video analytics decoder response
- **VA Decoder device:** video analytics device (if any attached)
- **VA Codec:** what codec is used to decode the attached stream
- **VA Average decoding time:** how much time is spent on video stream decoding

For any channel, you can press the *Details* button on the upper panel to see the list of all **channel-related errors**, starting from last the server start. This list is purged upon server restart.

	TITLE	ID	SERVER	STATUS	TIME	CONFIGURAT...	CONFIGURATION UPDATE RESULT TEXT	VIDEO LOST	BITRATE
	(Generic) ONVIF Compatible ...	(106)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully		
	Asoni CAM613 on 192.168.3...	(104)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully	yes	0
	Asoni CAM613 on 192.168.3...	(105)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully	yes	0
	Grundig GCI-G1536F on 192...	(114)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully		471087
	Grundig GCI-K0622D on 192...	(113)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully		53273
	Grundig GCI-K1627D on 192...	(116)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully		68642
	Vivotek FD8154 on 192.168...	(115)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully		33169
	Vivotek IP7131 on 192.168.3...	(112)	Central Server (101)	Success	12:23:30 PM	0	The operation completed successfully		29266

Channels live monitoring



For replication channels, main and secondary stream properties will be shown as zeroes or blank, as there is no actual incoming video stream.




Only channels attached to servers are shown here.

Note that *Not activated* recording status may both mean either that recording is not configured (disabled) or that recording has not been activated according to a schedule. The *Activated* status will appear if at least one of the channel streams is set to be recorded based on any configuration apart from *No recording*.

For any channel, you can also view the currently **active recording profiles** for all its streams. To do this, press the *Active recording profiles* button in the upper panel. A dialog window will pop up, providing the information about the stream recording configuration. An empty list means no recording configuration is assigned to any of the channel's streams. This feature is useful for verifying if the recording schedule is executed correctly.

Ganz CORTROL Global Administration Guide



Active recording profiles for the channel named i-PRO

Streams

This section displays the properties of **every recorded stream** separately. For example, if a channel has both main an secondary streams with audio activated, there will be three entries. Replication streams are also displayed separately.

- **Channel:** stream source, one of the existing enabled channels
- **Stream type:** video, audio, motion, external data (from [data sources](#)), or VCA metadata
- **Status:** current stream condition
- **Server:** originating server
- **Device:** originating device
- **Status time:** last status update timestamp
- **Recording storage:** target storage title
- **Recording directory:** one of the target storages on the corresponding server
- **Last recording time:** timestamp of the last recorded frame (useful for troubleshooting the recording)
- **Prerecording time:** actual number of second held in the pre-recording buffer (may be lower then the setting if not enough memory, or 0 when not required)
- **Information:** additional information, if any, will be displayed here (usually, errors; normally, the field is empty)

Monitoring

Export to CSV

✖

1 selected

Servers

Devices

Channels

Streams 440

Archive statistics

Storages


CHANNEL	STREAM TYPE	STATUS	SERVER	STATUS TIME	RECORDING STORAGE	LAST RECORDING TIME	PRERECORDING TIME
emul	Video stream	Normal	Global Server	7/12/2019 17:00:48	none	7/12/2019 16:59:18	0.0:00:05.000
emul 1	Video stream	Normal	Global Server	7/12/2019 17:00:48	none	7/12/2019 17:00:06	0.0:00:05.000
emul 10	Video stream	Normal	Global Server	7/12/2019 17:00:48	none	7/12/2019 16:59:50	0.0:00:05.000
emul 100	Video stream	Critical	Global Server	7/12/2019 17:00:48	none	7/12/2019 17:00:07	*0.0:00:03.950
emul 101	Video stream	Critical	Global Server	7/12/2019 17:00:48	none	7/12/2019 17:00:41	*0.0:00:03.099
emul 102	Video stream	Critical	Global Server	7/12/2019 17:00:48	none	7/12/2019 16:59:44	*0.0:00:02.150

Streams with reduced buffer size will have *Critical* status

Note that the **pre-recording** time here may differ from your pre-recording setting in the recording configuration. Ganz CORTROL server applies smart logic here and traces situations when larger buffer is not necessary, or even preventing the system from normal operation. Thus:

- if the currently used recording profile does not involve any pre-recording (e.g., *Continuous recording*, or event-driven with no defined E&A events), the buffer size will be reduced to 0
- if there is not enough memory for all channels (the server is overloaded), the server will reduce pre-recording buffers; channels with largest frame cache size will have their buffers reduces first pf all
- upon server startup, the buffer size is increased gradually for smoother start

Ganz CORTROL Global Administration Guide

 Removed and disabled channels will not be shown under this section: only active recorder tasks are displayed here.

Archive Statistics

Here, you can see **recording statistics** for every channel (all streams and all storages included):

- **Channel:** configured channel title
- **Begin date:** the time of the very **first** recording for the target channel
- **End date:** the time of the very **last** channel's recording
- **Duration:** total archive **duration** for each channel
- **Data size:** total archive **size** per channel, based on the time boundaries mentioned above
- **Data size per day:** an estimate of how much space one day's recordings will take (average per day, calculated based on existing archive size)
- **Protected interval:** total duration of the archive, which has been marked as protected, and will not be removed (erased)
- **Protected data size:** total size of the protected archive
- **Server:** the server where the data is recorded (convenient for filtered view based on the server)

Double-click any entry or use the *View* button on the top panel to display **details** for each channel: view the recording statistics per storage and with detailed information on every stream including audio, motion, VCA and external data feeds.

To review and **unlock** the footage that has been **protected** from erasing via Ganz CORTROL Client application, select the target channel(s) and click the *Protected intervals* button on the top panel.

Monitoring

Servers

Devices

Channels

Streams

Archive statistics

Storages

User sessions

Video walls


External services

Reports

Access control

OPC





ViewProtected intervalsExport to CSV✕ 1 selected

CHANNEL	BEGIN DATE	END DATE	DURATION	DATA SIZE	DATA SIZE PER DAY
 Store	7/8/2018 06:45:36	7/16/2018 15:33:39	8.8:48:02	109.90 GB	13.13 GB

Protected intervals

Protected intervals

Unprotect✕ 1 selected

CHANNEL	SERVER	STATUS	BEGIN DATE	END DATE	DURATION	INFORMA
 Store	Global Server		7/13/2018 08:42:07	7/13/2018 10:12:10	00.01:30:03	
 Store	Global Server		7/13/2018 12:22:08	7/13/2018 13:51:54	00.01:29:45	
 Store	Global Server		7/13/2018 13:51:54	7/13/2018 15:21:39	00.01:29:45	
 Store	Global Server		7/13/2018 15:21:39	7/13/2018 16:51:20	00.01:29:40	

Archive statistics and protected archive intervals

From this dialog box, you can **unlock the previously protected** parts of the archive. If these recordings fall under quotas (storage or duration, server wide or individual), they will be erased immediately.

Storages

Statistics, properties and status for each storage unit are displayed here:

Ganz CORTROL Global Administration Guide

- **Title:** storage label, either built-in or user-defined
- **Status:** operation status of the target storage
 - *Normal:* the storage can be used for recording and there are no issues detected
 - *Critical:* the storage cannot be used for recording due to one or more serious errors, check the Information column for description
- **Server:** storage location, i.e., on which server is configured
- **Status update time:** last time the storage status was obtained (use the *F5* button on your keyboard to refresh the list)
- **Path:** storage path on its server of origin
- **Encrypted:** indicates, if the target storage has encryption ON/OFF, or if there are encrypted storages without provided passwords (will be marked red)
- **Free space:** how much free space in gigabytes is left on the disk
- **Free space %:** same but shown as percentage in reference to the total storage size
- **Used space:** the amount of disk taken by all data (including third-party data)
- **Last available time:** the moment of time when the target storage was last available for recording
- **Total space:** entire storage size
- **Information:** additional details, if any (e.g., storage related errors)
- **Disk queue length:** number of read/write requests (local storage only)*



All storage information is retrieved through the API of the underlying operating system. If you think some of the information may be incorrect, check the same statistics via Windows interface.

*The *Disk queue length* column is useful for assessing the **storage condition**. It reflects either the current or the average queue length (whichever is higher) per disk. Generally, 5+ requests per disk indicate a bottleneck in the disk subsystem. 2+ requests per disk for a long period of time may also indicate bottlenecks. For RAID storages, the queue length is summarized, so, for example, for a system with 8 disks the queue length should not exceed 16. A value of 0 means the storage is not overloaded. An absent value (**empty**) means it cannot be retrieved: the field will be empty for network storages and for unreachable disks (e.g., server offline).

If one or more storages have issues, the corresponding section will have a red circle with the number of detected issues next to the section name. Inaccessible storage units will have no total and free space information.

User Sessions

This monitoring area displays currently active incoming Ganz CORTROL Client connections via both TCP and HTTP ports with the following details:

- **User:** user account
- **Remote address:** IP address and port of the client machine, from which the connection is made
- **Start time:** session start time
- **Type:** client application type, may be Ganz CORTROL Console, Ganz CORTROL Client, HTTP or Mobile
- **Software version:** remote client version
- a list of **CPU**, **memory** and **network load** stats from the remotely connected client machine, similarly to the ones in the *Servers* section

Disconnected sessions will automatically disappear from the list.

Ganz CONTROL Global Administration Guide

USER	ID	REMOTE ADDRESS	START TIME
Built-in Administrator account	(1)	192.168.1.83:54237	12/22/2015 12:53:39 PM

User Sessions live monitoring

Video Walls

This section contains information about the currently connected [video walls](#) and their displays.

Data Sources

This section contains information about the configured [data sources](#) and their status:

- **Title:** data source name
- **Status:** current data source status
- **Server:** the server that is receiving the data
- **Last data receive time:** the timestamp of the last received bit of data from the target data source
- **Error:** if any
- **Status time:** status timestamp
- **Additional information:** if any

External Services

If License Plate Recognition, Face Recognition and/or other [external services](#) (third-party integrations) are connected, their session properties will be displayed here: service name, remote address and involved user account.

Reports

This section contains health monitoring data for the configured automatic VCA and software counter [reports](#).

TITLE	STATUS	REPORT STATUS	EXECUTION TIME	NEXT EXECUTION TIME	STATUS TIME	INFORMATION
DailyCustomers	Normal	NotExecuted			1/5/2018 2:02:38 PM	
WeeklyCustomers	Normal	NotExecuted		1/7/2018 12:00:00 AM	1/5/2018 2:02:38 PM	

Report status

If a report has been sent at least once (by schedule, not as a test), the last execution time is shown here. For the reports that are currently set to be emailed automatically, the next (scheduled) execution time is also displayed.

Ganz CONTROL Global Administration Guide

Access Control

If any third-party [access control](#) services are connected, their connection properties and status will be displayed here.

OPC

If any third-party [OPC servers](#) are connected, their connection properties and status will be displayed here.

Indicators

All [indicators](#) configured in your system will be displayed here, so that you can see their status - all in one place.

GSM Modems

All [GMS modems](#) configured in the system will appear here:

- **Title:** modem name
- **Status:** current modem status
- **Server:** the server that has the modem physically connected to it
- **Error:** error code or text, if any
- **Status time:** status timestamp
- **Additional information:** error details, if any

Monitoring		<div>Export to CSV</div> <div>Notifications</div> <div>✖ 1 selected</div>							
Indicators									
GSM modems		TITLE	ID	STATUS	SERVER	ERROR	STATUS TIME	ADDITIONAL INFORMATION	
GSM modems			quectel	(2069)	Critical	My Server (101)	No connection to modem	6/28/2023 23:46:02	Failed to open serial port COM6: The system cannot find the file specified
MQTT clients									

Example of an offline GMS modem with critical status causing error in the Monitoring section

MQTT Clients

All currently active [MQTT clients](#) will appear here. If the MQTT client is configured but is inactive, it will not be listed.

Databases

This section lists the [time series databases](#) associated with data sources and data channels.

Ganz CORTROL Global Administration Guide

14.1 Audit

To access the global audit log in Ganz CORTROL Console, choose *Audit* section in the bottom-left-hand panel.

The audit log contains detailed information about the most important user activities and server events. Events are organized in a way similar to the Windows Event log, and can be filtered and sorted by any field just by clicking on the relevant field. By default, entries are sorted by time, with latest on top. Use *Search* field in the upper-right-hand menu to filter the records; press *Refresh* button to reload the item list.



Please note that your actual audited events may vary depending on the software license edition.

The log has two sections: *Servers* and *Users*; these can be accessed by clicking the corresponding items in the menu on the left, when in the *Audit* section.

Servers

Each event contains the following values:

- **Time:** event timestamp in the system locale-specific format
- **Server:** name of the server from which the event originates
- **Class/subclass:** event category
- **Event:** a brief description of the event; see below for the detailed information about the logged event types
- Other relevant fields - **user, resource, data, info, misc. IDs**, : additional information relevant to the event, e.g., error details, target resource type

Double-click any event in the list to view the full information.

Audit > Servers					
Built-in Administrator account Search					
Audit	Define filter	View	1 selected		
Servers	ID	TIME	SERVER	EVENT	INFORMATION
Users	(59)	4/5/2016 5:31:08 PM	Global Server (101)	Configuration loaded	The operation completed successfully
	(60)	4/5/2016 5:31:58 PM	Global Server (101)	Configuration loaded	The operation completed successfully
	(62)	4/5/2016 5:35:24 PM	Global Server (101)	Configuration loaded	The operation completed successfully
	(63)	4/5/2016 5:36:03 PM	Global Server (101)	Configuration loaded	The operation completed successfully
	(64)	4/5/2016 5:36:59 PM	Global Server (101)	Configuration loaded	The operation completed successfully
	(67)	4/5/2016 6:00:36 PM	Global Server (101)	Configuration loaded	The operation completed successfully
	(68)	4/5/2016 6:00:38 PM	Unknown resource (112)	Central server disconnected	1
	(69)	4/5/2016 6:00:38 PM	Unknown resource (112)	Configuration loaded	The operation completed successfully
	(70)	4/5/2016 6:00:39 PM	Unknown resource (112)	Central server connected	2
Configuration	(71)	4/5/2016 6:00:51 PM	Global Server (101)	Configuration loaded	The operation completed successfully
Events & Actions	(72)	4/5/2016 6:00:53 PM	Unknown resource (112)	Synchronization completed	
Monitoring	(73)	4/5/2016 6:00:53 PM	Unknown resource (112)	Configuration loaded	The operation completed successfully
Audit	(74)	4/5/2016 6:26:18 PM	Global Server (101)	Configuration loaded	The operation completed successfully

Audit log, *Servers* section

The following **events** are logged in this section:

- **Internal server events**
 - **Audio output action completed:** an E&A action to send audio to device was executed
 - **Automatic backup failed:** an automatic backup was scheduled but failed for some reason
 - **Automatic backup succeeded:** a scheduled backup copy of the databases was successfully created
 - **Central server connected:** central server has successfully connected to the target recording server
 - **Central server disconnected:** central server has disconnected from the target recording server because the target server is offline, unreachable, has been removed from the central

Ganz CONTROL Global Administration Guide

server configuration or has invalid configuration

- **Configuration loaded:** configuration has been successfully loaded from the database and applied to the target server
- **Configuration Loading failed:** unable to load or apply server configuration
- **Configuration reset failed:** an attempt to reset the recording server configuration was made but failed for some reason
- **Configuration reset requested:** recording server configuration reset was requested via Ganz CONTROL Console (this message will be normally followed by another entry reflecting the rest status)
- **Configuration request succeeded:** recording server configuration was successfully reset
- **Configuration saved:** server configuration was saved to the database
- **Connected to mirroring server:** central server successfully connected to its configured mirror
- **Connected to recording server:** central server successfully connected to a recording server
- **Disconnected from mirroring server:** central server disconnected from its configured mirror (e.g., because the mirror is no longer available)
- **Disconnected from recording server:** central server disconnected from a recording server
- **Event action failed:** an E&A action execution attempt was made but failed, double-click the event entry for details
- **Event action succeeded:** an E&A action was successfully executed, double-click the event entry for details
- **External users added:** an attempt to add new external users via AD/LDAP was made, see additional information for status details
- **External users removed:** external users were removed from the server configuration
- **External users updated:** AD/LDAP user list was synchronized
- **Failover node activated:** failover server changed its state from *Idle* and received configuration to act instead of a recording server
- **Failover status changed:** server was included or excluded from a failover cluster, or its status changed from/to *Unknown* (see server [health monitoring](#) for details)
- **Number of external users exceeded maximum allowed:** the number of imported AD/LDAP users exceeds maximum allowed by the license
- **Open VCA notification received:** server VCA engine event (e.g., VCA license error)
- **Remote update initiated:** remote software update was initiated via Ganz CONTROL Console
- **Server restarted by watchdog for maintenance:** server was restarted by the watchdog service (double-click the event entry for the details about restart reason)
- **Server started:** Ganz CONTROL server service started
- **Server stopped:** Ganz CONTROL server service stopped
- **Synchronization completed:** central server has successfully synchronized configuration data with the target recording server
- **Resource access**
 - **Archive**
 - **Bookmark added:** a bookmark was added to the target channel on behalf of the server (via E&A action, no user interaction)
- **Uncategorized**
 - **Permissions updated:** user permissions were edited, double-click the event entry for details
 - **Recording Error:** Unable to save video stream from particular channel
 - **Recording Recovered:** video stream recording recovered

Double-click any event to open it in a separate dialog box with **additional information** about event source, such as: backup file path for the *Automatic backup* event, error code for the *Open VCA notification* event etc.

Ganz CONTROL Global Administration Guide

Event 70:Central server connected	
Event details	
Id	(70)
Time	4/5/2016 6:00:39 PM
Class	Server
Subclass	Server activity
Event	Central server connected
Server	Unknown resource (112)
Remote address	192.168.1.83:59174
Session Id	2
OK	

Event example for the *Servers* audit log

Users

The events related to user input (configuration via Ganz CONTROL Console, resource access via client applications) are available here. Some of these (mostly configuration related) are triggered by user actions in Ganz CONTROL Console and some (mostly related to resource access) are based on user actions in Ganz CONTROL Client. The following **events** are logged in this section:

- **Events & Actions**
 - **Rule modifiers:** events related to rule schedules and conditions
 - Event **condition** added/removed/updated: a condition was modified
 - Event **schedule** added/removed/updated: a schedule was modified
 - Event **schedule item** added/removed/updated: an individual schedule item was modified
 - **Action** added/removed/updated: an E&A action was modified
 - **Event** added/removed/updated: an E&A event was modified
 - Event-action **rule** added/removed/updated: a rule in the E&A table was modified
 - **Global event** added/removed/updated: a global event was modified
 - **Mail server** added/removed/updated: an SMTP server in E&A configuration was modified
- **External services:** events associated with external services operating via HTTP API, such as FR, LPR and third-party software integrations
 - **External service** added/removed/updated: external service connection was modified
 - **External service group** added/removed/updated: a group for external services was modified via Ganz CONTROL Console
- **Failover management**
 - Failover cluster added/removed/updated: failover cluster settings were modified via Ganz CONTROL Console
- **Installation:** events related to software installation and upgrade

Ganz CORTROL Global Administration Guide

- Remote update requested: a user has requested remote server update via Ganz CORTROL Console (usually followed by the *Remote update initiated* event entry in the *Server* audit section)
- **Recording**: changes to recording setup via Ganz CORTROL Console
 - Recording **configuration** added/removed/updated
 - Recording **profile** added/removed/updated
 - Recording **schedule** added/removed/updated
 - Recording **schedule item** added/removed/updated
- **Resource access**: user actions concerning all types of resource access from connected clients
 - **Archive**: playback related events triggered from different Ganz CORTROL Client playback modes
 - Archive **replication** accessed: recordings from a channel replica were accessed
 - Archive **search** accessed: recordings from a channel were accessed
 - Archive **snapshot** exported: a single or multichannel snapshot was exported from one of the archive playback modes
 - Archive **timeline** accessed: archived data was accessed in a playback mode that has timeline
 - Archived **data accessed**: available recordings from a channel were played back
 - Archived **data exported**: a video clip was exported (double-click the event entry for details)
 - **Bookmark** added/removed: a new bookmark was appended to the channel timeline or deleted from it
 - **Bookmark popup** confirmed: bookmark popup caused by E&A action was approved by a user via Ganz CORTROL Client application
 - **Bookmark search** accessed: bookmark were searched from the Ganz CORTROL Client playback mode
 - **Live**
 - **Audio input** received from device: audio IN was activated from live view
 - **Audio output** sent to device: audio OUT was activated from live view
 - **External data** accessed: information from *Data sources* was streamed with live video
 - **Layout** added/removed/updated: a layout was modified in Ganz CORTROL Client
 - **Live data** accessed: live video stream was displayed
 - **Motion data** accessed: motion information was streamed with live video
 - **VCA data** accessed: Open VCA metadata was streamed with live video
- **PTZ**: pan, tilt, zoom, focus, iris related actions, as well as PTZ presets and tours for the target channel
 - **Navigate**: PTZ event from older database versions (backward compatibility)
 - PTZ **auto-focus/auto-iris** activated: device automatic focus/iris feature was activated
 - PTZ **focus/iris** started/stopped: device manual focus/iris capability was used
 - PTZ **pan/tilt started**: device was panned/tilted
 - PTZ **pan/tilt stopped**: this event is generated after five seconds after the last pan/tilt command (after the PTZ control was released)
 - PTZ **preset** saved/activated/deleted: PTZ preset was accessed
 - PTZ **tour** saved/activated/deactivated/deleted: PTZ tour was accessed
 - PTZ **zoom started**: device zoom IN/OUT capability was used
 - PTZ **zoom stopped**: this event is generated after five seconds after the last zoom IN/OUT command (after the PTZ control was released)
- **User defined**: this event is generated when an audit entry is created based on a user-defined E&A action *Write to audit log*
- **Video walls**: events based on video wall related user actions in Ganz CORTROL Client via *Resources* panel and/or *Video Walls* section
 - Video wall **current layout saved as startup**: the currently displayed layout was set

Ganz CORTROL Global Administration Guide

- as startup for the target video wall display via video wall management
- Video wall **layout saved as startup**: a layout was set as startup for the target video wall display
- Video wall **layout sequence paused**: the layout sequence currently assigned to a video wall display was stopped
- Video wall **layout sequence set**: a pre-saved layout sequence was assigned to a video wall display
- Video wall **layout set**: a pre-saved layout was assigned to a video wall display
- Video wall **object popped up**: an E&A action that displays an object (channel/map/layout) on a video wall screen has been executed
- Video wall **viewport** updated: an individual viewport contents was changed within a layout of a video wall display
- **Copied exported items**: exported files were copied from the Ganz CORTROL Client library to an external destination
- **External data search** accessed: archived information from *Data sources* was searched from Ganz CORTROL Client
- **External service search** accessed: archived external service data was searched from Ganz CORTROL Client
- **Live snapshot** exported: a snapshot was saved from the Ganz CORTROL Client live view mode
- **VCA search** accessed: archived VCA data was searched from the Ganz CORTROL Client playback mode
- **Resource administration**: resource related events caused by user actions in Ganz CORTROL Console management application
 - **Channels**
 - Channel added/removed/updated: target channel was modified in the described manner
 - Channel attached/detached: target channel was attached to/detached from its device
 - Channel enabled/disabled: target channel was activated/deactivated
 - Device channel group added/removed/updated: a channel group was modified in the described manner
 - **Data sources**
 - Data source added/removed/updated: a serial data source was modified in the described manner
 - Data source profile added/removed/updated: a profile for the data source was modified
 - **Devices**
 - Administer: device management event from older database versions (backward compatibility)
 - Device added/removed/updated: a device was modified in the described manner
 - Device group added/removed/updated: a device group was modified in the described manner
 - **Layouts** and layout **templates**
 - Layout template added/removed/updated: a layout grid was modified
 - Layout group added/removed/updated: a group for shared layouts was modified
 - **Live podcasts**
 - Live podcast added/removed/updated: a live broadcast was modified
 - Live podcast enabled/disabled: a live broadcast was activated/deactivated
 - **Maps**
 - Geo map added/removed/updated: a map based on the world map was modified
 - Map added/removed/updated: a picture-based map was modified
 - Map group added/removed/updated: a map/geo map group was modified
 - Map item added/removed/updated: an individual map item (e.g., channel marker) was modified on a map/geo map

Ganz CORTROL Global Administration Guide

- **Networks**
 - Network added/removed/updated: a network connection was modified
- **Folders**
 - Folders added/removed/updated: an organization was modified
- **Servers**
 - **Connection** updated: server connection (IP, port, SNMP settings) was modified (it is added/removed together with the server)
 - **Server** added/removed/updated: a server was modified in the Ganz CORTROL Global configuration
 - Server **configuration backed up**: server configuration was backed up manually via wizard (this event is only logged if the backup was run while Ganz CORTROL server was stopped)
 - Server **configuration restored**: server configuration was restored manually via wizard (this event is only logged if the wizard was run while Ganz CORTROL server was stopped)
 - **Server group** added/removed/updated: a server group was modified
- **Software counters**
 - Software counter added/removed/updated
- **User buttons**
 - User button added/removed/updated: a user button was modified
 - User button group added/removed/updated: a user button was modified
- **Video walls**
 - Video wall added/removed/modified: a video wall was modified
 - Video wall group added/removed/updated: a video wall was modified
- **Visual groups**
 - Visual group added/removed/modified: a visual group was modified
- **Security System** added/removed/updated, enabled/disabled
- **OPC client** added/removed/updated, enabled/disabled
- **Server security**: events related to server security, access and permission/policy/user management
 - **Administration permissions** updated: administrative permissions for Ganz CORTROL Console access were modified for a user or a user group
 - **Audit log** accessed: the *Audit* section of Ganz CORTROL Console was accessed
 - **Confirmed server warning** notification: a popup warning from the server E&A action was confirmed in Ganz CORTROL Client
 - **External user group** added/removed/updated: AD/LDAP user group was modified
 - **Client connection** permissions updated: administrative permissions related to remote client access were modified
 - **Log in**: a user has successfully logged into the target server
 - **Log out**: a user has logged out of the server or his session timed out
 - **Monitoring data** accessed: the *Monitoring* section of Ganz CORTROL Console was accessed
 - **Object added** to group: some object in the server configuration was added into a group of the corresponding type
 - **Object removed** from group: some object in the server configuration was deleted from a group of the corresponding type
 - **Permissions** added/removed: user permissions were modified
 - **Security policy** added/removed/updated: server security policy was modified
 - **Unsuccessful log in**: a user has attempted to log into the server without success
 - **User** added/removed/updated: a user account was modified
 - **User group** added/removed/updated: user group settings were modified

Double-click an event entry to see **details** about the related resource, such as: resource name, the user who did the changes or executed the action, destination path for the copied exported files etc.

Ganz CORTROL Global Administration Guide

Audit > Users

Built-in Administrator account

Search

Audit

Servers

Users

Configuration

Events & Actions

Monitoring

Audit

Define filter

View

1 selected

ID	TIME	USER LOGIN NAME	USER'S FULL NAME	CONNECTION ADDRESS	CONNECTION TYPE	EVENT	SERVER	INFORMATION
(24)	3/23/2016 3:27:25 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454	Monitor	Log out	Global Server (101)	
(22)	3/23/2016 2:19:41 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454		Receive Data	Global Server (101)	apix
(20)	3/23/2016 2:10:27 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454		Receive Data	Global Server (101)	vvtk
(19)	3/23/2016 2:10:27 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454		Receive Data	Global Server (101)	test
(16)	3/23/2016 2:06:55 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454		Receive Data	Global Server (101)	vvtk
(12)	3/23/2016 1:55:42 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454		Receive Data	Global Server (101)	test
(11)	3/23/2016 1:55:41 PM	admin	Built-in Administrator account (1)	127.0.0.1:62454	Monitor	Log in	Global Server (101)	
(10)	3/23/2016 1:55:35 PM	admin	none			Unsuccessful log in	Global Server (101)	
(9)	3/23/2016 1:55:30 PM	admin	none			Unsuccessful log in	Global Server (101)	
(8)	3/23/2016 1:55:27 PM	admin	none			Unsuccessful log in	Global Server (101)	
(7)	3/23/2016 1:55:24 PM	admin	none			Unsuccessful log in	Global Server (101)	
(3)	3/23/2016 1:54:14 PM	admin	Built-in Administrator account (1)	127.0.0.1:62443	Console	Log in	Global Server (101)	
(2)	3/23/2016 1:54:09 PM	admin	none			Unsuccessful log in	Global Server (101)	

Audit log, *Users* section

Problems

This section is a filter: it contains important messages from Servers and Users sections, which indicates that **the system has a potential problem**. For example, messages about system suspension indicate that some system setting cause system suspension, and this behavior may cause server freezes and gaps in the video archive.

List of potentially problematic errors:

- **Recording Error:** Unable to save video stream from particular channel
- **Configuration Loading failed:** unable to load or apply server configuration
- **Server restarted by Watchdog:** Critical server restart

Use the buttons in the upper panel:

- *Clear*: discard all entries and remove them from the problem list
- *View*: open the item details
- *Reset*: restore all log messages that are considered problems
- *Export to CSV*: save the list of problems and their details into a comma-separated-value format file

Audit > Problems

admin

Audit

Servers

Users

Problems 1842

Clear

View

Reset

Export to CSV

1 selected

ID	TIME	SERVER	EVENT	INFORMATION	ADDITIONAL INFORMATION
(8949)	6/28/2023 6:19:11 PM	Glo (101)	Suspension of server detected		[Duration in seconds]=93; [Start time]=6/28/2023 6:17:38 PM
(8940)	6/28/2023 4:28:18 PM	Glo (101)	Suspension of server detected		[Duration in seconds]=718; [Start time]=6/28/2023 4:16:20 PM
(8939)	6/28/2023 4:16:19 PM	Glo (101)	Suspension of server detected		[Duration in seconds]=3631; [Start time]=6/28/2023 3:15:48 PM

Problems section of the Audit log

The number in the red circle next to the section name indicates the number of logged problems.

Define Filters

Server and user audit logs can be filtered for easier analysis. Click the *Define filter* button on the upper panel to bring up the dialog box.

Available filters:

- by period
- by event

Ganz CONTROL Global Administration Guide

- by server
- by resource
- by user (only for the user-initiated events, *Users* tab)

In the *Set period* tab, specify the time limits for log output. You can set the date and time manually or use automated controls for preset time boundaries: last day/week/month, the whole time, and also set start/end boundaries equal to the log beginning/end.

The screenshot shows the 'Filter' window with the 'Set period' tab selected. The left sidebar contains 'Filter', 'Set period' (selected), 'Select events', and 'Select resources'. The main area is titled 'Set period' and 'Set query period'. It features four preset buttons: 'All time', 'Last day', 'Last week', and 'Last month'. The 'From date and time' section shows a date of 10/15/2015 and a time of 2:52:03 PM. Below this is an unchecked checkbox for 'From beginning' with the description 'Starts query from the first time the system was set up'. The 'To date and time' section shows a date of 12/22/2015 and a time of 2:52:03 PM. Below this is a checked checkbox for 'Until now' with the description 'Ends query when timestamp submitted'. At the bottom are buttons for 'Reset query', 'Submit query', and 'Cancel'.

Set the time boundaries for audit log output

In the *Select events* tab, choose specific event types to narrow down the search. Note how the choice differs for the *Servers* and *Users* log filters.

The screenshot shows the 'Filter' window with the 'Select events' tab selected. The left sidebar contains 'Filter', 'Set period', 'Select events' (selected), and 'Select resources'. The main area is titled 'Select events' and 'Select events'. It shows a list of event types under 'Internal server events': 'Automatic backup failed' (checked), 'Automatic backup succeeded' (unchecked), 'Central server connected' (unchecked), 'Central server disconnected' (unchecked), 'Configuration loaded' (unchecked), 'Configuration reset failed' (checked), and 'Configuration reset requested' (unchecked). At the bottom are buttons for 'Select all', 'Clear all', 'Reset query', 'Submit query', and 'Cancel'.

Specify event types for the *Servers* audit log output

In the *Select users* and *Select servers* tabs, you can choose target servers and users, who initiated the event. Note that if you want to search for events where a user was a target (e.g., user permissions changed), you need to select that user in the *Select resources* tab.

Ganz CORTROL Global Administration Guide

💡 Selecting **resources** will search for them in the additional event fields (i.e., events where these resources were a target). If you want to see events that were initiated by a specific **user** and/or on a specific **server**, choose them in the corresponding tabs - *Select servers* and *Select users*.

Filter *

Filter

⌚ Set period

⚡ Select events

📁 Select resources

Select events

Select events

☐ Recording schedule updated

☒ Resource access

- ☒ Archive
 - ☐ Archive replication accessed
 - ☒ Archive search accessed
 - ☒ Archive snapshot exported
 - ☐ Archive timeline accessed
 - ☒ Archived data accessed
 - ☒ Archived data exported

Select all

Clear all

Reset query


Submit query

Cancel

Specify event types for the *Users* audit log output

In the *Select resources* tab, you can choose which resources will be mentioned in the log entries. Note that if multiple resources are chosen, the filter will apply *OR* logic, meaning that output log will only be displayed if it contains log entries for **at least one** specified resource, and not for the combination of all specified resources.

Ganz CORTROL Global Administration Guide



Narrow down your search by specifying resources

Use the *Search* field to filter the resource list; both the list of *Resources in query* and general *All resources* will be affected by the *Search* filter. Press the *Reset query* button in the bottom left corner at any time to restart filter configuration; when you have finished, click *Submit query* to view the results. To discard filtering, simply switch to a different section in the menu on the left and then switch back to your desired section.

Detailed Audit


To track user activity in the archive playback mode of Ganz CORTROL Client, you can enable a *Detailed Archive Access Audit* and its intervals. By default, the feature is disabled. The default value for *Archive Access Audit Interval* is 15 minutes.

Setting up archive access audit and its intervals

To start logging user activity in *Archive Playback* mode, you need to turn the feature on:

1. In the left bottom panel - click on the *Configuration* tab
2. Select *Servers* on the left and double-click on your chosen server
3. Pick up storage in the popup window
4. Mark checkbox *Enable Detailed Archive Access Audit*
5. Set up your logging interval

Ganz CONTROL Global Administration Guide




An example on how to enable Detailed Archive Access Audit

Accessing logs

After you turn on playback audit logging, you can access log information in Ganz CONTROL Console:

1. In the left-bottom panel, select the *Audit* tab
2. In the left-top panel, click on *Users* and check for user activity
3. Double-click on the event you are interested in or select the event and use the *View* button on top



An example of the detailed audit review for the "streetView" camera

Reviewing log details

In the event detail window, you can find many details, including:

- Time - when the record was accessed
- User ID and User name - who accessed the record
- Channel ID/Channel Title - What channel was accessed
- Time from/Time to - what recording interval was accessed
- Remote address - IP and port of the particular machine that was used to access the recording

Logged Events

Events logged with enabled *Detailed Archive Access Audit*:

Ganz CORTROL Global Administration Guide

- **User Archive Data Display Accessed** - reviewing archive record time range
- **User Archive Data Export Accessed** - archived record video export attempts
- **User Archive Data Export Snapshot Accessed** - snapshot export attempts

15 Tools and Wizards

This chapter describes additional tools and wizards that are installed with the Ganz CORTROL server software.

See also earlier in this document: [license manager](#), [server setup wizard](#), quick [configuration wizard](#).

15.1 Archive Backup Wizard

Ganz CORTROL offers an option to **back up** any recordings from any server manually, in the proprietary Ganz CORTROL archive format. **Video, motion information, audio, VCA data streams**, as well as **external serial data** can be extracted from the original archive and saved elsewhere, with an option to include the **portable player** tool so that the downloaded recordings can be played on any Windows-based computer, even if it has no Ganz CORTROL installed.

The wizard is included with any Ganz CORTROL installation, including Ganz CORTROL Console management application and Ganz CORTROL Client application, and allows connection to **local and remote servers**.



The archive will be copied to the computer that has *Archive backup wizard* running on it. Thus, if you are connecting to a server remotely via *Archive backup wizard*, the archive copy will be **downloaded** to your computer from the server. As footage may be of significant size, make sure you have the required bandwidth available.

Start the Archive Backup Wizard from the Windows Start menu: *Start -> All Apps -> CBC AMERICA LLC -> Archive Backup Wizard* (in Windows 7 and older versions, use *Start -> All Programs -> software installation folder -> Tools -> Archive Backup Wizard*); alternatively, use *Search* to locate *Archive Backup Wizard* in the programs menu.

From the Ganz CORTROL Client application, the wizard can be launched via main application menu by opening *View -> Archive Backup Wizard* and choosing the server (one of the connected ones). The address of the server, and also the username and password, will be taken from the currently configured server connection.

Using Archive Backup Wizard

First, you will be asked to log into the target server: your user account must have an administrative permission to make archive backups plus permissions to back up footage from individual channels/channel groups. You can create archive backups from the local server or from any remote server (login procedure is analogous to Ganz CORTROL Console login), including individual recording servers. If you run the wizard from the Ganz CORTROL Client application, you will not be asked to log in; instead, your configured server connection will be used.

After you log in, you will be presented with the list of available recordings, grouped by channel and, if present, by [visual group](#). Select the channel(s) and/or visual groups you need by putting a checkmark next to each one; specify the required time range above the channel list and click *Next*.

Ganz CONTROL Global Administration Guide

Archive backup wizard

Step 1 of 4. Pickup dates and streams for backup

Pickup dates and streams for backup

Start time End time

Please provide local start and stop date/time for the backup process.

Tracks	
TITLE	SERVER
<input type="checkbox"/> Bar	
<input checked="" type="checkbox"/> Pool	
<input checked="" type="checkbox"/> Pool	192.168.1.83
<input checked="" type="checkbox"/> Facial recognitions	
<input type="checkbox"/> Facial recognitions	192.168.1.83
<input checked="" type="checkbox"/> 2nd Floor Corridor	
<input type="checkbox"/> 2nd Floor Corridor	192.168.1.83
<input type="checkbox"/> Live test	

Next Cancel

Choose the target time interval and required channels

Depending on the number of selected channels, their footage size, storage speed and connection latency, it may take a few moments to retrieve the stream information. Once it is done, you will be presented with a list of streams for each of the selected channels.


The **following tracks can be backed up**, depending on the channel recording settings and, therefore, stream availability:

- main video stream, substream and edge recordings
- video motion information
- audio stream
- VCA metadata
- external serial data from *Data sources*

Archive bookmarks and external service data (e.g., LPR/FR recognition results) are not available for backup.

Additionally, you can append the **portable player** tool with the copied part of the archive so that you can play the archive without having to install Ganz CONTROL server on another machine. Guidelines on the portable player usage are available in your Ganz CONTROL Client user guide.


Ganz CONTROL Global Administration Guide



Choose data streams and include portable player, if required

Here, you also need to specify a directory for the archive to be copied to: it may be a local hard disk, a shared network storage, or an attached USB drive. You are asked to choose an **empty folder** as a backup destination, so you may need to create a new folder from the standard *Select folder* dialog.


Ganz CONTROL Global Administration Guide



Backup progress

When ready, hit *Next* for the wizard to proceed with backing up the selected information. Depending on the size of the selected archive, the backup procedure may take some time and its progress will be displayed in the wizard window. When it is finished, you will get a confirmation with a short description of what has been done.

Ganz CONTROL Global Administration Guide



Archive backup succeeded


If you wish to back up more recordings, start the wizard again and follow the described procedure once again.

Postpone Your Archive Backup

If, during the backup progress, you decide to **stop** it for some reason, simply hit the *Cancel* button in the bottom right corner. You will then be presented with several options of how the wizard can proceed:


- save the task and files: save your current backup progress and preserve the wizard state until the next time you run it; you will be able to continue with the current backup item(s) then
- save files only: leave the files that have been downloaded so far but discard the wizard settings so that the next time you run it you will be presented with default choice
- remove files: discard current backup task completely and remove the downloaded files
- continue to download: go back and continue with the selected backup

Ganz CONTROL Global Administration Guide



Archive backup termination options

If you have chosen to save both the task and the files, next time you start the wizard you will be reminded of the unfinished backup job and offered to continue with it. If you click *Yes* to proceed with the unfinished task, it will be started automatically right after you provide your user credentials for the server login.



Continue with an unfinished backup task

15.2 Renderer Test Utility

Ganz CORTROL can utilize GPU for some operations in order to decrease the CPU load. To enable GPU acceleration, run the *Renderer Test Utility* from the Ganz CORTROL suite on the Ganz CORTROL Client workstation.

There are two supported GPU operations are:

- frame **decoding** on Ganz CORTROL Client side
- **rendering** on Ganz CORTROL Client side



GPU acceleration limitations:

- Only Windows 10 and corresponding Windows server OS editions (2016, 2019), or Windows 11.
- Only H.264 and H.265 streams for live view and digital PTZ in live view
- For fisheye image dewarp, only [Fisheye-II](#) is supported (choose the *Fisheye lens (6MP and larger resolution)* option in Ganz CORTROL Console)

All other cases will use CPU for decoding/rendering operations.

Before configuring GPU acceleration, make sure you have installed the latest official **drivers** for all your graphics cards. We also recommend having more **memory** for GPU (the more, the better). For integrated video cards, you can change this setting in BIOS. For discrete graphics, choose ones with more onboard memory (1GB per display or more).

For H.265: decoding is only available for the graphics cards that have HEVC support. Please check with the video card manufacturer for the specifications.

GPU Test and Configuration

On every client workstation where you want to enable GPU usage, launch the *Renderer Test Utility* by locating it in the *Start* menu, or simply by typing a part of the name in the Windows search. You can also run this wizard from the Ganz CORTROL Client application itself via main menu *Tools > GPU configuration wizard*. The client application will be closed during the test and then re-opened.


The first wizard screen is a **summary**. Here, you can select, which graphics cards will be used for decoding and for 3D rendering. To be able to do so, first run the GPU test so that Ganz CORTROL can learn about your GPU capabilities and determine the maximum possible load. During the test, each GPU is consequently loaded with test videos of different resolutions, starting from bigger ones. As a result, a value list is created for each GPU, which is then used by the Ganz CORTROL Client application for load balancing.



We recommend that you **re-run** the GPU test after each system change that may be related to graphics, as well as major OS updates (like feature updates) and Ganz CORTROL software upgrade.

To run the **performance test**: hit the *Test GPU* button in the bottom left corner. In the list, mark all GPUs that you wish to engage by putting check marks in the *Test* column. Then, select the target codecs, and click the *Test* button below.


Ganz CORTROL Global Administration Guide



Select graphics cards and run the test

If you have already launched the test earlier, the *Status* column will reflect the last test results. For the GPUs that have passed the test, there is no need to re-launch it, unless you have made changes to that video card configuration (e.g., added memory for the integrated card, installed a different device driver etc.). The test may take some time. If your Ganz CORTROL Client application is open, the wizard will ask you to close it and re-open later (and offer to do so automatically).

During the test, click the *Show log* button to see how the test is going. After the test is finished, the wizard will automatically switch to the previous screen, and you still will be able to view the last test log.



An example of Intel graphics card that has successfully passed the test for both h.264 and h.265 decoding.

Log colors:

- red: most important (errors, failures)

Ganz CORTROL Global Administration Guide

- yellow: warnings
- blue: information
- black: default
- gray: trace, details or low importance

Flags used in the test log indicate GPU capabilities:

- supported: graphics card is supported
- unsupported: hardware decoding is not supported by OS for this GPU
- legacy: video card is old or has old drivers, max resolution will be limited to 1080p
- canDecode: the GPU is OK to be used for decoding
- canRender: the GPU is OK to be used for rendering

As a result, the previously *Not passed* GPUs will change their status. GPUs that have passed the test, will be available for **decoding** (putting a check mark in the *Decode* column). Below the table, you can choose, which GPU will be used for **rendering**.

If you graphics card can decode both H.264 and H.265, you will have both codecs enabled after the test. However, you can deselect H.265 if you do not wish it to be decoded by GPU. Do not forget to restart Ganz CORTROL Client if you have just opened the wizard to change the settings (without running the test).



Video output process on the Ganz CORTROL Client side consists of two stages: decoding frames and rendering for displaying them. After decoding, the frames are converted and passed for rendering. If decoding and rendering operations happen on different GPUs, CPU is used in between so its load may grow a bit. Therefore, if only one GPU is used for decoding, it may be wiser to use the same GPU for rendering. Same logic is to be applied for cases when one GPU takes the most decoding load (this can be deduced from the GPU test log). But, if you happen to have a GPU that does not support decoding, you may want to use it for rendering, so that the total load is split between GPUs.

In general, according to our tests, **Intel GPUs have better decoding capabilities** (more channels can be decoded by them), and Nvidia GPUs (hi-end) are good at 3D rendering.

Click **OK** to **save** the settings and exit. If you close the wizard by clicking *Cancel* or *X*, the GPU settings will not be saved.



If you open the wizard and change **any settings** without running the test, please manually **restart** the **Ganz CORTROL Client** application for the changes to take effect.

You can re-open the wizard at any time to run the test again and/or change the settings.

Usage in Ganz CORTROL Client


After you have enabled GPU settings via wizard, the Ganz CORTROL Client application on the same machine will be able to use the GPU capabilities. Using GPU acceleration will significantly decrease the CPU load and will allow you to output more channels simultaneously on the same workstation. By combining GPU acceleration with substream usage you can gain even more, as using lower resolution streams for multichannel output is more efficient.

Ganz CORTROL Client will automatically use GPUs enabled via wizard, you do not have to enable anything else in the application settings. Limitations:

- **live** view and **DPTZ**
- **fisheye dewarp** (supported dewarp mode must be set in Ganz CORTROL Console, as described above)
- stream codec must be **H.264** or **H.265**
- stream **resolution** must be supported (see GPU test log for details), e.g., legacy GPUs will not be used for resolutions greater than FullHD

If you want to check whether the decoding is currently performed by GPU, enable rendering info in the Ganz CORTROL Client application settings. In the main menu, choose *Edit > Settings > select the Usability tab > enable the Show decoder information option > Save*.


Ganz CORTROL Global Administration Guide



Enable GPU status in Ganz CORTROL Client

After you have enabled this setting, each viewport in the live mode will have a **label next to the timestamp** (upper right corner):

- **CPU**: decoding is performed using CPU (GPU is not configured or overloaded, or stream codec/resolution is not compatible)
- **GPU**: the corresponding graphics card type will appear as a label - **Intel**, **Nvidia**, **AMD**, or **other GPU**.

 Ganz CORTROL Client will automatically switch to CPU decoding if the configured GPU is **overloaded** (more than **80%** of its decoder, renderer or memory is used).
Make sure you have at least 512MB of dedicated video memory per display (recommended minimum is 1GB per display).

Troubleshooting


If, immediately after enabling hardware acceleration, your Ganz CORTROL Client application behaves strangely, crashes, or causes other problems, try running it **without GPU** decoding. To do so a single time - for troubleshooting - use the *Ganz CORTROL Client without GPU decoding* shortcut from the Start menu (similar icon but in gray colors). This shortcut activates a so-called "**safe mode**" for the Ganz CORTROL Client application, which completely **ignores** the GPU settings configured via GPU test utility.


After launching the Ganz CORTROL Client application in "safe mode", check if the issue is gone. If the no-GPU mode helps, disable GPU decoding via *Renderer test utility* by de-selecting GPUs in the list (remove the check mark in the *Decode* column). If you have multiple graphics cards, the issue may be caused by one of them, so a wise approach would be to enable/disable the graphics adapters one by one in order to find out, which one is causing problems.

15.3 Problem Report Wizard

Ganz CORTROL features a comprehensive wizard-like tool for structured and detailed problem reporting. The tool is automatically installed at the same time as the the product and is thus available on any machine, where Ganz CORTROL software is installed.

Access Problem Report Wizard via *Start -> All Apps -> CBC AMERICA LLC -> Problem Report Wizard* (in Windows 7 and older versions, use *Start -> All Programs -> software installation folder -> Tools -> Problem Report Wizard*). Alternatively, use Windows Start Menu *Search* to locate the Problem Report Wizard in the programs menu.


 Make sure you run the Problem Report Wizard on the right computer: it gathers information from the machine it has been launched on, and **not** from any of the servers connected via Ganz CORTROL Console or Ganz CORTROL Client.



Run Problem Report Wizard from Windows Start menu

Agree to deliver system files to CBC AMERICA LLC support and hit *Next*. You can check which files are being taken from your system by clicking on the information button next to the agreement checkbox. Note that CBC AMERICA LLC will not transfer your data to any third-party companies; all the information gathered is required to help CBC AMERICA LLC efficiently resolve the reported problems.

Ganz CONTROL Global Administration Guide



VMS Client Application Problem Report Wizard

—

×

Step 1 of 3. User contact information

User name and valid e-mail address

Provided information will be used to send back solution or any other instructions based on provided Problem Report. It is highly recommended to use valid email address.

User Name

E-mail address


Back

Next

Cancel

Enter your contact information

Enter your name and your email address so that the CBC AMERICA LLC support team can contact you. Click *Next* to proceed.



VMS Client Application Problem Report Wizard

—

×

Step 2 of 3. Problem descriptions

Problem descriptions

PROBLEM	STEPS TO REPRODUCE	FOUND SOLUTION

Add problem description

Problem description already provided

Back

Send report

Cancel

Problem description

If you were asked by support team to generate a problem report, copy the **ticket ID** from the email communication and add it to the report by clicking the *Problem description already provided* button. This will help the support

Ganz CONTROL Global Administration Guide

team to classify your report faster, and it will also guarantee that your report will go directly to the team member responsible for the thread.

The screenshot shows the 'VMS Client Application Problem Report Wizard' at 'Step 2 of 3. Problem descriptions'. A modal dialog titled 'Add Support Ticket Number' is displayed over the wizard. The dialog contains the text: 'Please specify Support Ticket number you were issued per your support request.' Below this is a text input field labeled 'Support Ticket Number' containing the value '2015122810000291'. At the bottom of the dialog are 'Add' and 'Cancel' buttons. The background wizard interface includes a table with columns 'PROBLEM', 'PRODUCE', and 'FOUND SOLUTION'. At the bottom of the wizard, there is an 'Add problem description' button, a 'Problem description already provided' message, and 'Back', 'Send report', and 'Cancel' buttons.

Insert ticket number

If you are applying a new, unreferenced problem report, click the *Add problem description* button.

A short comprehensive wizard will guide you through the main issue categories, allowing you to choose the ones that are most applicable to your situation. You will be given the chance to enter error messages/codes, if there are any, and to attach snapshot(s). Make sure you provide the maximum amount of relevant information about the issue you are experiencing; always include **snapshots** if they are available.

Ganz CORTROL Global Administration Guide

The screenshot shows the 'VMS Client Application Problem Report Wizard' window. The title bar includes a warning icon and the text 'VMS Client Application Problem Report Wizard'. The main window has a dark blue header with 'Step 2 of 3. Problem description'. A modal dialog box titled 'Problem description' is open, containing the following fields and controls:

- Problem:** A dropdown menu with 'Server / Disconnects/restarts /' selected.
- Message:** A text input field containing 'No connection could be made because the target machine actively refused it'.
- Error code:** An empty text input field.
- Provide snapshot (optional):** A button labeled 'Browse for snapshot...' next to a file name 'untitled.png'.
- Buttons:** 'Back', 'Next', and 'Cancel' buttons are at the bottom of the modal. Below the modal, there are 'Back', 'Send report', and 'Cancel' buttons.

Enter problem classification and relevant details

You can add **multiple** descriptions to a single report. When you are ready, press the *Send report* button; the wizard will then try to send the report automatically.

The screenshot shows the 'VMS Client Application Problem Report Wizard' window. The title bar includes a warning icon and the text 'VMS Client Application Problem Report Wizard'. The main window has a dark blue header with 'Step 3 of 3. Gathering system information and sending data'. The content area is titled 'Finalizing wizard' and contains the following text:


Submission is in progress. Wizard is trying to contact website. Please wait, this could take some time. Once the request succeeded, wizard will take you to the next page. To abort the submission, click Cancel.

Below the text is a large magnifying glass icon and the text 'Gathering system information...'. At the bottom right, there is a 'Cancel' button.

Submitting report

If the server is offline, wizard will not be able to submit the report to CBC AMERICA LLC; instead, you will be invited to save the generated report locally. Press the *Finalise wizard without upload* button to finish.

Ganz CORTROL Global Administration Guide



Retry report submission or finish the wizard

Click *Save report as file* to save the compressed report on your computer; you are welcome to send it manually from any other computer to cortrol@cbcamerica.com. Click *Exit* to close the wizard.